

## TECHNICAL MANUAL

### Collection data

## INVERTER DRIVEN MULTI-INDOOR UNIT CLIMATE CONTROL SYSTEM

### Alternative refrigerant R410A use models (OUTDOOR UNIT)

#### **KX series** (Heat pump type)

- All-in-one type  
FDCA140HKXEN4R, 140HKXES4R, 160HKXES4R, 224HKXE4R, 280HKXE4R, 335HKXE4R
- All-in-one type (Used also for combination)  
FDCA335HKXE4R-K, 400HKXE4R, 450HKXE4R, 504HKXE4R, 560HKXE4R, 615HKXE4R, 680HKXE4R
- Combined type  
FDCA735HKXE4R, 800HKXE4R, 850HKXE4R, 900HKXE4R, 960HKXE4R, 1010HKXE4R, 1065HKXE4R, 1130HKXE4R, 1180HKXE4R, 1235HKXE4R, 1300HKXE4R, 1360HKXE4R

#### **KXR series** (Heat recovery type)

- All-in-one type  
FDCA224HKXRE4R, 280HKXRE4R, 335HKXRE4R
- All-in-one type (Used also for combination)  
FDCA335HKXRE4R-K, 400HKXRE4R, 450HKXRE4R, 504HKXRE4R, 560HKXRE4R, 615HKXRE4R, 680HKXRE4R
- Combined type  
FDCA735HKXRE4R, 800HKXRE4R, 850HKXRE4R, 900HKXRE4R, 960HKXRE4R, 1010HKXRE4R, 1065HKXRE4R, 1130HKXRE4R, 1180HKXRE4R, 1235HKXRE4R, 1300HKXRE4R, 1360HKXRE4R

### (INDOOR UNIT) –KX, KXR series–

FDTCA22KXE4R 28KXE4R 36KXE4R 45KXE4R 56KXE4R	FDTA28KXE4R 36KXE4R 45KXE4R 56KXE4R 71KXE4R 90KXE4R 112KXE4R 140KXE4R	FDTWA28KXE4R 45KXE4R 56KXE4R 71KXE4R 90KXE4R 112KXE4R 140KXE4R 28KXE5R 45KXE5R 56KXE5R	FDTQA22KXE4R 28KXE4R 36KXE4R  FDTSA22KXE4R 28KXE4R 36KXE4R 45KXE4R 71KXE4R	FDFLA28KXE4R 45KXE4R 71KXE4R  FDFUA28KXE4R 45KXE4R 56KXE4R 71KXE4R
FDQMA22KXE4R 28KXE4R 36KXE4R	FDUMA36KXE4R 45KXE4R 56KXE4R 71KXE4R 90KXE4R 112KXE4R 140KXE4R	FDURA45KXE4R 56KXE4R 71KXE4R 90KXE4R 112KXE4R 140KXE4R	FDEA36KXE4R 45KXE4R 56KXE4R 71KXE4R 112KXE4R 140KXE4R	FDKA22KXE4R 28KXE4R 36KXE4R 45KXE4R 56KXE4R 71KXE5R

(Note) See Manual No. '06•PAC, KX-T-110 concerning FDUMA22~140KXE5R.

# PREFACE

**KX4 series, KXR series allowed Indoor & Outdoor unit combinations.**

## ● Combination Table

Outdoor unit series		Connectable Indoor unit series – Series mixing is acceptable –		Non-connectable Indoor unit series	
Series name*1	Sales release date	Series name*1	Sales release date	Series name*1	Sales release date
<b>KXE4</b>	2004.4 ~	<b>KXE4</b>	2004.4 ~	<b>KXE4R</b> *2	2006.3 ~
		<b>KXE4A</b>	2004.11 ~		
<b>KXE4A</b>	2006.2 ~	<b>KXE4</b>	2004.4 ~	—	—
		<b>KXE4A</b>	2004.11 ~		
		<b>KXE4R</b>	2006.3 ~		
<b>KXE4R</b>	2006.5 ~	<b>KXE4</b>	2004.4 ~	—	—
		<b>KXE4A</b>	2004.11 ~		
		<b>KXE4R</b>	2006.3 ~		
<b>KXRE4</b>	2004.11 ~	<b>KXE4A</b>	2004.11 ~	<b>KXE4R</b> *3	2006.3 ~
<b>KXRE4A</b>	2006.2 ~	<b>KXE4A</b>	2004.11 ~	—	—
		<b>KXE4R</b>	2006.3 ~		
<b>KXRE4R</b>	2006.6 ~	<b>KXE4A</b>	2004.11 ~	—	—
		<b>KXE4R</b>	2006.3 ~		

\*1: Series name

**Outdoor unit**

e.g.

**KXE4 : FDCA280HKXE4**



**Indoor unit**

e.g.

**KXE4A : FDTA71HKXE4A**



\*2: Possible to connect if outdoor unit PWB assy (control) is replaced to new one (KXE4A or KXE4R)

\*3: Possible to connect if outdoor unit ROM is rewritten to new one (KXRE4A ~ KXRE4R)

## Special Notes

1. To improve product quality and comply with RoHS, the model of indoor unit and outdoor unit may change, but the content of product specification, basic control system, installation and service chapters in this document will not change. The same applies to the KX4 series in the combination table.
2. When making the equipment plan and carrying out construction of KX4, please pay special attention to the combination type of indoor unit and outdoor unit.
3. However, some parts number changes according to the model.  
Please refer to the parts list for each model.

## CONTENTS

<b>1 GENERAL INFORMATION .....</b>	<b>1</b>
1.1 Specific features .....	1
1.2 How to read the model name .....	3
1.3 Table of models .....	4
1.4 Table of indoor units panel (Optional) .....	4
1.5 Outdoor units combination table .....	5
<b>2 OUTDOOR UNIT .....</b>	<b>7</b>
2.1 Specifications .....	7
2.2 Exterior dimensions .....	16
2.3 Inside view .....	29
2.4 Exterior appearance .....	34
2.5 Noise level .....	35
2.6 Electrical wiring .....	38
<b>3 INDOOR UNIT .....</b>	<b>46</b>
3.1 Specifications .....	46
(a) Ceiling recessed compact type (FDTC) .....	46
(b) Ceiling recessed type (FDT) .....	48
(c) 2-way outlet ceiling recessed type (FDTW) .....	51
(d) Ceiling recessed single air supply port type (FDTQ) .....	54
(e) 1-way outlet ceiling recessed type (FDTS) .....	57
(f) High static pressure duct type (FDU) .....	59
(g) Medium static pressure ducted type (FDQM) .....	60
(h) Satellite ducted type (FDUM) .....	61
(i) Ceiling mounted duct type (FDUR) .....	64
(j) Ceiling suspended type (FDE) .....	67
(k) Wall mounted type (FDK) .....	70
(l) Floor standing exposed type (FDFL) .....	72
(m) Floor standing hidden type (FDFU) .....	73
3.2 Exterior dimensions .....	74
3.3 Exterior appearance .....	105
3.4 Characteristics of fan .....	108
3.5 Noise level .....	114
3.6 Electrical wiring .....	120
<b>4 COMMON MATTER .....</b>	<b>136</b>
4.1 Operation chart .....	136
4.2 Range of usage & limitations .....	144
4.3 Piping system .....	156
4.4 Selection chart .....	163

4.5	Application data .....	207
(1)	Installation of indoor unit .....	208
(a)	Ceiling recessed compact type (FDTC) .....	208
(b)	Ceiling recessed type (FDT) .....	213
(c)	2-way outlet ceiling recessed type (FDTW) .....	220
(d)	Ceiling recessed single air supply port type (FDTQ) .....	225
(e)	1-way outlet ceiling recessed type (FDTS) .....	233
(f)	Medium static pressure ducted type (FDQM) .....	239
(g)	High static pressure duct type (FDU) .....	244
(h)	Satellite ducted type (FDUM) .....	247
(i)	Ceiling mounted duct type (FDUR) .....	253
(j)	Ceiling suspended type (FDE) .....	259
(k)	Wall mounted type (FDK) .....	263
(l)	Floor standing exposed type (FDFL) .....	268
(m)	Floor standing hidden type (FDFU) .....	271
(2)	Installation of remote controller (Option parts) .....	274
(3)	Installation of outdoor unit .....	275
(4)	Refrigerant piping .....	279
(5)	Electric wiring .....	304
(6)	Setting function with the remote controller .....	310
(7)	Pump down operation .....	314
(8)	Test run .....	314
(9)	Notabilia as a unit designed for R410A .....	315
4.6	Outline of operation control by microcomputer .....	316
(1)	Wired remote controller (Optional parts) .....	316
(2)	Operation control function by the indoor controller .....	317
(3)	Operation control function by the outdoor controller .....	324
4.7	Maintenance data .....	439
(1)	Before starting troubleshooting .....	439
(2)	Procedures of trouble diagnosis .....	445
(a)	Diagnosis by the power supply reset .....	446
(b)	Error diagnosis procedures at the indoor unit side .....	447
(c)	Error diagnosis procedures at the outdoor unit side .....	456
(d)	How to advance checks for each faulty symptom .....	479
(e)	Check abnormal operation data with the remote controller .....	481
<b>5</b>	<b>WIRELESS KIT (Optional parts) .....</b>	<b>482</b>



# 1 GENERAL INFORMATION

## 1.1 Specific features

### (1) The new R410A refrigerant is used

The new refrigerant R410A, with an ozone destruction coefficient of zero, is used and the CO<sub>2</sub> discharge volume is reduced. In addition, R410A is a pseudo-azeotropic refrigerant, so there is little change in its consistency that would cause it to divide into the gas and liquid phases, or undergo temperature slide, and it is also possible to add refrigerant on-site.

### (2) Connectable indoor capacity

**Capacity from 80% to 150% is possible.**

Model \ Item	Number of connectable	Connectable capacity
FDCA140HKXEN4R	2 to 6 units	112 ~ 210
FDCA140HKXES4R		

**Capacity from 80% to 130% is possible.**

Model \ Item	Number of connectable	Connectable capacity
FDCA140HKXEN4R	2 to 8 units	112 ~ 182
FDCA140HKXES4R		

**Capacity from 50% to 130% is possible.**

(a) KX series

Model \ Item	Number of connectable	Connectable capacity
FDCA160HKXES4R	2 to 8 units	128 ~ 208
FDCA224HKXE4R	1 to 13 units	112 ~ 292
FDCA280HKXE4R	1 to 16 units	140 ~ 364
FDCA335HKXE4R	1 to 20 units	168 ~ 436
FDCA400HKXE4R	1 to 23 units	200 ~ 520
FDCA450HKXE4R	1 to 26 units	225 ~ 585
FDCA504HKXE4R	1 to 29 units	252 ~ 656
FDCA560HKXE4R	1 to 33 units	280 ~ 728
FDCA615HKXE4R	2 to 36 units	307 ~ 800
FDCA680HKXE4R	2 to 40 units	340 ~ 884
FDCA735HKXE4R	2 to 43 units	367 ~ 956
FDCA800HKXE4R	2 to 47 units	400 ~ 1040
FDCA850HKXE4R	2 to 48 units	425 ~ 1105
FDCA900HKXE4R	2 to 48 units	450 ~ 1170
FDCA960HKXE4R	2 to 48 units	480 ~ 1248
FDCA1010HKXE4R	2 to 48 units	505 ~ 1313
FDCA1065HKXE4R	2 to 48 units	532 ~ 1385
FDCA1130HKXE4R	3 to 48 units	565 ~ 1469
FDCA1180HKXE4R	3 to 48 units	590 ~ 1534
FDCA1235HKXE4R	3 to 48 units	617 ~ 1606
FDCA1300HKXE4R	3 to 48 units	650 ~ 1690
FDCA1360HKXE4R	3 to 48 units	680 ~ 1768

(b) KXR series

Model	Item	Number of connectable	Connectable capacity
FDCA224HKXRE4R		1 to 13 units	112 ~ 292
FDCA280HKXRE4R		1 to 16 units	140 ~ 364
FDCA335HKXRE4R		1 to 20 units	168 ~ 436
FDCA400HKXRE4R		1 to 23 units	200 ~ 520
FDCA450HKXRE4R		1 to 26 units	225 ~ 585
FDCA504HKXRE4R		1 to 29 units	252 ~ 656
FDCA560HKXRE4R		1 to 33 units	280 ~ 728
FDCA615HKXRE4R		2 to 36 units	307 ~ 800
FDCA680HKXRE4R		2 to 40 units	340 ~ 884
FDCA735HKXRE4R		2 to 43 units	367 ~ 956
FDCA800HKXRE4R		2 to 47 units	400 ~ 1040
FDCA850HKXRE4R		2 to 48 units	425 ~ 1105
FDCA900HKXRE4R		2 to 48 units	450 ~ 1170
FDCA960HKXRE4R		2 to 48 units	480 ~ 1248
FDCA1010HKXRE4R		2 to 48 units	505 ~ 1313
FDCA1065HKXRE4R		2 to 48 units	532 ~ 1385
FDCA1130HKXRE4R		3 to 48 units	565 ~ 1469
FDCA1180HKXRE4R		3 to 48 units	590 ~ 1534
FDCA1235HKXRE4R		3 to 48 units	617 ~ 1606
FDCA1300HKXRE4R		3 to 48 units	650 ~ 1690
FDCA1360HKXRE4R		3 to 48 units	680 ~ 1768

**(3) Indoor units are available with 11 capacities, in 13 types and 68 models.**

- 11 capacities...22(0.8 HP), 28(1 HP), 36(1.25 HP), 45(1.6 HP), 56(22 HP), 71(2.5 HP), 90(3.2 HP), 112(4 HP), 140(5 HP), 224(8 HP) and 280(10 HP).
- 13 types...Ceiling recessed compact type(FDTC), Ceiling recessed type(FDT), 2-way outlet ceiling recessed type(FDTW), Ceiling recessde single air supply port type (FDTQ), 1-way outlet ceiling recessed type(FDTS), Medium static pressure ducted type(FDQM), High static pressure duct type(FDU), Satellite ducted type(FDUM), Ceiling mounted duct type(FDUR), Ceiling suspension type(FDE), Wall mounted type(FDK), Floor standing exposed type(FDFL), and Floor standing hidden type (FDFU) .

**(4) Long piping design offers total piping length of 510 m (Exclusion FDCA140, 160 series)**

- Indoor and outdoor units can have a level difference of up to 50 m, with a one way piping length of up to 160 m. This is the top-class long piping design in the industry. A level difference of as 15 m between indoor units ensures that the system can meet a wide variety of air conditioning requirements in any building.

**(5) Super link system**

- Non polar 2-core signal wires for indoor, outdoor units by means of the automatic polarity selection.
- In addition, the max. 48 units can be controlled with a pair of signal wires. The high speed transmission method same as the computer network system [start up of 48 units can be completed within a few seconds by the determination of operation mode and the start of operation].
- As separate power supplies for the indoor and the outdoor units are employed, a pair of 2 signal wires only are required for the inter connecting wiring of indoor and outdoor uniits regardless of the number of units so that the installation work can be simplified, the cost of wiring work can be curtailed and causes of wiring error can be minimized.

**(6) Floor layout can be changed by resetting address unit number.**

- For change of floor layout, the control group can be recombined only by resetting address unit number.

**(7) Installation of automatic address setting function**

- The address setting method are divided into three types according to wiring method: “Automatic Address Setting,”“Remote controller Address Setting” and “Manual Address Setting,” In case of the Automatic Address Setting, no address needs be set as usual.

**(8) Layout free refrigerant piping**

- The branch type piping makes the system flexible enough to satisfy any layout plan on the floor or in a room.


**(9) Improvement of serviceability**

- Failures of indoor unit and outdoor units are shown on the liquid crystal display on the remote controller.
  - Failures of indoor unit and outdoor units can be checked by remote controller.
- Easy checking of outdoor inspection LED.
  - The LED can be checked without removing the service panel, and faulty units can be easily indentified out of several units.


- (10)** For outdoor unit, EN60555-2 and EN60555-3 are not applicable as consent by the utility company or notification to the utility company is given before usage.

## 1.2 How to read the model name

**(1) Outdoor unit**



**(2) Indoor unit**



### 1.3 Table of models

Model \ Capacity	22	28	36	45	56	71	90	112	140	224	280
Ceiling recessed compact type (FDTC)	○	○	○	○	○						
Ceiling recessed type (FDT)		○	○	○	○	○	○	○	○		
2-way outlet ceiling recessed type (FDTW)		○		○	○	○	○	○	○		
Ceiling recessed single air supply port type (FDTQ)	○	○	○								
1-way outlet ceiling recessed type (FDTS)	○	○	○	○		○					
Medium static pressure ducted type (FDQM)	○	○	○								
High static pressure ducted type (FDU)(1)										○	○
Stellite ducted type (FDUM)			○	○	○	○	○	○	○		
Ceiling mounted duct type (FDUR)				○	○	○	○	○	○		
Ceiling suspended type (FDE)			○	○	○	○		○	○		
Wall mounted type (FDK)	○	○	○	○	○	○					
Floor standing exposed type (FDFL)		○		○		○					
Floor standing hidden type (FDFU)		○		○	○	○					
Outdoor units to be combined FDC	K X	FDCA140HKXEN4R, 140HKXES4R, 160HKXES4R FDCA224HKXE4R, 280HKXE4R, 335HKXE4R, 335HKXE4R-K, 400HKXE4R, 450HKXE4R, 504HKXE4R, 560HKXE4R, 615HKXE4R, 680HKXE4R, 735HKXE4R, 800HKXE4R, 850HKXE4R, 900HKXE4R, 960HKXE4R, 1010HKXE4R, 1065HKXE4R, 1130HKXE4R, 1180HKXE4R, 1235HKXE4R, 1300HKXE4R, 1360HKXE4R									
	K X R	FDCA224HKXRE4R, 280HKXRE4R, 335HKXRE4R, 335HKXRE4R-K, 400HKXRE4R, 450HKXRE4R, 504HKXRE4R, 560HKXRE4R, 615HKXRE4R, 680HKXRE4R, 735HKXRE4R, 800HKXRE4R, 850HKXRE4R, 900HKXRE4R, 960HKXRE4R, 1010HKXRE4R, 1065HKXRE4R, 1130HKXRE4R, 1180HKXRE4R, 1235HKXRE4R, 1300HKXRE4R, 1360HKXRE4R									

Note (1) The FDUA224, 280KXE4R and FDKA71KXE5R indoor units cannot be connected to the FDCA140HKXEN4R, 140HKXES4R and 160HKXES4R outdoor units.

### 1.4 Table of indoor units panel (Optional)

Model	Parts Model
FDTC	Capacity:22,28,36,45,56 TC-PSA-24W-ER
FDT	Capacity:28,36,45,56, 71,90,112,140 T-PSA-35W-ER
FDTW	Capacity:28,45,56 TW-PSA-23W-ER
	Capacity:71,90 TW-PSA-33W-ER
	Capacity:112,140 TW-PSA-43W-ER
FDTQ (Direct blow panel)	Capacity:22,28,36 TQ-PSA-14W-ER
	TQ-PSB-14W-ER
FDTQ (Duct panel)	Capacity:22,28,36 QR-PNA-14W-ER
	QR-PNB-14W-ER
FDTS	Capacity:22, 28, 36, 45 TS-PSA-28W-ER
	Capacity:71 TS-PSA-38W-ER

## 1.5 Outdoor units combination table

### (1) KX series

(a) Models FDCA735, 800, 850, 900HKXE4R

Item Models	Combination outdoor unit models			Indoor unit	
	FDCA335HKXE4R-K	FDCA400HKXE4R	FDCA450HKXE4R	Connectable capacity	Number of connectable units
FDCA735HKXE4R	1	1	—	367 ~ 956	2 ~ 43
FDCA800HKXE4R	—	2	—	400 ~ 1040	2 ~ 47
FDCA850HKXE4R	—	1	1	425 ~ 1105	2 ~ 48
FDCA900HKXE4R	—	—	2	450 ~ 1170	

(b) Models FDCA960, 1010, 1065, 1130, 1180, 1235, 1300, 1360HKXE4R

Item Models	Combination outdoor unit models					Indoor unit	
	FDCA450 HKXE4R	FDCA504 HKXE4R	FDCA560 HKXE4R	FDCA615 HKXE4R	FDCA680 HKXE4R	Connectable capacity	Number of connectable units
FDCA960HKXE4R	1	1	—	—	—	480 ~ 1248	2 to 48 unit
FDCA1010HKXE4R	—	2	—	—	—	505 ~ 1313	
FDCA1065HKXE4R	—	1	1	—	—	532 ~ 1385	
FDCA1130HKXE4R	—	—	2	—	—	565 ~ 1469	3 to 48 unit
FDCA1180HKXE4R	—	—	1	1	—	590 ~ 1534	
FDCA1235HKXE4R	—	—	—	2	—	617 ~ 1606	
FDCA1300HKXE4R	—	—	—	1	1	650 ~ 1690	
FDCA1360HKXE4R	—	—	—	—	2	680 ~ 1768	

(c) Outdoor unit side branch pipe set (Optional)

Outdoor unit	Branch pipe set
For two units (for 735 ~ 1360)	DOS-2A-1

Note (1) Be sure to use this when combining units.

(d) Branch pipe set (Optional)

Total capacity downstream	Branching pipe set
Less than 180	DIS-22-1
180 or more but less than 371	DIS-180-1
371 or more but less than 540	DIS-371-1
540 or more	DIS-540-1

(e) Header pipe set (Optional)

Total capacity downstream	Header set model type	Number of branches
Less than 180	HEAD4-22-1	4 branches at the most
180 or more but less than 371	HEAD6-180-1	6 branches at the most
371 or more but less than 540	HEAD8-371-1	8 branches at the most
540 or more	HEAD8-540-1	8 branches at the most

## (2) KXR series

### (a) Models FDCA735, 800, 850, 900HKXRE4R

Item Models	Combination outdoor unit models			Indoor unit	
	FDCA335HKXRE4R-K	FDCA400HKXRE4R	FDCA450HKXRE4R	Connectable capacity	Number of connectable units
FDCA735HKXRE4R	1	1	—	367 ~ 956	2 ~ 43
FDCA800HKXRE4R	—	2	—	400 ~ 1040	2 ~ 47
FDCA850HKXRE4R	—	1	1	425 ~ 1105	2 ~ 48
FDCA900HKXRE4R	—	—	2	450 ~ 1170	

### (b) Models FDCA900, 1010, 1065, 1130, 1180, 1235, 1300, 1360HKXRE4R

Item Models	Combination outdoor unit models					Indoor unit	
	FDCA450 HKXRE4R	FDCA504 HKXRE4R	FDCA560 HKXRE4R	FDCA615 HKXRE4R	FDCA680 HKXRE4R	Connectable capacity	Number of connectable units
FDCA960HKXRE4R	1	1	—	—	—	480 ~ 1248	2 to 48 unit
FDCA1010HKXRE4R	—	2	—	—	—	505 ~ 1313	
FDCA1065HKXRE4R	—	1	1	—	—	532 ~ 1385	
FDCA1130HKXRE4R	—	—	2	—	—	565 ~ 1469	3 to 48 unit
FDCA1180HKXRE4R	—	—	1	1	—	590 ~ 1534	
FDCA1235HKXRE4R	—	—	—	2	—	617 ~ 1606	
FDCA1300HKXRE4R	—	—	—	1	1	650 ~ 1690	
FDCA1360HKXRE4R	—	—	—	—	2	680 ~ 1768	

### (c) Outdoor unit side branch pipe set (Optional)

Outdoor unit	Branch pipe set
For two units (for 735 ~ 1360)	DOS-2A-1-R

Note (1) Be sure to use this when combining units.

### (d) Branch pipe set (Optional)

In the upstream of a branching controller

Total capacity downstream	Branching pipe set
Less than 180	DIS-22-1-R
180 or more but less than 371	DIS-180-1-R
371 or more but less than 540	DIS-371-1-R
540 or more	DIS-540-1-R

In the downstream of a branching controller

Total capacity downstream	Branching pipe set
Less than 180	DIS-22-1
180 or more but less than 371	DIS-180-1

### (e) Branching controller model (Optional)

Total capacity downstream	Branching controller model	Number of connectable units
Less than 112	PFD112-ER	1 ~ 5
112 or more but less than 180	PFD180-ER	1 ~ 8
180 or more but less than 280	PFD280-ER	1 ~ 10

### (f) Integrated branching controller (Optional)

Model	Total of four branches		Per branch	
	Capacity restrictions	Maximum number of units connectable	Capacity restrictions	Maximum number of units connectable
PFD112X4-ER	Less than 371	16	Less than 112	5

Note (1) An indoor unit with a capacity up to 112 can be connected. Refer to page 290 for details.

## 2 OUTDOOR UNIT

### 2.1 Specifications

#### (1) KX series

Models FDCA140HKXEN4R, 140HKXES4R, 160HKXES4R

Model		FDCA140HKXEN4R	FDCA140HKXES4R	FDCA160HKXES4R
Item				
Power source		1 Phase 220/240V 50Hz	3 Phase 380-415V 50Hz/380V 60Hz <sup>(3)</sup>	
Nominal cooling capacity <sup>(1)</sup>	kW	14.6		16.0
Nominal heating capacity <sup>(1)</sup>	kW	16.6		18.0
Noise level	dB(A)	Cooling : 53, Heating : 53		
Exterior dimensions Height × Width × Depth	mm	1300 × 970 × 370		
Net weight	kg	125		
Refrigerant equipment compressor type & Q'ty		GT-C5139ND50		
Starting method		Direct line starting		
Capacity control	%	31 ~ 130		25 ~ 125
Crankcase heater	W	33		
Heat exchanger		Straight fin & inner grooved tubing		
Refrigerant control		Electronic expansion Valve +Capillary tube		
Refrigerant		R410A		
Quantity	kg	7.5		
Refrigerant oil	ℓ	1.6 (M-MA32R)		
Defrost control		Microcomputer controlled De-Icer		
Air handling equipment Fan type & Q'ty		Propeller fan × 2		
Motor	W	60 × 2		
Starting method		Direct start		
Air flow(Standard)	CMM	100		
Shock & vibration absorber		Rubber mount (for compressor)		
Safety equipment		Compressor overheat protection, overcurrent protection, power transistor overheating protection, abnormal high pressure protection		
Installation data Refrigerant piping size	mm(in)	Liquid line: φ9.52(3/8") Gas line: φ15.88(5/8")		
Connecting method		Flare piping		
Drain		Hole for drain(φ20 × 3pcs)		
Insulation for piping		Necessary (both Liquid & Gas lines)		
Accessories		Edging		
Indoor units to be combined		FDTCA22, 28, 36, 45, 56 FDTA28, 36, 45, 56, 71, 90, 112, 140 FDTWA28, 45, 56, 71, 90, 112, 140 FDTQA22, 28, 36 FDTSA22, 28, 36, 45, 71 FDQMA22, 28, 36 FDUMA36, 45, 56, 71, 90, 112, 140	FDURA45, 56, 71, 90, 112, 140 FDEA36, 45, 56, 71, 112, 140 FDKA22, 28, 36, 45, 56 FDFLA28, 45, 71 FDFUA28, 45, 56, 71	

Note (1) The cooling and heating capabilities imply the values when the indoor unit of rated capacity is connected under the condition specified in ISO-T1.  
(2) The FDKA71KXE5R indoor unit cannot be connected.  
(3) In the case of 60Hz, use specification category (T).

List of branch pipe part numbers (Select parts in accordance with the branching system used.)

Corresponding outdoor unit	Number of indoor units that can be connected	Branching system	
		Branch pipe system	Header system
FDCA140HKXEN4R FDCA140HKXES4R	2~6 units 2~8 units	DIS-22-1	HEAD4-22-1
FDCA160HKXES4R	2~8 units		

**Models FDCA224HKXE4R, 280HKXE4R, 335HKXE4R**

Item		Models	FDCA224HKXE4R	FDCA280HKXE4R	FDCA335HKXE4R
Power source			3 Phase 380-415V 50Hz/380V 60Hz		
Nominal cooling capacity <sup>(1)</sup>		kW	22.4	28.0	33.5
Nominal heating capacity <sup>(1)</sup>		kW	25.0	31.5	37.5
Noise level		dB(A)	Cooling : 57, Heating : 57	Cooling : 57, Heating : 58	Cooling:60.5, Heating:61
Exterior dimensions Height × Width × Depth		mm	1690 × 1350 × 720		
Net weight		kg	245		
Refrigerant equipment compressor type & Q' ty			GT-C5150ND75 × 1		
Starting method			Direct line starting		
Capacity control		%	27 ~ 126	20 ~ 114	19 ~ 117
Crankcase heater		W	33 × 1		
Heat exchanger			Straight fin & inner grooved tubing		
Refrigerant control			Electronic expansion valve		
Refrigerant			R410A		
Quantity		kg	14.2		
Refrigerant oil		ℓ	2.1 (M-MA32R)		
Defrost control			Microcomputer controlled De-Icer		
Air handling equipment Fan type & Q' ty			Propeller fan × 2		
Motor		W	126 × 2		386 × 2
Starting method			Direct start		
Air flow(Standard)		CMM	Cooling: 220, Heating: 180		Cooling:280, Heating:260
Shock & vibration absorber			Rubber mount (for compressor)		
Safety equipment			Compressor overheat protection, overcurrent protection, power transistor overheating protection, abnormal high pressure protection		
Installation data Refrigerant piping size		mm(in)	Liquid line: φ9.52(3/8") Gas line: φ19.05(3/4")	Liquid line: φ9.52(3/8") Gas line: φ22.22(7/8")	Liquid line: φ12.7(1/2") Gas line: φ25.4(1")
Connecting method			Gas line:Brazing, Liquid line:Flare		
Drain			Hole for drain(φ20 × 6pcs, φ45 × 3pcs)		
Insulation for piping			Necessary (both Liquid & Gas lines)		
Accessories			—		
Indoor units to be combined			FDCA22, 28, 36, 45, 56 FDTA28, 36, 45, 56, 71, 90, 112, 140 FDTWA28, 45, 56, 71, 90, 112, 140 FDTQA22, 28, 36 FDTSA22, 28, 36, 45, 71 FDQMA22, 28, 36 FDUA224, 280 FDUMA36, 45, 56, 71, 90, 112, 140	FDURA45, 56, 71, 90, 112, 140 FDEA36, 45, 56, 71, 112, 140 FDKA22, 28, 36, 45, 56, 71 FDFLA28, 45, 71 FDFUA28, 45, 56, 71	

Notes (1) The cooling and heating capabilities imply the values when the indoor unit of rated capacity is connected under the condition specified in ISO-T1.

(2) The refrigerant quantity in the connecting pipe is not included Charge it additionally at the site.

**List of branch pipe part numbers (Select parts in accordance with the branching system used.)**

Corresponding outdoor unit	Number of indoor units that can be connected	Branching system	
		Branch pipe system <sup>(1)</sup> (Total capacity after each branch)	Header system
FDCA224HKXE4R	1~13 units	<ul style="list-style-type: none"> <li>Downstream capacity less than 180 DIS-22-1</li> <li>Downstream capacity 180 to less than 371 DIS-180-1</li> <li>Downstream capacity 371 to less than 540 DIS-371-1</li> </ul>	<ul style="list-style-type: none"> <li>Downstream capacity less than 180 HEAD-22-1 (for up to 4 units max)</li> <li>Downstream capacity 180 to less than 371 HEAD-180-1 (up to 6 units max)</li> <li>Downstream capacity 371 to less than 540 HEAD8-371-1 (up to 8 units max)</li> </ul>
FDCA280HKXE4R	1~16 units		
FDCA335HKXE4R	1~20 units		

Note (1) In the branch piping method, the way branch piping is run needs to be in accordance with the total downstream capacity of the indoor units.



## Models FDCA335HKXE4R-K, 400HKXE4R, 450HKXE4R

Item		Models	FDCA335HKXE4R-K <sup>(3)</sup>	FDCA400HKXE4R	FDCA450HKXE4R
Power source			3 Phase 380-415V 50Hz/380V 60Hz		
Nominal cooling capacity <sup>(1)</sup>		kW	33.5	40.0	45.0
Nominal heating capacity <sup>(1)</sup>		kW	37.5	45.0	50.0
Noise level		dB(A)	Cooling: 56, Heating: 57	Cooling: 58.5, Heating: 59	Cooling: 61, Heating: 61
Exterior dimensions Height × Width × Depth		mm	1690 × 1350 × 720		
Net weight		kg	310		
Refrigerant equipment compressor type & Q'ty			GT-C5150ND78A × 2		
Starting method			Direct line starting		
Capacity control		%	19 ~ 130	15 ~ 114	13 ~ 112
Crankcase heater		W	33 × 2		
Heat exchanger			Straight fin & inner grooved tubing		
Refrigerant control			Electronic expansion valve		
Refrigerant			R410A		
Quantity		kg	17		
Refrigerant oil		ℓ	4.2 (M-MA32R)		
Defrost control			Microcomputer controlled De-Icer		
Air handling equipment Fan type & Q'ty			Propeller fan × 2		
Motor		W	386 × 2		
Starting method			Direct start		
Air flow(Standard)		CMM	Cooling: 220, Heating: 180	Cooling: 250, Heating: 220	Cooling: 260, Heating: 240
Shock & vibration absorber			Rubber mount (for compressor)		
Safety equipment			Compressor overheat protection, overcurrent protection, power transistor overheating protection, abnormal high pressure protection		
Installation data Refrigerant piping size		mm(in)	Liquid line: φ12.7(1/2") Gas line: φ25.4(1")		Liquid line: φ12.7(1/2") Gas line: φ28.58(11/8")
Connecting method			Gas line: Brazing, Liquid line: Flare		
Drain			Hole for drain (φ20 × 6pcs, φ45 × 3pcs)		
Insulation for piping			Necessary (both Liquid & Gas lines)		
Accessories			—		
Indoor units to be combined			FDTCA22, 28, 36, 45, 56 FDTA28, 36, 45, 56, 71, 90, 112, 140 FDTWA28, 45, 56, 71, 90, 112, 140 FDTQA22, 28, 36 FDTSA22, 28, 36, 45, 71 FDQMA22, 28, 36 FDUA224, 280 FDUMA36, 45, 56, 71, 90, 112, 140 FDURA45, 56, 71, 90, 112, 140 FDEA36, 45, 56, 71, 112, 140 FDKA22, 28, 36, 45, 56, 71 FDFLA28, 45, 71 FDFUA28, 45, 56, 71		

Notes (1) The cooling and heating capabilities imply the values when the indoor unit of rated capacity is connected under the condition specified in ISO-T1.

(2) The refrigerant quantity in the connecting pipe is not included Charge it additionally at the site.

(3) The FDCA335HKXE4R-K is an exclusive combination unit.

### List of branch pipe part numbers (Select parts in accordance with the branching system used.)

Corresponding outdoor unit	Number of indoor units that can be connected	Branching system	
		Branch pipe system <sup>(1)</sup> (Total capacity after each branch)	Header system
FDCA335HKXE4R-K	—	• Downstream capacity less than 180 DIS-22-1	• Downstream capacity less than 180 HEAD4-22-1 (for up to 4 units max)
FDCA400HKXE4R	1~23 units	• Downstream capacity 180 to less than 371 DIS-180-1	• Downstream capacity 180 to less than 371 HEAD6-180-1 (up to 6 units max)
FDCA450HKXE4R	1~26 units	• Downstream capacity 371 to less than 540 DIS-371-1 • Downstream capacity 540 or more DIS-540-1	• Downstream capacity 371 to less than 540 HEAD8-371-1 (up to 8 units max) • Downstream capacity 540 or more HEAD8-540-1 (up to 8 units max)

Note (1) In the branch piping method, the way branch piping is run needs to be in accordance with the total downstream capacity of the indoor units.

## Models FDCA504HKXE4R, 560HKXE4R

Item		Models	FDCA504HKXE4R	FDCA560HKXE4R
Power source			3 Phase 380-415V 50Hz/380V 60Hz	
Nominal cooling capacity <sup>(1)</sup>		kW	50.4	56.0
Nominal heating capacity <sup>(1)</sup>		kW	56.5	63.0
Noise level		dB(A)	Cooling: 60, Heating: 60.5	Cooling: 60.5, Heating: 62.5
Exterior dimensions Height × Width × Depth		mm	2048 × 1350 × 720	
Net weight		kg	340	
Refrigerant equipment compressor type & Q'ty			GT-C5150ND78A × 2	
Starting method			Direct line starting	
Capacity control		%	11 ~ 100	10 ~ 113
Crankcase heater		W	33 × 2	
Heat exchanger			Straight fin & inner grooved tubing	
Refrigerant control			Electronic expansion valve	
Refrigerant			R410A	
Quantity		kg	19.4	
Refrigerant oil		ℓ	4.2 (M-MA32R)	
Defrost control			Microcomputer controlled De-Icer	
Air handling equipment Fan type & Q'ty			Propeller fan × 2	
Motor		W	386 × 2	
Starting method			Direct start	
Air flow(Standard)		CMM	Cooling: 270, Heating: 250	
Shock & vibration absorber			Rubber mount (for compressor)	
Safety equipment			Compressor overheat protection, overcurrent protection, power transistor overheating protection, abnormal high pressure protection	
Installation data Refrigerant piping size		mm(in)	Liquid line: φ12.7(1/2") Gas line: φ28.58(1 1/8")	
Connecting method			Gas line: Brazing, Liquid line: Flare	
Drain			Hole for drain (φ20 × 6pcs, φ45 × 3pcs)	
Insulation for piping			Necessary (both Liquid & Gas lines)	
Accessories			—	
Indoor units to be combined			FDTCA22, 28, 36, 45, 56 FDTA28, 36, 45, 56, 71, 90, 112, 140 FDTWA28, 45, 56, 71, 90, 112, 140 FDTQA22, 28, 36 FDTSA22, 28, 36, 45, 71 FDQMA22, 28, 36 FDUA224, 280 FDUMA36, 45, 56, 71, 90, 112, 140	FDURA45, 56, 71, 90, 112, 140 FDEA36, 45, 56, 71, 112, 140 FDKA22, 28, 36, 45, 56, 71 FDFLA28, 45, 71 FDFUA28, 45, 56, 71

Notes (1) The cooling and heating capabilities imply the values when the indoor unit of rated capacity is connected under the condition specified in ISO-T1.  
 (2) The refrigerant quantity in the connecting pipe is not included Charge it additionally at the site.

### List of branch pipe part numbers (Select parts in accordance with the branching system used.)

Corresponding outdoor unit	Number of indoor units that can be connected	Branching system	
		Branch pipe system <sup>(1)</sup> (Total capacity after each branch)	Header system
FDCA504HKXE4R	1~29 units	<ul style="list-style-type: none"> <li>Downstream capacity less than 180 DIS-22-1</li> <li>Downstream capacity 180 to less than 371 DIS-180-1</li> </ul>	<ul style="list-style-type: none"> <li>Downstream capacity less than 180 HEAD4-22-1 (for up to 4 units max)</li> <li>Downstream capacity 180 to less than 371 HEAD6-180-1 (up to 6 units max)</li> </ul>
FDCA560HKXE4R	1~33 units	<ul style="list-style-type: none"> <li>Downstream capacity 371 to less than 540 DIS-371-1</li> <li>Downstream capacity 540 or more DIS-540-1</li> </ul>	<ul style="list-style-type: none"> <li>Downstream capacity 371 to less than 540 HEAD8-371-1 (up to 8 units max)</li> <li>Downstream capacity 540 or more HEAD8-540-1 (up to 8 units max)</li> </ul>

Note (1) In the branch piping method, the way branch piping is run needs to be in accordance with the total downstream capacity of the indoor units.

## Models FDCA615HKXE4R, 680HKXE4R

Item		Models	FDCA615HKXE4R	FDCA680HKXE4R
Power source			3 Phase 380-415V 50Hz/380V 60Hz	
Nominal cooling capacity <sup>(1)</sup>		kW	61.5	68.0
Nominal heating capacity <sup>(1)</sup>		kW	69.0	73.0
Noise level		dB(A)	Cooling: 63, Heating: 63	Cooling: 63.5, Heating: 63.5
Exterior dimensions Height × Width × Depth		mm	2048 × 1350 × 720	
Net weight		kg	355	
Refrigerant equipment compressor type & Q'ty			GT-C5150ND78A × 2	
Starting method			Direct line starting	
Capacity control		%	9 ~ 110	8 ~ 108
Crankcase heater		W	33 × 2	
Heat exchanger			Straight fin & inner grooved tubing	
Refrigerant control			Electronic expansion valve	
Refrigerant			R410A	
Quantity		kg	21.2	
Refrigerant oil		ℓ	4.2 (M-MA32R)	
Defrost control			Microcomputer controlled De-Icer	
Air handling equipment Fan type & Q'ty			Propeller fan × 2	
Motor		W	386 × 2	
Starting method			Direct start	
Air flow(Standard)		CMM	Cooling: 270, Heating: 250	
Shock & vibration absorber			Rubber mount (for compressor)	
Safety equipment			Compressor overheat protection, overcurrent protection, power transistor overheating protection, abnormal high pressure protection	
Installation data Refrigerant piping size		mm(in)	Liquid line: φ 12.7(1/2") Gas line: φ28.58(1 1/8")	
Connecting method			Gas line:Brazing, Liquid line:Flare	
Drain			Hole for drain (φ20 × 6pcs, φ45 × 3pcs)	
Insulation for piping			Necessary (both Liquid & Gas lines)	
Accessories			—	
Indoor units to be combined			FDTCA22, 28, 36, 45, 56 FDTA28, 36, 45, 56, 71, 90, 112, 140 FDTWA28, 45, 56, 71, 90, 112, 140 FDTQA22, 28, 36 FDTSA22, 28, 36, 45, 71 FDQMA22, 28, 36 FDUA224, 280 FDUMA36, 45, 56, 71, 90, 112, 140	FDURA45, 56, 71, 90, 112, 140 FDEA36, 45, 56, 71, 112, 140 FDKA22, 28, 36, 45, 56, 71 FDFLA28, 45, 71 FDFUA28, 45, 56, 71

Notes (1) The cooling and heating capabilities imply the values when the indoor unit of rated capacity is connected under the condition specified in ISO-T1.

(2) The refrigerant quantity in the connecting pipe is not included Charge it additionally at the site.

### List of branch pipe part numbers (Select parts in accordance with the branching system used.)

Corresponding outdoor unit	Number of indoor units that can be connected	Branching system	
		Branch pipe system <sup>(1)</sup> (Total capacity after each branch)	Header system
FDCA615HKXE4R	2~36 units	<ul style="list-style-type: none"> <li>Downstream capacity less than 180 DIS-22-1</li> <li>Downstream capacity 180 to less than 371 DIS-180-1</li> </ul>	<ul style="list-style-type: none"> <li>Downstream capacity less than 180 HEAD4-22-1 (for up to 4 units max)</li> <li>Downstream capacity 180 to less than 371 HEAD6-180-1 (up to 6 units max)</li> </ul>
FDCA680HKXE4R	2~40 units	<ul style="list-style-type: none"> <li>Downstream capacity 371 to less than 540 DIS-371-1</li> <li>Downstream capacity 540 or more DIS-540-1</li> </ul>	<ul style="list-style-type: none"> <li>Downstream capacity 371 to less than 540 HEAD8-371-1 (up to 8 units max)</li> <li>Downstream capacity 540 or more HEAD8-540-1 (up to 8 units max)</li> </ul>

Note (1) In the branch piping method, the way branch piping is run needs to be in accordance with the total downstream capacity of the indoor units.

## (2) KXR series

### Models FDCA224HKXRE4R, 280HKXRE4R, 335HKXRE4R

Item		Models	FDCA224HKXRE4R	FDCA280HKXRE4R	FDCA335HKXRE4R
Power source			3 Phase 380-415V 50Hz/380V 60Hz		
Nominal cooling capacity <sup>(1)</sup>	kW		22.4	28.0	33.5
Nominal heating capacity <sup>(1)</sup>	kW		25.0	31.5	37.5
Noise level	dB(A)		Cooling: 57, Heating: 57	Cooling: 57, Heating: 59	Cooling: 60.5, Heating: 62.5
Exterior dimensions Height × Width × Depth	mm		1690 × 1350 × 720		
Net weight	kg		250		
Refrigerant equipment compressor type & Q'ty			GT-C5150ND75 × 1		
Starting method			Direct line starting		
Capacity control	%		24 ~ 114	19 ~ 109	18 ~ 103
Crankcase heater	W		33 × 1		
Heat exchanger			Straigh fin & inner grooved tubing		
Refrigerant control			Electronic expansion valve		
Refrigerant			R410A		
Quantity	kg		14.2		
Refrigerant oil	ℓ		2.2 (M-MA32R)		
Defrost control			Microcomputer controlled De-Icer		
Air handling equipment Fan type & Q'ty			Propeller fan × 2		
Motor	W		126 × 2		386 × 2
Starting method			Direct start		
Air flow(Standard)	CMM		Cooling: 220, Heating: 180	Cooling: 220, Heating: 180	Cooling: 280, Heating: 260
Shock & vibration absorber			Rubber mount (for compressor)		
Safety equipment			Compressor overheat protection, overcurrent protection, power transistor overheating protection, abnormal high pressure protection		
Installation data Refrigerant piping size	mm(in)		Liquid line: φ 9.52(3/8") Suction gas line: φ19.05(3/4") Discharge gas line: φ15.88(5/8")	Liquid line: φ 9.52(3/8") Suction gas line: φ22.22(7/8") Discharge gas line: φ19.05(3/4")	Liquid line: φ12.7 (1/2") Suction gas line: φ22.22(7/8") Discharge gas line: φ19.05(3/4")
Connecting method			Suction or discharge line: Brazing, Liquid line: Flare		
Drain			Hole for drain (φ20 × 6pcs, φ45 × 3pcs)		
Insulation for piping			Necessary (both Liquid & Gas lines)		
Accessories			—		
Indoor units to be combined			FDCA22, 28, 36, 45, 56 FDTA28, 36, 45, 56, 71, 90, 112, 140 FDTWA28, 45, 56, 71, 90, 112, 140 FDTQA22, 28, 36 FDTSA22, 28, 36, 45, 71 FDQMA22, 28, 36 FDUA224, 280 FDUMA36, 45, 56, 71, 90, 112, 140	FDURA45, 56, 71, 90, 112, 140 FDEA36, 45, 56, 71, 112, 140 FDKA22, 28, 36, 45, 56, 71 FDFLA28, 45, 71 FDFUA28, 45, 56, 71	

Notes (1) The cooling and heating capabilities imply the values when the indoor unit of rated capacity is connected under the condition specified in ISO-T1.

(2) The refrigerant quantity in the connecting pipe is not included Charge it additionally at the site.

#### List of branch pipe part numbers (Select parts in accordance with the branching system used.)

Corresponding outdoor unit	Number of indoor units that can be connected	Branching system	
		In the upstream of a branching controller <sup>(1)</sup>	In the downstream of a branching controller <sup>(1)</sup>
FDCA224HKXRE4R	1~13 units	• Downstream Capacity less than 180 DIS-22-1-R	• Downstream Capacity less than 180 DIS-22-1
FDCA280HKXRE4R	1~16 units	• Downstream Capacity 180 to less than 371 DIS-180-1-R	• Downstream Capacity 180 to less than 371 DIS-180-1
FDCA335HKXRE4R	1~20 units	• Downstream Capacity 371 to less than 540 DIS-371-1-R	• Downstream Capacity 371 to less than 540 HEAD8-371-1 (up to 8 units max)

Note (1) In the branch piping method, the way branch piping is run needs to be in accordance with the total downstream capacity of the indoor units.

#### • Branching controller part numbers

Branching controller	Number of connectable units
Total capacity downstream Last than 112: PFD112-E	1~5
Total capacity downstream Last than 180: PFD180-E	1~8
Total capacity downstream Last than 280: PFD280-E	1~10

#### • Integrated branching controller part numbers

Integrated branching controller	Number of connectable units
Total capacity downstream Last than 371: PFD112X4-ER	1~16

Note (1) An indoor unit with a capacity up to 112 can be connected.

**Models FDCA335HKXRE4R-K, 400HKXRE4R, 450HKXRE4R**

Models		FDCA335HKXRE4R-K <sup>(3)</sup>	FDCA400HKXRE4R	FDCA450HKXRE4R
Item				
Power source		3 Phase 380-415V 50Hz/380V 60Hz		
Nominal cooling capacity <sup>(1)</sup>	kW	33.5	40.0	45.0
Nominal heating capacity <sup>(1)</sup>	kW	37.5	45.0	50.0
Noise level	dB(A)	Cooling: 57, Heating: 57.5	Cooling: 59.5, Heating: 60	Cooling: 62.5, Heating: 62.5
Exterior dimensions Height × Width × Depth	mm	1690 × 1350 × 720		
Net weight	kg	315		
Refrigerant equipment compressor type & Q' ty		GT-C5150ND78A × 2		
Starting method		Direct line starting		
Capacity control	%	18 ~ 130	14 ~ 113	13 ~ 109
Crankcase heater	W	33 × 2		
Heat exchanger		Straight fin & inner grooved tubing		
Refrigerant control		Electronic expansion valve		
Refrigerant		R410A		
Quantity	kg	14.2	17	
Refrigerant oil	ℓ	4.4 (M-MA32R)		
Defrost control		Microcomputer controlled De-Icer		
Air handling equipment Fan type & Q'ty		Propeller fan × 2		
Motor	W	386 × 2		
Starting method		Direct start		
Air flow(Standard)	CMM	Cooling: 220, Heating: 180	Cooling: 250, Heating: 220	Cooling: 260, Heating: 240
Shock & vibration absorber		Rubber mount (for compressor)		
Safety equipment		Compressor overheat protection, overcurrent protection, power transistor overheating protection, abnormal high pressure protection		
Installation data Refrigerant piping size	mm(in)	Liquid line: φ12.7 (1/2") Suction gas line: φ22.22(7/8") Discharge gas line: φ19.05(3/4")	Liquid line: φ12.7 (1/2") Suction gas line: φ28.58(11/8") Discharge gas line: φ22.22(7/8")	
Connecting method		Suction or discharge line:Brazing, Liquid line:Flare		
Drain		Hole for drain (φ20 × 6pcs, φ45 × 3pcs)		
Insulation for piping		Necessary (both Liquid & Gas lines)		
Accessories		—		
Indoor units to be combined		FDTCA22, 28, 36, 45, 56 FDTA28, 36, 45, 56, 71, 90, 112, 140 FDTWA28, 45, 56, 71, 90, 112, 140 FDTQA22, 28, 36 FDTSA22, 28, 36, 45, 71 FDQMA22, 28, 36 FDUA224, 280 FDUMA36, 45, 56, 71, 90, 112, 140	FDURA45, 56, 71, 90, 112, 140 FDEA36, 45, 56, 71, 112, 140 FDKA22, 28, 36, 45, 56, 71 FDFLA28, 45, 71 FDFUA28, 45, 56, 71	

Notes (1) The cooling and heating capabilities imply the values when the indoor unit of rated capacity is connected under the condition specified in ISO-T1.

(2) The refrigerant quantity in the connecting pipe is not included Charge it additionally at the site.

(3) The FDCA335HKXRE4R-K is an exclusive combination unit.

**List of branch pipe part numbers (Select parts in accordance with the branching system used.)**

Corresponding outdoor unit	Number of indoor units that can be connected	Branching system	
		In the upstream of a branching controller <sup>(1)</sup>	In the downstream of a branching controller <sup>(1)</sup>
FDCA335HKXRE4R-K	—	• Downstream Capacity less than 180 DIS-22-1-R	• Downstream Capacity less than 180 DIS-22-1
FDCA400HKXRE4R	1~23 units	• Downstream Capacity 180 to less than 371 DIS-180-1-R	• Downstream Capacity 180 to less than 371 DIS-180-1
FDCA450HKXRE4R	1~26 units	• Downstream Capacity 371 to less than 540 DIS-371-1-R	• Downstream Capacity 371 less than 180 DIS-371-1
		• Downstream Capacity 540 or more DIS-540-1-R	• Downstream Capacity 540 or more DIS-540-1-R

Note (1) In the branch piping method, the way branch piping is run needs to be in accordance with the total downstream capacity of the indoor units.

**• Branching controller part numbers**

Branching controller	Number of connectable units
Total capacity downstream Last than 112: PFD112-E	1~5
Total capacity downstream Last than 180: PFD180-E	1~8
Total capacity downstream Last than 280: PFD280-E	1~10

**• Integrated branching controller part numbers**

Integrated branching controller	Number of connectable units
Total capacity downstream Last than 371: PFD112X4-ER	1~16

Note (1) An indoor unit with a capacity up to 112 can be connected.

## Models FDCA504HKXRE4R, 560HKXRE4R

Models		FDCA504HKXRE4R	FDCA560HKXRE4R
Item			
Power source		3 Phase 380-415V 50Hz/380V 60Hz	
Nominal cooling capacity <sup>(1)</sup>	kW	50.4	56.0
Nominal heating capacity <sup>(1)</sup>	kW	56.5	63.0
Noise level	dB(A)	Cooling: 61, Heating: 61.5	Cooling: 62, Heating: 62.5
Exterior dimensions Height × Width × Depth	mm	2048 × 1350 × 720	
Net weight	kg	345	
Refrigerant equipment compressor type & Q'ty		GT-C5150ND78A × 2	
Starting method		Direct line starting	
Capacity control	%	11 ~ 107	9 ~ 107
Crankcase heater	W	33 × 2	
Heat exchanger		Straight fin & inner grooved tubing	
Refrigerant control		Electronic expansion valve	
Refrigerant		R410A	
Quantity	kg	19.4	
Refrigerant oil	ℓ	4.2 (M-MA32R)	
Defrost control		Microcomputer controlled De-Icer	
Air handling equipment Fan type & Q'ty		Propeller fan × 2	
Motor	W	386 × 2	
Starting method		Direct start	
Air flow(Standard)	CMM	Cooling: 270, Heating: 250	
Shock & vibration absorber		Rubber mount (for compressor)	
Safety equipment		Compressor overheat protection, overcurrent protection, power transistor overheating protection, abnormal high pressure protection	
Installation data Refrigerant piping size	mm(in)	Liquid line: ø12.7(1/2") Suction gas line: ø28.58(11/8") Discharge gas line: ø22.22 (7/8")	
Connecting method		Gas line:Brazing, Liquid line:Flare	
Drain		Hole for drain (φ 20 × 6pcs, φ 45 × 3pcs)	
Insulation for piping		Necessary (both Liquid & Gas lines)	
Accessories		—	
Indoor units to be combined		FDCA22, 28, 36, 45, 56 FDTA28, 36, 45, 56, 71, 90, 112, 140 FDTWA28, 45, 56, 71, 90, 112, 140 FDTQA22, 28, 36 FDTSA22, 28, 36, 45, 71 FDQMA22, 28, 36 FDUA224, 280 FDUMA36, 45, 56, 71, 90, 112, 140	FDURA45, 56, 71, 90, 112, 140 FDEA36, 45, 56, 71, 112, 140 FDKA22, 28, 36, 45, 56, 71 FDFLA28, 45, 71 FDFUA28, 45, 56, 71

Notes (1) The cooling and heating capabilities imply the values when the indoor unit of rated capacity is connected under the condition specified in ISO-T1.

(2) The refrigerant quantity in the connecting pipe is not included Charge it additionally at the site.

### List of branch pipe part numbers (Select parts in accordance with the branching system used.)

Corresponding Outdoor Unit	Number of Indoor Units that can be Connected	Branching System	
		In the upstream of a branching controller	In the downstream of a branching controller
FDCA504HKXRE4R	1~29 units	<ul style="list-style-type: none"> <li>Downstream Capacity less than 180 DIS-22-1-R</li> <li>Downstream Capacity 180 to less than 371 DIS-180-1-R</li> <li>Downstream Capacity 371 to less than 540 DIS-371-1-R</li> <li>Downstream Capacity 540 or more DIS-540-1-R</li> </ul>	<ul style="list-style-type: none"> <li>Downstream Capacity less than 180 DIS-22-1</li> <li>Downstream Capacity 180 to less than 371 DIS-180-1</li> </ul>
FDCA560HKXRE4R	1~33 units		

Note (1) In the branch piping method, the way branch piping is run needs to be in accordance with the total downstream capacity of the indoor units.

#### • Branching controller part numbers

Branching controller	Number of connectable units
Total capacity downstream Last than 112: PFD112-E	1~5
Total capacity downstream Last than 180: PFD180-E	1~8
Total capacity downstream Last than 280: PFD280-E	1~10

#### • Integrated branching controller part numbers

Integrated branching controller	Number of connectable units
Total capacity downstream Last than 371: PFD112X4-ER	1~16

Note (1) An indoor unit with a capacity up to 112 can be connected.

## Models FDCA615HKXRE4R, 680HKXRE4R

Models		FDCA615HKXRE4R	FDCA680HKXRE4R
Item			
Power source		3 Phase 380-415V 50Hz/380V 60Hz	
Nominal cooling capacity <sup>(1)</sup>	kW	61.5	68.0
Nominal heating capacity <sup>(1)</sup>	kW	69.0	73.0
Noise level	dB(A)	Cooling: 64, Heating: 64	Cooling: 64.5, Heating: 64.5
Exterior dimensions Height × Width × Depth	mm	2048 × 1350 × 720	
Net weight	kg	365	
Refrigerant equipment compressor type & Q' ty		GT-C5150ND78A × 2	
Starting method		Direct line starting	
Capacity control	%	8 ~ 110	8 ~ 100
Crankcase heater	W	33 × 2	
Heat exchanger		Straight fin & inner grooved tubing	
Refrigerant control		Electronic expansion valve	
Refrigerant		R410A	
Quantity	kg	26.2	
Refrigerant oil	ℓ	4.4 (M-MA32R)	
Defrost control		Microcomputer controlled De-Icer	
Air handling equipment Fan type & Q' ty		Propeller fan × 2	
Motor	W	386 × 2	
Starting method		Direct start	
Air flow(Standard)	CMM	Cooling: 270, Heating: 250	
Shock & vibration absorber		Rubber mount (for compressor)	
Safety equipment		Compressor overheat protection, overcurrent protection, power transistor overheating protection, abnormal high pressure protection	
Installation data Refrigerant piping size	mm(in)	Liquid line: ø12.7(1/2") Suction gas line: ø28.58(1 1/8") Discharge gas line: ø25.4 (1")	
Connecting method		Gas line:Brazing, Liquid line:Flare	
Drain		Hole for drain (φ20 × 6pcs, φ45 × 3pcs)	
Insulation for piping		Necessary (both Liquid & Gas lines)	
Accessories		—	
Indoor units to be combined		FDTCA22, 28, 36, 45, 56 FDTA28, 36, 45, 56, 71, 90, 112, 140 FDTWA28, 45, 56, 71, 90, 112, 140 FDTQA22, 28, 36 FDTSA22, 28, 36, 45, 71 FDQMA22, 28, 36 FDUA224, 280 FDUMA36, 45, 56, 71, 90, 112, 140	FDURA45, 56, 71, 90, 112, 140 FDEA36, 45, 56, 71, 112, 140 FDKA22, 28, 36, 45, 56, 71 FDFLA28, 45, 71 FDFUA28, 45, 56, 71

Notes (1) The cooling and heating capabilities imply the values when the indoor unit of rated capacity is connected under the condition specified in ISO-T1.

(2) The refrigerant quantity in the connecting pipe is not included Charge it additionally at the site.

### List of branch pipe part numbers (Select parts in accordance with the branching system used.)

Corresponding Outdoor Unit	Number of Indoor Units that can be Connected	Branching System	
		In the upstream of a branching controller	In the downstream of a branching controller
FDCA615HKXRE4R	2~36 units	<ul style="list-style-type: none"> <li>Downstream Capacity less than 180</li> <li>DIS-22-1-R</li> <li>Downstream Capacity 180 to less than 371</li> <li>DIS-180-1-R</li> <li>Downstream Capacity 371 to less than 540</li> <li>DIS-371-1-R</li> <li>Downstream Capacity 540 or more</li> <li>DIS-540-1-R</li> </ul>	<ul style="list-style-type: none"> <li>Downstream Capacity less than 180</li> <li>DIS-22-1</li> <li>Downstream Capacity 180 to less than 371</li> <li>DIS-180-1</li> </ul>
FDCA680HKXRE4R	2~40 units		

Note (1) In the branch piping method, the way branch piping is run needs to be in accordance with the total downstream capacity of the indoor units.

#### • Branching controller part numbers

Branching controller	Number of connectable units
Total capacity downstream Last than 112: PFD112-E	1~5
Total capacity downstream Last than 180: PFD180-E	1~8
Total capacity downstream Last than 280: PFD280-E	1~10

#### • Integrated branching controller part numbers

Integrated branching controller	Number of connectable units
Total capacity downstream Last than 371: PFD112X4-ER	1~16


Note (1) An indoor unit with a capacity up to 112 can be connected.

## 2.2 Exterior dimensions


### (1) KX series

Models FDCA140HKXEN4R, 140HKXES4R, 160HKXES4R

Unit: mm



### Required space for maintenance and air flow



### Minimum allowable space to the obstacles

Unit:mm

Installation type	I	II	III
Mark			
$L_1$	Open	Open	500
$L_2$	300	5	Open
$L_3$	150	300	150
$L_4$	5	5	5



#### Notes

- (1) Avoid the location where four sides are entirely surrounded by walls.
- (2) Fix the unit by anchor bolts without fail. Restrict the protrusion length of anchor bolt to 15 mm and under.
- (3) When strong wind blows against the unit, direct the air outlet port at a right angle to the wind direction.
- (4) Secure the space of 1 m and over at the top of unit.
- (5) Make the height of obstruction wall in front of air outlet port lower than the height of unit.




**Models FDCA224HKXE4R, 280HKXE4R, 335HKXE4R**

Unit : mm




Unit:mm

Dimensions	1	2
L1	500	Open
L2	10	10
L3	100	100
L4	10	Open
H1	1500	—
H2	Not limited	Not limited
H3	1000	Not limited
H4	Not limited	—





# Models FDCA335HKXE4R-K, 400HKXE4R, 450HKXE4R

Unit : mm




## Dimensions after connecting included refrigerant piping (Top view)



## VIEW A


Unit:mm

Dimensions	1	2
L1	500	Open
L2	10	10
L3	100	100
L4	10	Open
H1	1500	—
H2	Not limited	Not limited
H3	1000	Not limited
H4	Not limited	—




Models FDCA504HKXE4R, 560HKXE4R, 615HKXE4R, 680HKXE4R

Unit : mm



For dimensions of anchor bolt hole

Dimensions after connecting included refrigerant piping (Top view)




VIEW A

Unit:mm

Dimensions	1	2
L	500	Open
L2	10	10
L3	100	100
L4	10	Open
H	1500	—
H2	Not limited	Not limited
H3	1000	Not limited
H4	Not limited	—

# Models FDCA735HKXE4R, 800HKXE4R



Model FDCA850HKXE4R

Technical drawing of Model FDCA850HKXE4R showing front, side, and top views with dimensions and labels for various components like pipes, holes, and displays.

**Unit : mm**

**Front View Dimensions:**

- Overall width: 720
- Overall height: 1262
- Internal height segments: 1690, 797.8, 682, 84
- Refrigerant gas piping connection pipe:  $\phi 25.4$  (1")
- Refrigerant oil equalization piping connection pipe:  $\phi 9.52$  (3/8")
- Refrigerant liquid piping connection pipe:  $\phi 12.7$  (1/2")
- Refrigerant gas piping connection pipe:  $\phi 28.58$  (1 1/8")
- Power supply entry hole:  $(\phi 50)$
- 7-segment display
- Signal wire connection terminal box
- Power supply connection terminal box
- Power supply entry hole:  $(\phi 50)$
- Refrigerant piping exit hole:  $(\phi 88 \text{ or } \phi 100)$
- Model name label
- Refrigerant piping exit hole:  $(\phi 88 \text{ or } \phi 100)$
- Power supply entry hole:  $(40 \times 80)$
- Drain hole:  $(\phi 20, 6 \text{ pcs.})$
- Drain waste water hose hole:  $(\phi 45, 3 \text{ pcs.})$
- Air inlet
- Anchor bolt hole:  $(M10, 4 \text{ pcs.})$

**Side View Dimensions:**

- Overall width: 1350
- Overall height: 1262
- Internal height segments: 1690, 797.8, 682, 84
- Refrigerant gas piping connection pipe:  $\phi 25.4$  (1")
- Refrigerant oil equalization piping connection pipe:  $\phi 9.52$  (3/8")
- Refrigerant liquid piping connection pipe:  $\phi 12.7$  (1/2")
- Refrigerant gas piping connection pipe:  $\phi 28.58$  (1 1/8")
- Power supply entry hole:  $(\phi 50)$
- 7-segment display
- Signal wire connection terminal box
- Power supply connection terminal box
- Power supply entry hole:  $(\phi 50)$
- Refrigerant piping exit hole:  $(\phi 88 \text{ or } \phi 100)$
- Model name label
- Refrigerant piping exit hole:  $(\phi 88 \text{ or } \phi 100)$
- Power supply entry hole:  $(40 \times 80)$
- Drain hole:  $(\phi 20, 6 \text{ pcs.})$
- Drain waste water hose hole:  $(\phi 45, 3 \text{ pcs.})$
- Air inlet
- Anchor bolt hole:  $(M10, 4 \text{ pcs.})$

**Top View Dimensions:**

- Overall width: 2710
- Overall height: 1720
- Internal width segments: 250, 850, 510, 850, 250
- Internal height segments: 175, 1000, 360, 1000, 175
- Refrigerant gas piping connection pipe:  $\phi 25.4$  (1")
- Refrigerant oil equalization piping connection pipe:  $\phi 9.52$  (3/8")
- Refrigerant liquid piping connection pipe:  $\phi 12.7$  (1/2")
- Refrigerant gas piping connection pipe:  $\phi 28.58$  (1 1/8")
- Power supply entry hole:  $(\phi 50)$
- 7-segment display
- Signal wire connection terminal box
- Power supply connection terminal box
- Power supply entry hole:  $(\phi 50)$
- Refrigerant piping exit hole:  $(\phi 88 \text{ or } \phi 100)$
- Model name label
- Refrigerant piping exit hole:  $(\phi 88 \text{ or } \phi 100)$
- Power supply entry hole:  $(40 \times 80)$
- Drain hole:  $(\phi 20, 6 \text{ pcs.})$
- Drain waste water hose hole:  $(\phi 45, 3 \text{ pcs.})$
- Air inlet
- Anchor bolt hole:  $(M10, 4 \text{ pcs.})$

**VIEW A**

**Dimensions after connecting included refrigerant piping (Top view)**

- Refrigerant gas piping connection pipe:  $\phi 25.4$  (1")
- Refrigerant oil equalization piping connection pipe:  $\phi 9.52$  (3/8")
- Refrigerant liquid piping connection pipe:  $\phi 12.7$  (1/2")
- Refrigerant gas piping connection pipe:  $\phi 28.58$  (1 1/8")
- Power supply entry hole:  $(\phi 50)$
- 7-segment display
- Signal wire connection terminal box
- Power supply connection terminal box
- Power supply entry hole:  $(\phi 50)$
- Refrigerant piping exit hole:  $(\phi 88 \text{ or } \phi 100)$
- Model name label
- Refrigerant piping exit hole:  $(\phi 88 \text{ or } \phi 100)$
- Power supply entry hole:  $(40 \times 80)$
- Drain hole:  $(\phi 20, 6 \text{ pcs.})$
- Drain waste water hose hole:  $(\phi 45, 3 \text{ pcs.})$
- Air inlet
- Anchor bolt hole:  $(M10, 4 \text{ pcs.})$

**Installation space**

**Wall height H3**



**Wall height H2**

**Wall height H1**


**Wall height H4**

Insulation example	1	2
L1	500	Open
L2	10	10
L3	100	100
L4	10	Open
H1	1500	—
H2	No limited	No limited
H3	1000	No limited
H4	No limited	—

# Model FDCA900HKXE4R



Unit : mm		
Installation Dimensions	1	2
L1	500	Open
L2	10	10
L3	100	100
L4	10	Open
H1	1500	—
H2	No limited	No limited
H3	1000	No limited
H4	No limited	—

**Model FDCA960HKXE4R**



## Unit : mm





### Models FDCA224HKXRE4R, 280HKXRE4R, 335HKXRE4R

[illegible]

**Dimensions after connecting included refrigerant piping (Top view)**

Refrigerant suction gas piping connection pipe  
224:ø19.05(3/4")  
280,335:ø22.22(7/8")

Refrigerant discharge gas piping connection pipe  
224:ø15.88(5/8")  
280,335:ø19.05(3/4")

Refrigerant liquid piping connection pipe  
224,280:ø9.52(3/8")  
335:ø12.7(1/2")

Refrigerant piping exit hole  
(ø88 or ø100)

Carrying in or hole for hanging  
(180 × 44.7)

**VIEW A**

Unit:mm

Dimensions	1	2
L	500	Open
L2	10	10
L3	100	100
L4	10	Open
H	1500	—
H2	Not limited	Not limited
H3	1000	Not limited
H4	Not limited	—



## Unit:mm





<div><div>Installation example</div><div>Dimensions</div></div>		Unit:mm	
		1	2
L	500	Open	
L2	10	10	
L3	100	100	
L4	10	Open	
H	1500	——	
H2	Not limited	Not limited	
H3	1000	Not limited	
H4	Not limited	——	

**Model FDCA450HKXRE4R**

Unit:mm




**VIEW A**



		Unit:mm	
Installation example	1	2	
Dimensions			
L	500	Open	
L2	10	10	
L3	100	100	
L4	10	Open	
H	1500	——	
H2	Not limited	Not limited	
H3	1000	Not limited	
H4	Not limited	——	

Models FDCA504HKXRE4R, 560HKXRE4R, 615HKXRE4R, 680HKXRE4R


Unit : mm




## 2.3 Inside view


(1) KX series

Models FDCA140HKXEN4R, 140HKXES4R, 160HKXES4R












(2) KXR series  
Models FDCA224HKXRE4R, 280HKXRE4R, 335HKXRE4R









## 2.4 Exterior appearance

Models FDCA140HKXEN4R, 140HKXES4R, 160HKXES4R



Models FDCA224HKXE4R, 280HKXE4R, 335HKXE4R, 335HKXE4R-K, 400HKXE4R, 450HKXE4R  
504HKXE4R, 560HKXE4R, 615HKXE4R, 680HKXE4R  
224HKXRE4R, 280HKXRE4R, 335HKXRE4R, 335HKXRE4R-K, 400HKXRE4R, 450HKXRE4R  
504HKXRE4R, 560HKXRE4R, 615HKXRE4R, 680HKXRE4R



## 2.5 Noise level

Measured based on JIS B 8616

Mike position as highest noise level in position as below


Distance from front side 1m

Height 1m

### (1) KX series


**Models FDCA140HKXEN4R,  
140HKXES4R**

**Noise level** 53 dB (A) at cooling  
53 dB (A) at heating




**Model FDCA160HKXES4R**

**Noise level** 53 dB (A) at cooling  
53 dB (A) at heating




**Model FDCA224HKXE4R**

**Noise level** 57 dB (A) at cooling  
57 dB (A) at heating




**Model FDCA280HKXE4R**

**Noise level** 57 dB (A) at cooling  
58 dB (A) at heating




**Model FDCA335HKXE4R**

**Noise level** 60.5 dB (A) at cooling  
61 dB (A) at heating




**Model FDCA335HKXE4R-K**

**Noise level** 56 dB (A) at cooling  
57 dB (A) at heating




**Model FDCA400HKXE4R**

**Noise level** 58.5 dB (A) at cooling  
59 dB (A) at heating




**Model FDCA450HKXE4R**

**Noise level** 61 dB (A) at cooling  
61 dB (A) at heating




**Model FDCA504HKXE4R**


**Noise level** 60 dB (A) at cooling  
60.5 dB (A) at heating




**Noise level** 60.5 dB (A) at cooling  
62.5 dB (A) at heating



**Noise level** 63 dB (A) at cooling  
63 dB (A) at heating




**Noise level** 63.5 dB (A) at cooling  
63.5 dB (A) at heating




## (2) KXR series


**Noise level** 57 dB (A) at cooling  
57 dB (A) at heating




**Noise level** 57 dB (A) at cooling  
59 dB (A) at heating




**Noise level** 60.5 dB (A) at cooling  
62.5 dB (A) at heating




**Noise level** 57 dB (A) at cooling  
57.5 dB (A) at heating




**Noise level** 59.5 dB (A) at cooling  
60 dB (A) at heating




**Noise level** 62.5 dB (A) at cooling  
62.5 dB (A) at heating




**Noise level** 62.5 dB (A) at cooling  
62.5 dB (A) at heating



**Noise level** 61 dB (A) at cooling  
61.5 dB (A) at heating




**Noise level** 62 dB (A) at cooling  
62.5 dB (A) at heating




**Model FDCA615HKXRE4R**

Noise level 64 dB (A) at cooling  
64 dB (A) at heating

**Model FDCA680HKXRE4R**


Noise level 64.5 dB (A) at cooling  
64.5 dB (A) at heating




## 2.6 Electrical wiring

### (1) KX series

Model FDCA140HXEN4R








#### Meaning of marks


Mark	Parts name	Mark	Parts name
CM	Compressor motor	CNA~X	Connector
FMO1,2	Fan motor	SW1	Address setting SW for the number of tens
52C1	Magnetic contactor for CM	SW2	Address setting SW for the number of units
CH	Crankcase heater	SW3-1	Inspection LED reset
20S	Four-way valve (coil)	SW5-6,7,8	Capacity measurement mode
SV2,3	Solenoid valve (oil separator)	SW7	Clear data
EEVc,h	Electronic expansion valve	SW8	7-segment indicate unit digit
Tho-A	Thermistor (outdoor temp.)	SW9	7-segment indicate tens digit
Tho-C	Thermistor (dome bottom)	J1~J3	Unit selector
Tho-D	Thermistor (discharge pipe)	J5,6	Demand capacity selector
Tho-R	Thermistor (heat exchanger)	J8	Anti-snow measures
Tho-P	Thermistor (power transistor)	J13	External input selector level/pulse
Tho-S	Thermistor (suction pipe)	J15	Defrost start temperature selector
PSL	Low pressure sensor	LED1	Inspection indication (red)
PSH	High pressure sensor	LED2	Inspection indication (green)
CT	Current sensor	LED3	Inspection indication (green)
Tr	Transformer	7SEG1	7-segment LED (function indication)
TB, TBX	Terminal block	7SEG2	7-segment LED (data indication)
F	Fuse		



### Meaning of marks

Mark	Parts name	Mark	Parts name	Mark	Parts name
CM1	Compressor motor	Tho-R2	Thermistor (outdoor H.X. temp outlet)	SW7	Data clear/insert
FMO1,2	Fan motor (outdoor unit)	Tho-R3	Thermistor (outdoor H.X. temp inlet)	SW8	7seg indicate (unit digit)
52C1	Magnetic contactor for CM	Tho-R4	Thermistor (outdoor H.X. temp inlet)	SW9	7seg indicate (tens digit)
CH1	Crankcase heater	PSL	Low pressure sensor	SW10	Reset
X01-12	Auxiliary relay	PSH	High pressure sensor	J11,12	Set up model (volt)
20S	4way valve	CT1	Current sensor	J13	External input select level/pulse
SV1	Solenoid valve (CM1:bypass)	SA	Arrestor	J14	Defrost recover temp
SV6	Solenoid valve (oil separator CM1)	Tr	Transformer	J15	Defrost start temp
EEVH1,2	Expansion valve for heating	Va1-3	Varistor	J16	Heat recovery unit
EEVSC	Expansion valve for SC	TB1,2	Terminal block	LED1	Indication lamp (red)
63H1-1	High pressure switch (for protection)	F	Fuse	LED2	Indication lamp (green)
Tho-A	Thermistor (outdoor air temp)	CNA-Z	Connector	LED3	Indication lamp (green for service)
Tho-C1	Thermistor (dome temp)	SW1	Outdoor unit address (tens digit)	7SEG1	7seg L.E.D. (function indication)
Tho-D1	Thermistor (discharge temp)	SW2	Outdoor unit address (unit digit)	7SEG2	7seg L.E.D. (data indication)
Tho-P1	Thermistor (IPM temp)	SW3-1	L.E.D.reset	L1,L2	D.C.react
Tho-S	Thermistor (suction temp)	SW4-1~4	Set up model	C1-1,2,C2-1,2	Condensor
Tho-SC	Thermistor (SC1 temp)	SW4-5	Demand	PWB1~4	Printed wiring board
Tho-H	Thermistor (SC2 temp)	SW4-6	Demand	IPM	Intelligent power module
Tho-R1	Thermistor (outdoor H.X. temp outlet)	SW4-7	Address setting switch (master-slave)	FMC1,2	Fan for IPM
		SW4-8	Address setting switch (master-slave)		
		SW5-4-8	Spare		

CM Terminal




### Function of switches

Mark	Function
SW3-2	ON Auto backup operation
OFF	Regular operation
SW3-3	ON Set of renewal
OFF	Regular operation
SW3-4	ON Check mode non-available
OFF	Check mode available
SW3-5	ON Check of trial operation
OFF	Regular operation
SW3-6	ON Pipe wash mode
OFF	Regular operation
SW3-7	ON Forced cooling/heating
OFF	Regular operation
SW3-8	ON Test mode
OFF	Regular operation
SW5-1	ON Trial operation
OFF	Regular operation
SW5-2	ON Trial operation mode/cooling
OFF	Trial operation mode/heating
SW5-3	ON Pump down operation
OFF	Regular operation

### Color marks


Mark	Color
BK	Black
BL	Blue
BR	Brawn
GN	Green
GR	Gray
OR	Orange
RD	Red
WH	White
Y	Yellow
Y/GN	Yellow/Green





## Meaning of marks

Mark	Parts name	Mark	Parts name	Mark	Parts name
CM1,2	Compressor motor	Tho-R2	Thermistor (outdoor H.X. temp outlet)	SW7	Data clear/insert
FMO1,2	Fan motor (outdoor unit)	Tho-R3	Thermistor (outdoor H.X. temp inlet)	SW8	7seg indicate (unit digit)
52C1,2	Magnetic contactor for CM	Tho-R4	Thermistor (outdoor H.X. temp inlet)	SW9	7seg indicate (tens digit)
CH1,2	Crankcase heater	PSL	Low pressure sensor	SW10	Reset
X01~13	Auxiliary relay	PSH	High pressure sensor	J11,12	Set up model (volt)
20S	4way valve	CT1,CT2	Current sensor	J13	External input select level/pulse
SV1	Solenoid valve (CM1:bypass)	SA	Arrestor	J14	Defrost recover temp
SV2	Solenoid valve (CM2:bypass)	Tr	Transformer	J15	Defrost start temp
SV6	Solenoid valve (oil separator CM1)	Va1~3	Varistor	J16	Heat recovery unit
SV7	Solenoid valve (oil separator CM2)	TB1,2	Terminal block	LED1	Indication lamp (red)
EEVH1,2	Expansion valve for heating	F	Fuse	LED2	Indication lamp (green)
EEVSC	Expansion valve for SC	CNA-Z	Connector	LED3	Indication lamp (green for service)
63H1-1,2	High pressure switch (for protection)	SW1	Outdoor unit address (tens digit)	7SEG1	7seg L.E.D. (function indication)
Tho-A	Thermistor (outdoor air temp)	SW2	Outdoor unit address (unit digit)	7SEG2	7seg L.E.D. (data indication)
Tho-C1,2	Thermistor (dome temp)	SW3-1	L.E.D.reset	L1,L2,L3	D.C.reactor
Tho-D1,2	Thermistor (discharge temp)	SW4-1~4	Set up model	C1~1,2,C2~1,2	Condensor
Tho-P1,2	Thermistor (IPM temp)	SW4-5	Demand	PWB1~4	Printed wiring board
Tho-S	Thermistor (suction temp)	SW4-6	Demand	IPM	Intelligent power module
Tho-SC	Thermistor (SC1 temp)	SW4-7	Address setting switch (master-slave)	FMC1,2	Fan for IPM
Tho-H	Thermistor (SC2 temp)	SW4-8	Address setting switch (master-slave)		
Tho-R1	Thermistor (outdoor H.X. temp outlet)	SW5-4~8	Spare		



## Meaning of marks

Mark	Parts name	Mark	Parts name	Mark	Parts name
CM1,2	Compressor motor	Tho-R2	Thermistor (outdoor H.X. temp outlet)	SW7	Data clear/insert
FMO1,2	Fan motor (outdoor unit)	Tho-R3	Thermistor (outdoor H.X. temp inlet)	SW8	7seg indicate (unit digit)
52C1,2	Magnetic contactor for CM	Tho-R4	Thermistor (outdoor H.X. temp inlet)	SW9	7seg indicate (tens digit)
CH1,2	Crankcase heater	PSL	Low pressure sensor	SW10	Reset
X01-13	Auxiliary relay	PSH	High pressure sensor	J11,12	Set up model (volt)
20S	4way valve	CT1,CT2	Current sensor	J13	External input select level/pulse
SV1	Solenoid valve (CM1:bypass)	SA	Arrestor	J14	Defrost recover temp
SV2	Solenoid valve (CM2:bypass)	Tr	Transformer	J15	Defrost start temp
SV6	Solenoid valve (oil separator CM1)	Va1-3	Varistor	J16	Heat recovery unit
SV7	Solenoid valve (oil separator CM2)	TB1,2	Terminal block	LED1	Indication lamp (red)
EEVH1,2	Expansion valve for heating	F	Fuse	LED2	Indication lamp (green)
EEVSC	Expansion valve for SC	CNA-Z	Connector	LED3	Indication lamp (green for service)
63H1-1,2	High pressure switch (for protection)	SW1	Outdoor unit address (tens digit)	7SEG1	7seg L.E.D. (function indication)
Tho-A	Thermistor (outdoor air temp)	SW2	Outdoor unit address (unit digit)	7SEG2	7seg L.E.D. (data indication)
Tho-C1,2	Thermistor (dome temp)	SW3-1	L.E.D.reset	L1,L2	D.C.reactior
Tho-D1,2	Thermistor (discharge temp)	SW4-1-4	Set up model	C1-1,2,C2-1,2	Condensor
Tho-P1,2	Thermistor (IPM temp)	SW4-5	Demand	PWB1-4	Printed wiring board
Tho-S	Thermistor (suction temp)	SW4-6	Demand	IPM	Intelligent power module
Tho-SC	Thermistor (SC1 temp)	SW4-7	Address setting switch (master-slave)	FMC1,2	Fan for IPM
Tho-H	Thermistor (SC2 temp)	SW4-8	Address setting switch (master-slave)		
Tho-R1	Thermistor (outdoor H.X. temp outlet)	SW5-4-8	Spare		


## Function of switches

Mark	Function
SW3-2	ON Auto backup operation
OFF	Regular operation
SW3-3	ON Set of renewal
OFF	Regular operation
SW3-4	ON Check mode non-available
OFF	Check mode available
SW3-5	ON Check of trial operation
OFF	Regular operation
SW3-6	ON Pipe wash mode
OFF	Regular operation
SW3-7	ON Forced cooling/heating
OFF	Regular operation
SW3-8	ON Test mode
OFF	Regular operation
SW5-1	ON Trial operation
OFF	Regular operation
SW5-2	ON Trial operation mode/cooling
OFF	Trial operation mode/heating
SW5-3	ON Pump down operation
OFF	Regular operation

## Color marks

Mark	Color
BK	Black
BL	Blue
BR	Brown
GN	Green
GR	Gray
OR	Orange
RD	Red
WH	White
Y	Yellow
Y/GN	Yellow/Green





#### Meaning of marks


Mark	Parts name	Mark	Parts name	Mark	Parts name
CM1,2	Compressor motor	Tho-R1	Thermistor (outdoor H.X. temp outlet)	SW7	Data clear/insert
FMO1,2	Fan motor (outdoor unit)	Tho-R2	Thermistor (outdoor H.X. temp outlet)	SW8	7seg indicate (unit digit)
52C1,2	Magnetic contactor for CM	Tho-R3	Thermistor (outdoor H.X. temp inlet)	SW9	7seg indicate (tens digit)
CH1,2	Crankcase heater	Tho-R4	Thermistor (outdoor H.X. temp inlet)	SW10	Reset
X01-18	Auxiliary relay	PSL	Low pressure sensor	J11, J12	Set up model (volt)
20S	4way valve	PSH	High pressure sensor	J13	External input select level/pulse
20SL	4way valve	CT1, CT2	Current sensor	J14	Defrost recover temp
SV4	Solenoid valve (outdoor H.X.)	SA	Arrestor	J15	Defrost start temp
SV6	Solenoid valve (oil separator CM1)	Tr	Transformer	J16	Heat recovery unit
SV7	Solenoid valve (oil separator CM2)	Va1-3	Varistor	LED1	Indication lamp (red)
SV11	Solenoid valve (gas bypass)	TB1,2	Terminal block	LED2	Indication lamp (green)
EEVH1,2	Expansion valve for heating	F	Fuse	LED3	Indication lamp (green for service)
EEVSC	Expansion valve for SC	SW1	Outdoor unit address (tens digit)	7SEG1	7seg L.E.D. (function indication)
63H1-1,2	High pressure switch (for protection)	SW2	Outdoor unit address (unit digit)	7SEG2	7seg L.E.D. (data indication)
Tho-A	Thermistor (outdoor air temp)	SW3-1	L.E.D.reset	L1, L2	D.C.reactior
Tho-C1,2	Thermistor (dome temp)	SW4-1-4	Set up model	L3	D.C.reactior
Tho-D1,2	Thermistor (discharge temp)	SW4-5	Demand	C1-1,2, C2-1,2	Condensor
Tho-P1,2	Thermistor (IPM temp)	SW4-6	Demand	PWB1-4	Printed wiring board
Tho-S	Thermistor (suction temp)	SW4-7	Address setting switch (master - slave)	IPM	Intelligent power module
Tho-SC	Thermistor (SC1 temp)	SW4-8	Address setting switch (master - slave)	FMC1,2	Fan for IPM
Tho-H	Thermistor (SC2 temp)	SW5-4-8	Spare	CNA-Z	Connector

#### Function of switches

Mark	Function
SW3-2	ON Auto backup operation
	OFF Regular operation
SW3-3	ON Set of renewal
	OFF Regular operation
SW3-4	ON Check mode non-available
	OFF Check mode available
SW3-5	ON Check of trial operation
	OFF Regular operation
SW3-6	ON Pipe wash mode
	OFF Regular operation
SW3-7	ON Forced cooling/heating
	OFF Regular operation
SW3-8	ON Test mode
	OFF Regular operation
SW5-1	ON Trial operation
	OFF Regular operation
SW5-2	ON Trial operation mode/cooling
	OFF Trial operation mode/heating
SW5-3	ON Pump down operation
	OFF Regular operation

#### Color marks

Mark	Color
BK	Black
BL	Blue
BR	Brown
GN	Green
GR	Gray
OR	Orange
RD	Red
WH	White
Y	Yellow
P	Pink
Y/GN	Yellow/Green



# Meaning of marks

Mark	Parts name	Mark	Parts name	Mark	Parts name
CM1.2	Compressor motor	Tho-R1	Thermistor (outdoor H.X. temp outlet)	SW7	Data clear/insert
FM01.2	Fan motor (outdoor unit)	Tho-R2	Thermistor (outdoor H.X. temp outlet)	SW8	7seg indicate (unit digit)
52C1.2	Magnetic contactor for CM	Tho-R3	Thermistor (outdoor H.X. temp inlet)	SW9	7seg indicate (tens digit)
CH1.2	Crankcase heater	Tho-R4	Thermistor (outdoor H.X. temp inlet)	SW10	Reset
X01-18	Auxiliary relay	PSL	Low pressure sensor	J11.1,2	Set up model (volt)
20S	4way valve	PSH	High pressure sensor	J13	External input select level/pulse
20SL	4way valve	CT1,CT2	Current sensor	J14	Defrost recover temp
SV4	Solenoid valve (outdoor H.X.)	SA	Arrestor	J15	Defrost start temp
SV6	Solenoid valve (oil separator CM1)	Tr	Transformer	J16	Heat recovery unit
SV7	Solenoid valve (oil separator CM2)	Va1-3	Varistor	LED1	Indication lamp (red)
SV11	Solenoid valve (gas bypass)	TB1.2	Terminal block	LED2	Indication lamp (green)
EEVH1.2	Expansion valve for heating	F	Fuse	LED3	Indication lamp (green for service)
EEVSC	Expansion valve for SC	SW1	Outdoor unit address (tens digit)	7SEG1	7seg L.E.D. (function indication)
63H1-1,2	High pressure switch (for protection)	SW2	Outdoor unit address (unit digit)	7SEG2	7seg L.E.D. (data indication)
Tho-A	Thermistor (outdoor air temp)	SW3-1	L.E.D.reset	L1,L2	D.C.reactor
Tho-C1.2	Thermistor (dome temp)	SW4-1-4	Set up model	L3	D.C.reactor (* only 450 type)
Tho-D1.2	Thermistor (discharge temp)	SW4-5	Demand	C1-1,2,C2-1,2	Condensor
Tho-P1.2	Thermistor (IPM temp)	SW4-6	Demand	PWB1-4	Printed wiring board
Tho-S	Thermistor (suction temp)	SW4-7	Address setting switch (master - slave)	IPM	Intelligent power module
Tho-SC	Thermistor (SC1 temp)	SW4-8	Address setting switch (master - slave)	FM1.2	Fan for IPM
Tho-H	Thermistor (SC2 temp)	SW5-4-8	Spare	CNA-Z	Connector

# Function of switches

Mark	Function
SW3-2	ON Auto backup operation
	OFF Regular operation
SW3-7	ON Forced cooling/heating
	OFF Regular operation
SW3-8	ON Test mode
	OFF Regular operation
SW5-1	ON Trial operation
	OFF Regular operation
SW5-2	ON Trial operation mode/cooling
	OFF Trial operation mode/heating
SW5-3	ON Pump down operation
	OFF Regular operation

# Color marks

Mark	Color
BK	Black
BL	Blue
BR	Brown
GN	Green
GR	Gray
OR	Orange
RD	Red
WH	White
Y	Yellow
P	Pink
Y/GN	Yellow/Green

## 3 INDOOR UNIT

### 3.1 Specifications

#### (a) Ceiling recessed compact type (FDTC)

##### Models FDTCA22KXE4R, 28KXE4R

Item		Models	FDTCA22KXE4R	FDTCA28KXE4R
Nominal cooling capacity* <sup>1</sup>		kW	2.2	2.8
Nominal heating capacity* <sup>2</sup>		kW	2.5	3.2
Power source			1 Phase 220-240V 50Hz/220V 60Hz	
Noise level		dB(A)	Hi: 35 Me: 33 Lo: 32	
Exterior dimensions Height × Width × Depth		mm	Unit:248 × 570 × 570	Panel:35 × 700 × 700
Net weight		kg	Unit:15	Panel:3.5
Refrigerant equipment Heat exchanger			Louver fin & inner grooved tubing	
Refrigerant control			Electronic Expansion Valve	
Air handling equipment Fan type & Q'ty			Turbo fan × 1	
Motor		W	50 × 1	
Starting method			Direct line starting	
Air flow(Standard)		CMM	Hi: 9.5 Me: 8.5 Lo: 8	
Outside air intake			Possible	
Air filter, Q'ty			Long life filter × 1(Washable)	
Shock & vibration isolator			Rubber sleeve(for fan motor)	
Insulation (noise & heat)			Polyurethane foam	
Operation control Operation switch			Wired remote control switch (Optional:RC-E1R) Wireless kit (Optional:RCND-KIT-HER)	
Room temperature control			Thermostat by electronics	
Safety equipment			Internal thermostat for fan motor. Frost protection thermostat	
Installation data Refrigerant piping size		mm(in)	Liquid line: φ6.35(1/4") Gas line: φ9.52(3/8")	
Connecting method			Flare piping	
Drain hose			Connectable with VP25(I.D.25mm, O.D.32mm)	
Insulation for piping			Necessary (both Liquid & Gas line)	
Accessories			Mounting kit, Drain hose	
Optional parts			Decorative Panel	

Notes (1) The data are measured at the following conditions.

Operation	Item	Indoor air temperature		Outdoor air temperature		Standards
		DB	WB	DB	WB	
Cooling* <sup>1</sup>		27℃	19℃	35℃	24℃	ISO-T1
Heating* <sup>2</sup>		20℃	—	7℃	6℃	

(2) This packaged air-conditioner is manufactured and tested in conformity with the following standard.  
ISO-T1 "UNITARY AIR-CONDITIONERS"

●Decorative Panel model (Optional)

Model	Item	Panel Part No.
		T-PSA-24W-ER
FDTCA22,28 type		



# Models FDTCA36KXE4R, 45KXE4R, 56KXE4R

Item		Models	FDTCA36KXE4R	FDTCA45KXE4R	FDTCA56KXE4R
Nominal cooling capacity* <sup>1</sup>	kW		3.6	4.5	5.6
Nominal heating capacity* <sup>2</sup>	kW		4.6	5.0	6.3
Power source			1 Phase 220-240V 50Hz/220V 60Hz		
Noise level	dB(A)		Hi: 38 Me: 36 Lo: 34	Hi: 40 Me: 38 Lo: 36	Hi: 45 Me: 42 Lo: 39
Exterior dimensions Height × Width × Depth	mm		Unit:248 × 570 × 570 Panel:35 × 700 × 700		
Net weight	kg		Unit:16 Panel:3.5		
Refrigerant equipment Heat exchanger			Louver fin & inner grooved tubing		
Refrigerant control			Electronic Expansion Valve		
Air handling equipment Fan type & Q'ty			Turbo fan × 1		
Motor	W		50 × 1		
Starting method			Direct line starting		
Air flow(Standard)	CMM		Hi: 10 Me: 9 Lo: 8	Hi: 11 Me: 10 Lo: 9	Hi: 13 Me: 11.5 Lo: 10
Outside air intake			Possible		
Air filter, Q'ty			Long life filter × 1(Washable)		
Shock & vibration isolator			Rubber sleeve(for fan motor)		
Insulation (noise & heat)			Polyurethane foam		
Operation control Operation switch			Wired remote control switch (Optional:RC-E1R) Wireless kit (Optional:RCND-KIT-HER)		
Room temperature control			Thermostat by electronics		
Safety equipment			Internal thermostat for fan motor. Frost protection thermostat		
Installation data Refrigerant piping size	mm(in)		Liquid line: φ 6.35(1/4") Gas line: φ 12.7(1/2")		
Connecting method			Flare piping		
Drain hose			Connectable with VP25(I.D.25mm, O.D.32mm)		
Insulation for piping			Necessary (both Liquid & Gas lines)		
Accessories			Mounting kit, Drain hose		
Optional parts			Decorative Panel		

Notes (1) The data are measured at the following conditions.

Item	Indoor air temperature		Outdoor air temperature		Standards
	DB	WB	DB	WB	
Operation					
Cooling* <sup>1</sup>	27℃	19℃	35℃	24℃	ISO-T1
Heating* <sup>2</sup>	20℃	—	7℃	6℃	

(2) This packaged air-conditioner is manufactured and tested in conformity with the following standard.  
ISO-T1 "UNITARY AIR-CONDITIONERS"

●Decorative Panel model (Optional)

Item	Model
Panel Part No.	FDTCA36,45,56 type
	T-PSA-24W-ER

(b) Ceiling recessed type (FDT)

Models FDTA28KXE4R, 36KXE4R

Item		Models	FDTA28KXE4R	FDTA36KXE4R
Nominal cooling capacity* <sup>1</sup>	kW		2.8	3.6
Nominal heating capacity* <sup>2</sup>	kW		3.2	4.0
Power source			1 Phase 220-240V 50Hz/220V 60Hz	
Noise level	dB(A)		Hi: 35 Me: 33 Lo: 31	
Exterior dimensions Height × Width × Depth	mm		Unit:270 × 840 × 840 Panel:35 × 950 × 950	
Net weight	kg		Unit:24 Panel:7	
Refrigerant equipment Heat exchanger			Louver fin & inner grooved tubing	
Refrigerant control			Electronic Expansion Valve	
Air handling equipment Fan type & Q'ty			Turbo fan × 1	
Motor	W		14 × 1	
Starting method			Direct line starting	
Air flow(Standard)	CMM		Hi: 13 Me: 12 Lo: 11	
Outside air intake			Possible	
Air filter, Q'ty			Long life filter × 1(Washable)	
Shock & vibration isolator			Rubber sleeve(for fan motor)	
Insulation (noise & heat)			Polyurethane foam	
Operation control Operation switch			Wired remote control switch (Optional:RC-E1R) Wireless remote control switch (Optional:RCN-T-35W-ER)	
Room temperature control			Thermostat by electronics	
Safety equipment			Internal thermostat for fan motor. Frost protection thermostat	
Installation data Refrigerant piping size	mm(in)		Liquid line:φ6.35(1/4") Gas line:φ9.52(3/8")	Liquid line:φ6.35(1/4") Gas line:φ12.7(1/2")
Connecting method			Flare piping	
Drain hose			Connectable with VP25(I.D.25mm, O.D.32mm)	
Insulation for piping			Necessary (both Liquid & Gas line)	
Accessories			Mounting kit, Drain hose	
Optional parts			Decorative Panel	

Notes (1) The data are measured at the following conditions.

Item	Indoor air temperature		Outdoor air temperature		Standards
	DB	WB	DB	WB	
Operation					
Cooling* <sup>1</sup>	27℃	19℃	35℃	24℃	ISO-T1
Heating* <sup>2</sup>	20℃	—	7℃	6℃	

(2) This packaged air-conditioner is manufactured and tested in conformity with the following standard.  
ISO-T1 "UNITARY AIR-CONDITIONERS"

●Decorative Panel model (Optional)

Model	Item	Panel Part No.
FDTA28,36 type		T-PSA-35W-ER



**Models FDTA45KXE4R, 56KXE4R, 71KXE4R**

Item		Models	FDTA45KXE4R	FDTA56KXE4R	FDTA71KXE4R
Nominal cooling capacity* <sup>1</sup>	kW		4.5	5.6	7.1
Nominal heating capacity* <sup>2</sup>	kW		5.0	6.3	8.0
Power source			1 Phase 220-240V 50Hz/220V 60Hz		
Noise level	dB(A)		Hi: 35 Me: 33 Lo: 31	Hi: 36 Me: 34 Lo: 32	Hi: 37 Me: 35 Lo: 33
Exterior dimensions Height × Width × Depth	mm		Unit:270 × 840 × 840 Panel:35 × 950 × 950		
Net weight	kg		Unit:24 Panel:7		
Refrigerant equipment Heat exchanger			Louver fin & inner grooved tubing		
Refrigerant control			Electronic Expansion Valve		
Air handling equipment Fan type & Q'ty			Turbo fan × 1		
Motor	W		14 × 1		20 × 1
Starting method			Direct line starting		
Air flow(Standard)	CMM		Hi: 14 Me: 12 Lo: 11		Hi: 15 Me: 14 Lo: 13
Outside air intake			Possible		
Air filter, Q'ty			Long life filter × 1(Washable)		
Shock & vibration isolator			Rubber sleeve(for fan motor)		
Insulation (noise & heat)			Polyurethane foam		
Operation control Operation switch			Wired remote control switch (Optional:RC-E1R) Wireless remote control switch (Optional:RCN-T-35W-ER)		
Room temperature control			Thermostat by electronics		
Safety equipment			Internal thermostat for fan motor. Frost protection thermostat		
Installation data Refrigerant piping size	mm(in)		Liquid line:φ6.35(1/4") Gas line:φ12.7(1/2")		Liquid line:φ9.52(3/8") Gas line:φ15.88(5/8")
Connecting method			Flare piping		
Drain hose			Connectable with VP25(I.D.25mm, O.D.32mm)		
Insulation for piping			Necessary (both Liquid & Gas lines)		
Accessories			Mounting kit, Drain hose		
Optional parts			Decorative Panel		

Notes (1) The data are measured at the following conditions.

Item	Indoor air temperature		Outdoor air temperature		Standards
	DB	WB	DB	WB	
Operation					
Cooling* <sup>1</sup>	27℃	19℃	35℃	24℃	ISO-T1
Heating* <sup>2</sup>	20℃	—	7℃	6℃	

(2) This packaged air-conditioner is manufactured and tested in conformity with the following standard.  
**ISO-T1 "UNITARY AIR-CONDITIONERS"**

●Decorative Panel model (Optional)

Item	Model	Panel Part No.
	FDTA45,56,71 type	T-PSA-35W-ER

## Models FDTA90KXE4R, 112KXE4R, 140KXE4R

Item		Models	FDTA90KXE4R	FDTA112KXE4R	FDTA140KXE4R
Nominal cooling capacity* <sup>1</sup>	kW		9.0	11.2	14.0
Nominal heating capacity* <sup>2</sup>	kW		10.0	12.5	16.0
Power source		1 Phase 220-240V 50Hz/220V 60Hz			
Noise level	dB(A)		Hi: 43 Me: 35 Lo: 33	Hi: 43 Me: 42 Lo: 41	Hi: 45 Me: 43 Lo: 41
Exterior dimensions Height × Width × Depth	mm		Unit: 295 × 840 × 840 Panel:35 × 950 × 950	Unit: 365 × 840 × 840 Panel:35 × 950 × 950	
Net weight	kg		Unit:26 Panel:7	Unit:31 Panel:7	
Refrigerant equipment Heat exchanger		Louver fin & inner grooved tubing			
Refrigerant control		Electronic Expansion Valve			
Air handling equipment Fan type & Q'ty		Turbo fan × 1			
Motor	W		40 × 1	120 × 1	
Starting method		Direct line starting			
Air flow(Standard)	CMM		Hi: 21 Me: 16 Lo: 14	Hi: 27 Me: 23 Lo: 20	Hi: 29 Me: 26 Lo: 23
Outside air intake		Possible			
Air filter, Q'ty		Long life filter × 1(Washable)			
Shock & vibration isolator		Rubber sleeve(for fan motor)			
Insulation (noise & heat)		Polyurethane foam			
Operation control Operation switch		Wired remote control switch (Optional:RC-E1R) Wireless remote control switch (Optional:RCN-T-35W-ER)			
Room temperature control		Thermostat by electronics			
Safety equipment		Internal thermostat for fan motor. Frost protection thermostat			
Installation data Refrigerant piping size	mm(in)		Liquid line:φ 9.52(3/8") Gas line:φ 15.88(5/8")		
Connecting method		Flare piping			
Drain hose		Connectable with VP25(I.D.25mm, O.D.32mm)			
Insulation for piping		Necessary (both Liquid & Gas lines)			
Accessories		Mounting kit, Drain hose			
Optional parts		Decorative Panel			

Notes (1) The data are measured at the following conditions.

Item	Indoor air temperature		Outdoor air temperature		Standards
	DB	WB	DB	WB	
Operation					
Cooling* <sup>1</sup>	27℃	19℃	35℃	24℃	ISO-T1
Heating* <sup>2</sup>	20℃	—	7℃	6℃	

(2) This packaged air-conditioner is manufactured and tested in conformity with the following standard.  
**ISO-T1"UNITARY AIR-CONDITIONERS"**

●Decorative Panel model (Optional)

Item	Panel Part No.
Model	
FDTA90,112,140 type	T-PSA-35W-ER

(c) 2-way outlet ceiling recessed type (FDTW)

Models FDTWA28KXE4R, 45KXE4R, 56KXE4R  
28KXE5R, 45KXE5R, 56KXE5R

Item		Models	FDTWA28KXE4R 28KXE5R	FDTWA45KXE4R 45KXE5R	FDTWA56KXE4R 56KXE5R
Nominal cooling capacity* <sup>1</sup>		kW	2.8	4.5	5.6
Nominal heating capacity* <sup>2</sup>		kW	3.2	5.0	6.3
Power source			Refer to the following. <sup>(3)</sup>		
Noise level		dB(A)	Hi: 39 Me: 36 Lo: 33		
Exterior dimensions Height × Width × Depth		mm	Unit:285 × 817 × 620    Panel:8 × 1055 × 680		
Net weight		kg	Unit:19    Panel:7		
Refrigerant equipment Heat exchanger			Louver fin & inner grooved tubing		
Refrigerant control			Electronic Expansion Valve		
Air handling equipment Fan type & Q'ty			Turbo fan × 1		
Motor		W	30×1		
Starting method			Direct line starting		
Air flow(Standard)		CMM	Hi: 14    Me: 12    Lo: 10		
Outside air intake			Possible		
Air filter, Q'ty			Long life filter × 1 (Washable)		
Shock & vibration isolator			Rubber sleeve (for fan motor)		
Insulation (noise & heat)			Polyurethane foam		
Operation control Operation switch			Wired remote control switch (Optional:RC-E1R) Wireless kit (Optional:RCND-KIT-HER)		
Room temperature control			Thermostat by electronics		
Safety equipment			Internal thermostat for fan motor. Frost protection thermostat		
Installation data Refrigerant piping size		mm(in)	Liquid line: ϕ6.35(1/4") Gas line: ϕ9.52(3/8")	Liquid line: ϕ6.35(1/4") Gas line: ϕ12.7(1/2")	
Connecting method			Flare piping		
Drain hose			Connectable with VP25(I.D.25mm, O.D.32mm)		
Insulation for piping			Necessary (both Liquid & Gas lines)		
Accessories			Mounting kit, Drain hose		
Optional parts			Decorative Panel		

Notes (1) The data are measured at the following conditions.

Item	Indoor air temperature		Outdoor air temperature		Standards
	DB	WB	DB	WB	
Operation					
Cooling* <sup>1</sup>	27℃	19℃	35℃	24℃	ISO-T1
Heating* <sup>2</sup>	20℃	—	7℃	6℃	

(2) This packaged air-conditioner is manufactured and tested in conformity with the following standard.  
ISO-T1 "UNITARY AIR-CONDITIONERS"

●Decorative Panel model (Optional)

Item	Panel Part No.
Model	
FDTWA28, 45, 56 type	TW-PSA-23W-ER

(3) Power supply specifications.

Item	Power source
Model	
FDTWA28, 45, 56KXE4R	1 phase 220-240V 50Hz
FDTWA28, 45, 56KXE5R	1 phase 220-240V 50Hz/220V 60Hz

## Models FDTWA71KXE4R, 90KXE4R

Models		FDTWA71KXE4R	FDTWA90KXE4R
Nominal cooling capacity* <sup>1</sup>	kW	7.1	9.0
Nominal heating capacity* <sup>2</sup>	kW	8.0	10.0
Power source		1 Phase 220-240V 50Hz	
Noise level	dB(A)	Hi: 41 Me: 38 Lo: 35	Hi: 41 Me: 39 Lo: 36
Exterior dimensions Height × Width × Depth	mm	Unit:335 × 1054 × 620 Panel:8 × 1300 × 680	
Net weight	kg	Unit:26 Panel:9	
Refrigerant equipment Heat exchanger		Louver fin & inner grooved tubing	
Refrigerant control		Electronic Expansion Valve	
Air handling equipment Fan type & Q'ty		Turbo fan × 1	
Motor	W	35 × 1	40 × 1
Starting method		Direct line starting	
Air flow(Standard)	CMM	Hi: 16 Me: 13 Lo: 11	Hi: 19 Me: 16 Lo: 12
Outside air intake		Possible	
Air filter, Q'ty		Long life filter × 1(Washable)	
Shock & vibration isolator		Rubber sleeve(for fan motor)	
Insulation (noise & heat)		Polyurethane foam	
Operation control Operation switch		Wired remote control switch (Optional:RC-E1R) Wireless kit (Optional:RCND-KIT-HER)	
Room temperature control		Thermostat by electronics	
Safety equipment		Internal thermostat for fan motor. Frost protection thermostat	
Installation data Refrigerant piping size	mm(in)	Liquid line:φ 9.52(3/8"),Gas line:φ 15.88(5/8")	
Connecting method		Flare piping	
Drain hose		Connectable with VP25(I.D.25mm, O.D.32mm)	
Insulation for piping		Necessary (both Liquid & Gas lines)	
Accessories		Mounting kit, Drain hose	
Optional parts		Decorative Panel	

Notes (1) The data are measured at the following conditions.

Item	Indoor air temperature		Outdoor air temperature		Standards
	DB	WB	DB	WB	
Operation					
Cooling* <sup>1</sup>	27℃	19℃	35℃	24℃	ISO-T1
Heating* <sup>2</sup>	20℃	—	7℃	6℃	

(2) This packaged air-conditioner is manufactured and tested in conformity with the following standard.  
**ISO-T1 "UNITARY AIR-CONDITIONERS"**

●Decorative Panel model (Optional)

Model	Panel Part No.
FDTWA71,90 type	TW-PSA-33W-ER

## Models FDTWA112KXE4R, 140KXE4R

Models		FDTWA112KXE4R	FDTWA140KXE4R
<b>Item</b>	<b>Models</b>		
Nominal cooling capacity* <sup>1</sup>	kW	11.2	14.0
Nominal heating capacity* <sup>2</sup>	kW	12.5	16.0
Power source		1 Phase 220-240V 50Hz	
Noise level	dB(A)	Hi: 44 Me: 41 Lo: 38	Hi: 45 Me: 42 Lo: 39
Exterior dimensions Height × Width × Depth	mm	Unit:357 × 1524 × 620	Panel:8 × 1770 × 680
Net weight	kg	Unit:38	Panel:11
Refrigerant equipment Heat exchanger		Louver fin & inner grooved tubing	
Refrigerant control		Electronic Expansion Valve	
Air handling equipment Fan type & Q'ty		Turbo fan × 2	
Motor	W	40 × 2	50 × 2
Starting method		Direct line starting	
Air flow(Standard)	CMM	Hi: 28 Me: 25 Lo: 23	Hi: 32 Me: 28 Lo: 24
Outside air intake		Possible	
Air filter, Q'ty		Long life filter × 2(Washable)	
Shock & vibration isolator		Rubber sleeve(for fan motor)	
Insulation (noise & heat)		Polyurethane foam	
Operation control Operation switch		Wired remote control switch (Optional:RC-E1R) Wireless kit (Optional:RCND-KIT-HER)	
Room temperature control		Thermostat by electronics	
Safety equipment		Internal thermostat for fan motor. Frost protection thermostat	
Installation data Refrigerant piping size	mm(in)	Liquid line:φ 9.52(3/8"), Gas line:φ 15.88(5/8")	
Connecting method		Flare piping	
Drain hose		Connectable with VP25(I.D.25mm, O.D.32mm)	
Insulation for piping		Necessary (both Liquid & Gas line)	
Accessories		Mounting kit, Drain hose	
Optional parts		Decorative Panel	

Notes (1) The data are measured at the following conditions.

Item	Indoor air temperature		Outdoor air temperature		Standards
	DB	WB	DB	WB	
Operation					
Cooling* <sup>1</sup>	27℃	19℃	35℃	24℃	ISO-T1
Heating* <sup>2</sup>	20℃	—	7℃	6℃	

(2) This packaged air-conditioner is manufactured and tested in conformity with the following standard.  
ISO-T1 "UNITARY AIR-CONDITIONERS"

●Decorative Panel model (Optional)

Item	Panel Part No.
Model	
FDTWA112,140 type	TW-PSA-43W-ER

(d) Ceiling recessed single air supply port type (FDTQ)

Models FDTQA22KXE4R

Item		Model	FDTQA22KXE4R			
Panel name		Direct blow panel		Duct panel <sup>(3)</sup>		
Panel model(Optional)		TQ-PSA-14W-ER	TQ-PSB-14W-ER	QR-PNA-14W-ER	QR-PNB-14W-ER	
Nominal cooling capacity* <sup>1</sup>	kW	2.2				
Nominal heating capacity* <sup>2</sup>	kW	2.5				
Power source		1 Phase, 220-240V 50Hz/220V 60Hz				
Noise level	dB(A)	Hi: 38 Lo: 34		Hi: 42 Lo: 39		
Exterior dimensions Height × Width × Depth	mm	Unit:250×570×570 Panel:35×625×650	Unit:250×570×570 Panel:35×780×650	Unit:250×570×570 Panel:35×625×650	Unit:250×570×570 Panel:35×780×650	
Net weight	kg	Unit:19 Panel:2.5	Unit:19 Panel:3	Unit:19 Panel:2.5	Unit:19 Panel:3	
Refrigerant equipment Heat exchanger		Louver fin & inner grooved tubing				
Refrigerant control		Electronic Expansion Valve				
Air handling equipment Fan type & Q'ty		Centrifugal fan × 1				
Motor	W	20 × 1				
Starting method		Direct line starting				
Air flow(Standard)	CMM	Hi: 7 Lo: 5.4		Hi: 7 Lo: 6.5		
Available static pressure(at Hi)	Pa	—		30		
Outside air intake		Possible				
Air filter, Q'ty		Long life filter × 1(Washable)				
Shock & vibration isolator		Rubber sleeve(for fan motor)				
Insulation (noise & heat)		Polyurethane foam				
Operation control Operation switch		Wired remote control switch (Optional:RC-E1R) Wireless kit (Optional:RCND-KIT-HER)				
Room temperature control		Thermostat by electronics				
Safety equipment		Internal thermostat for fan motor. Frost protection thermostat				
Installation data Refrigerant piping size	mm(in)	Liquid line: ϕ6.35(1/4"), Gas line: ϕ9.52(3/8")				
Connecting method		Flare piping				
Drain hose		Connectable with VP25(I.D.25mm, O.D.32mm)				
Insulation for piping		Necessary (both Liquid & Gas lines)				
Accessories		Mounting kit, Drain hose				
Optional parts		Decorative Panel				

Notes (1) The data are measured at the following conditions.

Item	Indoor air temperature		Outdoor air temperature		Standards
	DB	WB	DB	WB	
Cooling <sup>*1</sup>	27℃	19℃	35℃	24℃	ISO-T1
Heating <sup>*2</sup>	20℃	—	7℃	6℃	

(2) This packaged air-conditioner is manufactured and tested in conformity with the following standard.  
ISO-T1 "UNITARY AIR-CONDITIONERS"

(3) This is the panel to be used when modified to the Duct panel type on site. See page 608 of the 2005 Handbook.

## Models FDTQA28KXE4R

Item		Model				FDTQA28KXE4R			
Panel name						Direct blow panel		Duct panel <sup>(3)</sup>	
Panel model(Optional)		TQ-PSA-14W-ER		TQ-PSB-14W-ER		QR-PNA-14W-ER		QR-PNB-14W-ER	
Nominal cooling capacity* <sup>1</sup>		kW		2.8					
Nominal heating capacity* <sup>2</sup>		kW		3.2					
Power source				1 Phase, 220-240V 50Hz/220V 60Hz					
Noise level		dB(A)		Hi: 38 Lo: 34		Hi: 42 Lo:39			
Exterior dimensions Height × Width × Depth		mm		Unit:250×570×570 Panel:35×625×650		Unit:250×570×570 Panel:35×780×650		Unit:250×570×570 Panel:35×625×650	
Net weight		kg		Unit:19 Panel:2.5		Unit:19 Panel:3		Unit:19 Panel:2.5	
Refrigerant equipment Heat exchanger				Slit fin & inner grooved tubing					
Refrigerant control				Electronic Expansion Valve					
Air handling equipment Fan type & Q'ty				Centrifugal fan × 1					
Motor		W		20 × 1					
Starting method				Direct line starting					
Air flow(Standard)		CMM		Hi: 7 Lo: 5.4		Hi: 7 Lo: 6.5			
Available static pressure(at Hi)		Pa		—		30			
Outside air intake				Possible					
Air filter, Q'ty				Long life filter × 1(Washable)					
Shock & vibration isolator				Rubber sleeve(for fan motor)					
Insulation (noise & heat)				Polyurethane foam					
Operation control Operation switch				Wired remote control switch (Optional:RC-E1R) Wireless kit (Optional:RCND-KIT-HER)					
Room temperature control				Thermostat by electronics					
Safety equipment				Internal thermostat for fan motor. Frost protection thermostat					
Installation data Refrigerant piping size		mm(in)		Liquid line: φ6.35(1/4"), Gas line: φ9.52(3/8")					
Connecting method				Flare piping					
Drain hose				Connectable with VP25(I.D.25mm, O.D.32mm)					
Insulation for piping				Necessary (both Liquid & Gas lines)					
Accessories				Mounting kit, Drain hose					
Optional parts				Decorative Panel					

Notes (1) The data are measured at the following conditions.

Item	Indoor air temperature		Outdoor air temperature		Standards
	DB	WB	DB	WB	
Cooling* <sup>1</sup>	27℃	19℃	35℃	24℃	ISO-T1
Heating* <sup>2</sup>	20℃	—	7℃	6℃	

(2) This packaged air-conditioner is manufactured and tested in conformity with the following standard.  
**ISO-T1 "UNITARY AIR-CONDITIONERS"**

(3) This is the panel to be used when modified to the Duct panel type on site. See page 608 of the 2005 Handbook.

## Models FDTQA36KXE4R

Model		FDTQA36KXE4R			
Item					
Panel name		Direct blow panel		Duct panel <sup>(3)</sup>	
Panel model(Optional)		TQ-PSA-14W-ER	TQ-PSB-14W-ER	QR-PNA-14W-ER	QR-PNB-14W-ER
Nominal cooling capacity <sup>*1</sup>	kW	3.6			
Nominal heating capacity <sup>*2</sup>	kW	4.0			
Power source		1 Phase, 220-240V 50Hz/220V 60Hz			
Noise level	dB(A)	Hi: 38 Lo: 34		Hi: 42 Lo:39	
Exterior dimensions Height × Width × Depth	mm	Unit:250×570×570 Panel:35×625×650	Unit:250×570×570 Panel:35×780×650	Unit:250×570×570 Panel:35×625×650	Unit:250×570×570 Panel:35×780×650
Net weight	kg	Unit:19 Panel:2.5	Unit:19 Panel:3	Unit:19 Panel:2.5	Unit:19 Panel:3
Refrigerant equipment Heat exchanger		Slit fin & inner grooved tubing			
Refrigerant control		Electronic Expansion Valve			
Air handling equipment Fan type & Q'ty		Centrifugal fan × 1			
Motor	W	20 × 1			
Starting method		Direct line starting			
Air flow(Standard)	CMM	Hi: 7 Lo: 5.4		Hi: 7 Lo: 6.5	
Available static pressure(at Hi)	Pa	—		30	
Outside air intake		Possible			
Air filter, Q'ty		Long life filter × 1 (Washable)			
Shock & vibration isolator		Rubber sleeve (for fan motor)			
Insulation (noise & heat)		Polyurethane foam			
Operation control Operation switch		Wired remote control switch (Optional:RC-E1R) Wireless kit (Optional:RCND-KIT-HER)			
Room temperature control		Thermostat by electronics			
Safety equipment		Internal thermostat for fan motor. Frost protection thermostat			
Installation data Refrigerant piping size	mm(in)	Liquid line: ϕ6.35(1/4"), Gas line: ϕ12.7(1/2")			
Connecting method		Flare piping			
Drain hose		Connectable with VP25(I.D.25mm, O.D.32mm)			
Insulation for piping		Necessary (both Liquid & Gas lines)			
Accessories		Mounting kit, Drain hose			
Optional parts		Decorative Panel			

Notes (1) The data are measured at the following conditions.

Item	Indoor air temperature		Outdoor air temperature		Standards
	DB	WB	DB	WB	
Operation					
Cooling* <sup>1</sup>	27℃	19℃	35℃	24℃	ISO-T1
Heating* <sup>2</sup>	20℃	—	7℃	6℃	

(2) This packaged air-conditioner is manufactured and tested in conformity with the following standard.  
**ISO-T1 "UNITARY AIR-CONDITIONERS"**

(3) This is the panel to be used when modified to the Duct panel type on site. See page 608 of the 2005 Handbook.



(e) 1-way outlet ceiling recessed type (FDTS)

Models FDTSA22KXE4R, 28KXE4R, 36KXE4R

Item		Models	FDTSA22KXE4R	FDTSA28KXE4R	FDTSA36KXE4R
Nominal cooling capacity* <sup>1</sup>		kW	2.2	2.8	3.6
Nominal heating capacity* <sup>2</sup>		kW	2.5	3.2	4.0
Power source			1 Phase 220-240V 50Hz		
Noise level		dB(A)	Hi: 39 Lo: 38	Hi: 40 Me: 39 Lo: 38	
Exterior dimensions Height × Width × Depth		mm	Unit:194 × 1040 × 650 Panel:10 × 1290 × 770		
Net weight		kg	Unit:26 Panel:6		
Refrigerant equipment Heat exchanger			Louver fin & inner grooved tubing		
Refrigerant control			Electronic Expansion Valve		
Air handling equipment Fan type & Q'ty			Centrifugal fan × 2		
Motor		W	35×1		
Starting method			Direct line starting		
Air flow(Standard)		CMM	Hi: 11 Lo: 8	Hi: 12 Me: 11 Lo: 10	
Outside air intake			Possible		
Air filter, Q'ty			Long life filter × 1 (Washable)		
Shock & vibration isolator			Rubber sleeve (for fan motor)		
Insulation (noise & heat)			Polyurethane foam		
Operation control Operation switch			Wired remote control switch (Optional:RC-E1R) Wireless kit (Optional:RCND-KIT-HER)		
Room temperature control			Thermostat by electronics		
Safety equipment			Internal thermostat for fan motor. Frost protection thermostat		
Installation data Refrigerant piping size		mm(in)	Liquid line:φ6.35(1/4") Gas line:φ9.52(3/8")		Liquid line:φ6.35(1/4") Gas line:φ12.7(1/2")
Connecting method			Flare piping		
Drain hose			Connectable with VP25(I.D.25mm, O.D.32mm)		
Insulation for piping			Necessary (both Liquid & Gas lines)		
Accessories			Mounting kit, Drain hose		
Optional parts			Decorative Panel		

Notes (1) The data are measured at the following conditions.

Operation	Indoor air temperature		Outdoor air temperature		Standards
	DB	WB	DB	WB	
Cooling* <sup>1</sup>	27℃	19℃	35℃	24℃	ISO-T1
Heating* <sup>2</sup>	20℃	—	7℃	6℃	

(2) This packaged air-conditioner is manufactured and tested in conformity with the following standard.  
JIS B8616 "UNITARY AIR-CONDITIONERS"

●Decorative Panel model (Optional)

Model	Item	Panel Part No.
		With Auto Swing
FDTSA22, 28, 36 type		TS-PSA-28W-ER

## Models FDTSA45KXE4R, 71KXE4R

Item		Models	FDTSA45KXE4R	FDTSA71KXE4R
Nominal cooling capacity* <sup>1</sup>		kW	4.5	7.1
Nominal heating capacity* <sup>2</sup>		kW	5.0	8.0
Power source			1 Phase 220-240V 50Hz	
Noise level		dB(A)	Hi: 43 Me: 40 Lo: 38	Hi: 44 Me: 40 Lo: 38
Exterior dimensions Height × Width × Depth		mm	Unit:194 × 1040 × 650 Panel:10 × 1290 × 770	Unit:194 × 1300 × 650 Panel:10 × 1500 × 790
Net weight		kg	Unit:26 Panel:6	Unit:30 Panel:7
Refrigerant equipment Heat exchanger			Louver fin & inner grooved tubing	
Refrigerant control			Electronic Expansion Valve	
Air handling equipment Fan type & Q'ty			Centrifugal fan × 2	Centrifugal fan × 4
Motor		W	40 × 1	25 × 2
Starting method			Direct line starting	
Air flow(Standard)		CMM	Hi: 14 Me: 12 Lo: 10	Hi: 18 Me: 15 Lo: 12
Outside air intake			Possible	
Air filter, Q'ty			Long life filter × 1(Washable)	
Shock & vibration isolator			Rubber sleeve(for fan motor)	
Insulation (noise & heat)			Polyurethane foam	
Operation control Operation switch			Wired remote control switch (Optional:RC-E1R) Wireless kit (Optional:RCND-KIT-HER)	
Room temperature control			Thermostat by electronics	
Safety equipment			Internal thermostat for fan motor. Frost protection thermostat	
Installation data Refrigerant piping size		mm(in)	Liquid line:φ 6.35(1/4") Gas line:φ 12.7(1/2")	Liquid line:φ 9.52(3/8") Gas line:φ 15.88(5/8")
Connecting method			Flare piping	
Drain hose			Connectable with VP25(I.D.25mm, O.D.32mm)	
Insulation for piping			Necessary (both Liquid & Gas lines)	
Accessories			Mounting kit, Drain hose	
Optional parts			Decorative Panel	

Notes (1) The data are measured at the following conditions.

Item	Indoor air temperature		Outdoor air temperature		Standards
	DB	WB	DB	WB	
Operation					
Cooling* <sup>1</sup>	27℃	19℃	35℃	24℃	ISO-T1
Heating* <sup>2</sup>	20℃	—	7℃	6℃	

(2) This packaged air-conditioner is manufactured and tested in conformity with the following standard.  
**ISO-T1 "UNITARY AIR-CONDITIONERS"**

●Decorative Panel model (Optional)

Model	Item	Panel Part No.
		With Auto Swing
FDTSA45 type		TS-PSA-28W-ER
FDTSA71 type		TS-PSA-38W-ER

(f) High static pressure duct type (FDU)

Models FDUA224KXE4R, 280KXE4R

Item		Models	FDUA224KXE4R	FDUA280KXE4R
Nominal cooling capacity* <sup>1</sup>	kW		22.4	28.0
Nominal heating capacity* <sup>2</sup>	kW		25.0	31.5
Power source			1 Phase 220-240V 50Hz	
Noise level	dB(A)		Hi: 48	Hi: 49
Exterior dimensions Height × Width × Depth	mm		360 × 1570 × 830	
Net weight	kg		92	
Refrigerant equipment Heat exchanger			Louver fin & inner grooved tubing	
Refrigerant control			Electronic Expansion Valve	
Air handling equipment Fan type & Q'ty			Multiblade centrifugal fan × 4	
Motor	W		200×2	230×1, 270×1
Starting method			Direct line starting	
Air flow(Standard)	CMM		51	68
Available static pressure	Pa		Standard:100, MAX:200	
Outside air intake			Available	
Air filter, Q'ty			Field purchased	
Shock & vibration isolator			Rubber sleeve(for fan motor)	
Insulation (noise & heat)			Polyurethane foam	
Operation control Operation switch			Wired remote control switch (Optional:RC-E1R) Wireless kit (Optional:RCND-KIT-HER)	
Room temperature control			Thermostat by electronics	
Safety equipment			Internal thermostat for fan motor. Frost protection thermostat	
Installation data Refrigerant piping size	mm(in)		Liquid line: φ9.52(3/8"), Gas line: φ19.05(3/4")	Liquid line: φ9.52(3/8"), Gas line: φ22.22(7/8")
Connecting method			Brazing	
Drain hose			Connectable with VP25 (I.D. 25mm, O.D. 32mm)	
Insulation for piping			Necessary (both Liquid & Gas lines)	
Accessories			Mounting kit	
Optional parts			-	

Notes (1) The data are measured at the following conditions.

Item	Indoor air temperature		Outdoor air temperature		Standards
	DB	WB	DB	WB	
Operation					
Cooling* <sup>1</sup>	27℃	19℃	35℃	24℃	ISO-T1
Heating* <sup>2</sup>	20℃	—	7℃	6℃	

(2) This packaged air-conditioner is manufactured and tested in conformity with the following standard.

ISO-T1 "UNITARY AIR-CONDITIONERS"

(3) The FDUA224, 280KXE4R indoor units cannot be connected to the FDCA140HKXEN4R, 140HKXES4R and 160HKXES4R outdoor units.

(g) Medium static pressure ducted type (FDQM)

Models FDQMA22KXE4R, 28KXE4R, 36KXE4R

Item		Models	FDQMA22KXE4R	FDQMA28KXE4R	FDQMA36KXE4R
Nominal cooling capacity <sup>*1</sup>	kW		2.2	2.8	3.6
Nominal heating capacity <sup>*2</sup>	kW		2.5	3.2	4.0
Power source		1 Phase 220-240V 50Hz/220V 60Hz			
Noise level	dB(A)	Hi: 34 Lo: 31			
Exterior dimensions Height × Width × Depth	mm	257 × 570 × 570			
Net weight	kg	21			
Refrigerant equipment Heat exchanger		Louver fin & inner grooved tubing	Slit fin & inner grooved tubing		
Refrigerant control		Electronic Expansion Valve			
Air handling equipment Fan type & Q'ty		Centrifugal fan × 1			
Motor	W	20×1			
Starting method		Direct line starting			
Air flow(Standard)	CMM	Hi: 7 Lo: 6.5			
Available static pressure ( at Hi)	Pa	30			
Outside air intake		Side			
Air filter, Q'ty		-			
Shock & vibration isolator		Rubber sleeve (for fan motor)			
Insulation (noise & heat)		Polyurethane foam			
Operation control Operation switch		Wired remote control switch (Optional:RC-E1R) Wireless kit (Optional:RCND-KIT-HER)			
Room temperature control		Thermostat by electronics			
Safety equipment		Internal thermostat for fan motor. Frost protection thermostat			
Installation data Refrigerant piping size	mm(in)	Liquid line: ϕ6.35(1/4") Gas line: ϕ9.52(3/8")			Liquid line: ϕ6.35(1/4") Gas line: ϕ12.7(1/2")
Connecting method		Flare piping			
Drain hose		Connectable with VP25(I.D.25mm, O.D.32mm )			
Insulation for piping		Necessary (both Liquid & Gas lines)			
Accessories		Mounting kit, Drain hose			
Optional parts		-			

Notes (1) The data are measured at the following conditions.

Item	Indoor air temperature		Outdoor air temperature		Standards
	DB	WB	DB	WB	
Operation					
Cooling* <sup>1</sup>	27℃	19℃	35℃	24℃	ISO-T1
Heating* <sup>2</sup>	20℃	—	7℃	6℃	

(2) This packaged air-conditioner is manufactured and tested in conformity with the following standard.  
ISO-T1 "UNITARY AIR-CONDITIONERS"

### (h) Satellite ducted type (FDUM)

#### Models FDUMA36KXE4R, 45KXE4R, 56KXE4R

Item		Models	FDUMA36KXE4R	FDUMA45KXE4R	FDUMA56KXE4R
Nominal cooling capacity* <sup>1</sup>	kW		3.6	4.5	5.6
Nominal heating capacity* <sup>2</sup>	kW		4.0	5.0	6.3
Power source		1 Phase 220-240V 50Hz			
Noise level	dB(A)		Hi: 34 Me: 32 Lo: 29	Hi: 35 Me: 32 Lo: 29	
Exterior dimensions Height × Width × Depth	mm	299 × 750 × 635			
Net weight	kg	34			
Refrigerant equipment Heat exchanger		Louver fin & inner grooved tubing			
Refrigerant control		Electronic Expansion Valve			
Air handling equipment Fan type & Q'ty		Centrifugal fan × 2			
Motor	W		50× 1	55× 1	
Starting method		Direct line starting			
Air flow(Standard)	CMM		Hi: 12 Me: 11 Lo: 10	Hi: 14 Me: 12 Lo: 11	
Available static pressure ( at Hi)	Pa	Standard:50, Hi speed:85			
Outside air intake		Side			
Air filter, Q'ty		—			
Shock & vibration isolator		Rubber sleeve(for fan motor)			
Insulation (noise & heat)		Polyurethane foam			
Operation control Operation switch		Wired remote control switch (Optional:RC-E1R) Wireless kit (Optional:RCND-KIT-HER)			
Room temperature control		Thermostat by electronics			
Safety equipment		Internal thermostat for fan motor. Frost protection thermostat			
Installation data Refrigerant piping size	mm(in)	Liquid line:φ6.35(1/4"),Gas line:φ12.7(1/2")			
Connecting method		Flare piping			
Drain hose		Connectable with VP25(I.D.25mm, O.D.32mm )			
Insulation for piping		Necessary (both Liquid & Gas lines)			
Accessories		Mounting kit, Drain hose			
Optional parts		—			

Notes (1) The data are measured at the following conditions.

Item	Indoor air temperature		Outdoor air temperature		Standards
	DB	WB	DB	WB	
Operation					
Cooling* <sup>1</sup>	27℃	19℃	35℃	24℃	ISO-T1
Heating* <sup>2</sup>	20℃	—	7℃	6℃	

(2) This packaged air-conditioner is manufactured and tested in conformity with the following standard.  
ISO-T1 "UNITARY AIR-CONDITIONERS"

## Models FDUMA71KXE4R, 90KXE4R

Item		Models	FDUMA71KXE4R	FDUMA90KXE4R
Nominal cooling capacity <sup>*1</sup>	kW		7.1	9.0
Nominal heating capacity <sup>*2</sup>	kW		8.0	10.0
Power source			1 Phase 220-240V 50Hz	
Noise level	dB(A)		Hi: 35 Me: 32 Lo: 29	Hi: 36 Me: 33 Lo: 30
Exterior dimensions Height × Width × Depth	mm		299 × 950 × 635	
Net weight	kg		40	
Refrigerant equipment Heat exchanger			Louver fin & inner grooved tubing	
Refrigerant control			Electronic Expansion Valve	
Air handling equipment Fan type & Q'ty			Centrifugal fan × 2	
Motor	W		90×1	100×1
Starting method			Direct line starting	
Air flow(Standard)	CMM		Hi: 18 Me: 16 Lo: 14	Hi: 20 Me: 18 Lo: 15
Available static pressure ( at Hi)	Pa		Standard:50, Hi speed:85	
Outside air intake			Side	
Air filter, Q'ty			—	
Shock & vibration isolator			Rubber sleeve(for fan motor)	
Insulation (noise & heat)			Polyurethane foam	
Operation control Operation switch			Wired remote control switch (Optional:RC-E1R) Wireless kit (Optional:RCND-KIT-HER)	
Room temperature control			Thermostat by electronics	
Safety equipment			Internal thermostat for fan motor. Frost protection thermostat	
Installation data Refrigerant piping size	mm(in)		Liquid line:φ 9.52(3/8"),Gas line:φ 15.88(5/8")	
Connecting method			Flare piping	
Drain hose			Connectable with VP25(I.D.25mm, O.D.32mm)	
Insulation for piping			Necessary (both Liquid & Gas lines)	
Accessories			Mounting kit, Drain hose	
Optional parts			—	

Notes (1) The data are measured at the following conditions.

Item	Indoor air temperature		Outdoor air temperature		Standards
	DB	WB	DB	WB	
Operation					
Cooling <sup>*1</sup>	27℃	19℃	35℃	24℃	ISO-T1
Heating <sup>*2</sup>	20℃	—	7℃	6℃	

(2) This packaged air-conditioner is manufactured and tested in conformity with the following standard.  
ISO-T1 "UNITARY AIR-CONDITIONERS"

**Models FDUMA112KXE4R, 140KXE4R**

Item		Models	FDUMA112KXE4R	FDUMA140KXE4R
Nominal cooling capacity <sup>*1</sup>		kW	11.2	14.0
Nominal heating capacity <sup>*2</sup>		kW	12.5	16.0
Power source			1 Phase 220-240V 50Hz	
Noise level		dB(A)	Hi: 38 Me: 35 Lo: 32	Hi: 39 Me: 37 Lo: 34
Exterior dimensions Height × Width × Depth		mm	350 × 1370 × 635	
Net weight		kg	59	59
Refrigerant equipment Heat exchanger			Louver fin & inner grooved tubing	
Refrigerant control			Electronic Expansion Valve	
Air handling equipment Fan type & Q'ty			Centrifugal fan × 3	
Motor		W	45 × 1, 90 × 1	50 × 1, 100 × 1
Starting method			Direct line starting	
Air flow(Standard)		CMM	Hi: 28 Me: 25 Lo: 22	Hi: 34 Me: 31 Lo: 27
Available static pressure (at Hi)		Pa	Standard:60, Hi speed:90	Standard:60, Hi speed:85
Outside air intake			Side	
Air filter, Q'ty			—	
Shock & vibration isolator			Rubber sleeve(for fan motor)	
Insulation (noise & heat)			Polyurethane foam	
Operation control Operation switch			Wired remote control switch (Optional:RC-E1R) Wireless kit (Optional:RCND-KIT-HER)	
Room temperature control			Thermostat by electronics	
Safety equipment			Internal thermostat for fan motor. Frost protection thermostat	
Installation data Refrigerant piping size		mm(in)	Liquid line:φ 9.52(3/8"), Gas line:φ 15.88(5/8")	
Connecting method			Flare piping	
Drain hose			Connectable with VP25(I.D.25mm, O.D.32mm)	
Insulation for piping			Necessary (both Liquid & Gas lines)	
Accessories			Mounting kit, Drain hose	
Optional parts			—	

Notes (1) The data are measured at the following conditions.

Item	Indoor air temperature		Outdoor air temperature		Standards
	DB	WB	DB	WB	
Operation					
Cooling <sup>*1</sup>	27℃	19℃	35℃	24℃	ISO-T1
Heating <sup>*2</sup>	20℃	—	7℃	6℃	

(2) This packaged air-conditioner is manufactured and tested in conformity with the following standard.  
ISO-T1 "UNITARY AIR-CONDITIONERS"



(i) Ceiling mounted duct type (FDUR)

Models FDURA45KXE4R, 56KXE4R

Item		Models	FDURA45KXE4R	FDURA56KXE4R
Nominal cooling capacity <sup>*1</sup>	kW		4.5	5.6
Nominal heating capacity <sup>*2</sup>	kW		5.0	6.3
Power source			1 Phase 220-240V 50Hz	
Noise level	dB(A)		Hi: 40 Lo: 36	Hi: 41 Lo: 37
Exterior dimensions Height × Width × Depth	mm		295 × 850 × 650	
Net weight	kg		39	39
Refrigerant equipment Heat exchanger			Louver fin & inner grooved tubing	
Refrigerant control			Electronic Expansion valve	
Air handling equipment Fan type & Q'ty			Multiblade centrifugal fan × 2	
Motor	W		90 × 1	130 × 1
Starting method			Direct line starting	
Air flow(Standard)	CMM		Hi: 17 Lo: 13.5	Hi: 21 Lo: 17
Available static pressure (at Hi)	Pa		Standard:50, Max:85	
Outside air intake			—	
Air filter Q'ty			Polypropylene net × 1(Washable)	
Shock & vibration isolator			Rubber sleeve(for fan motor)	
Operation control Operation switch			Wired remote control switch (Optional:RC-E1R) Wireless kit (Optional:RCND-KIT-HER)	
Room temperature control			Thermostat by electronics	
Safety equipment			Internal thermostat for fan motor Frost protection thermostat	
Installation data Refrigerant piping size	mm(in)		Liquid line: φ6.35 (1/4") Gas line: φ12.7 (1/2")	
Connecting method			Flare piping	
Drain hose			Connectable with VP25(I.D.25mm, O.D.32mm)	
Insulation for piping			Necessary (both Liquid & Gas lines)	
Accessories			Mounting kit, Drain hose	
Optional parts			Silent panel, Duct joint	

Notes (1)The data are measured at the following conditions.

Item	Indoor air temperature		Outdoor air temperature		Standards
	DB	WB	DB	WB	
Operation					
Cooling <sup>*1</sup>	27℃	19℃	35℃	24℃	ISO-T1
Heating <sup>*2</sup>	20℃	—	7℃	6℃	

(2)This packaged air-conditioner is manufactured and tested in conformity with the following standard.  
ISO-T1"UNITARY AIR-CONDITIONERS"

## Models FDURA71KXE4R, 90KXE4R

Item		Models	FDURA71KXE4R	FDURA90KXE4R
Nominal cooling capacity* <sup>1</sup>	kW		7.1	9.0
Nominal heating capacity* <sup>2</sup>	kW		8.0	10.0
Power source			1 Phase 220-240V 50Hz	
Noise level	dB(A)		Hi: 41 Lo: 37	Hi: 42 Lo: 37
Exterior dimensions Height × Width × Depth	mm		295 × 850 × 650	350 × 1370 × 650
Net weight	kg		40	63
Refrigerant equipment Heat exchanger			Louver fin & inner grooved tubing	
Refrigerant control			Electronic Expansion valve	
Air handling equipment Fan type & Q'ty			Multiblade centrifugal fan × 2	
Motor	W		230 × 1	280 × 1
Starting method			Direct line starting	
Air flow(Standard)	CMM		Hi: 25 Lo: 18.5	Hi: 34 Lo: 27
Available static pressure (at Hi)	Pa		Standard:50, Max:130	
Outside air intake			—	
Air filter Q'ty			Polypropylene net × 1(Washable)	
Shock & vibration isolator			Rubber sleeve(for fan motor)	
Operation control Operation switch			Wired remote control switch (Optional:RC-E1R) Wireless kit (Optional:RCND-KIT-HER)	
Room temperature control			Thermostat by electronics	
Safety equipment			Internal thermostat for fan motor. Frost protection thermostat	
Installation data Refrigerant piping size	mm(in)		Liquid line: φ9.52 (3/8") Gas line: φ15.88 (5/8")	
Connecting method			Flare piping	
Drain hose			Connectable with VP25(I.D.25mm, O.D.32mm)	
Insulation for piping			Necessary (both Liquid & Gas lines)	
Accessories			Mounting kit, Drain hose	
Optional parts			Silent panel, Duct Joint	

Notes (1)The data are measured at the following conditions.

Item	Indoor air temperature		Outdoor air temperature		Standards
	DB	WB	DB	WB	
Operation					
Cooling* <sup>1</sup>	27℃	19℃	35℃	24℃	ISO-T1
Heating* <sup>2</sup>	20℃	—	7℃	6℃	

(2)This packaged air-conditioner is manufactured and tested in conformity with the following standard.  
ISO-T1"UNITARY AIR-CONDITIONERS"

## Models FDURA112KXE4R, 140KXE4R

Item		Models	FDURA112KXE4R	FDURA140KXE4R
Nominal cooling capacity* <sup>1</sup>	kW		11.2	14.0
Nominal heating capacity* <sup>2</sup>	kW		12.5	16.0
Power source			1 Phase 220-240V 50Hz	
Noise level	dB(A)		Hi: 42 Lo: 38	Hi: 43 Lo: 39
Exterior dimensions Height × Width × Depth	mm		350 × 1370 × 650	
Net weight	kg		63	65
Refrigerant equipment Heat exchanger			Louver fin & inner grooved tubing	
Refrigerant control			Electronic Expansion valve	
Air handling equipment Fan type & Q'ty			Multiblade centrifugal fan × 2	
Motor	W		280×1	460×1
Starting method			Direct line starting	
Air flow(Standard)	CMM		Hi: 34 Lo: 27	Hi: 42 Lo: 33.5
Available static pressure (at Hi)	Pa		Standard: 50, Max: 130	
Outside air intake			—	
Air filter, Q'ty			Polypropylene net × 1(Washable)	
Shock & vibration isolator			Rubber sleeve(for fan motor)	
Operation control Operation switch			Wired remote control switch (Optional:RC-E1R) Wireless kit (Optional:RCND-KIT-HER)	
Room temperature control			Thermostat by electronics	
Safety equipment			Internal thermostat for fan motor. Frost protection thermostat	
Installation data Refrigerant piping size	mm(in)		Liquid line: φ9.52 (3/8") Gas line: φ15.88 (5/8")	
Connecting method			Flare piping	
Drain hose			Connectable with VP25(I.D.25mm, O.D.32mm)	
Insulation for piping			Necessary (both Liquid & Gas lines)	
Accessories			Mounting kit, Drain hose	
Optional parts			Silent panel, Duct joint	

Notes (1) The data are measured at the following conditions.

Item	Indoor air temperature		Outdoor air temperature		Standards
	DB	WB	DB	WB	
Operation					
Cooling* <sup>1</sup>	27℃	19℃	35℃	24℃	ISO-T1
Heating* <sup>2</sup>	20℃	—	7℃	6℃	

(2) This packaged air-conditioner is manufactured and tested in conformity with the following standard.  
ISO-T1"UNITARY AIR-CONDITIONERS"

(j) Ceiling suspended type (FDE)

Models FDEA36KXE4R, 45KXE4R

Item		Models	FDEA36KXE4R	FDEA45KXE4R
Nominal cooling capacity* <sup>1</sup>	kW		3.6	4.5
Nominal heating capacity* <sup>2</sup>	kW		4.0	5.0
Power source			1 Phase 220-240V 50Hz/220V 60Hz	
Noise level	dB(A)		Hi: 39 Me: 38 Lo: 36	
Exterior dimensions Height × Width × Depth	mm		210 × 1070 × 690	
Net weight	kg		30	
Refrigerant equipment Heat exchanger			Louver fin & inner grooved tubing	
Refrigerant control			Electronic Expansion Valve	
Air handling equipment Fan type & Q'ty			Centrifugal fan × 2	
Motor	W		25 × 1	
Starting method			Direct line starting	
Air flow(Standard)	CMM		Hi: 11 Me: 9 Lo: 7	
Outside air intake			Not possible	
Air filter, Q'ty			Long life filter × 2 (Washable)	
Shock & vibration isolator			Rubber sleeve (for fan motor)	
Insulation (noise & heat)			Polyurethane foam	
Operation control Operation switch			Wired remote control switch (Optional:RC-E1R) Wireless kit (Optional:RCND-KIT-HER)	
Room temperature control			Thermostat by electronics	
Safety equipment			Internal thermostat for fan motor. Frost protection thermostat	
Installation data Refrigerant piping size	mm(in)		Liquid line: φ 6.35(1/4"), Gas line: φ 12.7(1/2")	
Connecting method			Flare piping	
Drain hose			Connectable with VP20(I.D.20mm, O.D.26mm)	
Insulation for piping			Necessary (both Liquid & Gas lines)	
Accessories			Mounting kit, Drain hose	
Optional parts			—	

Notes (1) The data are measured at the following conditions.

Item	Indoor air temperature		Outdoor air temperature		Standards
	DB	WB	DB	WB	
Operation					
Cooling* <sup>1</sup>	27℃	19℃	35℃	24℃	ISO-T1
Heating* <sup>2</sup>	20℃	—	7℃	6℃	

(2) This packaged air-conditioner is manufactured and tested in conformity with the following standard.

ISO-T1 "UNITARY AIR-CONDITIONERS"

## Models FDEA56KXE4R, 71KXE4R

Item		Models	FDEA56KXE4R	FDEA71KXE4R
Nominal cooling capacity* <sup>1</sup>		kW	5.6	7.1
Nominal heating capacity* <sup>2</sup>		kW	6.3	8.0
Power source			1 Phase 220-240V 50Hz/220V 60Hz	
Noise level		dB(A)	Hi: 39 Me: 38 Lo: 36	Hi: 41 Me: 39 Lo: 37
Exterior dimensions Height × Width × Depth		mm	210 × 1070 × 690	210 × 1320 × 690
Net weight		kg	30	36
Refrigerant equipment Heat exchanger			Louver fin & inner grooved tubing	
Refrigerant control			Electronic Expansion Valve	
Air handling equipment Fan type & Q'ty			Centrifugal fan × 2	Centrifugal fan × 4
Motor		W	25 × 1	20 × 2
Starting method			Direct line starting	
Air flow(Standard)		CMM	Hi: 11 Me: 9 Lo: 7	Hi: 18 Me: 14 Lo: 12
Outside air intake			Not possible	
Air filter, Q'ty			Long life filter × 2(Washable)	
Shock & vibration isolator			Rubber sleeve(for fan motor)	
Insulation (noise & heat)			Polyurethane foam	
Operation control Operation switch			Wired remote control switch (Optional:RC-E1R) Wireless kit (Optional:RCND-KIT-HER)	
Room temperature control			Thermostat by electronics	
Safety equipment			Internal thermostat for fan motor. Frost protection thermostat	
Installation data Refrigerant piping size		mm(in)	Liquid line: φ6.35(1/4"), Gas line: φ12.7(1/2")	Liquid line: φ9.52(3/8"), Gas line: φ15.88(5/8")
Connecting method			Flare piping	
Drain hose			Connectable with VP20(I.D.20mm, O.D.26mm)	
Insulation for piping			Necessary (both Liquid & Gas lines)	
Accessories			Mounting kit, Drain hose	
Optional parts			—	

Notes (1) The data are measured at the following conditions.

Item	Indoor air temperature		Outdoor air temperature		Standards
	DB	WB	DB	WB	
Operation					
Cooling* <sup>1</sup>	27℃	19℃	35℃	24℃	ISO-T1
Heating* <sup>2</sup>	20℃	—	7℃	6℃	

(2) This packaged air-conditioner is manufactured and tested in conformity with the following standard.

**ISO-T1 "UNITARY AIR-CONDITIONERS"**

## Models FDEA112KXE4R, 140KXE4R

Item		Models	FDEA112KXE4R	FDEA140KXE4R
Nominal cooling capacity <sup>*1</sup>		kW	11.2	14.0
Nominal heating capacity <sup>*2</sup>		kW	12.5	16.0
Power source			1 Phase 220-240V 50Hz/220V 60Hz	
Noise level		dB(A)	Hi: 44 Me: 41 Lo: 39	Hi: 46 Me: 44 Lo: 43
Exterior dimensions Height × Width × Depth		mm	250 × 1620 × 690	
Net weight		kg	46	
Refrigerant equipment Heat exchanger			Louver fin & inner grooved tubing	
Refrigerant control			Electronic Expansion Valve	
Air handling equipment Fan type & Q'ty			Centrifugal fan × 4	
Motor		W	30 × 2	38 × 2
Starting method			Direct line starting	
Air flow(Standard)		CMM	Hi: 26 Me: 23 Lo: 21	Hi: 29 Me: 26 Lo: 23
Outside air intake			Not possible	
Air filter, Q'ty			Long life filter × 2(Washable)	
Shock & vibration isolator			Rubber sleeve(for fan motor)	
Insulation (noise & heat)			Polyurethane foam	
Operation control Operation switch			Wired remote control switch (Optional:RC-E1R) Wireless kit (Optional:RCND-KIT-HER)	
Room temperature control			Thermostat by electronics	
Safety equipment			Internal thermostat for fan motor. Frost protection thermostat	
Installation data Refrigerant piping size		mm(in)	Liquid line: φ9.52(3/8"), Gas line: φ15.88(5/8")	
Connecting method			Flare piping	
Drain hose			Connectable with VP20(I.D.20mm, O.D.26mm)	
Insulation for piping			Necessary (both Liquid & Gas lines)	
Accessories			Mounting kit, Drain hose	
Optional parts			—	

Notes (1) The data are measured at the following conditions.

Item	Indoor air temperature		Outdoor air temperature		Standards
	DB	WB	DB	WB	
Operation					
Cooling <sup>*1</sup>	27℃	19℃	35℃	24℃	ISO-T1
Heating <sup>*2</sup>	20℃	—	7℃	6℃	

(2) This packaged air-conditioner is manufactured and tested in conformity with the following standard.

**ISO-T1 "UNITARY AIR-CONDITIONERS"**

(k) Wall mounted type (FDK)

Models FDKA22KXE4R, 28KXE4R, 36KXE4R, 45KXE4R

Item		Models	FDKA22KXE4R	FDKA28KXE4R	FDKA36KXE4R	FDKA45KXE4R
Nominal cooling capacity <sup>*1</sup>	kW		2.2	2.8	3.6	4.5
Nominal heating capacity <sup>*2</sup>	kW		2.5	3.2	4.0	5.0
Power source		1 Phase 220-240V 50Hz				
Noise level	dB(A)	Hi: 40 Me: 36 Lo: 32			Hi: 41 Me: 37 Lo: 33	Hi: 41 Me: 37 Lo: 32
Exterior dimensions Height × Width × Depth	mm	298 × 840 × 240				
Net weight	kg	12				12.5
Refrigerant equipment Heat exchanger		Louver fin & inner grooved tubing				
Refrigerant control		Electronic Expansion Valve				
Air handling equipment Fan type & Q'ty		Tangential fan ×1				
Motor	W	33×1				
Starting method		Direct line starting				
Air flow(Standard)	CMM	Hi: 8 Me: 7 Lo: 6			Hi: 10 Me: 9 Lo: 7	Hi: 11 Me: 9 Lo: 7
Outside air intake		Not possible				
Air filter, Q'ty		Long life filter × 2(Washable)				
Shock & vibration isolator		Rubber sleeve(for fan motor)				
Insulation (noise & heat)		Polyurethane foam				
Operation control Operation switch		Wired remote control switch (Optional:RC-E1R) Wireless kit (Optional:RCND-KIT-HER)				
Room temperature control		Thermostat by electronics				
Safety equipment		Internal thermostat for fan motor. Frost protection thermostat				
Installation data Refrigerant piping size	mm(in)	Liquid line:φ 6.35(1/4") Gas line:φ 9.52(3/8")			Liquid line:φ 6.35(1/4") Gas line:φ 12.7(1/2")	
Connecting method		Flare piping				
Drain hose		Connectable with VP16(I.D.16mm, O.D.22mm)				
Insulation for piping		Necessary (both Liquid & Gas lines)				
Accessories		Mounting kit, Drain hose				
Optional parts		—				

Notes (1) The data are measured at the following conditions.

Item	Indoor air temperature		Outdoor air temperature		Standards
	DB	WB	DB	WB	
Operation					
Cooling* <sup>1</sup>	27℃	19℃	35℃	24℃	ISO-T1
Heating* <sup>2</sup>	20℃	—	7℃	6℃	

(2) This packaged air-conditioner is manufactured and tested in conformity with the following standard.

ISO-T1 "UNITARY AIR-CONDITIONERS"

## Models FDKA56KXE4R, 71KXE5R

Item		Models	FDKA56KXE4R	FDKA71KXE5R
Nominal cooling capacity* <sup>1</sup>	kW		5.6	7.1
Nominal heating capacity* <sup>2</sup>	kW		6.3	8.0
Power source			1 Phase 220-240V 50Hz	
Noise level	dB(A)		Hi: 46 Me: 43 Lo: 39	
Exterior dimensions Height × Width × Depth	mm		298 × 840 × 240	318 × 1098 × 248
Net weight	kg		13	18
Refrigerant equipment Heat exchanger			Louver fin & inner grooved tubing	
Refrigerant control			Electronic Expansion Valve	
Air handling equipment Fan type & Q'ty			Tangential fan × 1	
Motor	W		33 × 1	40 × 1
Starting method			Direct line starting	
Air flow(Standard)	CMM		Hi: 14 Me: 12 Lo: 10	Hi: 21 Me: 18 Lo: 15
Outside air intake			Not possible	
Air filter, Q'ty			Long life filter × 2(Washable)	
Shock & vibration isolator			Rubber sleeve(for fan motor)	
Insulation (noise & heat)			Polyurethane foam	
Operation control Operation switch			Wired remote control switch (Optional:RC-E1R) Wireless kit (Optional:RCND-KIT-HER)	
Room temperature control			Thermostat by electronics	
Safety equipment			Internal thermostat for fan motor. Frost protection thermostat	
Installation data Refrigerant piping size	mm(in)		Liquid line:φ 6.35(1/4") Gas line:φ 12.7(1/2")	Liquid line:φ 9.52(3/8") Gas line:φ 15.88(5/8")
Connecting method			Flare piping	
Drain hose			Connectable with VP16(I.D.16mm, O.D.22mm)	
Insulation for piping			Necessary (both Liquid & Gas lines)	
Accessories			Mounting kit, Drain hose	
Optional parts			—	

Notes (1) The data are measured at the following conditions.

Item	Indoor air temperature		Outdoor air temperature		Standards
	DB	WB	DB	WB	
Operation					
Cooling* <sup>1</sup>	27℃	19℃	35℃	24℃	ISO-T1
Heating* <sup>2</sup>	20℃	—	7℃	6℃	

(2) This packaged air-conditioner is manufactured and tested in conformity with the following standard.

**ISO-T1 "UNITARY AIR-CONDITIONERS"**

(3) The FDKA71KXE5R indoor unit cannot be connected to the FDCA140HKXEN4R, 140HKXES4R and 160HKXES4R outdoor units.



(I) Floor standing exposed type (FDFL)

Models FDFLA28KXE4R, 45KXE4R, 71KXE4R

Item		Models	FDFLA28KXE4R	FDFLA45KXE4R	FDFLA71KXE4R
Nominal cooling capacity* <sup>1</sup>	kW		2.8	4.5	7.1
Nominal heating capacity* <sup>2</sup>	kW		3.2	5.0	8.0
Power source		1 Phase 220-240V 50Hz			
Noise level	dB(A)	Hi: 41 Me:38 Lo: 36	Hi: 43 Me:41 Lo: 40		
Exterior dimensions Height × Width × Depth	mm	630 × 1196 × 225			630 × 1481 × 225
Net weight	kg	32			40
Refrigerant equipment Heat exchanger		Louver fin & inner grooved tubing			
Refrigerant control		Electronic Expansion Valve			
Air handling equipment Fan type & Q'ty		Centrifugal fan × 2			
Motor	W	30 × 1	40 × 1		
Starting method		Direct line starting			
Air flow(Standard)	CMM	Hi: 12 Me: 11 Lo: 10	Hi: 14 Me: 12 Lo: 10	Hi: 18 Me: 15 Lo: 12	
Outside air intake		Not possible			
Air filter, Q'ty		Polypropylene net × 2(Washable)			
Shock & vibration isolator		Rubber sleeve(for fan motor)			
Insulation (noise & heat)		Polyurethane foam			
Operation control Operation switch		Wired remote control switch (Optional:RC-E1R) Wireless kit (Optional:RCND-KIT-HER)			
Room temperature control		Thermostat by electronics			
Safety equipment		Internal thermostat for fan motor. Frost protection thermostat			
Installation data Refrigerant piping size	mm(in)	Liquid line:φ 6.35(1/4") Gas line:φ 9.52(3/8")	Liquid line:φ 6.35(1/4") Gas line:φ 12.7(1/2")	Liquid line:φ 9.52(3/8") Gas line:φ 15.88(5/8")	
Connecting method		Flare piping			
Drain hose		Connectable with PT20A			
Insulation for piping		Necessary (both Liquid & Gas lines)			
Accessories		Mounting kit, Drain hose			
Optional parts		—			

Notes (1) The data are measured at the following conditions.

Item	Indoor air temperature		Outdoor air temperature		Standards
	DB	WB	DB	WB	
Cooling* <sup>1</sup>	27℃	19℃	35℃	24℃	ISO-T1
Heating* <sup>2</sup>	20℃	—	7℃	6℃	

(2) This packaged air-conditioner is manufactured and tested in conformity with the following standard.

ISO-T1 "UNITARY AIR-CONDITIONERS"

(m) Floor standing hidden type (FDFU)

Models FDFUA28KXE4R, 45KXE4R, 56KXE4R, 71KXE4R

Models		FDFUA28KXE4R	FDFUA45KXE4R	FDFUA56KXE4R	FDFUA71KXE4R
Nominal cooling capacity* <sup>1</sup>	kW	2.8	4.5	5.6	7.1
Nominal heating capacity* <sup>2</sup>	kW	3.2	5.0	6.3	8.0
Power source		1 Phase 220-240V 50Hz			
Noise level	dB(A)	Hi: 41 Me:38 Lo: 36	Hi: 43 Me:41 Lo: 40		
Exterior dimensions Height × Width × Depth	mm	630 × 1077 × 225			630 × 1362 × 225
Net weight	kg	25			32
Refrigerant equipment Heat exchanger		Louver fin & inner grooved tubing			
Refrigerant control		Electronic Expansion Valve			
Air handling equipment Fan type & Q'ty		Centrifugal fan × 2			
Motor	W	30×1	40×1		
Starting method		Direct line starting			
Air flow(Standard)	CMM	Hi: 12 Me: 11 Lo: 10	Hi: 14 Me: 12 Lo: 10		Hi: 18 Me: 15 Lo: 12
Outside air intake		Not possible			
Air filter, Q'ty		Polypropylene net × 2(Washable)			
Shock & vibration isolator		Rubber sleeve(for fan motor)			
Insulation (noise & heat)		Polyurethane foam			
Operation control Operation switch		Wired remote control switch (Optional:RC-E1R) Wireless kit (Optional:RCND-KIT-HER)			
Room temperature control		Thermostat by electronics			
Safety equipment		Internal thermostat for fan motor. Frost protection thermostat			
Installation data Refrigerant piping size	mm(in)	Liquid line:φ 6.35(1/4") Gas line: φ9.52(3/8")	Liquid line:φ 6.35(1/4") Gas line: φ12.7(1/2")		Liquid line:φ 9.52(3/8") Gas line: φ15.88(5/8")
Connecting method		Flare piping			
Drain hose		Connectable with PT20A			
Insulation for piping		Necessary (both Liquid & Gas lines)			
Accessories		Mounting kit, Drain hose			
Optional parts		—			

Notes (1) The data are measured at the following conditions.

Item	Indoor air temperature		Outdoor air temperature		Standards
	DB	WB	DB	WB	
Cooling* <sup>1</sup>	27℃	19℃	35℃	24℃	ISO-T1
Heating* <sup>2</sup>	20℃	—	7℃	6℃	

(2) This packaged air-conditioner is manufactured and tested in conformity with the following standard.





**ISO-T1 "UNITARY AIR-CONDITIONERS"**

## 3.2 Exterior dimensions

### (1) Indoor unit

#### (a) Ceiling recessed compact type (FDTC)


Models FDTCA22KXE4R, 28KXE4R, 36KXE4R, 45KXE4R, 56KXE4R







(b) Ceiling recessed compact type (FDT)

Models FDTA28KXE4R, 36KXE4R, 45KXE4R, 56KXE4R, 71KXE4R


unit : mm




## Models FDTA90KXE4R



VIEW A







VIEW B




**Models FDTA112KXE4R, 140KXE4R**


unit : mm



**VIEW A**





**VIEW B**







(c) 2-way outlet ceiling recessed type (FDTW)

Models FDTWA28KXE4R, 45KXE4R, 56KXE4R  
28KXE5R, 45KXE5R, 56KXE5R

Unit : mm



VIEW A







## Unit: mm







**Models** FDTQA22KXE4R, 28KXE4R, 36KXE4R

The image contains two technical drawings of the VP25 unit.

**Front View (Left):** Shows the front of the unit with a width of 490 mm and a height of 155 mm. The top section has a height of 68 mm, and the bottom section has a height of 37.5 mm. The top section contains a "Supply air duct (Knock out)" and "Holes for tapping screws  $\phi 4-12$  pcs." The bottom section contains a "Drain (Connectable with VP25)". The bottom section has a width of 30 mm on the left and right sides, and a central width of 150 mm. The total width is 490 mm.


**Side View (Right):** Shows the side of the unit with a width of 210 mm and a height of 248 mm. The top section has a width of 140 mm and a height of 135 mm. The bottom section has a width of 42 mm and a height of 197 mm. The bottom section contains a "Gas piping" (22, 28:  $\phi 9.52(3/8)$ ; 36:  $\phi 12.7(1/2)$ ) and a "Liquid piping" ( $\phi 6.35(1/4)$ ). The bottom section also contains an "Opening for exit wiring".



– 81 –

Models FDTQA22KXE4R, 28KXE4R, 36KXE4R


Direct blow panel (TQ-PSB-14W-ER)



- When modified to the Duct panel type on site.

Models FDTQA22KXE4R, 28KXE4R 36KXE4R


**Duct panel (QR-PNA-14W-ER)**



- When modified to the Duct Cassetteria type on site.


Models FDTQA22KXE4R, 28KXE4R, 36KXE4R

**Duct panel (QR-PNB-14W-ER)**





(e) 1-way outlet ceiling recessed type (FDTS)

Models FDTSA22KXE4R, 28KXE4R, 36KXE4R, 45KXE4R





# Models FDTSA71KXE4R

Unit : mm




## Decorative Panel






(f) Medium static pressure ducted type (FDQM)

Models FDQMA22KXE4R, 28KXE4R, 36KXE4R







**VIEW A**






(g) High static pressure duct type (FDU)

Model FDUA224KXE4R, 280KXE4R






Space for installation and service



(h) Satellite ducted type (FDUM)


Models FDUMA36KXE4R, 45KXE4R, 56KXE4R

Unit : mm






**VIEW B**

Space for installation and service




**Models FDUMA71KXE4R, 90KXE4R**

Unit : mm






**VIEW B**

Space for installation and service




**Models FDUMA112KXE4R, 140KXE4R**

Unit : mm




Space for installation and service





(i) Ceiling mounted duct type (FDUR)

Models FDURA45KXE4R, 56KXE4R, 71KXE4R

Unit : mm




Space for installation and service





**Models FDURA90KXE4R, 112KXE4R, 140KXE4R**

Unit : mm




**Space for installation and service**



(j) Ceiling suspended type (FDE)


Models FDEA36KXE4R, 45KXE4R, 56KXE4R

Unit : mm




Models FDEA71KXE4R

Unit : mm



**Models FDEA112KXE4R, 140KXE4R**

Unit : mm







(k) Wall mounted type (FDK)

Models FDKA22KXE4R, 28KXE4R, 36KXE4R, 45KXE4R, 56KXE4R

Unit : mm




Model FDKA71KXE5R




**Models** FDFLA28KXE4R, 45KXE4R, 71KXE4R

Note (1) Value in ( ) indicates 71 type.



**Models** FDFUA28KXE4R, 45KXE4R, 56KXE4R, 71KXE4R



Note (1) Value in ( ) indicates 71 type.





### (3) Branching controller (Heat recovery type only)

#### Model PFD112-ER





- Notes (1) Do not operate a unit when it is not connected to the branch controller.
- (2) Branch controllers cannot be installed above and below each other. Install them so that they are level with respect to each other.
- (3) Connection wires should be run from a surface facing the inspection opening.
- (4) Be sure to provide the servicing space specified in the diagram at left.
- (5) If multiple indoor units are connected to a single branching controller, please control them with a single remote controller. Also activate the remote control sensor when this is done.
- (6) Connect the irregular joints shown in the following table in accordance with the connection pipe diameter.  
(Use the flare nuts provided for the branch controller.)

Irregular size Joints		
For outdoor unit suction gas piping For indoor unit gas piping	For outdoor unit discharge gas piping	
2 pcs.	2 pcs.	1 pcs.
 A	 B	 C



- (7) A noise may be emitted by the branching controller as a result of control during operation or stopping of an indoor unit. If it is installed in the ceiling where it is exposed, take adequate precautions with the installation location.

## Model PFD180-ER



- Notes (1) Do not operate a unit when it is not connected to the branch controller.
- (2) Branch controllers cannot be installed above and below each other. Install them so that they are level with respect to each other.
- (3) Connection wires should be run from a surface facing the inspection opening.
- (4) Be sure to provide the servicing space specified in the diagram at left.
- (5) If multiple indoor units are connected to a single branching controller, please control them with a single remote controller. Also activate the remote control sensor when this is done.
- (6) A noise may be emitted by the branching controller as a result of control during operation or stopping of an indoor unit. If it is installed in the ceiling where it is exposed, take adequate precautions with the installation location.

## Model PFD280-ER




- Notes (1) Do not operate a unit when it is not connected to the branch controller.
- (2) Branch controllers cannot be installed above and below each other. Install them so that they are level with respect to each other.
- (3) Connection wires should be run from a surface facing the inspection opening.
- (4) Be sure to provide the servicing space specified in the diagram at left.
- (5) If multiple indoor units are connected to a single branching controller, please control them with a single remote controller. Also activate the remote control sensor when this is done.
- (6) Connect the irregular joints shown in the following table in accordance with the connection pipe diameter.

Irregular size Joints		
For outdoor unit suction gas piping For indoor unit gas piping	For outdoor unit discharge gas piping	
2 pcs.	2 pcs.	1 pcs.
 ID 19.05 ID 15.88 A	 ID 22.22 ID 15.88 B	 ID 19.05 ID 15.88 C

- (7) A noise may be emitted by the branching controller as a result of control during operation or stopping of an indoor unit. If it is installed in the ceiling where it is exposed, take adequate precautions with the installation location.


■ Relay kit with branch controller





(4) Integrated branching remote controller (Heat recovery type only)  
Model PFD112X4-ER

- Remarks: 1. A branching controller cannot be installed upside down. Please install it in such a manner that the main body is held levelly.  
2. Be sure to set a service space as shown in the figure below.  
3. When multiple indoor units are connected to one branch, use one remote controller for control, or enable the remote controller sensor.  
4. Noise may arise from the branching controller during the control when the indoor unit is operated or stopped. Pay attention to the installation location when the installation is conducted from the ceiling.  
5. Use the provided liquid header to connect the liquid pipe via the horizontal branch.




Weight  
30kg

Unit : mm

Outdoor refrigerant piping connection port (discharge gas)  
ø15.88 (flare)

(When connecting ø19.05 use the irregular joint B which is provided.  
When connecting with ø12.7 pipe. Cut off to connect with the irregular joint A supplied with the unit.)



Outdoor refrigerant piping connection port (suction gas)  
ø15.88 (flange)  
(ø19.05, ø22.22 cut off to connect)

Indoor refrigerant piping connection port  
ø15.88 (flare)

(When connecting ø9.52 use the irregular joint A which is provided.  
When connecting with ø12.7 pipe. Cut off to connect with the irregular joint A supplied with the unit.)


6. Use the joints shown in the table below for connecting pipes of different diameters. (For the flare nuts, use those provided with the branching controller.)

Irregular size joints		Flange joint
For outdoor unit gas suction pipe For indoor unit gas pipe	For outdoor unit gas discharge pipe	For outdoor unit gas suction pipe
5 pcs.	1 pc.	1 pc.
<p>A</p>	<p>B</p>	

### 3.3 Exterior appearance


#### (a) Ceiling recessed compact type (FDTC)

- Decorative panel




#### (b) Ceiling recessed type (FDT)

- Decorative panel



#### (c) 2-way outlet ceiling recessed type (FDTW)




- Decorative panel

Standard type

Panel part No.	Type	Panel color	Applicable model
TW-PSA-23W-ER	With Auto swing	Pearl white	FDTW28, 45, 56
TW-PSA-33W-ER			FDTW71, 90
TW-PSA-43W-ER			FDTW112, 140

**(d) Ceiling recessed single air supply port type (FDTQ)**


This illustration shows the direct blow panel (TQ-PSA-14W-ER). Painting color is the same for other panels.



● Decorative panel

Panel part No.		Type	Panel color	Applicable model
Direct blow panel	TQ-PSA-14W-ER	With Auto swing	Pearl white	FDTQ22, 28, 36
	TQ-PSB-14W-ER			
Duct panel	QR-PNA-14W-ER	Non Auto swing	Pearl white	FDTQ22, 28, 36
	QR-PNB-14W-ER			


**(e) 1-way outlet ceiling recessed type (FDTS)**



● Decorative panel

Panel part No.	Type	Panel color	Applicable model
TS-PSA-28W-ER	With Auto swing	Ceramic white	FDTS28, 36, 45
TS-PSA-38W-ER			FDTS71



- (f) Medium static pressure ducted type (FDQM) .....Zinc steel plate
- (g) High static pressure ducted type (FDU).....Zinc steel plate
- (h) Satellite ducted type (FDUM) ..... Zinc steel plate
- (i) Ceiling mounted duct type (FDUR) ..... Zinc steel plate
- (j) Ceiling suspension type (FDE)




(k) Wall mounted type (FDK)

Models FDKA22, 28, 36, 45, 56KXE4R

Model FDKA71KXE5R



(l) Floor standing exposed type (FDL)




(m) Floor standing hidden type (FDFU) ..... Zinc steel plate

### 3.4 Characteristics of fan

#### (1) Ceiling recessed single air supply port type (FDTQ)

(Only when FDTQA22, 28 and 36 model are used for the Duct panel type.)

Models FDTQA22, 28 36KXE4R



## (2) Medium static pressure ducted type (FDQM)

### Satellite ducted type (FDUM)

- External static pressure table


Unit : Pa

Model	Duct specs. Air flow (m <sup>3</sup> /min)	1 spot closing		Standard		Square duct	
		Stan- dard	High <sup>(1)</sup> speed	Stan- dard	High <sup>(1)</sup> speed	Stan- dard	High <sup>(1)</sup> speed
FDQMA22 28 36		-	-	30	-	-	-
FDUMA36	12	-	-	50	85	50	90
FDUMA45 56	14	-	-	50	85	50	90
FDUMA71	18	35	70	50	85	55	90
FDUMA90	20	30	65	50	85	55	90
FDUMA112	28	50	80	60	90	65	95
FDUMA140	34	50	75	60	85	65	95

Note (1) For high speed operation, insert the white connector and the red connector beside the control box in other places respectively.

### How to interpret the blower characteristics table

#### Example : Case of FDUMA71KXE4R




#### 1 2-spot blowout.....

Internal resistance increases more than the standard 3-spot blowout. Approx. 14Pa at 17m³/min


#### 2 Square duct blowout.....

Internal resistance decreases more than the standard round duct (ø200 3-spot). 3Pa at 17 m³/min. (External static pressure increases in reverse.)


Models FDQMA22KXE4R, 28KXE4R, 36KXE4R




Model FDUMA36KXE4R




Models FDUMA45KXE4R, 56KXE4R




Model FDUMA71KXE4R




Model FDUMA90KXE4R



Model FDUMA112KXE4R




## Model FDUMA140KXE4R




### (3) Ceiling mounted duct type (FDUR)

#### Model FDURA45KXE4R




#### Model FDURA56KXE4R







Model FDURA71KXE4R




Model FDURA90KXE4R



Model FDURA112KXE4R



Model FDURA140KXE4R



#### (4) High static pressure ducted type (FDU)

##### How to interpret the blower characteristics table

Example • What is the Fan Controller's Volume Number setting if, at the high operation speed of FDUA224KXE4R, it is required to have 120Pa outside static pressure at 56m<sup>3</sup>/min airflow volume as the operation point?

Move the 120Pa outside static pressure point to the right as shown in the diagram below. The “(a) -point”, i.e. where this intersects with the solid curve tracing the 56m<sup>3</sup>/min airflow volume upwards, is the appropriate Volume Number.

In this example the appropriate Volume Number is “No. 3”.

- In this situation, a condition of 50m<sup>3</sup>/min airflow volume at 96Pa outside static pressure can be predicated at Low Tap and it can be concluded that operation is possible.


Always follow the procedure in “(b) -point” to verify that the condition at Low Tap is not outside the Feasible Operation Airflow Volume Range.

Notes (1) Circled values in the Special Feature Table indicate Fan Controller Volume Numbers. Volume Numbers with no entry are outside the Feasible Operation Airflow Volume Range and therefore operation is not possible.

(2) The Fan Controller Volume Number is set at “No.5” when shipped from the assembly plant.


##### Model FDUA224KXE4R

High——• Condition of standard rating  
Low ---- Rated air volume: 100Pa



##### Model FDUA280KXE4R

High——• Condition of standard rating  
Low ---- Rated air volume: 100Pa



### 3.5 Noise level

Note (1) The data are based on the following conditions.

Ambient air temperature: Indoor unit 27°C DB, 19°C WB. Outdoor unit 35°C DB


(2) The data in the chart are measured in an anechoic room.

(3) The noise levels measured in the field are usually higher than the data because of reflection.

#### (a) Ceiling recessed compact type (FDTC)


Measured based on JIS B 8616

Mike position as right




##### Models FDTC A22KXE4R, 28KXE4R

Noise level 35 dB (A) at HIGH  
33 dB (A) at MEDIUM  
32 dB (A) at LOW




##### Model FDTC A36KXE4R

Noise level 38 dB (A) at HIGH  
36 dB (A) at MEDIUM  
34 dB (A) at LOW




##### Model FDTC A45KXE4R

Noise level 40 dB (A) at HIGH  
38 dB (A) at MEDIUM  
36 dB (A) at LOW



##### Model FDTC A56KXE4R


Noise level 45 dB (A) at HIGH  
42 dB (A) at MEDIUM  
39 dB (A) at LOW



#### (b) Ceiling recessed type (FDT)


Measured based on JIS B 8616

Mike position as right




##### Models FDT A28KXE4R, 36KXE4R, 45KXE4R

Noise level 35 dB (A) at HIGH  
33 dB (A) at MEDIUM  
31 dB (A) at LOW




##### Model FDT A56KXE4R

Noise level 36 dB (A) at HIGH  
34 dB (A) at MEDIUM  
32 dB (A) at LOW




##### Model FDT A71KXE4R

Noise level 37 dB (A) at HIGH  
35 dB (A) at MEDIUM  
33 dB (A) at LOW




**Model FDTA90KXE4R**


Noise level 43 dB (A) at HIGH  
41 dB (A) at MEDIUM  
38 dB (A) at LOW

**Model FDTA112KXE4R**

Noise level 43 dB (A) at HIGH  
41 dB (A) at MEDIUM  
38 dB (A) at LOW

**Model FDTA140KXE4R**


Noise level 45 dB (A) at HIGH  
43 dB (A) at MEDIUM  
41 dB (A) at LOW

**(c) 2-way outlet ceiling recessed type (FDTW)**


**Models FDTWA28KXE4R, 45KXE4R, 56KXE4R Model FDTWA71KXE4R**  
**28KXE5R, 45KXE5R, 56KXE5R**

Measured based on JIS B 8616


Mike position as below




Noise level 39 dB (A) at HIGH  
36 dB (A) at MEDIUM  
33 dB (A) at LOW




Noise level 41 dB (A) at HIGH  
38 dB (A) at MEDIUM  
35 dB (A) at LOW

**Model FDTWA90KXE4R**


Noise level 41 dB (A) at HIGH  
39 dB (A) at MEDIUM  
36 dB (A) at LOW

**Model FDTWA112KXE4R**

Noise level 44 dB (A) at HIGH  
41 dB (A) at MEDIUM  
38 dB (A) at LOW

**Model FDTWA140KXE4R**


Noise level 45 dB (A) at HIGH  
42 dB (A) at MEDIUM  
39 dB (A) at LOW



**(d) Ceiling recessed single air supply type (FDTQ)**


Measured based on JIS B 8616

Mike position as below




**Models FDTQA22KXE4R, 28KXE4R  
36KXE4R**

**Noise level** 38 dB (A) at HIGH  
34 dB (A) at LOW



**When used as the Duct panel type  
Models FDTQA22KXE4R, 28KXE4R  
36KXE4R**


**Noise level** 42 dB (A) at HIGH  
39 dB (A) at LOW



**(e) 1-way outlet ceiling recessed type (FDTS)**


Measured based on JIS B 8616

Mike position as below




**Model FDTSA22KXE4R**

**Noise level** 39 dB (A) at HIGH  
38 dB (A) at LOW




**Models FDTSA28KXE4R, 36KXE4R**

**Noise level** 40 dB (A) at HIGH  
39 dB (A) at MEDIUM  
38 dB (A) at LOW




**Model FDTSA45KXE4R**

**Noise level** 43 dB (A) at HIGH  
40 dB (A) at MEDIUM  
38 dB (A) at LOW



**Model FDTSA71KXE4R**


**Noise level** 44 dB (A) at HIGH  
40 dB (A) at MEDIUM  
38 dB (A) at LOW



**(f) High static pressure ducted type (FDU)**

Measured based on JIS B 8616

Mike position as right



**• Power level**


(Measurement conditions: JIS-B8616, measurement location: reverberation chamber)

(Unit: dB)

Form factor	Outlet side	Intake side
FDUA224KXE4R	74	63
FDUA280KXE4R	75	64


**Model FDU A224KXE4R**

**Noise level** 38 dB (A) at HIGH  
35 dB (A) at MEDIUM  
32 dB (A) at LOW




**Model FDU A280KXE4R**

**Noise level** 39 dB (A) at HIGH  
37 dB (A) at MEDIUM  
34 dB (A) at LOW




(g) Medium static pressure ducted type (FDQU)  
Satellite ducted type (FDUM)

Measured based on JIS B 8616  
Mike position as right




Models FDQMA22KXE4R, 28KXE4R  
36KXE4R

Noise level 34 dB (A) at HIGH  
31 dB (A) at LOW




Model FDUMA36KXE4R

Noise level 34 dB (A) at HIGH  
32 dB (A) at MEDIUM  
29 dB (A) at LOW




Models FDUMA45KXE4R, 56KXE4R  
71KXE4R

Noise level 35 dB (A) at HIGH  
32 dB (A) at MEDIUM  
29 dB (A) at LOW




Model FDUMA90KXE4R

Noise level 36 dB (A) at HIGH  
33 dB (A) at MEDIUM  
30 dB (A) at LOW




Model FDUMA112KXE4R

Noise level 38 dB (A) at HIGH  
35 dB (A) at MEDIUM  
32 dB (A) at LOW



Model FDUMA140KXE4R

Noise level 39 dB (A) at HIGH  
37 dB (A) at MEDIUM  
34 dB (A) at LOW






## (h) Ceiling mounted duct type (FDUR)

Measured based on JIS B 8616


Mike position as right



### Model FDURA45KXE4R

Noise level 40 dB (A) at HIGH


36 dB (A) at LOW



### Model FDURA56KXE4R

Noise level 41 dB (A) at HIGH


37 dB (A) at LOW



### Model FDURA71KXE4R

Noise level 41 dB (A) at HIGH


37 dB (A) at LOW



### Model FDURA90KXE4R

Noise level 42 dB (A) at HIGH


37 dB (A) at LOW



### Model FDURA112KXE4R

Noise level 42 dB (A) at HIGH


38 dB (A) at LOW



### Model FDURA140KXE4R

Noise level 43 dB (A) at HIGH


49 dB (A) at LOW



## (i) Ceiling suspended type (FDE)

Measured based on JIS B 8616

Mike position as below




### Model FDEA71KXE4R

Noise level 41 dB (A) at HIGH

39 dB (A) at MEDIUM

37 dB (A) at LOW




### Model FDEA112KXE4R

Noise level 44 dB (A) at HIGH

41 dB (A) at MEDIUM

39 dB (A) at LOW




### Model FDEA140KXE4R

Noise level 46 dB (A) at HIGH

44 dB (A) at MEDIUM

43 dB (A) at LOW




### Models FDEA36KXE4R, 45KXE4R, 56KXE4R

Noise level 39 dB (A) at HIGH


38 dB (A) at MEDIUM

36 dB (A) at LOW




(j) Wall mounted type (FDK)

Measured based on JIS B 8616  
Mike position as right




Models FDKA22KXE4R, 28KXE4R

Noise level 40 dB (A) at HIGH  
36 dB (A) at MEDIUM  
32 dB (A) at LOW




Model FDKA36KXE4R

Noise level 41 dB (A) at HIGH  
37 dB (A) at MEDIUM  
33 dB (A) at LOW




Model FDKA45KXE4R

Noise level 41 dB (A) at HIGH  
37 dB (A) at MEDIUM  
32 dB (A) at LOW




Model FDKA56KXE4R

Noise level 46 dB (A) at HIGH  
43 dB (A) at MEDIUM  
39 dB (A) at LOW




Model FDKA71KXE5R

Noise level 46 dB (A) at HIGH  
43 dB (A) at MEDIUM  
39 dB (A) at LOW




(k) Floor standing type (FDFL, FDFU))

Measured based on JIS B 8616  
Mike position as right



Models FDFLA28KXE4R, FDFUA28KXE4R


Noise level 41 dB (A) at HIGH  
38 dB (A) at MEDIUM  
36 dB (A) at LOW



Models FDFLA45KXE4R, 71KXE4R

FDFUA45KXE4R, 56KXE4R, 71KXE4R

Noise level 43 dB (A) at HIGH  
41 dB (A) at MEDIUM  
40 dB (A) at LOW






### 3.6 Electrical wiring

#### (1) Indoor unit

##### (a) Ceiling recessed compact type (FDTC)

Models FDTCA22KXE4R, 28KXE4R, 36KXE4R

45KXE4R, 56KXE4R



Note(1) Always turn off power before you unplug the fan motor connector shown in an area ※1 delineated by a dotted line, otherwise a breakdown of the fan motor may result.

#### Meaning of marks


Mark	Parts name	Mark	Parts name	Mark	Parts name
FMI	Fan motor	SW2	Indoor unit address units digit	XR4	Inspection output(DC12V output)
DM	Drain motor	SW3	Outdoor unit address tens digit	XR5	Remote operation input(volt-free contact)
FS	Float switch	SW4	Outdoor unit address units digit	X4	Auxiliary relay(For DM)
LM1~4	Louver motor	SW6	Model capacity setting	TB	Terminal block(○ mark)
SM	Stepping motor(For Exp.v)	Tr1	Transformer	CnA~Z	Connector
ThI-A	Thermistor	F	Fuse	■ mark	Closed-end connector
ThI-R1	Thermistor	LED1	Indication lamp(Red)		
ThI-R2	Thermistor	LED2	Indication lamp(Green)		
ThI-R3	Thermistor	XR1	Operation output(DC12V output)		
Thc	Thermistor	XR2	Heating output(DC12V output)		
SW1	Indoor unit address tens digit	XR3	Thermo ON output(DC12V output)		

#### Color marks

Mark	Color	Mark	Color
BK	Black	WH	White
BL	Blue	Y	Yellow
BR	Brown	P	Pink
OR	Orange	Y/GN	Yellow/Green
RD	Red		

#### Function of switches

Mark	Function
SW5-1	ON Testrun of condensate pump motor OFF Normal
SW5-3	ON Input Reverse Invalid OFF signal Run stop
SW5-4	ON Emergency stop signal:Invalid OFF Emergency stop signal:valid
SW9-4	ON Fan control:UH,H,M OFF Fan control:H,M,L



② By means of function setting from the remote controller unit, set the setting ㉔ of "I/U FUNCTION▲" (indoor unit function) to "Hi CEILING 1" (high-speed tap).


- | Function number ㉑ | Function description ㉒ | Setting ㉓    |
|-------------------|------------------------|--------------|
| 01                | Hi CEILING SET         | Hi CEILING 1 |

## Color marks

## Function of switches

Mark		Function	
SW5-1	ON	Test run of condensate pump motor	
	OFF	Normal	
SW5-3	ON	Input	Reverse Invalid
	OFF	signal	Run stop
SW5-4	ON	Emergency stop signal:valid	
	OFF	Emergency stop signal:Invalid	

Mark	Parts name	Mark	Parts name	Mark	Parts name
<b>FMI</b>	Fan motor	<b>SW1</b>	Indoor unit address tens digit	<b>XR3</b>	Thermo ON output(DC12V output)
<b>CFI</b>	Capacitor for FMI	<b>SW2</b>	Indoor unit address units digit	<b>XR4</b>	Inspection output(DC12V output)
<b>DM</b>	Drain motor	<b>SW3</b>	Outdoor unit address tens digit	<b>XR5</b>	Remote operation input(volt-free contact)
<b>FS</b>	Float switch	<b>SW4</b>	Outdoor unit address units digit	<b>X1,2,3,6</b>	Auxiliary relay(For FM)
<b>LM1~4</b>	Louver motor	<b>SW6</b>	Model capacity setting	<b>X4</b>	Auxiliary relay(For DM)
<b>SM</b>	Stepping motor(For Exp.v)	<b>Tr1</b>	Transformer	<b>TB1,2</b>	Terminal block(○ mark)
<b>Th1-A</b>	Thermistor	<b>F</b>	Fuse	<b>CnA~Z</b>	Connector
<b>Th1-R1</b>	Thermistor	<b>LED1</b>	Indication lamp(Red)	<b>■mark</b>	Closed-end connector
<b>Th1-R2</b>	Thermistor	<b>LED2</b>	Indication lamp(Green)		
<b>Th1-R3</b>	Thermistor	<b>XR1</b>	Operation output(DC12V output)		
<b>ThC</b>	Thermistor	<b>XR2</b>	Heating output(DC12V output)		



When increasing of static pressure is required, the following two methods are available in switching the blower fan tap. Switch to the high-speed tap with one of these methods.

- ② By means of function setting from the remote controller unit, set the setting ㉔ of "I/U FUNCTION▲" (indoor unit function) to "Hi CEILING 1" (high-speed tap).


Function number ㉠	Function description ㉢	Setting ㉡
01	Hi CEILING SET	Hi CEILING

Mark	Parts name	Mark	Parts name	Mark	Parts name
<b>FMI</b>	Fan motor	<b>SW2</b>	Indoor unit address units digit	<b>XR4</b>	Inspection output(DC12V output)
<b>DM</b>	Drain motor	<b>SW3</b>	Outdoor unit address tens digit	<b>XR5</b>	Remote operation input(volt-free contact)
<b>FS</b>	Float switch	<b>SW4</b>	Outdoor unit address units digit	<b>X4</b>	Auxiliary relay(For DM)
<b>LM1~4</b>	Louver motor	<b>SW6</b>	Model capacity setting	<b>TB1,2</b>	Terminal block(○ mark)
<b>SM</b>	Stepping motor(For Exp.v)	<b>Tr1</b>	Transformer	<b>CnA~Z</b>	Connector
<b>ThI-A</b>	Thermistor	<b>F</b>	Fuse	<b>■mark</b>	Closed-end connector
<b>ThI-R1</b>	Thermistor	<b>LED1</b>	Indication lamp(Red)		
<b>ThI-R2</b>	Thermistor	<b>LED2</b>	Indication lamp(Green)		
<b>ThI-R3</b>	Thermistor	<b>XR1</b>	Operation output(DC12V output)		
<b>ThC</b>	Thermistor	<b>XR2</b>	Heating output(DC12V output)		
<b>SW1</b>	Indoor unit address tens digit	<b>XR3</b>	Thermo ON output(DC12V output)		

Mark	Color	Mark	Color
<b>BK</b>	Black	<b>RD</b>	Red
<b>BL</b>	Blue	<b>WH</b>	White
<b>BR</b>	Brown	<b>Y</b>	Yellow
<b>BR/WH</b>	Brown/White	<b>P</b>	Pink
<b>OR</b>	Orange	<b>Y/GN</b>	Yellow/Green
<b>OR/WH</b>	Orange/White		

Mark		Function	
SW5-1	ON	Test run of condensate pump motor	
	OFF	Normal	
SW5-3	ON	Input	Reverse Invalid
	OFF	signal	Run stop
SW5-4	ON	Emergency stop signal:valid	
	OFF	Emergency stop signal:Invalid	

(c) 2-way outlet ceiling recessed type(FDTW)  
Model All models



Note(1) \*1. FMI2 is equipped only for 112,140.

Meaning of marks

Mark	Parts name	Mark	Parts name	Mark	Parts name
<b>FMI1,2</b>	Fan motor	<b>SW1</b>	Indoor unit address tens digit	<b>XR3</b>	Thermo ON output(DC12V output)
<b>CFI1,2</b>	Capacitor for FMI	<b>SW2</b>	Indoor unit address units digit	<b>XR4</b>	Inspection output(DC12V output)
<b>DM</b>	Drain motor	<b>SW3</b>	Outdoor unit address tens digit	<b>XR5</b>	Remote operation input(volt-free contact)
<b>FS</b>	Float switch	<b>SW4</b>	Outdoor unit address units digit	<b>X1,2,3,6</b>	Auxiliary relay(For FM)
<b>LM</b>	Louver motor	<b>SW6</b>	Model capacity setting	<b>X4</b>	Auxiliary relay(For DM)
<b>SM</b>	Stepping motor(For Exp.v)	<b>TrI</b>	Transformer	<b>X5</b>	Auxiliary relay(For LM)
<b>ThI-A</b>	Thermistor	<b>F</b>	Fuse	<b>TB</b>	Terminal block(○ mark)
<b>ThI-R1</b>	Thermistor	<b>LED1</b>	Indication lamp(Red)	<b>CnA~Z</b>	Connector
<b>ThI-R2</b>	Thermistor	<b>LED2</b>	Indication lamp(Green)	<b>■mark</b>	Closed-end connector
<b>ThI-R3</b>	Thermistor	<b>XR1</b>	Operation output(DC12V output)		
<b>ThC</b>	Thermistor	<b>XR2</b>	Heating output(DC12V output)		


Color marks

Mark	Color	Mark	Color
<b>BK</b>	Black	<b>RD</b>	Red
<b>BL</b>	Blue	<b>WH</b>	White
<b>BR</b>	Brown	<b>Y</b>	Yellow
<b>OR</b>	Orange	<b>Y/GN</b>	Yellow/Green

Function of switches

Mark	Function	
<b>SW5-1</b>	ON	Test run of condensate pump motor
	OFF	Normal
<b>SW5-3</b>	ON	Input Reverse Invalid
	OFF	signal Run stop
<b>SW5-4</b>	ON	Emergency stop signal:Invalid
	OFF	Emergency stop signal:valid

(d) Ceiling recessed single air supply port type(FDTQ)  
Models FDTQA22KXE4R, 28KXE4R, 36KXE4R



**Color marks**


Mark	Color	Mark	Color
BK	Black	RD	Red
BL	Blue	WH	White
BR	Brown	Y	Yellow
GR	Gray	Y/GN	Yellow/Green
OR	Orange		

**Function of switches**

Mark	Function	
SW5-1	ON	Test run of condensate pump motor
	OFF	Normal
SW5-3	ON	Input signal
	OFF	Reverse Invalid
SW5-4	ON	Emergency stop signal:valid
	OFF	Emergency stop signal:Invalid

**Meaning of marks**

Mark	Parts name	Mark	Parts name	Mark	Parts name
FMI	Fan motor	ThI-R3	Thermistor	XR1	Operation output(DC12V output)
49FI	Internal thermostat for FMI	ThC	Thermistor	XR2	Heating output(DC12V output)
CFI	Capacitor for FMI	SW1	Indoor unit address tens digit	XR3	Thermo ON output(DC12V output)
DM	Drain motor	SW2	Indoor unit address units digit	XR4	Inspection output(DC12V output)
FS	Float switch	SW3	Outdoor unit address tens digit	XR5	Remote operation input(volt-free contact)
LM	Louver motor	SW4	Outdoor unit address units digit	X1,2,3,6	Auxiliary relay(For FM)
LS	Limit switch	SW6	Model capacity setting	X4	Auxiliary relay(For DM)
SM	Stepping motor(For Exp.v)	TrI	Transformer	X5	Auxiliary relay(For LM)
ThI-A	Thermistor	F	Fuse	TB	Terminal block(○ mark)
ThI-R1	Thermistor	LED1	Indication lamp(Red)	CnA~Z	Connector
ThI-R2	Thermistor	LED2	Indication lamp(Green)	■mark	Closed-end connector



When increasing of static pressure is required, the following two methods are available in switching the blower fan tap. Switch to the high-speed tap with one of these methods.

- ② By means of function setting from the remote controller unit, set the setting ㉔ of "I/U FUNCTION▲" (indoor unit function) to "Hi CEILING 1" (high-speed tap).


Function number ㉑	Function description ㉒	Setting ㉓
01	Hi CEILING SET	Hi CEILING 1

Mark	Parts name	Mark	Parts name	Mark	Parts name
<b>FMI1,2</b>	Fan motor	<b>ThC</b>	Thermistor	<b>XR2</b>	Heating output(DC12V output)
<b>CFI1,2</b>	Capacitor for FMI	<b>SW1</b>	Indoor unit address tens digit	<b>XR3</b>	Thermo ON output(DC12V output)
<b>DM</b>	Drain motor	<b>SW2</b>	Indoor unit address units digit	<b>XR4</b>	Inspection output(DC12V output)
<b>FS</b>	Float switch	<b>SW3</b>	Outdoor unit address tens digit	<b>XR5</b>	Remote operation input(volt-free contact)
<b>LM</b>	Louver motor	<b>SW4</b>	Outdoor unit address units digit	<b>X1,2,3,6</b>	Auxiliary relay(For FM)
<b>LS</b>	Louver switch	<b>SW6</b>	Model capacity setting	<b>X4</b>	Auxiliary relay(For DM)
<b>SM</b>	Stepping motor(For Exp.v)	<b>TrI</b>	Transformer	<b>X5</b>	Auxiliary relay(For LM)
<b>ThI-A</b>	Thermistor	<b>F</b>	Fuse	<b>TB</b>	Terminal block(○ mark)
<b>ThI-R1</b>	Thermistor	<b>LED1</b>	Indication lamp(Red)	<b>CnA~Z</b>	Connector
<b>ThI-R2</b>	Thermistor	<b>LED2</b>	Indication lamp(Green)	<b>■mark</b>	Closed-end connector
<b>ThI-R3</b>	Thermistor	<b>XR1</b>	Operation output(DC12V output)		

Mark	Color	Mark	Color
<b>BK</b>	Black	<b>RD</b>	Red
<b>BL</b>	Blue	<b>RD/Y</b>	Red/Yellow
<b>BR</b>	Brown	<b>WH</b>	White
<b>GR</b>	Gray	<b>Y</b>	Yellow
<b>OR</b>	Orange	<b>Y/GN</b>	Yellow/Green

Mark		Function	
SW5-1	ON	Test run of condensate pump motor	
	OFF	Normal	
SW5-3	ON	Input	Reverse Invalid
	OFF	signal	Run stop
SW5-4	ON	Emergency stop signal:valid	
	OFF	Emergency stop signal:Invalid	

(f) Medium static pressure type(FDQM)  
Models FDQMA22KXE4R, 28KXE4R, 36KXE4R



Meaning of marks

Mark	Parts name	Mark	Parts name	Mark	Parts name
<b>FMI</b>	Fan motor	<b>ThC</b>	Thermistor	<b>XR1</b>	Operation output(DC12V output)
<b>49FI</b>	Internal thermostat for FMI	<b>SW1</b>	Indoor unit address tens digit	<b>XR2</b>	Heating output(DC12V output)
<b>CFI</b>	Capacitor for FMI	<b>SW2</b>	Indoor unit address units digit	<b>XR3</b>	Thermo ON output(DC12V output)
<b>DM</b>	Drain motor	<b>SW3</b>	Outdoor unit address tens digit	<b>XR4</b>	Inspection output(DC12V output)
<b>FS</b>	Float switch	<b>SW4</b>	Outdoor unit address units digit	<b>XR5</b>	Remote operation input(volt-free contact)
<b>SM</b>	Stepping motor(For Exp.v)	<b>SW6</b>	Model capacity setting	<b>X1,2,3,6</b>	Auxiliary relay(For FM)
<b>ThI-A</b>	Thermistor	<b>TrI</b>	Transformer	<b>X4</b>	Auxiliary relay(For DM)
<b>ThI-R1</b>	Thermistor	<b>F</b>	Fuse	<b>TB</b>	Terminal block(○ mark)
<b>ThI-R2</b>	Thermistor	<b>LED1</b>	Indication lamp(Red)	<b>CnA-Z</b>	Connector
<b>ThI-R3</b>	Thermistor	<b>LED2</b>	Indication lamp(Green)	<b>■mark</b>	Closed-end connector


Color marks

Mark	Color	Mark	Color
<b>BK</b>	Black	<b>RD</b>	Red
<b>BL</b>	Blue	<b>WH</b>	White
<b>BR</b>	Brown	<b>Y</b>	Yellow
<b>GR</b>	Gray	<b>Y/GN</b>	Yellow/Green
<b>OR</b>	Orange		

Function of switches

Mark	Function	
<b>SW5-1</b>	ON	Test run of condensate pump motor
	OFF	Normal
<b>SW5-3</b>	ON	Input Reverse Invalid
	OFF	signal Run stop
<b>SW5-4</b>	ON	Emergency stop signal:Valid
	OFF	Emergency stop signal:Invalid

(9) High static pressure ducted type (FDU)  
Models All models



Meaning of marks

Mark	Parts name	Mark	Parts name	Mark	Parts name
FM1, 2	Fan motor (with thermostat)	TrI	Transformer	TB	Terminal block (○ mark)
CF1, 2	FMi condenser	SM	Stepping motor (For Exp.v)	52FL, FH	Electromagnetic contactor for FMi
FC	Fan controller	SW1	Indoor unit address tens digit	X1~3, 6	Auxiliary relay (For FM)
NF	Noise filter	SW2	Indoor unit address tens digit	XR1	Operation output (DC12V output)
FS	Float switch	SW3	Outdoor unit address tens digit	XR2	Heating output (DC12V output)
ThI-A	Thermistor	SW4	Outdoor unit address units digit	XR3	Thermo ON output (DC12V output)
ThI-R1	Thermistor	SW6	Model capacity selector	XR4	Inspection output (DC12V output)
ThI-R2	Thermistor	LED1	Indication lamp (Red)	XR5	Remote operation (volt-free contact)
ThI-R3	Thermistor	LED2	Indication lamp (Green)	CnA~Z	Connector
Thc	Thermistor	F	Fuse	■ mark	Closed-end connector

Color marks

Mark	Color	Mark	Color
BK	Black	RD/Y	Red/Yellow
BL	Blue	P	Pink
BR	Brown	WH	White
OR	Orange	Y	Yellow
OR/WH	Orange/White	Y/WH	Yellow/White
RD	Red	Y/GN	Yellow/Green

Function of switches

Mark	Function
SW5-3	ON Input Reverse Invalid
	OFF signal Run stop
SW5-4	ON Emergency stop signal:Invalid
	OFF Emergency stop signal:valid





① Set SW9-4 provided on the indoor unit PCB to ON.

② By means of function setting from the remote controller unit, set the setting ㉔ of "I/U FUNCTION▲" (indoor unit function) to "Hi CEILING 1" (high-speed tap).


Function number ㉑	Function description ㉒	Setting ㉓
01	Hi CEILING SET	Hi CEILING 1

### Function of switches

Mark		Function	
SW5-1	ON	Test run of condensate pump motor	
	OFF	Normal	
SW5-3	ON	Input	Reverse Invalid
	OFF	signal	Run stop
SW5-4	ON	Emergency stop signal:valid	
	OFF	Emergency stop signal:Invalid	

Mark	Color	Mark	Color
<b>BK</b>	Black	<b>OR</b>	Orange
<b>BL</b>	Blue	<b>RD</b>	Red
<b>BL/Y</b>	Blue/yellow	<b>RD/Y</b>	Red/Yellow
<b>BR</b>	Brown	<b>WH</b>	White
<b>BR/Y</b>	Brown/yellow	<b>Y</b>	Yellow
<b>GR</b>	Gray	<b>Y/GN</b>	Yellow/Green

Mark	Parts name	Mark	Parts name	Mark	Parts name
<b>FMI1,2</b>	Fan motor	<b>SW1</b>	Indoor unit address tens digit	<b>XR2</b>	Heating output(DC12V output)
<b>CFI1,2</b>	Capacitor for FMI	<b>SW2</b>	Indoor unit address units digit	<b>XR3</b>	Thermo ON output(DC12V output)
<b>DM</b>	Drain motor	<b>SW3</b>	Outdoor unit address tens digit	<b>XR4</b>	Inspection output(DC12V output)
<b>FS</b>	Float switch	<b>SW4</b>	Outdoor unit address units digit	<b>XR5</b>	Remote operation input(volt-free contact)
<b>SM</b>	Stepping motor(For Exp.v)	<b>SW6</b>	Model capacity setting	<b>X1,2,3,6</b>	Auxiliary relay(For FM)
<b>ThI-A</b>	Thermistor	<b>TrI</b>	Transformer	<b>X4</b>	Auxiliary relay(For DM)
<b>ThI-R1</b>	Thermistor	<b>F</b>	Fuse	<b>TB</b>	Terminal block(○ mark)
<b>ThI-R2</b>	Thermistor	<b>LED1</b>	Indication lamp(Red)	<b>CnA~Z</b>	Connector
<b>ThI-R3</b>	Thermistor	<b>LED2</b>	Indication lamp(Green)	<b>■mark</b>	Closed-end connector
<b>ThC</b>	Thermistor	<b>XR1</b>	Operation output(DC12V output)		



② By means of function setting from the remote controller unit, set the setting ③ of "I/U FUNCTION▲" (indoor unit function) to "Hi CEILING 1" (high-speed tap).

- | Function number ㉠ | Function description ㉢ | Setting ㉣    |
|-------------------|------------------------|--------------|
| 01                | Hi CEILING SET         | Hi CEILING 1 |

## Meaning of marks


### Color marks

Mark	Color	Mark	Color
<b>BK</b>	Black	<b>RD</b>	Red
<b>BL</b>	Blue	<b>WH</b>	White
<b>BR</b>	Brown	<b>Y</b>	Yellow
<b>GR</b>	Gray	<b>Y/GN</b>	Yellow/Green
<b>OR</b>	Orange		

### Function of switches

Mark		Function	
SW5-1	ON	Test run of condensate pump motor	
	OFF	Normal	
SW5-3	ON	Input	Reverse Invalid
	OFF	signal	Run stop
SW5-4	ON	Emergency stop signal:valid	
	OFF	Emergency stop signal:Invalid	

(I) Ceiling suspended type (FDE)  
Models All models



Note(1) \*1. FMI2 is equipped only for 71,112,140.

Meaning of marks

Mark	Parts name	Mark	Parts name	Mark	Parts name
<b>FMI1,2</b>	Fan motor	<b>SW2</b>	Indoor unit address units digit	<b>XR3</b>	Thermo ON output(DC12V output)
<b>CF1,2</b>	Capacitor for FMI	<b>SW3</b>	Outdoor unit address tens digit	<b>XR4</b>	Inspection output(DC12V output)
<b>LM</b>	Louver motor	<b>SW4</b>	Outdoor unit address units digit	<b>XR5</b>	Remote operation input(volt-free contact)
<b>SM</b>	Stepping motor(For Exp.v)	<b>SW6</b>	Model capacity setting	<b>X1,2,3,6</b>	Auxiliary relay(For FM)
<b>ThI-A</b>	Thermistor	<b>TrI</b>	Transformer	<b>TB1,2</b>	Terminal block(○ mark)
<b>ThI-R1</b>	Thermistor	<b>F</b>	Fuse	<b>CnA~Z</b>	Connector
<b>ThI-R2</b>	Thermistor	<b>LED1</b>	Indication lamp(Red)	<b>■mark</b>	Closed-end connector
<b>ThI-R3</b>	Thermistor	<b>LED2</b>	Indication lamp(Green)		
<b>ThC</b>	Thermistor	<b>XR1</b>	Operation output(DC12V output)		
<b>SW1</b>	Indoor unit address tens digit	<b>XR2</b>	Heating output(DC12V output)		


Color marks

Mark	Color	Mark	Color
<b>BK</b>	Black	<b>WH</b>	White
<b>BL</b>	Blue	<b>Y</b>	Yellow
<b>BR</b>	Brown	<b>P</b>	Pink
<b>OR</b>	Orange	<b>Y/GN</b>	Yellow/Green
<b>RD</b>	Red		

Function of switches

Mark	Function
<b>SW5-3</b>	ON Input Reverse Invalid
	OFF signal Run stop
<b>SW5-4</b>	ON Emergency stop signal:valid
	OFF Emergency stop signal:Invalid

(k) Wall mounted type (FDK)  
Models FDKA22KXE4R, 28KXE4R, 36KXE4R, 45KXE4R, 56KXE4R



**Meaning of marks**


Mark	Parts name	Mark	Parts name	Mark	Parts name
FMI	Fan motor	SW3	Outdoor unit address tens digit	XR4	Inspection output(DC12V output)
LM	Louver motor	SW4	Outdoor unit address units digit	XR5	Remote operation input(volt-free contact)
SM	Stepping motor(For Exp.v)	SW6	Model capacity setting	TB	Terminal block(○ mark)
ThI-A	Thermistor	TrI	Transformer	CnA~Z	Connector
ThI-R1	Thermistor	F	Fuse	■mark	Closed-end connector
ThI-R2	Thermistor	LED1	Indication lamp(Red)		
ThI-R3	Thermistor	LED2	Indication lamp(Green)		
ThC	Thermistor	XR1	Operation output(DC12V output)		
SW1	Indoor unit address tens digit	XR2	Heating output(DC12V output)		
SW2	Indoor unit address units digit	XR3	Thermo ON output(DC12V output)		

**Color marks**

Mark	Color	Mark	Color
BK	Black	WH	White
BL	Blue	Y	Yellow
BR	Brown	P	Pink
OR	Orange	Y/GN	Yellow/Green
RD	Red		

**Function of switches**

Mark	Function
SW5-3	ON Input Reverse Invalid
	OFF signal Run stop
SW5-4	ON Emergency stop signal:valid
	OF Emergency stop signal:Invalid




## Function of switches

### Color marks

Mark	Color
BK	Black
BL	Blue
BR	Brown
OR	Orange
RD	Red
WH	White
Y	Yellow
P	Pink
Y/GN	Yellow/green

(l) Floor standing exposed type (FDFL)  
(m) Floor standing hidden type (FDFU)  
Models All models



Meaning of marks

Mark	Parts name	Mark	Parts name	Mark	Parts name
<b>FMI</b>	Fan motor	<b>SW2</b>	Indoor unit address units digit	<b>XR2</b>	Heating output(DC12V output)
<b>CFI</b>	Capacitor for FMI	<b>SW3</b>	Outdoor unit address tens digit	<b>XR3</b>	Thermo ON output(DC12V output)
<b>SM</b>	Stepping motor(For Exp.v)	<b>SW4</b>	Outdoor unit address units digit	<b>XR4</b>	Inspection output(DC12V output)
<b>Thl-A</b>	Thermistor	<b>SW6</b>	Model capacity setting	<b>XR5</b>	Remote operation input(volt-free contact)
<b>Thl-R1</b>	Thermistor	<b>Trl</b>	Transformer	<b>X1,2,3,6</b>	Auxiliary relay(For FM)
<b>Thl-R2</b>	Thermistor	<b>F</b>	Fuse	<b>TB</b>	Terminal block(○ mark)
<b>Thl-R3</b>	Thermistor	<b>LED1</b>	Indication lamp(Red)	<b>CnA~Z</b>	Connector
<b>ThC</b>	Thermistor	<b>LED2</b>	Indication lamp(Green)	<b>■mark</b>	Closed-end connector
<b>SW1</b>	Indoor unit address tens digit	<b>XR1</b>	Operation output(DC12V output)		


Color marks

Mark	Color	Mark	Color
<b>BK</b>	Black	<b>RD/Y</b>	Red/Yellow
<b>BL</b>	Blue	<b>WH</b>	White
<b>BR</b>	Brown	<b>Y</b>	Yellow
<b>OR</b>	Orange	<b>Y/GN</b>	Yellow/Green
<b>RD</b>	Red		

Function of switches


Mark	Function
<b>ON</b>	Emergency stop signal : Valid
<b>SW5-4</b>	OFF Emergency stop signal : Invalid

(2) Branching controller (Heat recovery type only)  
**Models PFD112-ER, 180-ER, 280-ER**



4 way valve	4-way valve for switching between cooling and heating.
SVH	Solenoid valve for heating
SVG	Solenoid valve for oil return
XR1	Relay for operation output
X1,XR2	Relay for heating output
X2,X3,XR3	Operating mode switching
XR4	Check output
CnB~U	Connector

- Notes 1. This diagram shows the circuit diagram when the branch flow controller and relay kit (product with a branching controller attached) is connected.
2. ——— shows the current wiring.
3. The option shows when the remote start/stop/monitoring kit is connected.



4 way valve	4 way valve for switching between cooling and heating
SVH	Solenoid valve for heating
SVG	Solenoid valve for oil return
XR1	Relay for operation output
X1,XR2	Relay for heating output
X2,X3,XR3	Operating mode switching
XR4	Check output
CnB~U	Connector

Remarks: 1. This figure indicates the circuit diagram of connecting 4 branching controllers and 4 relay kits (branching controller accessories) respectively.  
 2. --- indicates the field wiring.  
 3. Connect the signal line between a branching controller and an indoor unit to the connector of the corresponding refrigerant system.

(3) Integrated branching controller (Heat recovery type only)  
 Models PFD112X4-ER



## 4 COMMON MATTER

### 4.1 Operation chart

Since the Multi KX or KXR series air conditioner units are free multitype to which the indoor units of different capacity and different model can be connected, the operation characteristics of all combinations are very complicated, therefore only the individual operation characteristics of indoor and outdoor units are shown.

#### (a) Operating characteristic of outdoor unit

##### (i) KX Series

##### 1) All-in-one type

(220-240V 50Hz)

(380-415V 50Hz/380V 60Hz)

Models		FDCA140HKXEN4R	FDCA140HKXES4R <sup>(2)</sup>
Item			
Cooling power consumption	kW	4.20-4.20	4.20-4.20/4.20
Heating power consumption		4.45-4.45	4.45-4.45/4.45
Cooling running current	A	21.2-19.4	6.87-6.29/6.87
Heating running current		22.5-20.6	7.27-6.64/7.27
Inrush current (MAX.)	A	5	
Cooling power factor	%	90-90	93-93/93
Heating power factor		90-90	93-93/93

(380-415V 50Hz/380V 60Hz)

Models		FDCA160HKXES4R <sup>(2)</sup>	FDCA224HKXE4R
Item			
Cooling power consumption	kW	5.46-5.46/5.46	5.70-5.70/5.70
Heating power consumption		4.90-4.90/4.90	5.98-5.98/5.98
Cooling running current	A	8.91-8.17/8.91	9.6-8.8/9.6
Heating running current		8.00-7.33/8.00	9.6-8.8/9.6
Inrush current (MAX.)	A	5	
Cooling power factor	%	93-93/93	90-90/90
Heating power factor		93-93/93	95-95/95

(380-415V 50Hz/380V 60Hz)

Models		FDCA280HKXE4R	FDCA335HKXE4R
Item			
Cooling power consumption	kW	8.26-8.26/8.26	9.53-9.53/9.53
Heating power consumption		8.06-8.06/8.06	9.84-9.84/9.84
Cooling running current	A	13.6-12.4/13.6	15.4-14.2/15.4
Heating running current		13.3-12.2/13.3	16.3-14.9/16.3
Inrush current (MAX.)	A	5	
Cooling power factor	%	92-93/92	93-93/93
Heating power factor		92-92/92	92-92/92

Notes (1) This packaged air-conditioner is manufactured and tested in conformity with the following standard.

ISO-T1 "UNITARY AIR-CONDITIONERS"

(2) In the case of 60 Hz, use specification category (T). (FDCA140, 160HKXES4R only)

##### 2) All-in-one type (also for combined use)

(380-415V 50Hz/380V 60Hz)

Models		FDCA400HKXE4R	FDCA450HKXE4R
Item			
Cooling power consumption	kW	11.27-11.27/11.27	12.97-12.97/12.97
Heating power consumption		11.73-11.73/11.73	13.10-13.10/13.10
Cooling running current	A	18.4-16.9/18.4	21.1-19.3/21.1
Heating running current		19.6-17.9/19.6	21.7-19.9/21.7
Inrush current (MAX.)	A	8	
Cooling power factor	%	93-93/93	93-93/93
Heating power factor		91-91/91	92-92/92

Note (1) This packaged air-conditioner is manufactured and tested in conformity with the following standard.

ISO-T1 "UNITARY AIR-CONDITIONERS"

(380-415V 50Hz/380V 60Hz)

Models		FDCA504HKXE4R	FDCA560HKXE4R
Item			
Cooling power consumption	kW	14.73-14.73/14.73	17.21-17.21/17.21
Heating power consumption		15.15-15.15/15.15	17.07-17.07/17.07
Cooling running current	A	24.1-22.0/24.1	28.2-25.8/28.2
Heating running current		25.2-23.1/25.2	28.5-26.1/28.5
Inrush current (MAX.)	A	8	
Cooling power factor	%	93-93/93	
Heating power factor		91-91/91	

(380-415V 50Hz/380V 60Hz)

Models		FDCA615HKXE4R	FDCA680HKXE4R
Item			
Cooling power consumption	kW	20.37-20.37/20.37	24.98-24.98/24.98
Heating power consumption		18.48-18.48/18.48	19.08-19.08/19.08
Cooling running current	A	33.1-30.3/33.1	40.3-36.9/40.3
Heating running current		30.7-28.1/30.7	31.6-29.0/31.6
Inrush current (MAX.)	A	8	
Cooling power factor	%	94-94/94	
Heating power factor		91-91/91	92-92/92

Note (1) This packaged air-conditioner is manufactured and tested in conformity with the following standard.  
ISO-T1 "UNITARY AIR-CONDITIONERS"

## 2) Combined type

(380-415V 50Hz/380V 60Hz)

Models		FDCA735HKXE4R	FDCA800HKXE4R
Item		FDCA335HKXE4R-K	FDCA400HKXE4R
Nominal cooling capacity	kW	73.5	80.0
Nominal heating capacity		82.5	90.0
Cooling power consumption	kW	20.21-20.21/20.21	22.54-22.54/22.54
Heating power consumption		20.66-20.66/20.66	23.46-23.46/23.46
Cooling running current	A	32.9-30.2/32.9	36.8-33.8/36.8
Heating running current		34.4-31.4/34.4	39.2-35.8/39.2
Inrush current (MAX.)	A	16	
Cooling power factor	%	93-93/93	93-93/93
Heating power factor		91-91/91	91-91/91

(380-415V 50Hz/380V 60Hz)

Models		FDCA850HKXE4R	FDCA900HKXE4R
Item		FDCA400HKXE4R	FDCA450HKXE4R
Nominal cooling capacity	kW	85.0	90.0
Nominal heating capacity		95.0	100.0
Cooling power consumption	kW	24.22-24.22/24.22	25.94-25.94/25.94
Heating power consumption		24.83-24.83/24.83	26.2-26.2/26.2
Cooling running current	A	39.5-36.2/39.5	42.2-38.6/42.2
Heating running current		41.3-37.8/41.3	43.4-39.8/43.8
Inrush current (MAX.)	A	16	
Cooling power factor	%	93-93/93	94-93/94
Heating power factor		92-92/92	92-92/92

Note (1) This packaged air-conditioner is manufactured and tested in conformity with the following standard.  
ISO-T1 "UNITARY AIR-CONDITIONERS"

(380-415V 50Hz/380V 60Hz)

Models		FDCA960HKXE4R		FDCA1010HKXE4R	
		FDCA450HKXE4R	FDCA504HKXE4R	FDCA504HKXE4R	FDCA504HKXE4R
Item					
Nominal cooling capacity	kW	96.0		101.0	
Nominal heating capacity		108.0		113.0	
Cooling power consumption	kW	27.70-27.70/27.70		29.46-29.46/29.46	
Heating power consumption		28.25-28.25/28.25		30.30-30.30/30.30	
Cooling running current	A	45.1-41.3/45.1		48.2-44.0/48.2	
Heating running current		46.9-43.0/46.9		50.4-46.2/50.4	
Inrush current (MAX.)	A	16			
Cooling power factor	%	93-93/93			
Heating power factor		92-92/92		91-91/91	

(380-415V 50Hz/380V 60Hz)

Models		FDCA1065HKXE4R		FDCA1130HKXE4R	
		FDCA504HKXE4R	FDCA560HKXE4R	FDCA560HKXE4R	FDCA560HKXE4R
Item					
Nominal cooling capacity	kW	106.5		113.0	
Nominal heating capacity		119.5		127.0	
Cooling power consumption	kW	31.93-31.93/31.93		34.41-34.41/34.41	
Heating power consumption		32.21-32.21/32.21		34.13-34.13/34.13	
Cooling running current	A	52.3-47.8/52.3		56.4-51.6/56.4	
Heating running current		53.7-49.2/53.7		57.0-52.2/57.0	
Inrush current (MAX.)	A	16			
Cooling power factor	%	93-93/93			
Heating power factor		91-91/91			

(380-415V 50Hz/380V 60Hz)

Models		FDCA1180HKXE4R		FDCA1235HKXE4R	
		FDCA560HKXE4R	FDCA615HKXE4R	FDCA615HKXE4R	FDCA615HKXE4R
Item					
Nominal cooling capacity	kW	118.0		123.5	
Nominal heating capacity		132.0		138.0	
Cooling power consumption	kW	37.57-37.57/37.57		40.74-40.74/40.74	
Heating power consumption		35.54-35.54/35.54		36.96-36.96/36.96	
Cooling running current	A	61.3-56.1/61.3		66.2-60.6/66.2	
Heating running current		59.2-54.2/59.2		61.4-56.2/61.4	
Inrush current (MAX.)	A	16			
Cooling power factor	%	93-93/93		94-94/94	
Heating power factor		91-91/91			

(380-415V 50Hz/380V 60Hz)

Models		FDCA1300HKXE4R		FDCA1360HKXE4R	
		FDCA615HKXE4R	FDCA680HKXE4R	FDCA680HKXE4R	FDCA680HKXE4R
Item					
Nominal cooling capacity	kW	130.0		136.0	
Nominal heating capacity		142.0		146.0	
Cooling power consumption	kW	45.35-45.35/45.35		49.96-49.96/49.96	
Heating power consumption		37.56-37.56/37.56		38.16-38.16/38.16	
Cooling running current	A	73.4-67.2/73.4		80.6-73.8/80.6	
Heating running current		62.3-57.1/62.3		63.2-58.0/63.2	
Inrush current (MAX.)	A	16			
Cooling power factor	%	94-94/94			
Heating power factor		92-92/92			

Note (1) This packaged air-conditioner is manufactured and tested in conformity with the following standard.  
ISO-T1 "UNITARY AIR-CONDITIONERS"

**(ii) KXR Series****1) All-in-one type**

(380-415V 50Hz/380V 60Hz)

Models		FDCA224HKXRE4R	FDCA280HKXRE4R	FDCA335HKXRE4R
Item				
Cooling power consumption	kW	6.66-6.66/6.66	9.23-9.23/9.23	10.17-10.17/10.17
Heating power consumption		6.33-6.33/6.33	8.97-8.97/8.97	10.34-10.34/10.34
Cooling running current	A	10.1-9.2/10.1	14.7-13.4/14.7	16.5-15.1/16.5
Heating running current		9.8-9.0/9.8	14.2-13.0/14.2	17.1-15.6/17.1
Inrush current (MAX.)	A	5		
Cooling power factor	%	99-99/99	95-96/95	94-94/94
Heating power factor		98-98/98	96-96/96	92-92/92

Note (1) This packaged air-conditioner is manufactured and tested in conformity with the following standard.  
ISO-T1 "UNITARY AIR-CONDITIONERS"

**2) All-in-one type (also for combined use)**

(380-415V 50Hz/380V 60Hz)

Models		FDCA400HKXRE4R	FDCA450HKXRE4R
Item			
Cooling power consumption	kW	11.61-11.61/11.61	13.57-13.57/13.57
Heating power consumption		12.18-12.18/12.18	13.55-13.55/13.55
Cooling running current	A	19.0-17.4/19.0	21.6-19.8/21.6
Heating running current		20.3-18.6/20.3	22.4-20.5/22.4
Inrush current (MAX.)	A	8	
Cooling power factor	%	93-93/93	95-95/95
Heating power factor		91-91/91	92-92/92

(380-415V 50Hz/380V 60Hz)

Models		FDCA504HKXRE4R	FDCA560HKXRE4R
Item			
Cooling power consumption	kW	15.69-15.69/15.69	18.76-18.76/18.76
Heating power consumption		15.62-15.62/15.62	17.69-17.69/17.69
Cooling running current	A	24.6-22.5/24.6	29.7-27.2/29.7
Heating running current		26.1-23.9/26.1	29.5-27.0/29.5
Inrush current (MAX.)	A	8	
Cooling power factor	%	97-97/97	96-96/96
Heating power factor		91-91/91	

(380-415V 50Hz/380V 60Hz)

Models		FDCA615HKXRE4R	FDCA680HKXRE4R
Item			
Cooling power consumption	kW	21.47-21.47/21.47	25.99-25.99/25.99
Heating power consumption		19.11-19.11/19.11	19.69-19.69/19.69
Cooling running current	A	34.7-31.8/34.7	44.9-41.1/44.9
Heating running current		31.6-28.9/31.6	34.0-31.1/34.0
Inrush current (MAX.)	A	8	
Cooling power factor	%	94-94/94	88-88/88
Heating power factor		92-92/92	88-88/88

Note (1) This packaged air-conditioner is manufactured and tested in conformity with the following standard.  
ISO-T1 "UNITARY AIR-CONDITIONERS"

## 2) Combined type

(380-415V 50Hz/380V 60Hz)

Models		FDCA735HKXRE4R		FDCA800HKXRE4R	
		FDCA335HKXRE4R-K	FDCA400HKXRE4R	FDCA400HKXRE4R	FDCA400HKXRE4R
Item					
Nominal cooling capacity	kW	73.5		80.0	
Nominal heating capacity		82.5		90.0	
Cooling power consumption	kW	21.08-21.08/21.08		23.22-23.22/23.22	
Heating power consumption		21.55-21.55/21.55		24.36-24.36/24.36	
Cooling running current	A	34.4-31.5/34.4		38.0-34.8/38.0	
Heating running current		35.8-32.8/35.8		40.6-37.2/40.6	
Inrush current (MAX.)	A	16			
Cooling power factor	%	93-93/93		93-93/93	
Heating power factor		92-92/92		91-91/91	

(380-415V 50Hz/380V 60Hz)

Models		FDCA850HKXRE4R		FDCA900HKXRE4R	
		FDCA400HKXRE4R	FDCA450HKXRE4R	FDCA450HKXRE4R	FDCA450HKXRE4R
Item					
Nominal cooling capacity	kW	85.0		90.0	
Nominal heating capacity		95.0		100.0	
Cooling input	kW	25.18-25.18/25.18		27.14-27.14/27.14	
Heating input		25.73-25.73/25.73		27.1-27.1/27.1	
Cooling running current	A	40.6-37.3/40.6		43.2-39.6/43.2	
Heating running current		42.7-39.1/42.7		44.8-41.0/44.8	
Inrush current (MAX.)	A	16			
Cooling power factor	%	94-94/94		95-95/95	
Heating power factor		92-92/92		92-92/92	

(380-415V 50Hz/380V 60Hz)

Models		FDCA960HKXRE4R		FDCA1010HKXRE4R	
		FDCA450HKXRE4R	FDCA504HKXRE4R	FDCA504HKXRE4R	FDCA504HKXRE4R
Item					
Nominal cooling capacity	kW	96.0		101.0	
Nominal heating capacity		108.0		113.0	
Cooling power consumption	kW	29.26-29.26/29.26		31.88-31.88/31.88	
Heating power consumption		29.17-29.17/29.17		31.24-31.24/31.24	
Cooling running current	A	46.2-42.3/46.2		49.2-45.0/49.2	
Heating running current		48.5-44.4/48.5		52.2-47.8/52.2	
Inrush current (MAX.)	A	16			
Cooling power factor	%	96-96/96		98-99/98	
Heating power factor		91-91/91			

(380-415V 50Hz/380V 60Hz)

Models		FDCA1065HKXRE4R		FDCA1130HKXRE4R	
		FDCA504HKXRE4R	FDCA560HKXRE4R	FDCA560HKXRE4R	FDCA560HKXRE4R
Item					
Nominal cooling capacity	kW	106.5		113.0	
Nominal heating capacity		119.5		127.0	
Cooling power consumption	kW	34.45-34.45/34.45		37.52-37.52/37.52	
Heating power consumption		33.31-33.31/33.31		35.38-35.38/35.38	
Cooling running current	A	54.3-49.7/54.3		59.4-54.4/59.4	
Heating running current		55.6-50.9/55.6		59.0-54.0/59.0	
Inrush current (MAX.)	A	16			
Cooling power factor	%	96-96/96			
Heating power factor		91-91/91			

Note (1) This packaged air-conditioner is manufactured and tested in conformity with the following standard.  
ISO-T1 "UNITARY AIR-CONDITIONERS"

(380-415V 50Hz/380V 60Hz)

Models		FDCA1180HKXRE4R		FDCA1235HKXRE4R	
		FDCA560HKXRE4R	FDCA615HKXRE4R	FDCA615HKXRE4R	FDCA615HKXRE4R
Item					
Nominal cooling capacity	kW	118.0		123.5	
Nominal heating capacity		132.0		138.0	
Cooling power consumption	kW	40.23-40.23/40.23		42.94-42.94/42.94	
Heating power consumption		36.80-36.80/36.80		38.22-38.22/38.22	
Cooling running current	A	64.4-59.0/64.4		69.4-63.6/69.4	
Heating running current		61.1-55.9/61.1		63.2-57.8/63.2	
Inrush current (MAX.)	A	16			
Cooling power factor	%	95-95/95		94-94/94	
Heating power factor		92-92/92			

(380-415V 50Hz/380V 60Hz)

Models		FDCA1300HKXRE4R		FDCA1360HKXRE4R	
		FDCA615HKXRE4R	FDCA680HKXRE4R	FDCA680HKXRE4R	FDCA680HKXRE4R
Item					
Nominal cooling capacity	kW	130.0		136.0	
Nominal heating capacity		142.0		146.0	
Cooling power consumption	kW	47.46-47.46/47.46		51.98-51.98/51.98	
Heating power consumption		38.80-38.80/38.80		39.38-39.38/39.38	
Cooling running current	A	79.6-72.9/79.6		89.8-82.2/89.8	
Heating running current		65.6-60.0/65.6		68.0-62.2/68.0	
Inrush current (MAX.)	A	16			
Cooling power factor	%	91-91/91		88-88/88	
Heating power factor		90-90/90		88-88/88	

Note (1) This packaged air-conditioner is manufactured and tested in conformity with the following standard.  
ISO-T1 "UNITARY AIR-CONDITIONERS"

## (iii) Operating characteristic of indoor unit

## FDTC Series

(220-240V 50Hz/220V 60Hz)

Models		FDTC Series				
		22	28	36	45	56
Power consumption (kW)		0.027-0.027/0.027		0.034-0.034/0.034	0.043-0.043/0.043	0.046-0.046/0.046
Running current (A)		0.10-0.09/0.10		0.11-0.10/0.11	0.15-0.13/0.15	0.15-0.13/0.15

## FDT Series

(220-240V 50Hz/220V 60Hz)

Models		FDT Series					
		28	36	45	56	71	90
Power consumption (kW)		Cooling : 0.050-0.059/0.061 Heating : 0.046-0.054/0.056				Cooling : 0.064-0.073/0.077 Heating : 0.058-0.067/0.070	Cooling : 0.059-0.059/0.059 Heating : 0.056-0.056/0.056
Running current (A)		Cooling : 0.24-0.25/0.30 Heating : 0.22-0.23/0.28				Cooling : 0.31-0.32/0.40 Heating : 0.29-0.30/0.36	Cooling : 0.20-0.17/0.20 Heating : 0.19-0.17/0.19

(220-240V 50Hz/220V 60Hz)

Models		FDT Series	
		112	140
Power consumption (kW)		Cooling : 0.081-0.081/0.081 Heating : 0.077-0.077/0.077	Cooling : 0.090-0.090/0.090 Heating : 0.086-0.086/0.086
Running current (A)		Cooling : 0.26-0.24/0.26 Heating : 0.25-0.23/0.25	Cooling : 0.29-0.26/0.29 Heating : 0.28-0.25/0.28

## FDTW Series

(28 ~ 56: 220-240V 50Hz/220V 60Hz, 71 ~ 140: 220V/240V 50Hz)

Models		FDTW Series						
		28	45	56	71	90	112	140
Power consumption (kW)		0.09-0.10/0.09			0.10/0.11	0.12/0.13	0.18/0.20	0.20/0.24
Running current (A)		0.43-0.44/0.43			0.48/0.50	0.57/0.59	0.86/0.89	0.90/0.98

Notes (1) This packaged air-conditioner is manufactured and tested in conformity with the following standard.  
ISO-T1 "UNITARY AIR-CONDITIONERS"

(2) The values shown in the above table are common to both cooling and heating operations.

**FDTQ Series**

(220-240V 50Hz/220V 60Hz)

Models	FDTQ Series(Direct blow panel)			FDTQ Series(Duct panel)		
	22	28	36	22	28	36
Power consumption (kW)	0.045-0.050/0.047			0.050-0.055/0.053		
Running current (A)	0.21-0.22/0.22			0.23-0.24/0.26		

**FDTs Series**

(220-240V 50Hz)

Models	FDTs Series				
	22	28	36	45	71
Power consumption (kW)	0.07-0.08			0.09-0.11	0.12-0.15
Running current (A)	0.33-0.36			0.43-0.46	0.58-0.63

**FDQM, FDUM Series**

(220-240V 50Hz)

Models	FDQM Series			FDUM Series					
	22	28	36	36	45, 56	71	90	112	140
Power consumption (kW)	0.050-0.055			0.11-0.13	0.14-0.16	0.15-0.17	0.16-0.19	0.24-0.28	0.28-0.32
Running current (A)	0.23-0.24			0.51-0.56	0.63-0.67	0.68-0.71	0.73-0.79	1.07-1.17	1.28-1.32

**FDE Series**

(220-240V 50Hz/220V 60Hz)

Models	FDE Series				
	36	45	56	71	112
Power consumption (kW)	Cooling : 0.043-0.049/0.049 Heating : 0.039-0.045/0.045			Cooling : 0.082-0.092/0.088 Heating : 0.074-0.084/0.081	Cooling : 0.124-0.141/0.14 Heating : 0.113-0.129/0.128
Running current (A)	Cooling : 0.19-0.20/0.23 Heating : 0.18-0.19/0.21			Cooling : 0.37-0.38/0.41 Heating : 0.34-0.35/0.37	Cooling : 0.56-0.59/0.65 Heating : 0.52-0.54/0.59

(220-240V 50Hz/220V 60Hz)

Models	FDE Series
	140
Power consumption (kW)	Cooling : 0.137-0.154/0.158 Heating : 0.125-0.141/0.145
Running current (A)	Cooling : 0.62-0.65/0.73 Heating : 0.57-0.59/0.67

**FDU Series**

(220-240V 50Hz)

Models	FDU Series	
	224	280
Power consumption (kW)	Cooling : 0.46-0.56 Heating : 0.42-0.49	Cooling : 0.7-0.75 Heating : 0.64-0.66
Running current (A)	Cooling : 2.3-2.5 Heating : 2.0-2.1	Cooling : 3.5-3.4 Heating : 3.2-3.0

**FDK, FDFL, FDFU Series**

(220-240V 50Hz)

Models	FDK Series						FDFL, FDFU Series		
	22	28	36	45	56	71	28	45, 56	71
Power consumption (kW)	Cooling : 0.05-0.05 Heating : 0.04-0.05			0.05-0.05		0.09-0.11	0.09-0.10	0.09-0.10	0.09-0.10
Running current (A)	0.23-0.21			0.23-0.21		0.41-0.48	0.41-0.42	0.41-0.42	0.41-0.42

**FDUR Series**

(220-240V 50Hz)

Models	FDUR Series					
	45	56	71	90	112	140
Power consumption (kW)	Cooling : 0.15-0.17 Heating : 0.14-0.16	Cooling : 0.21-0.24 Heating : 0.20-0.23	Cooling : 0.29-0.32 Heating : 0.27-0.30	Cooling : 0.35-0.39 Heating : 0.34-0.38	Cooling : 0.39-0.45 Heating : 0.34-0.39	
Running current (A)	Cooling : 0.69-0.73 Heating : 0.67-0.70	Cooling : 0.97-1.02 Heating : 0.95-1.00	Cooling : 1.40-1.44 Heating : 1.33-1.37	Cooling : 1.65-1.79 Heating : 1.63-1.74	Cooling : 1.83-1.94 Heating : 1.65-1.76	

Notes (1) This packaged air-conditioner is manufactured and tested in conformity with the following standard.

ISO-T1 "UNITARY AIR-CONDITIONERS"

(2) The values shown in the above table are common to both cooling and heating operations.






## 4.2 Range of usage & limitations

- (1) KX series  
(a) All-in-one type


System		FDCA140HKXEN4R, 140HKXES4R		FDCA160HKXES4R
Item		Refer to the Selection chart. (See page 166)		
Indoor intake air temperature (Upper, lower limits)				
Outdoor air temperature (Upper, lower limits)				
Indoor units that can be used in combination	Number of connected units	2 to 6 units	2 to 8 units	2 to 8 units
	Total capacity	112 ~ 210	112 ~ 182	128 ~ 208
Total Piping Length (Total of the lengths of all piping)		MAX. 100m		
Maximum Piping Distance (From outdoor unit to farthest indoor unit)		Indoor unit MAX. 70m		
Total length of ø9.52 liquid pipe		Within 50 m		
Difference in height between indoor and outdoor units	Outdoor unit is higher	MAX. 30m		
	Outdoor unit is lower	MAX. 15m		
Difference in height between indoor units		MAX. 4m		
Indoor unit atmosphere (behind ceiling) temperature and humidity		Dew point temperature 28 °C or less, relative humidity 80% or less		
Compressor stop/start frequency	1 cycle time	7 min or more (4 minutes or more from start to stop or 3 minutes or more from stop to start)		
	Stop time	3 min or more		
Power source voltage	Voltage fluctuation	Within ±10% of rated voltage		
	Voltage drop during start	Within ±15% of rated voltage		
	Phase unbalance	Within ±3% of rated voltage		

Allowable length of refrigerant piping, height difference between indoor and outdoor unit

### (1) Branch pipe method (using branch piping)



### (2) Header System (Header used)




Note (1) There is no limit to the permissible piping lengths for the main pipes or other piping, but keep furthest indoor unit piping to 50 m with a diameter of ø9.52.

(2) A branch piping system cannot be connected after a header system.


System		FDCA224HKXE4R	FDCA280HKXE4R	FDCA335HKXE4R
Item				
Indoor intake air temperature (Upper, lower limits)		Refer to the Selection chart. (See page 167)		
Outdoor air temperature (Upper, lower limits)				
Indoor units that can be used in combination	Number of connected units	1 to 13 units	1 to 16 units	1 to 20 units
	Total capacity	112 ~ 292	140 ~ 364	168 ~ 436
Total piping length		MAX. 510m		
Single direction piping length		Indoor unit MAX. 160m		
Outdoor unit to first branch (main piping)		Max. 130m		
Piping length after the first branch		Max. 40m		
Difference in height between indoor and outdoor units	Outdoor unit is higher	MAX. 50m		
	Outdoor unit is lower	MAX. 40m		
Difference in height between indoor units		MAX. 15m		
Permissible height difference between the first branch and the indoor unit				
Indoor unit atmosphere (behind ceiling) temperature and humidity		Dew point temperature 28 ℃ or less, relative humidity 80% or less		
Compressor stop/start frequency	1 cycle time	7 min or more (4 minutes or more from start to stop or 3 minutes or more from stop to start)		
	Stop time	3 min or more		
Power source voltage	Voltage fluctuation	Within ±10% of rated voltage		
	Voltage drop during start	Within ±15% of rated voltage		
	Phase unbalance	Within ±3% of rated voltage		

Allowable length of refrigerant piping, height difference between indoor and outdoor unit

### (1) Branch pipe method (using branch piping)



### (2) Header System (Header used)




Note (1) A branch piping system cannot be connected after a header system.

(b) All-in-one type (also for combined use)


System		FDCA400HKXE4R	FDCA450HKXE4R	FDCA504HKXE4R
Item	Indoor intake air temperature (Upper, lower limits)	Refer to the Selection chart. (See page 167)		
	Outdoor air temperature (Upper, lower limits)			
Indoor units that can be used in combination	Number of connected units	1 to 23 unit	1 to 26 unit	1 to 29 unit
	Total capacity	200 ~ 520	225 ~ 585	252 ~ 656
Total piping length		MAX. 510m		
Single direction piping length		Indoor unit MAX. 160m		
Outdoor unit to first branch (main piping)		Max. 130m		
Piping length after the first branch		Max. 40m		
Permissible height difference between the first branch and the indoor unit		Max. 15m		
Difference in height between indoor and outdoor units	Outdoor unit is higher	MAX. 50m		
	Outdoor unit is lower	MAX. 40m		
Difference in height between indoor units		MAX. 15m		
Indoor unit atmosphere (behind ceiling) temperature and humidity		Dew point temperature 28 °C or less, relative humidity 80% or less		
Compressor stop/start frequency	1 cycle time	7 min or more (4 minutes or more from start to stop or 3 minutes or more from stop to start)		
	Stop time	3 min or more		
Power source voltage	Voltage fluctuation	Within $\pm 10\%$ of rated voltage		
	Voltage drop during start	Within $\pm 15\%$ of rated voltage		
	Phase unbalance	Within $\pm 3\%$ of rated voltage		

Allowable length of refrigerant piping, height difference between indoor and outdoor unit

(1) Branch pipe method (using branch piping)



(2) Header System (Header used)




Note (1) A branch piping system cannot be connected after a header system.


System		FDCA560HKXE4R	FDCA615HKXE4R	FDCA680HKXE4R
Item				
Indoor intake air temperature (Upper, lower limits)		Refer to the Selection chart. (See page 167)		
Outdoor air temperature (Upper, lower limits)				
Indoor units that can be used in combination	Number of connected units	1 to 33 unit	2 to 36 unit	2 to 40 unit
	Total capacity	280 ~ 728	307 ~ 800	340 ~ 884
Total piping length		MAX. 510m		
Single direction piping length		Indoor unit MAX. 160m		
Outdoor unit to first branch (main piping)		Max. 130m		
Piping length after the first branch		Max. 40m		
Permissible height difference between the first branch and the indoor unit		Max. 15m		
Difference in height between indoor and outdoor units	Outdoor unit is higher	MAX. 50m		
	Outdoor unit is lower	MAX. 40m		
Difference in height between indoor units		MAX. 15m		
Indoor unit atmosphere (behind ceiling) temperature and humidity		Dew point temperature 28 °C or less, relative humidity 80% or less		
Compressor stop/start frequency	1 cycle time	7 min or more (4 minutes or more from start to stop or 3 minutes or more from stop to start)		
	Stop time	3 min or more		
Power source voltage	Voltage fluctuation	Within $\pm 10\%$ of rated voltage		
	Voltage drop during start	Within $\pm 15\%$ of rated voltage		
	Phase unbalance	Within $\pm 3\%$ of rated voltage		

Allowable length of refrigerant piping, height difference between indoor and outdoor unit

### (1) Branch pipe method (using branch piping)



### (2) Header System (Header used)




Note (1) A branch piping system cannot be connected after a header system.

### (c) Combined type


System		FDCA735HKXE4R	FDCA800HKXE4R	FDCA850HKXE4R	FDCA900HKXE4R
Item	Indoor intake air temperature (Upper, lower limits)	Refer to the Selection chart. (see page 167)			
	Outdoor air temperature (Upper, lower limits)				
Indoor units that can be used in combination	Number of connected units	2 to 43 units	2 to 47 units	2 to 48 units	2 to 48 units
	Total capacity	367 ~ 956	400 ~ 1040	425 ~ 1105	450 ~ 1170
Total piping length		MAX. 510m			
Single direction piping length		Indoor unit MAX. 160m			
Outdoor unit to first branch (main piping)		Max. 130m			
Permissible height difference between the first branch and the indoor unit		Max. 15m			
Piping length after the first branch		Max. 40m			
Difference in height between indoor and outdoor units	Outdoor unit is higher	MAX. 50m			
	Outdoor unit is lower	MAX. 40m			
Difference in height between indoor units		MAX. 15m			
Difference in height between outdoor units (Same system)		MAX. 1m			
Difference between an outdoor unit and on outdoor unit side branch pipe		MAX. 5m			
Length of oil equalization piping		MAX. 10m			
Indoor unit atmosphere (behind ceiling) temperature and humidity		Dew point temperature 28 °C or less, relative humidity 80% or less			
Compressor stop/start frequency	1 cycle time	7 min or more (4 minutes or more from start to stop or 3 minutes or more from stop to start)			
	Stop time	3 min or more			
Power source voltage	Voltage fluctuation	Within $\pm 10\%$ of rated voltage			
	Voltage drop during start	Within $\pm 15\%$ of rated voltage			
	Phase unbalance	Within $\pm 3\%$ of rated voltage			

Allowable length of refrigerant piping, height difference between indoor and outdoor unit

#### (1) Branch pipe method (using branch piping)



#### (2) Header System (Header used)




Note (1) A branch piping system cannot be connected after a header system.


System		FDCA960 HKXE4R	FDCA1010 HKXE4R	FDCA1065 HKXE4R	FDCA1130 HKXE4R	FDCA1180 HKXE4R	FDCA1235 HKXE4R	FDCA1300 HKXE4R	FDCA1360 HKXE4R
Indoor intake air temperature (Upper, lower limits)		Refer to the Selection chart. (see page 167)							
Outdoor air temperature (Upper, lower limits)									
Indoor units that can be used in combination	Number of connected units	2 to 48 units			3 to 48 units				
	Total capacity	480~1248	505~1313	532~1385	565~1469	590~1534	617~1606	650~1690	680~1768
Total piping length		MAX. 510m							
Single direction piping length		Indoor unit MAX. 160m							
Outdoor unit to first branch (main piping)		Max. 130m							
Piping length after the first branch		Max. 40m							
Permissible height difference between the first branch and the indoor unit		Max. 15m							
Difference in height between indoor and outdoor units	Outdoor unit is higher	MAX. 50m							
	Outdoor unit is lower	MAX. 40m							
Difference in height between indoor units		MAX. 15m							
Difference in height between outdoor units (Same system)		MAX. 1m							
Difference between an outdoor unit and on outdoor unit side branch pipe		MAX. 5m							
Length of oil equalization piping		MAX. 10m							
Indoor unit atmosphere (behind ceiling) temperature and humidity		Dew point temperature 28 ℃ or less, relative humidity 80% or less							
Compressor stop/start frequency	1 cycle time	7 min or more (4 minutes or more from start to stop or 3 minutes or more from stop to start)							
	Stop time	3 min or more							
Power source voltage	Voltage fluctuation	Within ±10% of rated voltage							
	Voltage drop during start	Within ±15% of rated voltage							
	Phase unbalance	Within ±3% of rated voltage							

Allowable length of refrigerant piping, height difference between indoor and outdoor unit

### (1) Branch pipe method (using branch piping)



### (2) Header System (Header used)



Note (1) A branch piping system cannot be connected after a header system.

## (2) KXR series

### (a) All-in-one type

System		FDCA224HKXRE4R	FDCA280HKXRE4R	FDCA335HKXRE4R
Item	Indoor intake air temperature (Upper, lower limits)	Refer to the Selection chart. (See page 167)		
	Outdoor air temperature (Upper, lower limits)			
Indoor units that can be used in combination	Number of connected units	1 to 13 units	1 to 16 units	1 to 20 units
	Total capacity	112 ~ 292	140 ~ 364	168 ~ 434
Total piping length		MAX. 510m		
Single direction piping length		Indoor unit MAX. 160m		
Outdoor unit to first branch (main piping)		Max. 130m		
Piping length after the first branch		Max. 40m (The flow distribution controller can be set to any value in this range.)		
Difference in height between indoor and outdoor unit	Outdoor unit is higher	MAX. 50m		
	Outdoor unit is lower	MAX. 40m		
Difference in height between indoor unit in the system and branching controller		MAX. 15m		
Permissible height difference between the first branch and the indoor unit		MAX. 15m		
Height difference between flow distribution controller and indoor unit	Indoor unit is higher	MAX. 1m		
	Indoor unit is lower	MAX. 4m		
Indoor unit and flow distribution controller (indoor) air temperature · humidity		Dew point temperature 28 °C or less, relative humidity 80% or less		
Compressor stop/start frequency	1 cycle time	7 min or more (4 minutes or more from start to stop or 3 minutes or more from stop to start)		
	Stop time	3 min or more		
Power source voltage	Voltage fluctuation	Within ±10% of rated voltage		
	Voltage drop during start	Within ±15% of rated voltage		
	Phase unbalance	Within ±3% of rated voltage		

Note (1) For details, see page 155 (Refrigerant piping length and height restrictions).

**(b) All-in-one type (also for combined use)**

System		FDCA400HKXRE4R	FDCA450HKXRE4R	FDCA504HKXRE4R
Item				
Indoor intake air temperature (Upper, lower limits)		Refer to the Selection chart. (See page 167)		
Outdoor air temperature (Upper, lower limits)				
Indoor units that can be used in combination	Number of connected units	1 to 23 units	1 to 26 units	1 to 29 units
	Total capacity	200 ~ 520	225 ~ 585	252 ~ 656
Total piping length		MAX. 510m		
Single direction piping length		Indoor unit MAX. 160m		
Outdoor unit to first branch (main piping)		Max. 130m		
Piping length after the first branch		Max. 40m (The flow distribution controller can be set to any value in this range)		
Difference in height between indoor and outdoor unit	Outdoor unit is higher	MAX. 50m		
	Outdoor unit is lower	MAX. 40m		
Difference in height between indoor unit in the system and branching controller		MAX. 15m		
Permissible height difference between the first branch and the indoor unit		MAX. 15m		
Height difference between flow distribution controller and indoor unit	Indoor unit is higher	MAX. 1m		
	Indoor unit is lower	MAX. 4m		
Indoor unit and flow distribution controller (indoor) air temperature · humidity		Dew point temperature 28 °C or less, relative humidity 80% or less		
Compressor stop/start frequency	1 cycle time	7 min or more (4 minutes or more from start to stop or 3 minutes or more from stop to start)		
	Stop time	3 min or more		
Power source voltage	Voltage fluctuation	Within ±10% of rated voltage		
	Voltage drop during start	Within ±15% of rated voltage		
	Phase unbalance	Within ± 3% of rated voltage		

Note (1) For details, see page 155 (Refrigerant piping length and height restrictions).



System		FDCA560HKXRE4R	FDCA615HKXRE4R	FDCA680HKXRE4R
Item				
Indoor intake air temperature (Upper, lower limits)		Refer to the Selection chart. (See page 167)		
Outdoor air temperature (Upper, lower limits)				
Indoor units that can be used in combination	Number of connected units	1 to 33 units	2 to 36 units	2 to 40 units
	Total capacity	280 ~ 728	307 ~ 800	340 ~ 884
Total piping length		MAX. 510m		
Single direction piping length		MAX. 160m		
Outdoor unit to first branch (main piping)		Max. 130m		
Piping length after the first branch		Max. 40m (The flow distribution controller can be set to any value in this range)		
Difference in height between indoor and outdoor unit	Outdoor unit is higher	MAX. 50m		
	Outdoor unit is lower	MAX. 40m		
Difference in height between indoor unit in the system and branching controller		MAX. 15m		
Permissible height difference between the first branch and the indoor unit		MAX. 15m		
Height difference between flow distribution controller and indoor unit	Indoor unit is higher	MAX. 1m		
	Indoor unit is lower	MAX. 4m		
Indoor unit and flow distribution controller (indoor) air temperature · humidity		Dew point temperature 28 °C or less, relative humidity 80% or less		
Compressor stop/start frequency	1 cycle time	7 min or more (4 minutes or more from start to stop or 3 minutes or more from stop to start)		
	Stop time	3 min or more		
Power source voltage	Voltage fluctuation	Within ±10% of rated voltage		
	Voltage drop during start	Within ±15% of rated voltage		
	Phase unbalance	Within ± 3% of rated voltage		

Note (1) For details, see page 155 (Refrigerant piping length and height restrictions).

(c) Combined type

System		FDCA735HKXRE4R	FDCA800HKXRE4R	FDCA850HKXRE4R	FDCA900HKXRE4R
Item					
Indoor intake air temperature (Upper, lower limits)		Refer to the Selection chart. (see page 167)			
Outdoor air temperature (Upper, lower limits)					
Indoor units that can be used in combination	Number of connected units	2 to 43 units	2 to 47 units	2 to 48 units	2 to 48 units
	Total capacity	368 ~ 955	400 ~ 1040	425 ~ 1105	450 ~ 1170
Total piping length		MAX. 510m			
Single direction piping length		Indoor unit MAX. 160m			
Outdoor unit to first branch (main piping)		Max. 130m			
Piping length after the first branch		Max. 40m (The flow distribution controller can be set to any value in this range)			
Difference in height between indoor and outdoor unit	Outdoor unit is higher	MAX. 50m			
	Outdoor unit is lower	MAX. 40m			
Difference in height between indoor unit in the system and branching controller		MAX. 15m			
Difference in height between outdoor units (Same system)		MAX. 1m			
Difference between an outdoor unit and an outdoor unit side branching pipe		MAX. 5m			
Length of oil equalization piping		MAX. 10m			
Permissible height difference between the first branch and the indoor unit		MAX. 15m			
Height difference between flow distribution controller and indoor unit	Indoor unit is higher	MAX. 1m			
	Indoor unit is lower	MAX. 4m			
Indoor unit and flow distribution controller (indoor) air temperature · humidity		Dew point temperature 28 °C or less, relative humidity 80% or less			
Compressor stop/start frequency	1 cycle time	7 min or more (4 minutes or more from start to stop or 3 minutes or more from stop to start)			
	Stop time	3 min or more			
Power source voltage	Voltage fluctuation	Within ±10% of rated voltage			
	Voltage drop during start	Within ±15% of rated voltage			
	Phase unbalance	Within ±3% of rated voltage			

Note (1) For details, see page 155 (Refrigerant piping length and height restrictions).


System		FDCA960 HKXRE4R	FDCA1010 HKXRE4R	FDCA1065 HKXRE4R	FDCA1130 HKXRE4R	FDCA1180 HKXRE4R	FDCA1235 HKXRE4R	FDCA1300 HKXRE4R	FDCA1360 HKXRE4R
Item									
Indoor intake air temperature (Upper, lower limits)		Refer to the Selection chart. (see page 167)							
Outdoor air temperature (Upper, lower limits)									
Indoor units that can be used in combination	Number of connected units	2 to 48 units			3 to 48 units				
	Total capacity	480 ~ 1248	505 ~ 1313	532 ~ 1385	565 ~ 1469	590 ~ 1534	617 ~ 1606	650 ~ 1690	680 ~ 1768
Total piping length		MAX. 510m							
Single direction piping length		MAX. 160m							
Outdoor unit to first branch (main piping)		Max. 130m							
Piping length after the first branch		Max. 40m (The flow distribution controller can be set to any value in this range)							
Difference in height between indoor and outdoor unit	Outdoor unit is higher	MAX. 50m							
	Outdoor unit is lower	MAX. 40m							
Difference in height between indoor unit in the system and branching controller		MAX. 15m							
Difference in height between outdoor units (Same system)		MAX. 1m							
Difference between an outdoor unit and an outdoor unit side branching pipe		MAX. 5m							
Length of oil equalization piping		MAX. 10m							
Permissible height difference between the first branch and the indoor unit		MAX. 15m							
Height difference between flow distri- bution controller and indoor unit	Indoor unit is higher	MAX. 1m							
	Indoor unit is lower	MAX. 4m							
Indoor unit and flow distribution controller (indoor) air temperature · humidity		Dew point temperature 28 °C or less, relative humidity 80% or less							
Compressor stop/start frequency	1 cycle time	7 min or more (4 minutes or more from start to stop or 3 minutes or more from stop to start)							
	Stop time	3 min or more							
Power source voltage	Voltage fluctuation	Within ±10% of rated voltage							
	Voltage drop during start	Within ±15% of rated voltage							
	Phase unbalance	Within ±3% of rated voltage							

Note (1) For details, see page 155 (Refrigerant piping length and height restrictions).

Allowable length of refrigerant piping, height difference between indoor and outdoor unit
<p>① R410A</p> <p>② R32</p> <p>③ R407C</p> <p>④ R404A</p> <p>⑤ R450A</p> <p>⑥ R452B</p> <p>⑦ R450B</p> <p>⑧ R450C</p> <p>⑨ R450D</p> <p>⑩ R450E</p> <p>⑪ R450F</p> <p>⑫ R450G</p> <p>⑬ R450H</p> <p>⑭ R450I</p> <p>⑮ R450J</p> <p>⑯ R450K</p> <p>⑰ R450L</p> <p>⑱ R450M</p> <p>⑲ R450N</p> <p>⑳ R450O</p> <p>㉑ R450P</p> <p>㉒ R450Q</p> <p>㉓ R450R</p> <p>㉔ R450S</p> <p>㉕ R450T</p> <p>㉖ R450U</p> <p>㉗ R450V</p> <p>㉘ R450W</p> <p>㉙ R450X</p> <p>㉚ R450Y</p> <p>㉛ R450Z</p> <p>㉜ R450AA</p> <p>㉝ R450AB</p> <p>㉞ R450AC</p> <p>㉟ R450AD</p> <p>㊱ R450AE</p> <p>㊲ R450AF</p> <p>㊳ R450AG</p> <p>㊴ R450AH</p> <p>㊵ R450AI</p> <p>㊶ R450AJ</p> <p>㊷ R450AK</p> <p>㊸ R450AL</p> <p>㊹ R450AM</p> <p>㊺ R450AN</p> <p>㊻ R450AO</p> <p>㊼ R450AP</p> <p>㊽ R450AQ</p> <p>㊾ R450AR</p> <p>㊿ R450AS</p> <p>㉑ R450AT</p> <p>㉒ R450AU</p> <p>㉓ R450AV</p> <p>㉔ R450AW</p> <p>㉕ R450AX</p> <p>㉖ R450AY</p> <p>㉗ R450AZ</p> <p>㉘ R450BA</p> <p>㉙ R450BB</p> <p>㉚ R450BC</p> <p>㉛ R450BD</p> <p>㉜ R450BE</p> <p>㉝ R450BF</p> <p>㉞ R450BG</p> <p>㉟ R450BH</p> <p>㊱ R450BI</p> <p>㊲ R450BJ</p> <p>㊳ R450BK</p> <p>㊴ R450BL</p> <p>㊵ R450BM</p> <p>㊶ R450BN</p> <p>㊷ R450BO</p> <p>㊸ R450BP</p> <p>㊹ R450BQ</p> <p>㊺ R450BR</p> <p>㊻ R450BS</p> <p>㊼ R450BT</p> <p>㊽ R450BU</p> <p>㊾ R450BV</p> <p>㊿ R450BW</p> <p>㉑ R450BX</p> <p>㉒ R450BY</p> <p>㉓ R450BZ</p> <p>㉔ R450CA</p> <p>㉕ R450CB</p> <p>㉖ R450CC</p> <p>㉗ R450CD</p> <p>㉘ R450CE</p> <p>㉙ R450CF</p> <p>㉚ R450CG</p> <p>㉛ R450CH</p> <p>㉜ R450CI</p> <p>㉝ R450CJ</p> <p>㉞ R450CK</p> <p>㉟ R450CL</p> <p>㊱ R450CM</p> <p>㊲ R450CN</p> <p>㊳ R450CO</p> <p>㊴ R450CP</p> <p>㊵ R450CQ</p> <p>㊶ R450CR</p> <p>㊷ R450CS</p> <p>㊸ R450CT</p> <p>㊹ R450CU</p> <p>㊺ R450CV</p> <p>㊻ R450CW</p> <p>㊼ R450CX</p> <p>㊽ R450CY</p> <p>㊾ R450CZ</p> <p>㊿ R450DA</p> <p>㉑ R450DB</p> <p>㉒ R450DC</p> <p>㉓ R450DD</p> <p>㉔ R450DE</p> <p>㉕ R450DF</p> <p>㉖ R450DG</p> <p>㉗ R450DH</p> <p>㉘ R450DI</p> <p>㉙ R450DJ</p> <p>㉚ R450DK</p> <p>㉛ R450DL</p> <p>㉜ R450DM</p> <p>㉝ R450DN</p> <p>㉞ R450DO</p> <p>㉟ R450DP</p> <p>㊱ R450DQ</p> <p>㊲ R450DR</p> <p>㊳ R450DS</p> <p>㊴ R450DT</p> <p>㊵ R450DU</p> <p>㊶ R450DV</p> <p>㊷ R450DW</p> <p>㊸ R450DX</p> <p>㊹ R450DY</p> <p>㊺ R450DZ</p> <p>㊻ R450EA</p> <p>㊼ R450EB</p> <p>㊽ R450EC</p> <p>㊾ R450ED</p> <p>㊿ R450EE</p> <p>㉑ R450EF</p> <p>㉒ R450EG</p> <p>㉓ R450EH</p> <p>㉔ R450EI</p> <p>㉕ R450EJ</p> <p>㉖ R450EK</p> <p>㉗ R450EL</p> <p>㉘ R450EM</p> <p>㉙ R450EN</p> <p>㉚ R450EO</p> <p>㉛ R450EP</p> <p>㉜ R450EQ</p> <p>㉝ R450ER</p> <p>㉞ R450ES</p> <p>㉟ R450ET</p> <p>㊱ R450EU</p> <p>㊲ R450EV</p> <p>㊳ R450EW</p> <p>㊴ R450EX</p> <p>㊵ R450EY</p> <p>㊶ R450EZ</p> <p>㊷ R450FA</p> <p>㊸ R450FB</p> <p>㊹ R450FC</p> <p>㊺ R450FD</p> <p>㊻ R450FE</p> <p>㊼ R450FF</p> <p>㊽ R450FG</p> <p>㊾ R450FH</p> <p>㊿ R450FI</p> <p>㉑ R450FJ</p> <p>㉒ R450FK</p> <p>㉓ R450FL</p> <p>㉔ R450FM</p> <p>㉕ R450FN</p> <p>㉖ R450FO</p> <p>㉗ R450FP</p> <p>㉘ R450FQ</p> <p>㉙ R450FR</p> <p>㉚ R450FS</p> <p>㉛ R450FT</p> <p>㉜ R450FU</p> <p>㉝ R450FV</p> <p>㉞ R450FW</p> <p>㉟ R450FX</p> <p>㊱ R450FY</p> <p>㊲ R450FZ</p> <p>㊳ R450GA</p> <p>㊴ R450GB</p> <p>㊵ R450GC</p> <p>㊶ R450GD</p> <p>㊷ R450GE</p> <p>㊸ R450GF</p> <p>㊹ R450GG</p> <p>㊺ R450GH</p> <p>㊻ R450GI</p> <p>㊼ R450GJ</p> <p>㊽ R450GK</p> <p>㊾ R450GL</p> <p>㊿ R450GM</p> <p>㉑ R450GN</p> <p>㉒ R450GO</p> <p>㉓ R450GP</p> <p>㉔ R450GQ</p> <p>㉕ R450GR</p> <p>㉖ R450GS</p> <p>㉗ R450GT</p> <p>㉘ R450GU</p> <p>㉙ R450GV</p> <p>㉚ R450GW</p> <p>㉛ R450GX</p> <p>㉜ R450GY</p> <p>㉝ R450GZ</p> <p>㉞ R450HA</p> <p>㉟ R450HB</p> <p>㊱ R450HC</p> <p>㊲ R450HD</p> <p>㊳ R450HE</p> <p>㊴ R450HF</p> <p>㊵ R450HG</p> <p>㊶ R450HH</p> <p>㊷ R450HI</p> <p>㊸ R450HJ</p> <p>㊹ R450HK</p> <p>㊺ R450HL</p> <p>㊻ R450HM</p> <p>㊼ R450HN</p> <p>㊽ R450HO</p> <p>㊾ R450HP</p> <p>㊿ R450HQ</p> <p>㉑ R450HR</p> <p>㉒ R450HS</p> <p>㉓ R450HT</p> <p>㉔ R450HU</p> <p>㉕ R450HV</p> <p>㉖ R450HW</p> <p>㉗ R450HX</p> <p>㉘ R450HY</p> <p>㉙ R450HZ</p> <p>㉚ R450IA</p> <p>㉛ R450IB</p> <p>㉜ R450IC</p> <p>㉝ R450ID</p> <p>㉞ R450IE</p> <p>㉟ R450IF</p> <p>㊱ R450IG</p> <p>㊲ R450IH</p> <p>㊳ R450II</p> <p>㊴ R450IJ</p> <p>㊵ R450IK</p> <p>㊶ R450IL</p> <p>㊷ R450IM</p> <p>㊸ R450IN</p> <p>㊹ R450IO</p> <p>㊺ R450IP</p> <p>㊻ R450IQ</p> <p>㊼ R450IR</p> <p>㊽ R450IS</p> <p>㊾ R450IT</p> <p>㊿ R450IU</p> <p>㉑ R450IV</p> <p>㉒ R450IW</p> <p>㉓ R450IX</p> <p>㉔ R450IY</p> <p>㉕ R450IZ</p> <p>㉖ R450JA</p> <p>㉗ R450JB</p> <p>㉘ R450JC</p> <p>㉙ R450JD</p> <p>㉚ R450JE</p> <p>㉛ R450JF</p> <p>㉜ R450JG</p> <p>㉝ R450JH</p> <p>㉞ R450JI</p> <p>㉟ R450JJ</p> <p>㊱ R450JK</p> <p>㊲ R450JL</p> <p>㊳ R450JM</p> <p>㊴ R450JN</p> <p>㊵ R450JO</p> <p>㊶ R450JP</p> <p>㊷ R450JQ</p> <p>㊸ R450JR</p> <p>㊹ R450JS</p> <p>㊺ R450JT</p> <p>㊻ R450JU</p> <p>㊼ R450JV</p> <p>㊽ R450JW</p> <p>㊾ R450J</p>


(a) FDCA224HKXRE4R ~ FDCA680HKXRE4R (All-in-one type)

### 1) Branching system




Note (1) Please do not attach large traps or dirdhouses behind to the hose behind the first joint (acceptable only if higher than 500mm.)

## 2) Integrated branching system



Note (1) Please do not attach large traps or dirdhouses behind to the hose behind the first joint (acceptable only if higher than 500mm.)

(b) FDCA735HKXRE4R ~ FDCA1360HKXRE4R (Combined type)




## Permissible piping length

- Equalizing oil pipe  $\ell_a \leq 10$  m
- Refrigerant piping  $\ell_b \leq 5$  m
- Refrigerant piping  $\ell_c \leq 5$  m

Note (1) Use limitations other than the above are the same as for the All-in-one type.

## 4.3 Piping system

(1) KX Series  
Models FDCA140HKXEN4R, 140HKXES4R, 160HKXES4R



Notes (1) Preset point of protective devices.

PSH:4.055 (ON)/3.658 (OFF) MPa

PSL:0.079 (ON)/0.227 (OFF) MPa

(2) Function of thermistor

Thi-R1,2:Heating operation:Indoor fan control

Cooling operation:Frost prevention control

Super heat control

Thi-R3:Super heat control


Tho-R:For control of defrosting.

Tho-A:For heating and cooling to low outdoor temp., for control of defrosting.

Tho-D:For control of discharge pipe temperature.

Tho-S:For control of suction pipe temperature.


Tho-C:For control of temperature under the dome.



Models FDCA224HKXE4R, 280HKXE4R, 335HKXE4R

- Notes (1) Preset point of protective devices  
63H1: Open 3.8MPa, Close 2.9MPa  
(For protection)
- (2) Function of thermistor
- PSH: For compressor control  
Cooling: 3.70 ON (MPa)  
Heating: 3.00 ON (MPa)
- PSL: ON 0.18MPa, OFF 0.236MPa  
(For compressor control)  
ON 0.134MPa, OFF 0.18MPa  
(For Protection)

- Thi-R1, R2: Heating operation : Indoor fan control.  
Cooling operation : Frost prevention control.  
Super heat control.
- Thi-R3: For super heat control of cooling operation.
- Tho-D: For control of discharge pipe temperature.
- Tho-C: For control of temperature under the dome.
- Tho-S: For control of suction pipe temperature.
- Tho-R1, R2: For control of defrosting.
- Tho-A: For control of defrosting.
- Tho-R3, R4: Electronic expansion valve (EEVH1, 2) control of heating operation
- Tho-SC: Electronic expansion valve (EEVSC) control of cooling operation.
- Tho-H: For super heat control of sub-cooling coil.



- Notes (1) Preset point of protective devices  
63H1-1, 2: Open 4.15MPa, Close 3.15MPa  
(For protection)
- (2) Function of thermistor
- PSH: For compressor control  
Cooling: 3.70 ON (MPa)  
Heating: 3.00 ON (MPa)
- PSL: ON 0.18MPa, OFF 0.20MPa  
(For compressor control)  
ON 0.134MPa, OFF 0.18MPa  
(For protection)

Thi-R1, R2: Heating operation : Indoor fan control.  
Cooling operation : Frost prevention control.  
Super heat control.


Thi-R3: For super heat control of cooling operation.  
Tho-D: For control of discharge pipe temperature.  
Tho-C: For control of temperature under the dome.  
Tho-S: For control of suction pipe temperature.  
Tho-R1, R2: For control of defrosting.  
Tho-A: For control of defrosting.  
Tho-R3, R4: Electronic expansion valve (EEVH1, 2) control of heating operation  
Tho-SC: Electronic expansion valve (EEVSC) control of cooling operation.  
Tho-H: For super heat control of sub-cooling coil.

Models FDCA35HKXE4R-K, 400HKXE4R, 450HKXE4R, 504HKXE4R, 560HKXE4R, 615HKXE4R, 680HKXE4R

(2) KXR series

(a) Cooling and heating operation

Models FDCA224HKXRE4R, 280HKXRE4R, 335HKXRE4R



- Note (1) Preset point of protective devices  
63H1: Open 4.15MPa, Close 3.15MPa  
(For protection)
- (2) Function of thermistor  
PSH: For compressor control  
Cooling: 3.70 ON (MPa)  
Heating: 3.00 ON (MPa)  
PSL: ON 0.18MPa, OFF 0.236MPa  
(For compressor control)  
ON 0.134MPa, OFF 0.134MPa  
(For Protection)

- Thi-R1, R2: Heating operation: Indoor fan control,  
Cooling operation: Frost prevention control.  
Super heat control.
- Thi-R3: For super heat control of cooling operation.
- Tho-D: For control of discharge pipe temperature.
- Tho-C: For control of temperature under the dome.
- Tho-S: For control of suction pipe temperature.
- Tho-R1, R2: For control of defrosting.
- Tho-A: For control of defrosting.
- Tho-R3, R4: Electric expansion valve (EEVH1, 2) control of heating operation.
- Tho-SC: Electric expansion valve (EEVSC) control of cooling operation.
- Tho-H: For super heat control of sub-cooling coil.

List of branch controller  
Solenoid valve operations

	Cooling	Heating
SVH	Close	Open
SVG	Close	Close






- (2) Function of thermistor  
 PSH: For compressor control  
     Cooling: 3.70 ON (MPa)  
     Heating: 3.00 ON (MPa)  
 PSL: ON 0.18MPa, OFF 0.20MPa  
     (For compressor control)  
     ON 0.134MPa, OFF 0.18MPa  
     (For Protection)

- |             |   |
|-------------|---|
| Thi-R1, R2: | Heating operation: Indoor fan control,<br>Cooling operation: Frost prevention control.<br>Super heat control. |
| Thi-R3:     | For super heat control of cooling operation.  |
| Tho-D:      | For control of discharge pipe temperature.  |
| Tho-C:      | For control of temperature under the dome.  |
| Tho-S:      | For control of suction pipe temperature.  |
| Tho-R1, R2: | For control of defrosting.  |
| Tho-A:      | For control of defrosting.  |
| Tho-R3, R4: | Electric expansion valve (EEVH1, 2) control of heating operation.   |
| Tho-SC:     | Electric expansion valve (EEVSC) control of cooling operation.  |
| Tho-H:      | For super heat control of sub-cooling coil.   |

## List of branch controller Solenoid valve operations

	Cooling	Heeting
SVH	Close	Open
SVG	Close	Close

(b) Mixed heating/cooling operation  
Models FDCA224HKXRE4R, 280HKXRE4R, 335HKXRE4R




- Note (1) Preset point of protective devices  
63H1: Open 4.15MPa, Close 3.15MPa  
(For protection)
- (2) Function of thermistor  
PSH: For compressor control  
Cooling: 3.70 ON (MPa)  
Heating: 3.00 ON (MPa)  
PSL: ON 0.18MPa, OFF 0.236MPa  
(For compressor control)  
ON 0.134MPa, OFF 0.134MPa  
(For Protection)

- Thi-R1, R2: Heating operation: Indoor fan control,  
Cooling operation: Frost prevention control.  
Super heat control.
- Thi-R3: For super heat control of cooling operation.
- Tho-D: For control of discharge pipe temperature.
- Tho-C: For control of temperature under the dome.
- Tho-S: For control of suction pipe temperature.
- Tho-R1, R2: For control of defrosting.
- Tho-A: For control of defrosting.
- Tho-R3, R4: Electric expansion valve (EEVH1, 2) control of heating operation.
- Tho-SC: Electric expansion valve (EEVSC) control of cooling operation.
- Tho-H: For super heat control of sub-cooling coil.

List of branch controller  
Solenoid valve operations

	Cooling	Heating
SVH	Close	Open
SVG	Close	Close



- Note (1) Preset point of protective devices  
63H1-1, 2: Open 4.15MPa, Close 3.15MPa  
(For protection)
- (2) Function of thermistor  
PSH: For compressor control  
Cooling: 3.70 ON (MPa)  
Heating: 3.00 ON (MPa)  
PSL: ON 0.18MPa, OFF 0.20MPa  
(For compressor control)  
ON 0.134MPa, OFF 0.18MPa  
(For Protection)


- Thi-R1, R2: Heating operation: Indoor fan control,  
Cooling operation: Frost prevention control.  
Super heat control.
- Thi-R3: For super heat control of cooling operation.
- Tho-D: For control of discharge pipe temperature.
- Tho-C: For control of temperature under the dome.
- Tho-S: For control of suction pipe temperature.
- Tho-R1, R2: For control of defrosting.
- Tho-A: For control of defrosting.
- Tho-R3, R4: Electric expansion valve (EEVH1, 2) control of heating operation.
- Tho-SC: Electric expansion valve (EEVSC) control of cooling operation.
- Tho-H: For super heat control of sub-cooling coil.

List of branch controller  
Solenoid valve operations

	Cooling	Heating
SVH	Close	Open
SVG	Close	Close

## 4.4 Selection chart

### (1) Equipment selection flow



## (2) Capacity calculation method

### (a) Calculating the indoor unit capacity compensation

Indoor unit capacity (cooling, heating) = Indoor unit total rated capacity  
× Capacity compensation coefficient according to temperature conditions  
See item (3) (a) concerning the capacity compensation coefficient according to temperature conditions.

### (b) Calculating the outdoor unit capacity compensation

Outdoor Unit Capacity (Cooling, Heating) = Outdoor unit rated capacity (rated capacity when 100% connected)  
× Capacity compensation coefficient according to temperature conditions  
× Capacity compensation coefficient according to piping length  
× Capacity compensation coefficient according to height difference  
× Correction of heating capacity in relation to the frost on the outdoor unit heat exchanger  
× Capacity compensation coefficient according to indoor unit connection capacity

- ① See item (3) (a) concerning the capacity compensation coefficient according to temperature conditions.
- ② See item (3) (c) concerning the capacity compensation coefficient according to piping length.  
In the case of cooling capacity compensation, the compensation coefficient differs depending on the piping size if the length exceeds 90 m, so exercise caution. The compensation coefficient is the same in the case of heating capacity compensation regardless of the model (horsepower).
- ③ See item (3) (d) concerning the capacity compensation coefficient according to height difference. This compensation should be carried out only in cases where the outdoor unit is lower during cooling and higher during heating.
- ④ See item (3) (e) correction of heating capacity in relation to the frost on the outdoor unit heat exchanger. This compensation should be carried out only when calculating the heating capacity.
- ⑤ See item (3) (f) concerning the capacity compensation coefficient according to indoor unit connected capacity. This compensation should be carried out only in cases where the indoor unit total capacity is 100% or higher.

### (c) Calculating system capacity

Compare the capacities determined in items (a) and (b) above and let the smaller value be the system capacity (cooling, heating).

- ① In cases where indoor unit total capacity (cooling, heating) > outdoor unit capacity (cooling, heating)  
System capacity (cooling, heating) = Outdoor unit capacity (cooling, heating)
- ② In cases where indoor unit total capacity (cooling, heating) < outdoor unit capacity (cooling, heating)  
System capacity (cooling, heating) = Indoor unit capacity (cooling, heating)

### (d) Calculating indoor unit capacity [item (c) ① only]

Indoor unit capacity (cooling, heating) = System capacity (cooling, heating)  
× [(Indoor unit capacity) / (Indoor unit total capacity)]

## Capacity calculation examples

### Example 1

#### Cooling (when the indoor unit connected total capacity is less than 100%)

- Outdoor unit FDCA735HKXE4R ..... 1 Unit
- Indoor unit FDTA71KXE4R ..... 8 Units
- Piping length ..... 60 m (Equivalent length)
- Indoor, outdoor unit height difference ..... 15 m (Outdoor unit is lower)
- Temperature conditions ..... Outdoor temperature: 33°C DB
- Temperature conditions ..... Indoor temperature: 19°C WB

#### <Indoor unit total cooling capacity>: Item (2) (a) calculation.

- Indoor unit rated cooling capacity: 7.1 kW
- Capacity compensation coefficient according to temperature conditions:  
1.02 (Calculated according to Indoor 19°C WB / Outdoor 33°C DB); (See page 167)  
Indoor unit cooling capacity: 7.1 kW × 1.02 = 7.2 kW
- Indoor unit total cooling capacity calculation;  
indoor unit total cooling capacity: 7.2 kW × 8 units = 57.6 kW

#### <Outdoor unit maximum cooling capacity> : Item (2) (b) calculation

- Outdoor unit rated cooling capacity: 73.5 kW
- Capacity compensation coefficient according to temperature conditions:  
1.02 (Calculated according to Indoor 19°C WB / Outdoor 33°C DB); (See page 167)  
Outdoor unit cooling capacity: 73.5 kW × 1.02 = 75.0 kW
- Capacity compensation coefficient according to piping length: 0.96 (calculated according to 60 m length); (See page 170)  
75.0 kW × 0.96 = 72.0 kW

- Capacity compensation coefficient according to height difference: 0.97 (calculated according to 15 m difference); (See page 175)  
 $72.0 \text{ kW} \times 0.97 \approx 69.8 \text{ kW}$
- Capacity compensation coefficient according to indoor unit connected total capacity:  $1.0 \leftarrow (71 \times 8) / 735 < 100\%$   
 No compensation

#### <System cooling capacity>: Item (2) (c) calculation

Compare the indoor unit total cooling capacity and the outdoor unit maximum cooling capacity. The smaller value is the actual system cooling capacity.

- Indoor unit total cooling capacity: 57.6 kW  $\Rightarrow$  System cooling capacity: 57.6 kW
- Outdoor unit maximum cooling capacity: 69.8 kW

#### <Indoor unit capacity compensation> No compensation (7.2 kW)

### Example 2

(Notes) Calculations were made using the European specification  $\phi 34.92$  gas pipe.

#### Cooling (when the indoor unit connected total capacity is 100% or higher)

- Outdoor unit FDCA735HKXE4R ..... 1 Unit
- Indoor unit FDTA71KXE4R ..... 11 Units
- Piping length ..... 120 m (Equivalent length)
- Indoor, outdoor unit height difference ..... 15 m (Outdoor unit is higher)
- Temperature conditions ..... Outdoor temperature: 35°C DB
- Temperature conditions ..... Indoor temperature: 18°C WB

#### <Indoor unit total cooling capacity>: Item (2) (a) calculation.

- Indoor unit rated cooling capacity: 7.1 kW
- Capacity compensation coefficient according to temperature conditions:  
 0.94 (Calculated according to Indoor 18°C WB / Outdoor 35°C DB); (See page 167)  
 Indoor unit cooling capacity:  $7.1 \text{ kW} \times 0.94 \approx 6.7 \text{ kW}$
- Indoor unit total cooling capacity calculation;  
 indoor unit total cooling capacity:  $6.7 \text{ kW} \times 11 \text{ units} \approx 73.7 \text{ kW}$

#### <Outdoor unit maximum cooling capacity> : Item (2) (b) calculation

- Outdoor unit rated cooling capacity: 73.5 kW
- Capacity compensation coefficient according to temperature conditions:  
 0.94 (Calculated according to Indoor 18°C WB / Outdoor 35°C DB); (See page 167)  
 Outdoor unit cooling capacity:  $73.5 \text{ kW} \times 0.94 \approx 69.1 \text{ kW}$
- Capacity compensation coefficient according to piping length: 0.93 (calculated according to 120 m length); (See page 170)  
 $69.1 \text{ kW} \times 0.93 \approx 64.3 \text{ kW}$
- Capacity compensation coefficient according to height difference: 1.0 (the outdoor unit is higher during cooling)  
 No compensation
- Capacity compensation coefficient according to indoor unit connected total capacity:  $1.07 \leftarrow (71 \times 11) / 735 = 106\%$  (See page 181)  
 $64.3 \text{ kW} \times 1.07 \approx 68.8 \text{ kW}$

#### <System cooling capacity>: Item (2) (c) calculation

Compare the indoor unit total cooling capacity and the outdoor unit maximum cooling capacity. The smaller value is the actual system cooling capacity.

- Indoor unit total cooling capacity : 73.7 kW  $\Rightarrow$  System cooling capacity: 68.8 kW
- Outdoor unit maximum cooling capacity : 68.8 kW

#### <Indoor unit cooling capacity Compensation>: Item (2) (d) calculation.

$$\frac{68.8 \text{ kW} \times 6.7 \text{ kW}}{73.7 \text{ kW}} \approx 6.3 \text{ kW}$$

### Example 3

#### Heating (when the indoor unit connected total capacity is 100% or higher)

- Outdoor unit FDCA735HKXE4R ..... 1 Unit
- Indoor unit FDTA71KXE4R ..... 11 Units
- Piping length ..... 60 m (Equivalent length)
- Indoor, outdoor unit height difference ..... 20 m (Outdoor unit is higher)
- Temperature conditions ..... Outdoor temperature: 6°C WB
- Temperature conditions ..... Indoor temperature: 19°C DB

#### <Indoor unit total heating capacity>: Item (2) (a) calculation.

- Indoor unit rated heating capacity: 8.0 kW
- Capacity compensation coefficient according to temperature conditions:  
 1.04 (Calculated according to Outdoor 6°C WB / Indoor 19°C DB); (See page 168)  
 Indoor unit heating capacity:  $8.0 \text{ kW} \times 1.04 \approx 8.3 \text{ kW}$
- Indoor unit total heating capacity calculation;  
 indoor unit total heating capacity:  $8.3 \text{ kW} \times 11 \text{ units} \approx 91.3 \text{ kW}$

### <Outdoor unit maximum heating capacity> : Item (2) (b) calculation

- Outdoor unit rated heating capacity: 82.5 kW
- Capacity compensation coefficient according to temperature conditions:  
1.04 (Calculated according to Outdoor 6°C WB / Indoor 19°C DB); (See page 168)  
Outdoor unit heating capacity:  $82.5 \text{ kW} \times 1.04 = 85.8 \text{ kW}$
- Capacity compensation coefficient according to piping length: 0.96 (calculated according to 60 m length); (See page 170)  
 $85.8 \text{ kW} \times 0.96 \approx 82.4 \text{ kW}$
- Capacity compensation coefficient according to height difference: 0.96 (calculated according to 20 m difference); (See page 175)  
 $82.4 \text{ kW} \times 0.96 \approx 79.1 \text{ kW}$
- Correction of heating capacity in relation to the frost on the outdoor unit heat exchanger: 1.0;  
 $79.1 \text{ kW} \times 1.0 \approx 79.1 \text{ kW}$ .
- Capacity compensation coefficient according to indoor unit connected total capacity:  $1.07 \leftarrow (71 \times 11) / 735 = 106\%$  (See page 181)  
 $79.1 \text{ kW} \times 1.07 \approx \underline{84.6 \text{ kW}}$ .

### <System heating capacity>: Item (2) (c) calculation

Compare the indoor unit total heating capacity and the outdoor unit maximum heating capacity. The smaller value is the actual system heating capacity.

- Indoor unit total heating capacity : 91.3 kW  $\Rightarrow$  System heating capacity: 84.6 kW
- Outdoor unit maximum heating capacity : 84.6 kW


### <Indoor unit heating capacity compensation> (Item (2) (d) calculation

$$\frac{84.6 \text{ kW} \times 8.3 \text{ kW}}{91.3 \text{ kW}} \approx \underline{7.7 \text{ kW}}$$

## (3) Capacity compensation coefficient

### (a) Range of usage & limitations or Coefficient of cooling and heating capacity in relation to temperatures


#### (i) Models FDCA140HKXEN4R, 140HKXES4R, 160HKXES4R





(ii) Models FDCA224~1360HKXE4R, 224~1360HKXRE4R

1) Range of usage & limitations




2) Coefficient of cooling and heating capacity in relation to temperatures

Notes (1) When there is simultaneous cooling operation with an outside temperature of 5°C or less, there is a reduction in cooling capacity compared with cooling operation only. (KXR series only)  
(Not suitable for year-round cooling applications in server rooms and the like.)


(b) Capacity compensation coefficient and power consumption compensation coefficient according to indoor and outdoor temperature conditions.

1) Capacity compensation coefficient


◆ Cooling








## 2) Power consumption correction factor






**(c) Correction of cooling and heating capacity in relation to one way length of refrigerant piping.**


**1) Cooling**

**a) KX series**


**Models FDCA140HKXEN4R, 140, 160HKXES4R**




**Model FDCA224HKXE4R**











**Model FDCA280HKXE4R**











**Model FDCA335HKXE4R**




Note (1) Parts with the \* mark show the piping size in case used in Europe.




Note (1) Parts with the \* mark show the piping size in case used in Europe.









Note (1) Parts with the \* mark show the piping size in case used in Europe.











Note (1) Parts with the \* mark show the piping size in case used in Europe.










#### b) KXR series



Note (1) Parts with the \* mark show the piping size in case used in Europe.




Note (1) Parts with the \* mark show the piping size in case used in Europe.



Note (1) Parts with the \* mark show the piping size in case used in Europe.

## 2) Heating (Common)



Note (1) Equivalent piping length can be obtained by calculating as follows.

Equivalent piping length = Real gas piping length + Number of bends in gas piping × Equivalent piping length of bends.

Equivalent length of each joint

Unit : m/one part

Gas piping size	φ9.52	φ12.7	φ15.88	φ19.05	φ25.4	φ28.58	φ31.8
Joint (90°elbow)	0.15	0.20	0.25	0.30	0.40	0.45	0.55

- (d) When the outdoor unit is located at a lower height than the indoor unit in cooling operation and when the outdoor unit is located at a higher height than the indoor unit in heating operation, the following values should be subtracted from the values in the above table.

Height difference between the indoor unit and outdoor unit in the vertical height difference	5 m	10 m	15 m	20 m	25 m	30 m
Adjustment coefficient	0.99	0.98	0.97	0.96	0.95	0.94

Height difference between the indoor unit and outdoor unit in the vertical height difference	35 m	40 m	45 m	50 m
Adjustment coefficient	0.93	0.92	0.91	0.90

- (e) Correction of heating capacity in relation to the frost on the outdoor unit heat exchanger

Air inlet temperature of outdoor unit in °C WB	-15	-13	-11	-9	-7	-5	-3	-1	1	3	5 or more
Adjustment coefficient	0.96	0.96	0.95	0.94	0.93	0.91	0.88	0.86	0.87	0.92	1


The correction factors will change drastically according to weather conditions. So necessary adjustment should be made empirically according to the weather data of the particular area.

- (f) The capacity compensation coefficient and power consumption compensation coefficient vary according to the total capacity of concurrently operating indoor units, as shown next page.




### Model FDCA140HKXEN4R, 140, 160HKXES4R

#### ◆ Capacity compensation coefficient




#### ◆ Power consumption compensation coefficient




### Model FDCA224HKXE4R

### 224HKXRE4R

#### ◆ Capacity compensation coefficient





#### ◆ Power consumption compensation coefficient





**Model FDCA280HKXE4R**  
**280HKXRE4R**

◆ Capacity compensation coefficient





◆ Power consumption compensation coefficient





**Model FDCA335HKXE4R**  
**335HKXRE4R**

◆ Capacity compensation coefficient




◆ Power consumption compensation coefficient




**Model FDCA400HKXE4R  
400HKXRE4R**

◆ Capacity compensation coefficient

Cooling




Heating




◆ Power consumption compensation coefficient

Cooling




Heating




**Model FDCA450HKXE4R  
450HKXRE4R**

◆ Capacity compensation coefficient

Cooling




Heating




◆ Power consumption compensation coefficient

Cooling




Heating




**Model FDCA504HKXE4R**  
**504HKXRE4R**


◆ **Capacity compensation coefficient**  
**Cooling**




**Heating**



◆ **Power consumption compensation coefficient**  
**Cooling**




**Heating**




**Model FDCA560HKXE4R**  
**560HKXRE4R**


◆ **Capacity compensation coefficient**  
**Cooling**




**Heating**



◆ **Power consumption compensation coefficient**  
**Cooling**




**Heating**




**Model FDCA615HKXE4R**  
**615HKXRE4R**


◆ **Capacity compensation coefficient**  
**Cooling**




**Heating**



◆ **Power consumption compensation coefficient**  
**Cooling**




**Heating**




**Model FDCA680HKXE4R**  
**680HKXRE4R**


◆ **Capacity compensation coefficient**  
**Cooling**




**Heating**



◆ **Power consumption compensation coefficient**  
**Cooling**




**Heating**




**Model FDCA735HKXE4R  
735HKXRE4R**

◆ **Capacity compensation coefficient**

**Cooling**




**Heating**




◆ **Power consumption compensation coefficient**

**Cooling**




**Heating**




**Model FDCA800HKXE4R  
800HKXRE4R**

◆ **Capacity compensation coefficient**

**Cooling**




**Heating**




◆ **Power consumption compensation coefficient**

**Cooling**



**Heating**




**Model FDCA850HKXE4R**


**850HKXRE4R**

◆ **Capacity compensation coefficient**

**Cooling**




**Heating**




◆ **Power consumption compensation coefficient**

**Cooling**



**Heating**




**Model FDCA900HKXE4R**


**900HKXRE4R**

◆ **Capacity compensation coefficient**

**Cooling**




**Heating**




◆ **Power consumption compensation coefficient**

**Cooling**




**Heating**




**Model FDCA960HKXE4R  
960HKXRE4R**


◆ **Capacity compensation coefficient**  
**Cooling**




**Heating**



◆ **Power consumption compensation coefficient**  
**Cooling**




**Heating**




**Model FDCA1010HKXE4R  
1010HKXRE4R**


◆ **Capacity compensation coefficient**  
**Cooling**




**Heating**



◆ **Power consumption compensation coefficient**  
**Cooling**




**Heating**






**Model FDCA1065HKXE4R**  
**1065HKXRE4R**


◆ **Capacity compensation coefficient**  
**Cooling**




**Heating**



◆ **Power consumption compensation coefficient**  
**Cooling**




**Heating**




**Model FDCA1130HKXE4R**  
**1130HKXRE4R**


◆ **Capacity compensation coefficient**  
**Cooling**




**Heating**



◆ **Power consumption compensation coefficient**  
**Cooling**




**Heating**




**Model FDCA1180HKXE4R**  
**1180HKXRE4R**


◆ **Capacity compensation coefficient**  
**Cooling**




**Heating**



◆ **Power consumption compensation coefficient**  
**Cooling**




**Heating**




**Model FDCA1235HKXE4R**  
**1235HKXRE4R**


◆ **Capacity compensation coefficient**  
**Cooling**




**Heating**



◆ **Power consumption compensation coefficient**  
**Cooling**




**Heating**




**Model FDCA1300HKXE4R  
1300HKXRE4R**


◆ **Capacity compensation coefficient**  
**Cooling**




**Heating**



◆ **Power consumption compensation coefficient**  
**Cooling**




**Heating**




**Model FDCA1360HKXE4R  
1360HKXRE4R**


◆ **Capacity compensation coefficient**  
**Cooling**




**Heating**



◆ **Power consumption compensation coefficient**  
**Cooling**



**Heating**



(4) Sensible heat capacity

(a) FDTC Series

Model FDTCA22KXE4R

Air Flow	Outdoor Temp °CDB	Indoor Temp													
		14°CWB		16°CWB		18°CWB		19°CWB		20°CWB		22°CWB		24°CWB	
		TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
Hi	10	—	—	1.91	1.79	2.16	1.98	2.29	1.99	2.42	2.01	2.65	2.15	2.88	2.15
	12	—	—	1.91	1.79	2.16	1.98	2.29	1.99	2.42	2.01	2.65	2.15	2.88	2.15
	14	—	—	1.91	1.79	2.16	1.98	2.29	1.99	2.42	2.01	2.65	2.15	2.88	2.15
	16	—	—	1.91	1.79	2.16	1.98	2.29	1.99	2.42	2.01	2.65	2.15	2.88	2.15
	18	—	—	1.91	1.79	2.16	1.98	2.29	1.99	2.42	2.01	2.65	2.15	2.88	2.15
	20	—	—	1.90	1.79	2.16	1.98	2.29	1.99	2.42	2.01	2.65	2.15	2.88	2.15
	22	—	—	1.90	1.79	2.16	1.98	2.29	1.99	2.42	2.01	2.65	2.15	2.88	2.15
	24	—	—	1.90	1.79	2.16	1.98	2.29	1.99	2.42	2.00	2.64	2.15	2.86	2.14
	26	1.60	1.54	1.90	1.79	2.16	1.98	2.29	1.99	2.42	2.00	2.63	2.14	2.84	2.14
	28	1.60	1.53	1.90	1.79	2.15	1.97	2.27	1.98	2.40	2.00	2.60	2.14	2.79	2.12
	30	1.60	1.53	1.90	1.79	2.14	1.97	2.26	1.98	2.38	1.99	2.56	2.12	2.75	2.11
	32	1.59	1.53	1.88	1.78	2.11	1.96	2.23	1.97	2.35	1.98	2.52	2.11	2.70	2.09
	34	1.59	1.52	1.86	1.77	2.09	1.95	2.20	1.96	2.32	1.97	2.48	2.10	2.65	2.08
	35	1.58	1.52	1.85	1.77	2.07	1.94	2.20	1.95	2.30	1.96	2.47	2.09	2.63	2.07
	36	1.58	1.52	1.83	1.76	2.06	1.94	2.18	1.95	2.29	1.96	2.45	2.08	2.61	2.07
	38	1.58	1.52	1.81	1.74	2.04	1.93	2.15	1.94	2.26	1.94	2.41	2.07	2.57	2.05
	39	1.58	1.51	1.80	1.73	2.02	1.92	2.13	1.93	2.24	1.94	2.39	2.07	2.55	2.04

Model FDTCA28KXE4R

Air Flow	Outdoor Temp °CDB	Indoor Temp													
		14°CWB		16°CWB		18°CWB		19°CWB		20°CWB		22°CWB		24°CWB	
		TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
Hi	10	—	—	2.42	2.01	2.76	2.22	2.92	2.24	3.09	2.26	3.38	2.41	3.67	2.41
	12	—	—	2.42	2.01	2.76	2.22	2.92	2.24	3.09	2.26	3.38	2.41	3.67	2.41
	14	—	—	2.42	2.01	2.76	2.22	2.92	2.24	3.09	2.26	3.38	2.41	3.67	2.41
	16	—	—	2.42	2.01	2.76	2.22	2.92	2.24	3.09	2.26	3.38	2.41	3.67	2.41
	18	—	—	2.42	2.01	2.76	2.22	2.92	2.24	3.09	2.26	3.38	2.41	3.67	2.41
	20	—	—	2.42	2.01	2.76	2.22	2.92	2.24	3.09	2.26	3.38	2.41	3.67	2.41
	22	—	—	2.42	2.00	2.75	2.22	2.92	2.24	3.09	2.26	3.38	2.41	3.67	2.41
	24	—	—	2.42	2.00	2.75	2.22	2.91	2.24	3.08	2.26	3.36	2.40	3.64	2.40
	26	2.04	1.92	2.42	2.00	2.75	2.22	2.91	2.24	3.07	2.25	3.34	2.40	3.61	2.39
	28	2.03	1.92	2.42	2.00	2.74	2.21	2.89	2.23	3.05	2.24	3.30	2.39	3.55	2.37
	30	2.03	1.92	2.41	2.00	2.72	2.21	2.88	2.22	3.03	2.24	3.26	2.37	3.50	2.35
	32	2.02	1.91	2.39	1.99	2.69	2.18	2.84	2.21	2.99	2.22	3.21	2.36	3.43	2.33
	34	2.02	1.91	2.36	1.98	2.66	2.17	2.80	2.19	2.95	2.21	3.16	2.33	3.37	2.31
	35	2.02	1.91	2.35	1.98	2.64	2.16	2.80	2.19	2.93	2.20	3.14	2.31	3.35	2.30
	36	2.02	1.91	2.34	1.97	2.62	2.16	2.77	2.18	2.91	2.19	3.12	2.30	3.32	2.28
	38	2.01	1.90	2.31	1.96	2.59	2.14	2.73	2.15	2.87	2.18	3.07	2.29	3.26	2.26
	39	2.01	1.90	2.29	1.96	2.57	2.14	2.71	2.15	2.85	2.17	3.05	2.28	3.24	2.26

Model FDTCA36KXE4R

Air Flow	Outdoor Temp °CDB	Indoor Temp													
		14°CWB		16°CWB		18°CWB		19°CWB		20°CWB		22°CWB		24°CWB	
		TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
Hi	10	—	—	3.12	2.58	3.54	2.84	3.75	2.87	3.97	2.90	4.34	3.09	4.72	3.09
	12	—	—	3.12	2.58	3.54	2.84	3.75	2.87	3.97	2.90	4.34	3.09	4.72	3.09
	14	—	—	3.12	2.58	3.54	2.84	3.75	2.87	3.97	2.90	4.34	3.09	4.72	3.09
	16	—	—	3.12	2.58	3.54	2.84	3.75	2.87	3.97	2.90	4.34	3.09	4.72	3.09
	18	—	—	3.12	2.58	3.54	2.84	3.75	2.87	3.97	2.90	4.34	3.09	4.72	3.09
	20	—	—	3.11	2.58	3.54	2.84	3.75	2.87	3.97	2.90	4.34	3.09	4.71	3.09
	22	—	—	3.11	2.58	3.54	2.84	3.75	2.87	3.97	2.90	4.34	3.09	4.71	3.09
	24	—	—	3.11	2.58	3.54	2.84	3.75	2.87	3.96	2.89	4.32	3.08	4.68	3.08
	26	2.62	2.46	3.11	2.58	3.53	2.84	3.74	2.87	3.95	2.89	4.30	3.07	4.64	3.06
	28	2.61	2.46	3.11	2.58	3.52	2.83	3.72	2.86	3.92	2.87	4.25	3.06	4.57	3.04
	30	2.61	2.45	3.10	2.57	3.50	2.83	3.70	2.85	3.90	2.86	4.19	3.04	4.50	3.01
	32	2.60	2.45	3.07	2.56	3.46	2.81	3.65	2.83	3.84	2.84	4.13	3.01	4.41	2.99
	34	2.60	2.45	3.04	2.55	3.42	2.79	3.60	2.81	3.79	2.83	4.06	2.99	4.33	2.96
	35	2.59	2.45	3.02	2.54	3.39	2.78	3.60	2.81	3.77	2.82	4.04	2.98	4.30	2.93
	36	2.59	2.45	3.00	2.53	3.37	2.77	3.56	2.79	3.74	2.81	4.01	2.96	4.27	2.92
	38	2.58	2.44	2.97	2.52	3.33	2.75	3.51	2.78	3.69	2.79	3.95	2.93	4.20	2.90
	39	2.58	2.44	2.95	2.51	3.31	2.75	3.49	2.77	3.67	2.78	3.92	2.92	4.17	2.89

Note (1) Symbols are as follows :

**TC** :Total cooling capacity (kw)  
**SHC** :Sensible heat capacity (kw)

### Model FDTCA45KXE4R

Air Flow	Outdoor Temp	Indoor Temp													
		14°CWB		16°CWB		18°CWB		19°CWB		20°CWB		22°CWB		24°CWB	
	°CDB	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
Hi	10	—	—	3.90	3.04	4.43	3.35	4.69	3.38	4.96	3.41	5.43	3.63	5.90	3.63
	12	—	—	3.90	3.04	4.43	3.35	4.69	3.38	4.96	3.41	5.43	3.63	5.90	3.63
	14	—	—	3.90	3.04	4.43	3.35	4.69	3.38	4.96	3.41	5.43	3.63	5.90	3.63
	16	—	—	3.90	3.04	4.43	3.35	4.69	3.38	4.96	3.41	5.43	3.63	5.90	3.63
	18	—	—	3.90	3.04	4.43	3.35	4.69	3.38	4.96	3.41	5.43	3.63	5.90	3.63
	20	—	—	3.89	3.04	4.43	3.35	4.69	3.38	4.96	3.41	5.43	3.63	5.89	3.63
	22	—	—	3.89	3.04	4.42	3.34	4.69	3.38	4.96	3.41	5.43	3.63	5.89	3.63
	24	—	—	3.89	3.04	4.42	3.34	4.68	3.38	4.95	3.41	5.40	3.62	5.85	3.61
	26	3.28	2.88	3.89	3.04	4.41	3.34	4.68	3.38	4.94	3.41	5.37	3.61	5.80	3.60
	28	3.27	2.87	3.88	3.04	4.40	3.33	4.65	3.36	4.91	3.39	5.31	3.59	5.71	3.57
	30	3.26	2.87	3.88	3.04	4.37	3.32	4.62	3.35	4.87	3.37	5.24	3.56	5.62	3.54
	32	3.25	2.87	3.84	3.02	4.32	3.30	4.56	3.33	4.81	3.35	5.16	3.53	5.52	3.50
	34	3.24	2.86	3.80	3.00	4.27	3.28	4.50	3.30	4.74	3.32	5.08	3.50	5.42	3.46
	35	3.24	2.86	3.78	2.99	4.24	3.26	4.50	3.30	4.71	3.31	5.04	3.49	5.38	3.45
	36	3.24	2.86	3.75	2.98	4.22	3.25	4.45	3.28	4.68	3.30	5.01	3.48	5.33	3.44
	38	3.23	2.86	3.71	2.96	4.16	3.23	4.39	3.25	4.62	3.28	4.93	3.44	5.25	3.41
	39	3.23	2.85	3.69	2.95	4.14	3.22	4.36	3.24	4.59	3.26	4.90	3.43	5.21	3.39

### Model FDTCA56KXE4R

Model FDCAS3024W																
Air Flow	Outdoor Temp	Indoor Temp														
		14°CWB		16°CWB		18°CWB		19°CWB		20°CWB		22°CWB		24°CWB		
	°CDB	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	
Hi	10	—	—	4.85	3.69	5.51	4.05	5.84	4.10	6.17	4.14	6.75	4.39	7.34	4.39	
	12	—	—	4.85	3.69	5.51	4.05	5.84	4.10	6.17	4.14	6.75	4.39	7.34	4.39	
	14	—	—	4.85	3.69	5.51	4.05	5.84	4.10	6.17	4.14	6.75	4.39	7.34	4.39	
	16	—	—	4.85	3.69	5.51	4.05	5.84	4.10	6.17	4.14	6.75	4.39	7.34	4.39	
	18	—	—	4.85	3.69	5.51	4.05	5.84	4.10	6.17	4.14	6.75	4.39	7.34	4.39	
	20	—	—	4.84	3.68	5.51	4.05	5.84	4.10	6.17	4.14	6.75	4.39	7.33	4.39	
	22	—	—	4.84	3.68	5.50	4.05	5.84	4.10	6.17	4.14	6.75	4.39	7.33	4.39	
	24	—	—	4.84	3.68	5.50	4.04	5.83	4.09	6.16	4.14	6.72	4.38	7.27	4.37	
	26	4.08	3.48	4.84	3.68	5.49	4.04	5.82	4.09	6.15	4.13	6.69	4.37	7.22	4.35	
	28	4.07	3.47	4.83	3.68	5.47	4.03	5.78	4.07	6.10	4.11	6.61	4.34	7.11	4.31	
	30	4.06	3.47	4.83	3.68	5.44	4.02	5.75	4.06	6.06	4.10	6.52	4.31	6.99	4.27	
	32	4.05	3.46	4.78	3.65	5.38	3.99	5.68	4.03	5.98	4.06	6.42	4.27	6.87	4.23	
	34	4.04	3.46	4.73	3.63	5.31	3.97	5.61	4.00	5.90	4.03	6.32	4.24	6.74	4.19	
	35	4.03	3.46	4.70	3.62	5.28	3.95	5.60	3.99	5.86	4.01	6.28	4.21	6.69	4.17	
	36	4.03	3.46	4.67	3.61	5.25	3.93	5.54	3.97	5.82	4.00	6.23	4.20	6.64	4.16	
	38	4.02	3.45	4.61	3.58	5.18	3.90	5.47	3.94	5.75	3.96	6.14	4.16	6.53	4.11	
	39	4.02	3.45	4.59	3.57	5.15	3.89	5.43	3.92	5.71	3.95	6.09	4.15	6.48	4.10	

### (b) FDT Series

#### Model FDTA28KXE4R

Air Flow	Outdoor Temp	Indoor Temp													
		14°CWB		16°CWB		18°CWB		19°CWB		20°CWB		22°CWB		24°CWB	
	°CDB	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
Hi	10	—	—	2.42	2.33	2.76	2.64	2.92	2.72	3.09	2.73	3.38	2.95	3.67	2.94
	12	—	—	2.42	2.33	2.76	2.64	2.92	2.72	3.09	2.73	3.38	2.95	3.67	2.94
	14	—	—	2.42	2.33	2.76	2.64	2.92	2.72	3.09	2.73	3.38	2.95	3.67	2.94
	16	—	—	2.42	2.33	2.76	2.64	2.92	2.72	3.09	2.73	3.38	2.95	3.67	2.94
	18	—	—	2.42	2.33	2.76	2.64	2.92	2.72	3.09	2.73	3.38	2.95	3.67	2.94
	20	—	—	2.42	2.33	2.76	2.64	2.92	2.72	3.09	2.73	3.38	2.95	3.67	2.94
	22	—	—	2.42	2.32	2.75	2.64	2.92	2.72	3.09	2.73	3.38	2.95	3.67	2.94
	24	—	—	2.42	2.32	2.75	2.64	2.91	2.72	3.08	2.73	3.36	2.94	3.64	2.93
	26	2.04	1.96	2.42	2.32	2.75	2.64	2.91	2.72	3.07	2.73	3.34	2.93	3.61	2.93
	28	2.03	1.95	2.42	2.32	2.74	2.63	2.89	2.71	3.05	2.72	3.30	2.92	3.55	2.90
	30	2.03	1.95	2.41	2.32	2.72	2.61	2.88	2.71	3.03	2.72	3.26	2.91	3.50	2.89
	32	2.02	1.94	2.39	2.29	2.69	2.58	2.84	2.70	2.99	2.70	3.21	2.90	3.43	2.87
	34	2.02	1.94	2.36	2.27	2.66	2.55	2.80	2.68	2.95	2.69	3.16	2.87	3.37	2.85
	35	2.02	1.94	2.35	2.26	2.64	2.53	2.80	2.67	2.93	2.68	3.14	2.87	3.35	2.84
	36	2.02	1.94	2.34	2.24	2.62	2.52	2.77	2.66	2.91	2.68	3.12	2.86	3.32	2.83
	38	2.01	1.93	2.31	2.21	2.59	2.49	2.73	2.62	2.87	2.66	3.07	2.85	3.26	2.82
	39	2.01	1.93	2.29	2.20	2.57	2.47	2.71	2.60	2.85	2.65	3.05	2.84	3.24	2.81

Note (1) Symbols are as follows :

**TC** :Total cooling capacity (kw)  
**SHC** :Sensible heat capacity (kw)

### Model FDTA36KXE4R

Air Flow	Outdoor Temp °CDB	Indoor Temp													
		14°CWB		16°CWB		18°CWB		19°CWB		20°CWB		22°CWB		24°CWB	
		TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
Hi	10	—	—	3.12	2.74	3.54	3.02	3.75	3.04	3.97	3.05	4.34	3.28	4.72	3.28
	12	—	—	3.12	2.74	3.54	3.02	3.75	3.04	3.97	3.05	4.34	3.28	4.72	3.28
	14	—	—	3.12	2.74	3.54	3.02	3.75	3.04	3.97	3.05	4.34	3.28	4.72	3.28
	16	—	—	3.12	2.74	3.54	3.02	3.75	3.04	3.97	3.05	4.34	3.28	4.72	3.28
	18	—	—	3.12	2.74	3.54	3.02	3.75	3.04	3.97	3.05	4.34	3.28	4.72	3.28
	20	—	—	3.11	2.74	3.54	3.02	3.75	3.04	3.97	3.05	4.34	3.28	4.71	3.28
	22	—	—	3.11	2.74	3.54	3.02	3.75	3.04	3.97	3.05	4.34	3.28	4.71	3.28
	24	—	—	3.11	2.74	3.54	3.01	3.75	3.03	3.96	3.05	4.32	3.27	4.68	3.27
	26	2.62	2.52	3.11	2.74	3.53	3.01	3.74	3.03	3.95	3.05	4.30	3.27	4.64	3.25
	28	2.61	2.51	3.11	2.74	3.52	3.01	3.72	3.02	3.92	3.04	4.25	3.25	4.57	3.23
	30	2.61	2.51	3.10	2.73	3.50	3.00	3.70	3.02	3.90	3.03	4.19	3.23	4.50	3.20
	32	2.60	2.50	3.07	2.72	3.46	2.98	3.65	3.00	3.84	3.01	4.13	3.21	4.41	3.18
	34	2.60	2.49	3.04	2.70	3.42	2.96	3.60	2.99	3.79	3.00	4.06	3.18	4.33	3.15
	35	2.59	2.49	3.02	2.70	3.39	2.96	3.60	2.98	3.77	2.99	4.04	3.17	4.30	3.14
	36	2.59	2.49	3.00	2.69	3.37	2.95	3.56	2.96	3.74	2.98	4.01	3.16	4.27	3.13
	38	2.58	2.48	2.97	2.67	3.33	2.93	3.51	2.95	3.69	2.96	3.95	3.12	4.20	3.09
	39	2.58	2.48	2.95	2.67	3.31	2.92	3.49	2.94	3.67	2.95	3.92	3.11	4.17	3.08

### Model FDTA45KXE4R

Air Flow	Outdoor Temp °CDB	Indoor Temp													
		14°CWB		16°CWB		18°CWB		19°CWB		20°CWB		22°CWB		24°CWB	
		TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
Hi	10	—	—	3.90	3.16	4.43	3.48	4.69	3.52	4.96	3.55	5.43	3.77	5.90	3.78
	12	—	—	3.90	3.16	4.43	3.48	4.69	3.52	4.96	3.55	5.43	3.77	5.90	3.78
	14	—	—	3.90	3.16	4.43	3.48	4.69	3.52	4.96	3.55	5.43	3.77	5.90	3.78
	16	—	—	3.90	3.16	4.43	3.48	4.69	3.52	4.96	3.55	5.43	3.77	5.90	3.78
	18	—	—	3.90	3.16	4.43	3.48	4.69	3.52	4.96	3.55	5.43	3.77	5.90	3.78
	20	—	—	3.89	3.16	4.43	3.48	4.69	3.52	4.96	3.55	5.43	3.77	5.89	3.78
	22	—	—	3.89	3.16	4.42	3.48	4.69	3.52	4.96	3.55	5.43	3.77	5.89	3.78
	24	—	—	3.89	3.16	4.42	3.47	4.68	3.52	4.95	3.54	5.40	3.76	5.85	3.77
	26	3.28	3.01	3.89	3.16	4.41	3.47	4.68	3.51	4.94	3.54	5.37	3.75	5.80	3.73
	28	3.27	3.00	3.88	3.16	4.40	3.47	4.65	3.50	4.91	3.53	5.31	3.73	5.71	3.71
	30	3.26	3.00	3.88	3.16	4.37	3.46	4.62	3.49	4.87	3.51	5.24	3.71	5.62	3.68
	32	3.25	3.00	3.84	3.13	4.32	3.44	4.56	3.47	4.81	3.49	5.16	3.69	5.52	3.65
	34	3.24	2.99	3.80	3.11	4.27	3.41	4.50	3.44	4.74	3.46	5.08	3.66	5.42	3.62
	35	3.24	2.99	3.78	3.10	4.24	3.40	4.50	3.44	4.71	3.45	5.04	3.64	5.38	3.60
	36	3.24	2.99	3.75	3.09	4.22	3.39	4.45	3.42	4.68	3.44	5.01	3.63	5.33	3.59
	38	3.23	2.99	3.71	3.07	4.16	3.37	4.39	3.39	4.62	3.41	4.93	3.60	5.25	3.56
	39	3.23	2.98	3.69	3.07	4.14	3.36	4.36	3.38	4.59	3.40	4.90	3.59	5.21	3.55

### Model FDTA56KXE4R

Air Flow	Outdoor Temp °CDB	Indoor Temp													
		14°CWB		16°CWB		18°CWB		19°CWB		20°CWB		22°CWB		24°CWB	
		TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
Hi	10	—	—	4.85	3.60	5.51	3.96	5.84	4.01	6.17	4.05	6.75	4.31	7.34	4.31
	12	—	—	4.85	3.60	5.51	3.96	5.84	4.01	6.17	4.05	6.75	4.31	7.34	4.31
	14	—	—	4.85	3.60	5.51	3.96	5.84	4.01	6.17	4.05	6.75	4.31	7.34	4.31
	16	—	—	4.85	3.60	5.51	3.96	5.84	4.01	6.17	4.05	6.75	4.31	7.34	4.31
	18	—	—	4.85	3.60	5.51	3.96	5.84	4.01	6.17	4.05	6.75	4.31	7.34	4.31
	20	—	—	4.84	3.60	5.51	3.96	5.84	4.01	6.17	4.05	6.75	4.31	7.33	4.31
	22	—	—	4.84	3.60	5.50	3.96	5.84	4.01	6.17	4.05	6.75	4.31	7.33	4.31
	24	—	—	4.84	3.60	5.50	3.95	5.83	4.01	6.16	4.04	6.72	4.29	7.27	4.29
	26	4.08	3.39	4.84	3.60	5.49	3.95	5.82	4.00	6.15	4.04	6.69	4.28	7.22	4.27
	28	4.07	3.38	4.83	3.59	5.47	3.94	5.78	3.99	6.10	4.02	6.61	4.25	7.11	4.23
	30	4.06	3.38	4.83	3.59	5.44	3.93	5.75	3.97	6.06	4.01	6.52	4.21	6.99	4.18
	32	4.05	3.37	4.78	3.57	5.38	3.90	5.68	3.94	5.98	3.97	6.42	4.16	6.87	4.14
	34	4.04	3.37	4.73	3.55	5.31	3.87	5.61	3.91	5.90	3.94	6.32	4.13	6.74	4.08
	35	4.03	3.37	4.70	3.53	5.28	3.85	5.60	3.91	5.86	3.92	6.28	4.11	6.69	4.06
	36	4.03	3.37	4.67	3.52	5.25	3.84	5.54	3.88	5.82	3.90	6.23	4.10	6.64	4.05
	38	4.02	3.36	4.61	3.50	5.18	3.81	5.47	3.84	5.75	3.87	6.14	4.06	6.53	4.01
	39	4.02	3.36	4.59	3.48	5.15	3.79	5.43	3.83	5.71	3.85	6.09	4.04	6.48	4.00

Note (1) Symbols are as follows :

**TC** :Total cooling capacity (kw)  
**SHC** :Sensible heat capacity (kw)

### Model FDTA71KXE4R

Air Flow	Outdoor Temp	Indoor Temp													
		14°CWB		16°CWB		18°CWB		19°CWB		20°CWB		22°CWB		24°CWB	
	°CDB	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
Hi	10	—	—	6.15	4.57	6.99	5.01	7.41	5.08	7.82	5.13	8.56	5.45	9.30	5.46
	12	—	—	6.15	4.57	6.99	5.01	7.41	5.08	7.82	5.13	8.56	5.45	9.30	5.46
	14	—	—	6.15	4.57	6.99	5.01	7.41	5.08	7.82	5.13	8.56	5.45	9.30	5.46
	16	—	—	6.15	4.57	6.99	5.01	7.41	5.08	7.82	5.13	8.56	5.45	9.30	5.46
	18	—	—	6.15	4.57	6.99	5.01	7.41	5.08	7.82	5.13	8.56	5.45	9.30	5.46
	20	—	—	6.14	4.57	6.99	5.01	7.41	5.08	7.82	5.13	8.56	5.45	9.29	5.46
	22	—	—	6.13	4.56	6.98	5.01	7.41	5.08	7.82	5.13	8.56	5.45	9.29	5.46
	24	—	—	6.13	4.56	6.97	5.01	7.39	5.07	7.81	5.12	8.52	5.43	9.22	5.43
	26	5.17	4.29	6.13	4.56	6.97	5.00	7.38	5.07	7.80	5.12	8.48	5.42	9.15	5.40
	28	5.15	4.29	6.13	4.56	6.94	4.99	7.33	5.05	7.74	5.09	8.38	5.38	9.01	5.34
	30	5.15	4.28	6.12	4.56	6.90	4.97	7.29	5.03	7.68	5.07	8.27	5.34	8.87	5.29
	32	5.13	4.27	6.06	4.53	6.82	4.94	7.20	4.98	7.58	5.03	8.14	5.28	8.70	5.24
	34	5.12	4.27	5.99	4.49	6.74	4.90	7.11	4.95	7.48	4.99	8.02	5.23	8.55	5.17
	35	5.11	4.26	5.96	4.47	6.70	4.88	7.10	4.94	7.43	4.97	7.96	5.21	8.48	5.15
	36	5.11	4.26	5.92	4.46	6.65	4.86	7.02	4.91	7.38	4.94	7.90	5.19	8.41	5.13
	38	5.10	4.26	5.85	4.43	6.57	4.82	6.93	4.87	7.28	4.90	7.78	5.14	8.28	5.08
	39	5.09	4.25	5.81	4.41	6.52	4.80	6.88	4.85	7.23	4.88	7.72	5.12	8.21	5.06

### Model FDTA90KXE4R

Air Flow		Outdoor Temp	Indoor Temp													
			14°CWB		16°CWB		18°CWB		19°CWB		20°CWB		22°CWB		24°CWB	
		°CDB	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
Hi	10	—	—	7.79	6.03	8.86	6.63	9.39	6.70	9.92	6.76	10.85	7.20	11.79	7.21	
	12	—	—	7.79	6.03	8.86	6.63	9.39	6.70	9.92	6.76	10.85	7.20	11.79	7.21	
	14	—	—	7.79	6.03	8.86	6.63	9.39	6.70	9.92	6.76	10.85	7.20	11.79	7.21	
	16	—	—	7.79	6.03	8.86	6.63	9.39	6.70	9.92	6.76	10.85	7.20	11.79	7.21	
	18	—	—	7.79	6.03	8.86	6.63	9.39	6.70	9.92	6.76	10.85	7.20	11.79	7.21	
	20	—	—	7.79	6.03	8.86	6.63	9.39	6.70	9.92	6.76	10.85	7.20	11.78	7.20	
	22	—	—	7.78	6.02	8.85	6.62	9.39	6.70	9.92	6.76	10.85	7.20	11.78	7.20	
	24	—	—	7.78	6.02	8.84	6.62	9.37	6.69	9.90	6.75	10.80	7.18	11.69	7.17	
	26	6.55	5.69	7.78	6.02	8.83	6.61	9.36	6.69	9.88	6.74	10.75	7.16	11.60	7.14	
	28	6.53	5.68	7.77	6.02	8.79	6.60	9.30	6.66	9.81	6.71	10.62	7.11	11.42	7.07	
	30	6.53	5.68	7.76	6.01	8.75	6.58	9.24	6.64	9.74	6.69	10.49	7.06	11.24	7.00	
	32	6.51	5.67	7.68	5.98	8.64	6.53	9.13	6.59	9.61	6.64	10.32	7.00	11.03	6.93	
	34	6.49	5.66	7.60	5.94	8.54	6.49	9.01	6.54	9.49	6.58	10.16	6.94	10.84	6.87	
	35	6.48	5.65	7.55	5.92	8.49	6.47	9.00	6.54	9.42	6.56	10.09	6.91	10.76	6.84	
	36	6.48	5.65	7.51	5.90	8.43	6.45	8.90	6.50	9.36	6.54	10.02	6.88	10.67	6.81	
	38	6.46	5.65	7.42	5.86	8.33	6.40	8.78	6.45	9.23	6.49	9.86	6.82	10.49	6.74	
	39	6.45	5.64	7.37	5.84	8.27	6.38	8.72	6.42	9.17	6.46	9.79	6.79	10.41	6.71	

### Model FDTA112KXE4R

Air Flow	Outdoor Temp	Indoor Temp													
		14°CWB		16°CWB		18°CWB		19°CWB		20°CWB		22°CWB		24°CWB	
		°CDB	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC
Hi	10	—	—	9.70	7.61	11.02	8.35	11.68	8.44	12.34	8.52	13.51	9.09	14.67	9.10
	12	—	—	9.70	7.61	11.02	8.35	11.68	8.44	12.34	8.52	13.51	9.09	14.67	9.10
	14	—	—	9.70	7.61	11.02	8.35	11.68	8.44	12.34	8.52	13.51	9.09	14.67	9.10
	16	—	—	9.70	7.61	11.02	8.35	11.68	8.44	12.34	8.52	13.51	9.09	14.67	9.10
	18	—	—	9.70	7.61	11.02	8.35	11.68	8.44	12.34	8.52	13.51	9.09	14.67	9.10
	20	—	—	9.69	7.61	11.02	8.35	11.68	8.44	12.34	8.52	13.51	9.09	14.66	9.09
	22	—	—	9.68	7.60	11.01	8.35	11.68	8.44	12.34	8.52	13.51	9.09	14.66	9.09
	24	—	—	9.68	7.60	11.00	8.34	11.66	8.43	12.32	8.51	13.44	9.07	14.55	9.05
	26	8.15	7.21	9.68	7.60	10.99	8.34	11.65	8.43	12.30	8.50	13.37	9.04	14.44	9.02
	28	8.13	7.20	9.67	7.60	10.94	8.32	11.57	8.40	12.21	8.46	13.22	8.98	14.21	8.92
	30	8.12	7.20	9.65	7.59	10.89	8.30	11.50	8.37	12.12	8.43	13.05	8.92	13.99	8.85
	32	8.10	7.18	9.55	7.55	10.75	8.24	11.36	8.31	11.96	8.36	12.85	8.84	13.73	8.76
	34	8.08	7.17	9.45	7.50	10.63	8.19	11.21	8.25	11.80	8.30	12.64	8.77	13.48	8.68
	35	8.06	7.16	9.40	7.48	10.56	8.16	11.20	8.24	11.73	8.27	12.56	8.74	13.38	8.64
	36	8.06	7.16	9.34	7.45	10.49	8.13	11.08	8.19	11.65	8.24	12.47	8.71	13.27	8.60
	38	8.04	7.15	9.23	7.40	10.36	8.08	10.93	8.14	11.49	8.18	12.28	8.64	13.06	8.53
	39	8.03	7.14	9.17	7.38	10.29	8.05	10.85	8.10	11.41	8.15	12.19	8.59	12.96	8.50

Note (1) Symbols are as follows :

**TC** :Total cooling capacity (kw)  
**SHC** :Sensible heat capacity (kw)

### Model FDTA140KXE4R

Air Flow	Outdoor Temp °CDB	Indoor Temp													
		14°CWB		16°CWB		18°CWB		19°CWB		20°CWB		22°CWB		24°CWB	
		TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
Hi	10	—	—	12.12	8.96	13.78	9.83	14.60	9.96	15.43	10.06	16.88	10.70	18.34	10.71
	12	—	—	12.12	8.96	13.78	9.83	14.60	9.96	15.43	10.06	16.88	10.70	18.34	10.71
	14	—	—	12.12	8.96	13.78	9.83	14.60	9.96	15.43	10.06	16.88	10.70	18.34	10.71
	16	—	—	12.12	8.96	13.78	9.83	14.60	9.96	15.43	10.06	16.88	10.70	18.34	10.71
	18	—	—	12.12	8.96	13.78	9.83	14.60	9.96	15.43	10.06	16.88	10.70	18.34	10.71
	20	—	—	12.11	8.95	13.78	9.83	14.60	9.96	15.43	10.06	16.88	10.70	18.33	10.70
	22	—	—	12.10	8.95	13.76	9.83	14.60	9.96	15.43	10.06	16.88	10.70	18.33	10.70
	24	—	—	12.10	8.95	13.75	9.82	14.57	9.95	15.40	10.05	16.80	10.67	18.19	10.65
	26	10.19	8.41	12.10	8.95	13.73	9.82	14.56	9.94	15.37	10.04	16.72	10.64	18.05	10.60
	28	10.16	8.39	12.08	8.94	13.68	9.79	14.46	9.90	15.26	9.99	16.52	10.54	17.77	10.49
	30	10.15	8.39	12.07	8.93	13.61	9.76	14.38	9.86	15.15	9.94	16.31	10.46	17.49	10.39
	32	10.12	8.37	11.94	8.87	13.44	9.69	14.20	9.78	14.95	9.86	16.06	10.36	17.16	10.26
	34	10.09	8.36	11.82	8.82	13.29	9.62	14.01	9.70	14.76	9.78	15.81	10.27	16.86	10.15
	35	10.08	8.35	11.75	8.78	13.20	9.58	14.00	9.70	14.66	9.74	15.69	10.22	16.73	10.11
	36	10.08	8.35	11.68	8.75	13.12	9.54	13.85	9.63	14.56	9.70	15.58	10.17	16.59	10.06
	38	10.05	8.34	11.54	8.69	12.95	9.46	13.66	9.56	14.36	9.62	15.34	10.07	16.32	9.95
	39	10.04	8.33	11.47	8.65	12.87	9.42	13.57	9.51	14.27	9.58	15.23	10.03	16.20	9.91

### (c) FDTW Series

#### Models FDTWA28KXE4R, 28KXE5R

Air Flow	Outdoor Temp °CDB	Indoor Temp													
		14°CWB		16°CWB		18°CWB		19°CWB		20°CWB		22°CWB		24°CWB	
		TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
Hi	10	—	—	2.42	2.26	2.76	2.49	2.92	2.51	3.09	2.53	3.38	2.72	3.67	2.72
	12	—	—	2.42	2.26	2.76	2.49	2.92	2.51	3.09	2.53	3.38	2.72	3.67	2.72
	14	—	—	2.42	2.26	2.76	2.49	2.92	2.51	3.09	2.53	3.38	2.72	3.67	2.72
	16	—	—	2.42	2.26	2.76	2.49	2.92	2.51	3.09	2.53	3.38	2.72	3.67	2.72
	18	—	—	2.42	2.26	2.76	2.49	2.92	2.51	3.09	2.53	3.38	2.72	3.67	2.72
	20	—	—	2.42	2.26	2.76	2.49	2.92	2.51	3.09	2.53	3.38	2.72	3.67	2.71
	22	—	—	2.42	2.26	2.75	2.49	2.92	2.51	3.09	2.53	3.38	2.72	3.67	2.71
	24	—	—	2.42	2.26	2.75	2.49	2.91	2.51	3.08	2.53	3.36	2.71	3.64	2.71
	26	2.04	1.96	2.42	2.26	2.75	2.49	2.91	2.51	3.07	2.53	3.34	2.71	3.61	2.69
	28	2.03	1.95	2.42	2.26	2.74	2.49	2.89	2.50	3.05	2.52	3.30	2.69	3.55	2.68
	30	2.03	1.95	2.41	2.26	2.72	2.48	2.88	2.50	3.03	2.51	3.26	2.68	3.50	2.66
	32	2.02	1.94	2.39	2.24	2.69	2.47	2.84	2.49	2.99	2.49	3.21	2.66	3.43	2.64
	34	2.02	1.94	2.36	2.23	2.66	2.45	2.80	2.47	2.95	2.48	3.16	2.64	3.37	2.62
	35	2.02	1.94	2.35	2.23	2.64	2.45	2.80	2.47	2.93	2.48	3.14	2.61	3.35	2.61
	36	2.02	1.94	2.34	2.22	2.62	2.44	2.77	2.46	2.91	2.47	3.12	2.61	3.32	2.58
	38	2.01	1.93	2.31	2.21	2.59	2.43	2.73	2.45	2.87	2.45	3.07	2.59	3.26	2.56
	39	2.01	1.93	2.29	2.21	2.57	2.43	2.71	2.43	2.85	2.44	3.05	2.59	3.24	2.56

#### Models FDTWA45KXE4R, 45KXE5R

Air Flow	Outdoor Temp °CDB	Indoor Temp													
		14°CWB		16°CWB		18°CWB		19°CWB		20°CWB		22°CWB		24°CWB	
		TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
Hi	10	—	—	3.90	3.29	4.43	3.64	4.69	3.67	4.96	3.70	5.43	3.96	5.90	3.96
	12	—	—	3.90	3.29	4.43	3.64	4.69	3.67	4.96	3.70	5.43	3.96	5.90	3.96
	14	—	—	3.90	3.29	4.43	3.64	4.69	3.67	4.96	3.70	5.43	3.96	5.90	3.96
	16	—	—	3.90	3.29	4.43	3.64	4.69	3.67	4.96	3.70	5.43	3.96	5.90	3.96
	18	—	—	3.90	3.29	4.43	3.64	4.69	3.67	4.96	3.70	5.43	3.96	5.90	3.96
	20	—	—	3.89	3.29	4.43	3.64	4.69	3.67	4.96	3.70	5.43	3.96	5.89	3.95
	22	—	—	3.89	3.29	4.42	3.64	4.69	3.67	4.96	3.70	5.43	3.96	5.89	3.95
	24	—	—	3.89	3.29	4.42	3.64	4.68	3.67	4.95	3.70	5.40	3.95	5.85	3.94
	26	3.28	3.14	3.89	3.29	4.41	3.64	4.68	3.67	4.94	3.69	5.37	3.94	5.80	3.93
	28	3.27	3.14	3.88	3.29	4.40	3.63	4.65	3.65	4.91	3.68	5.31	3.92	5.71	3.89
	30	3.26	3.13	3.88	3.29	4.37	3.61	4.62	3.64	4.87	3.67	5.24	3.89	5.62	3.86
	32	3.25	3.12	3.84	3.27	4.32	3.59	4.56	3.62	4.81	3.64	5.16	3.86	5.52	3.83
	34	3.24	3.11	3.80	3.25	4.27	3.56	4.50	3.60	4.74	3.62	5.08	3.84	5.42	3.80
	35	3.24	3.11	3.78	3.24	4.24	3.55	4.50	3.60	4.71	3.61	5.04	3.82	5.38	3.78
	36	3.24	3.11	3.75	3.23	4.22	3.54	4.45	3.57	4.68	3.59	5.01	3.79	5.33	3.74
	38	3.23	3.10	3.71	3.22	4.16	3.52	4.39	3.54	4.62	3.57	4.93	3.76	5.25	3.72
	39	3.23	3.10	3.69	3.21	4.14	3.51	4.36	3.53	4.59	3.56	4.90	3.75	5.21	3.71

Note (1) Symbols are as follows :

**TC** :Total cooling capacity (kw)  
**SHC** :Sensible heat capacity (kw)



### Models FDTWA56KXE4R, 56KXE5R

Air Flow	Outdoor Temp °CDB	Indoor Temp													
		14°CWB		16°CWB		18°CWB		19°CWB		20°CWB		22°CWB		24°CWB	
		TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
Hi	10	—	—	4.85	3.77	5.51	4.15	5.84	4.19	6.17	4.23	6.75	4.50	7.34	4.51
	12	—	—	4.85	3.77	5.51	4.15	5.84	4.19	6.17	4.23	6.75	4.50	7.34	4.51
	14	—	—	4.85	3.77	5.51	4.15	5.84	4.19	6.17	4.23	6.75	4.50	7.34	4.51
	16	—	—	4.85	3.77	5.51	4.15	5.84	4.19	6.17	4.23	6.75	4.50	7.34	4.51
	18	—	—	4.85	3.77	5.51	4.15	5.84	4.19	6.17	4.23	6.75	4.50	7.34	4.51
	20	—	—	4.84	3.77	5.51	4.15	5.84	4.19	6.17	4.23	6.75	4.50	7.33	4.50
	22	—	—	4.84	3.77	5.50	4.14	5.84	4.19	6.17	4.23	6.75	4.50	7.33	4.50
	24	—	—	4.84	3.77	5.50	4.14	5.83	4.18	6.16	4.22	6.72	4.49	7.27	4.48
	26	4.08	3.57	4.84	3.77	5.49	4.13	5.82	4.18	6.15	4.22	6.69	4.48	7.22	4.46
	28	4.07	3.56	4.83	3.76	5.47	4.12	5.78	4.17	6.10	4.20	6.61	4.44	7.11	4.42
	30	4.06	3.56	4.83	3.76	5.44	4.11	5.75	4.15	6.06	4.19	6.52	4.42	6.99	4.38
	32	4.05	3.55	4.78	3.74	5.38	4.07	5.68	4.12	5.98	4.15	6.42	4.38	6.87	4.34
	34	4.04	3.55	4.73	3.72	5.31	4.05	5.61	4.09	5.90	4.12	6.32	4.34	6.74	4.29
	35	4.03	3.55	4.70	3.70	5.28	4.03	5.60	4.09	5.86	4.10	6.28	4.32	6.69	4.27
	36	4.03	3.55	4.67	3.69	5.25	4.02	5.54	4.05	5.82	4.09	6.23	4.31	6.64	4.26
	38	4.02	3.54	4.61	3.66	5.18	3.99	5.47	4.02	5.75	4.05	6.14	4.27	6.53	4.22
	39	4.02	3.54	4.59	3.65	5.15	3.98	5.43	4.00	5.71	4.04	6.09	4.25	6.48	4.20

### Model FDTWA71KXE4R

Air Flow	Outdoor Temp °CDB	Indoor Temp													
		14°CWB		16°CWB		18°CWB		19°CWB		20°CWB		22°CWB		24°CWB	
		TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
Hi	10	—	—	6.15	4.64	6.99	5.10	7.41	5.16	7.82	5.22	8.56	5.54	9.30	5.54
	12	—	—	6.15	4.64	6.99	5.10	7.41	5.16	7.82	5.22	8.56	5.54	9.30	5.54
	14	—	—	6.15	4.64	6.99	5.10	7.41	5.16	7.82	5.22	8.56	5.54	9.30	5.54
	16	—	—	6.15	4.64	6.99	5.10	7.41	5.16	7.82	5.22	8.56	5.54	9.30	5.54
	18	—	—	6.15	4.64	6.99	5.10	7.41	5.16	7.82	5.22	8.56	5.54	9.30	5.54
	20	—	—	6.14	4.64	6.99	5.10	7.41	5.16	7.82	5.22	8.56	5.54	9.29	5.54
	22	—	—	6.13	4.64	6.98	5.09	7.41	5.16	7.82	5.22	8.56	5.54	9.29	5.54
	24	—	—	6.13	4.64	6.97	5.09	7.39	5.16	7.81	5.21	8.52	5.53	9.22	5.51
	26	5.17	4.37	6.13	4.64	6.97	5.09	7.38	5.15	7.80	5.21	8.48	5.51	9.15	5.49
	28	5.15	4.37	6.13	4.63	6.94	5.08	7.33	5.13	7.74	5.18	8.38	5.47	9.01	5.44
	30	5.15	4.36	6.12	4.63	6.90	5.06	7.29	5.12	7.68	5.15	8.27	5.43	8.87	5.39
	32	5.13	4.36	6.06	4.60	6.82	5.03	7.20	5.07	7.58	5.11	8.14	5.38	8.70	5.33
	34	5.12	4.35	5.99	4.57	6.74	4.99	7.11	5.03	7.48	5.07	8.02	5.33	8.55	5.27
	35	5.11	4.35	5.96	4.56	6.70	4.97	7.10	5.03	7.43	5.05	7.96	5.30	8.48	5.24
	36	5.11	4.35	5.92	4.54	6.65	4.95	7.02	5.00	7.38	5.03	7.90	5.28	8.41	5.22
	38	5.10	4.34	5.85	4.50	6.57	4.90	6.93	4.96	7.28	4.99	7.78	5.24	8.28	5.18
	39	5.09	4.34	5.81	4.49	6.52	4.88	6.88	4.93	7.23	4.97	7.72	5.22	8.21	5.15

### Model FDTWA90KXE4R

Air Flow	Outdoor Temp °CDB	Indoor Temp													
		14°CWB		16°CWB		18°CWB		19°CWB		20°CWB		22°CWB		24°CWB	
		TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
Hi	10	—	—	7.79	5.72	8.86	6.27	9.39	6.36	9.92	6.43	10.85	6.81	11.79	6.84
	12	—	—	7.79	5.72	8.86	6.27	9.39	6.36	9.92	6.43	10.85	6.81	11.79	6.84
	14	—	—	7.79	5.72	8.86	6.27	9.39	6.36	9.92	6.43	10.85	6.81	11.79	6.84
	16	—	—	7.79	5.72	8.86	6.27	9.39	6.36	9.92	6.43	10.85	6.81	11.79	6.84
	18	—	—	7.79	5.72	8.86	6.27	9.39	6.36	9.92	6.43	10.85	6.81	11.79	6.84
	20	—	—	7.79	5.71	8.86	6.27	9.39	6.36	9.92	6.43	10.85	6.81	11.78	6.83
	22	—	—	7.78	5.71	8.85	6.27	9.39	6.36	9.92	6.43	10.85	6.81	11.78	6.83
	24	—	—	7.78	5.71	8.84	6.27	9.37	6.35	9.90	6.42	10.80	6.79	11.69	6.79
	26	6.55	5.36	7.78	5.71	8.83	6.26	9.36	6.35	9.88	6.41	10.75	6.77	11.60	6.74
	28	6.53	5.35	7.77	5.71	8.79	6.25	9.30	6.32	9.81	6.38	10.62	6.72	11.42	6.68
	30	6.53	5.35	7.76	5.70	8.75	6.22	9.24	6.30	9.74	6.35	10.49	6.67	11.24	6.61
	32	6.51	5.34	7.68	5.66	8.64	6.17	9.13	6.24	9.61	6.29	10.32	6.61	11.03	6.54
	34	6.49	5.33	7.60	5.62	8.54	6.13	9.01	6.19	9.49	6.24	10.16	6.54	10.84	6.47
	35	6.48	5.33	7.55	5.60	8.49	6.11	9.00	6.19	9.42	6.21	10.09	6.51	10.76	6.44
	36	6.48	5.33	7.51	5.58	8.43	6.07	8.90	6.14	9.36	6.18	10.02	6.48	10.67	6.41
	38	6.46	5.32	7.42	5.54	8.33	6.03	8.78	6.09	9.23	6.13	9.86	6.42	10.49	6.34
	39	6.45	5.32	7.37	5.51	8.27	6.01	8.72	6.06	9.17	6.11	9.79	6.39	10.41	6.31

Note (1) Symbols are as follows :

**TC** :Total cooling capacity (kw)  
**SHC** :Sensible heat capacity (kw)

### Model FDTWA112KXE4R

Air Flow	Outdoor Temp	Indoor Temp													
		14°CWB		16°CWB		18°CWB		19°CWB		20°CWB		22°CWB		24°CWB	
	°CDB	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
Hi	10	—	—	9.70	7.63	11.02	8.38	11.68	8.46	12.34	8.53	13.51	9.12	14.67	9.11
	12	—	—	9.70	7.63	11.02	8.38	11.68	8.46	12.34	8.53	13.51	9.12	14.67	9.11
	14	—	—	9.70	7.63	11.02	8.38	11.68	8.46	12.34	8.53	13.51	9.12	14.67	9.11
	16	—	—	9.70	7.63	11.02	8.38	11.68	8.46	12.34	8.53	13.51	9.12	14.67	9.11
	18	—	—	9.70	7.63	11.02	8.38	11.68	8.46	12.34	8.53	13.51	9.12	14.67	9.11
	20	—	—	9.69	7.63	11.02	8.38	11.68	8.46	13.34	8.53	13.51	9.12	14.66	9.11
	22	—	—	9.68	7.62	11.01	8.38	11.68	8.46	12.34	8.53	13.51	9.12	14.66	9.11
	24	—	—	9.68	7.62	11.00	8.37	11.66	8.46	12.32	8.53	13.44	9.10	14.55	9.07
	26	8.15	7.23	9.68	7.62	10.99	8.37	11.65	8.45	12.30	8.52	13.37	9.07	14.44	9.03
	28	8.13	7.22	9.67	7.62	10.94	8.35	11.57	8.42	12.21	8.48	13.22	9.00	14.21	8.96
	30	8.12	7.21	9.65	7.61	10.89	8.32	11.50	8.39	12.12	8.45	13.05	8.94	13.99	8.87
	32	8.10	7.20	9.55	7.57	10.75	8.27	11.36	8.33	11.96	8.39	12.85	8.87	13.73	8.78
	34	8.08	7.19	9.45	7.52	10.63	8.22	11.21	8.28	11.80	8.33	12.64	8.80	13.48	8.70
	35	8.06	7.19	9.40	7.50	10.56	8.19	11.20	8.27	11.73	8.30	12.56	8.75	13.38	8.67
	36	8.06	7.19	9.34	7.47	10.49	8.16	11.08	8.22	11.65	8.27	12.47	8.72	13.27	8.62
	38	8.04	7.17	9.23	7.43	10.36	8.11	10.93	8.17	11.49	8.21	12.28	8.65	13.06	8.55
	39	8.03	7.16	9.17	7.40	10.29	8.08	10.85	8.13	11.41	8.18	12.19	8.62	12.96	8.52

### Model FDTWA140KXE4R

Air Flow	Outdoor Temp	Indoor Temp													
		14°CWB		16°CWB		18°CWB		19°CWB		20°CWB		22°CWB		24°CWB	
	°CDB	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
Hi	10	—	—	12.12	9.16	13.78	10.05	14.60	10.17	15.43	10.28	16.88	10.92	18.34	10.92
	12	—	—	12.12	9.16	13.78	10.05	14.60	10.17	15.43	10.28	16.88	10.92	18.34	10.92
	14	—	—	12.12	9.16	13.78	10.05	14.60	10.17	15.43	10.28	16.88	10.92	18.34	10.92
	16	—	—	12.12	9.16	13.78	10.05	14.60	10.17	15.43	10.28	16.88	10.92	18.34	10.92
	18	—	—	12.12	9.16	13.78	10.05	14.60	10.17	15.43	10.28	16.88	10.92	18.34	10.92
	20	—	—	12.11	9.16	13.78	10.05	14.60	10.17	15.43	10.28	16.88	10.92	18.33	10.91
	22	—	—	12.10	9.15	13.76	10.04	14.60	10.17	15.43	10.28	16.88	10.92	18.33	10.91
	24	—	—	12.10	9.15	13.75	10.04	14.57	10.16	15.40	10.27	16.80	10.89	18.19	10.86
	26	10.19	8.62	12.10	9.15	13.73	10.03	14.56	10.16	15.37	10.26	16.72	10.86	18.05	10.82
	28	10.16	8.61	12.08	9.15	13.68	10.01	14.46	10.12	15.26	10.21	16.52	10.79	17.77	10.72
	30	10.15	8.60	12.07	9.14	13.61	9.98	14.38	10.08	15.15	10.17	16.31	10.70	17.49	10.63
	32	10.12	8.59	11.94	9.07	13.44	9.91	14.20	10.01	14.95	10.08	16.06	10.61	17.16	10.50
	34	10.09	8.58	11.82	9.01	13.29	9.84	14.01	9.92	14.76	10.00	15.81	10.51	16.86	10.40
	35	10.08	8.57	11.75	8.98	13.20	9.81	14.00	9.91	14.66	9.96	15.69	10.46	16.73	10.36
	36	10.08	8.57	11.68	8.95	13.12	9.76	13.85	9.85	14.56	9.92	15.58	10.42	16.59	10.29
	38	10.05	8.56	11.54	8.89	12.95	9.69	13.66	9.78	14.36	9.83	15.34	10.33	16.32	10.20
	39	10.04	8.55	11.47	8.86	12.87	9.65	13.57	9.74	14.27	9.79	15.23	10.29	16.20	10.16

### (d) FDTQ , FDQM Series

#### Model FDTQA22KXE4R , FDQMA22KXE4R

Air Flow	Outdoor Temp	Indoor Temp													
		14°CWB		16°CWB		18°CWB		19°CWB		20°CWB		22°CWB		24°CWB	
		°CDB	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC
Hi	10	—	—	1.91	1.47	2.16	1.62	2.29	1.64	2.42	1.65	2.65	1.75	2.88	1.76
	12	—	—	1.91	1.47	2.16	1.62	2.29	1.64	2.42	1.65	2.65	1.75	2.88	1.76
	14	—	—	1.91	1.47	2.16	1.62	2.29	1.64	2.42	1.65	2.65	1.75	2.88	1.76
	16	—	—	1.91	1.47	2.16	1.62	2.29	1.64	2.42	1.65	2.65	1.75	2.88	1.76
	18	—	—	1.91	1.47	2.16	1.62	2.29	1.64	2.42	1.65	2.65	1.75	2.88	1.76
	20	—	—	1.90	1.47	2.16	1.62	2.29	1.64	2.42	1.65	2.65	1.75	2.88	1.76
	22	—	—	1.90	1.47	2.16	1.62	2.29	1.64	2.42	1.65	2.65	1.75	2.88	1.76
	24	—	—	1.90	1.47	2.16	1.62	2.29	1.64	2.42	1.65	2.64	1.75	2.86	1.76
	26	1.60	1.39	1.90	1.47	2.16	1.62	2.29	1.64	2.42	1.65	2.63	1.75	2.84	1.75
	28	1.60	1.39	1.90	1.47	2.15	1.61	2.27	1.63	2.40	1.64	2.60	1.74	2.79	1.72
	30	1.60	1.39	1.90	1.47	2.14	1.61	2.26	1.62	2.38	1.64	2.56	1.72	2.75	1.71
	32	1.59	1.39	1.88	1.46	2.11	1.59	2.23	1.61	2.35	1.62	2.52	1.71	2.70	1.70
	34	1.59	1.38	1.86	1.45	2.09	1.58	2.20	1.60	2.32	1.61	2.48	1.70	2.65	1.68
	35	1.58	1.38	1.85	1.45	2.07	1.58	2.20	1.60	2.30	1.61	2.47	1.69	2.63	1.67
	36	1.58	1.38	1.83	1.44	2.06	1.57	2.18	1.59	2.29	1.60	2.45	1.68	2.61	1.66
	38	1.58	1.38	1.81	1.43	2.04	1.56	2.15	1.57	2.26	1.58	2.41	1.67	2.57	1.65
	39	1.58	1.37	1.80	1.42	2.02	1.56	2.13	1.56	2.24	1.58	2.39	1.66	2.55	1.64

Note (1) Symbols are as follows :

**TC** :Total cooling capacity (kw)  
**SHC** :Sensible heat capacity (kw)

### Model FDTQA28KXE4R , FDQMA28KXE4R

Air Flow	Outdoor Temp	Indoor Temp													
		14°CWB		16°CWB		18°CWB		19°CWB		20°CWB		22°CWB		24°CWB	
	°CDB	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
Hi	10	—	—	2.42	1.91	2.76	2.09	2.92	2.12	3.09	2.14	3.38	2.28	3.67	2.28
	12	—	—	2.42	1.91	2.76	2.09	2.92	2.12	3.09	2.14	3.38	2.28	3.67	2.28
	14	—	—	2.42	1.91	2.76	2.09	2.92	2.12	3.09	2.14	3.38	2.28	3.67	2.28
	16	—	—	2.42	1.91	2.76	2.09	2.92	2.12	3.09	2.14	3.38	2.28	3.67	2.28
	18	—	—	2.42	1.91	2.76	2.09	2.92	2.12	3.09	2.14	3.38	2.28	3.67	2.28
	20	—	—	2.42	1.90	2.76	2.09	2.92	2.12	3.09	2.14	3.38	2.28	3.67	2.28
	22	—	—	2.42	1.90	2.75	2.09	2.92	2.12	3.09	2.14	3.38	2.28	3.67	2.28
	24	—	—	2.42	1.90	2.75	2.09	2.91	2.12	3.08	2.13	3.36	2.27	3.64	2.26
	26	2.04	1.80	2.42	1.90	2.75	2.09	2.91	2.11	3.07	2.13	3.34	2.26	3.61	2.25
	28	2.03	1.80	2.42	1.90	2.74	2.09	2.89	2.10	3.05	2.12	3.30	2.25	3.55	2.24
	30	2.03	1.80	2.41	1.90	2.72	2.08	2.88	2.10	3.03	2.11	3.26	2.23	3.50	2.21
	32	2.02	1.79	2.39	1.89	2.69	2.06	2.84	2.08	2.99	2.10	3.21	2.21	3.43	2.19
	34	2.02	1.79	2.36	1.88	2.66	2.05	2.80	2.07	2.95	2.08	3.16	2.19	3.37	2.17
	35	2.02	1.79	2.35	1.87	2.64	2.04	2.80	2.07	2.93	2.07	3.14	2.18	3.35	2.15
	36	2.02	1.79	2.34	1.86	2.62	2.04	2.77	2.05	2.91	2.07	3.12	2.17	3.32	2.14
	38	2.01	1.79	2.31	1.85	2.59	2.02	2.73	2.04	2.87	2.05	3.07	2.15	3.26	2.13
	39	2.01	1.79	2.29	1.85	2.57	2.02	2.71	2.03	2.85	2.04	3.05	2.14	3.24	2.12

### Model FDTQA36KXE4R , FDQMA36KXE4R

Air Flow	Outdoor Temp	Indoor Temp													
		14°CWB		16°CWB		18°CWB		19°CWB		20°CWB		22°CWB		24°CWB	
		°CDB	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC
Hi	10	—	—	3.12	2.27	3.54	2.49	3.75	2.52	3.97	2.55	4.34	2.71	4.72	2.71
	12	—	—	3.12	2.27	3.54	2.49	3.75	2.52	3.97	2.55	4.34	2.71	4.72	2.71
	14	—	—	3.12	2.27	3.54	2.49	3.75	2.52	3.97	2.55	4.34	2.71	4.72	2.71
	16	—	—	3.12	2.27	3.54	2.49	3.75	2.52	3.97	2.55	4.34	2.71	4.72	2.71
	18	—	—	3.12	2.27	3.54	2.49	3.75	2.52	3.97	2.55	4.34	2.71	4.72	2.71
	20	—	—	3.11	2.27	3.54	2.49	3.75	2.52	3.97	2.55	4.34	2.71	4.71	2.71
	22	—	—	3.11	2.27	3.54	2.48	3.75	2.52	3.97	2.55	4.34	2.71	4.71	2.71
	24	—	—	3.11	2.27	3.54	2.48	3.75	2.52	3.96	2.54	4.32	2.70	4.68	2.69
	26	2.62	2.12	3.11	2.27	3.53	2.48	3.74	2.51	3.95	2.54	4.30	2.69	4.64	2.68
	28	2.61	2.12	3.11	2.26	3.52	2.47	3.72	2.50	3.92	2.53	4.25	2.67	4.57	2.65
	30	2.61	2.12	3.10	2.26	3.50	2.47	3.70	2.49	3.90	2.52	4.19	2.65	4.50	2.63
	32	2.60	2.11	3.07	2.25	3.46	2.45	3.65	2.47	3.84	2.49	4.13	2.62	4.41	2.59
	34	2.60	2.11	3.04	2.23	3.42	2.43	3.60	2.45	3.79	2.47	4.06	2.59	4.33	2.56
	35	2.59	2.11	3.02	2.22	3.39	2.42	3.60	2.45	3.77	2.46	4.04	2.58	4.30	2.55
	36	2.59	2.11	3.00	2.21	3.37	2.41	3.56	2.43	3.74	2.45	4.01	2.57	4.27	2.54
	38	2.58	2.10	2.97	2.20	3.33	2.39	3.51	2.41	3.69	2.43	3.95	2.55	4.20	2.51
	39	2.58	2.10	2.95	2.19	3.31	2.38	3.49	2.40	3.67	2.42	3.92	2.53	4.17	2.50

### (e) FDTS Series

#### Model FDTSA22KXE4R

Air Flow	Outdoor Temp	Indoor Temp													
		14°CWB		16°CWB		18°CWB		19°CWB		20°CWB		22°CWB		24°CWB	
		°CDB	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC
Hi	10	—	—	1.91	1.83	2.16	2.08	2.29	2.20	2.42	2.33	2.65	2.55	2.88	2.62
	12	—	—	1.91	1.83	2.16	2.08	2.29	2.20	2.42	2.33	2.65	2.55	2.88	2.62
	14	—	—	1.91	1.83	2.16	2.08	2.29	2.20	2.42	2.33	2.65	2.55	2.88	2.62
	16	—	—	1.91	1.83	2.16	2.08	2.29	2.20	2.42	2.33	2.65	2.55	2.88	2.62
	18	—	—	1.91	1.83	2.16	2.08	2.29	2.20	2.42	2.33	2.65	2.55	2.88	2.62
	20	—	—	1.90	1.83	2.16	2.08	2.29	2.20	2.42	2.33	2.65	2.55	2.88	2.62
	22	—	—	1.90	1.82	2.16	2.08	2.29	2.20	2.42	2.33	2.65	2.55	2.88	2.62
	24	—	—	1.90	1.82	2.16	2.07	2.29	2.20	2.42	2.32	2.64	2.53	2.86	2.61
	26	1.60	1.54	1.90	1.82	2.16	2.07	2.29	2.20	2.42	2.32	2.63	2.52	2.84	2.60
	28	1.60	1.53	1.90	1.82	2.15	2.06	2.27	2.18	2.40	2.30	2.60	2.49	2.79	2.59
	30	1.60	1.53	1.90	1.82	2.14	2.05	2.26	2.17	2.38	2.29	2.56	2.46	2.75	2.58
	32	1.59	1.53	1.88	1.80	2.11	2.03	2.23	2.14	2.35	2.26	2.52	2.42	2.70	2.56
	34	1.59	1.52	1.86	1.78	2.09	2.00	2.20	2.11	2.32	2.23	2.48	2.38	2.65	2.54
	35	1.58	1.52	1.85	1.77	2.07	1.99	2.20	2.11	2.30	2.21	2.47	2.37	2.63	2.52
	36	1.58	1.52	1.83	1.76	2.06	1.98	2.18	2.09	2.29	2.20	2.45	2.35	2.61	2.50
	38	1.58	1.52	1.81	1.74	2.04	1.95	2.15	2.06	2.26	2.17	2.41	2.31	2.57	2.46
	39	1.58	1.51	1.80	1.73	2.02	1.94	2.13	2.05	2.24	2.15	2.39	2.30	2.55	2.44

Note (1) Symbols are as follows :

**TC** :Total cooling capacity (kw)  
**SHC** :Sensible heat capacity (kw)

### Model FDTSA28KXE4R

Air Flow	Outdoor Temp	Indoor Temp													
		14°CWB		16°CWB		18°CWB		19°CWB		20°CWB		22°CWB		24°CWB	
	°CDB	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
Hi	10	—	—	2.42	2.33	2.76	2.64	2.92	2.77	3.09	2.78	3.38	2.99	3.67	2.98
	12	—	—	2.42	2.33	2.76	2.64	2.92	2.77	3.09	2.78	3.38	2.99	3.67	2.98
	14	—	—	2.42	2.33	2.76	2.64	2.92	2.77	3.09	2.78	3.38	2.99	3.67	2.98
	16	—	—	2.42	2.33	2.76	2.64	2.92	2.77	3.09	2.78	3.38	2.99	3.67	2.98
	18	—	—	2.42	2.33	2.76	2.64	2.92	2.77	3.09	2.78	3.38	2.99	3.67	2.98
	20	—	—	2.42	2.33	2.76	2.64	2.92	2.77	3.09	2.78	3.38	2.99	3.67	2.98
	22	—	—	2.42	2.32	2.75	2.64	2.92	2.77	3.09	2.78	3.38	2.99	3.67	2.98
	24	—	—	2.42	2.32	2.75	2.64	2.91	2.77	3.08	2.78	3.36	2.99	3.64	2.97
	26	2.04	1.96	2.42	2.32	2.75	2.64	2.91	2.77	3.07	2.78	3.34	2.98	3.61	2.97
	28	2.03	1.95	2.42	2.32	2.74	2.63	2.89	2.76	3.05	2.77	3.30	2.97	3.55	2.95
	30	2.03	1.95	2.41	2.32	2.72	2.61	2.88	2.75	3.03	2.76	3.26	2.96	3.50	2.93
	32	2.02	1.94	2.39	2.29	2.69	2.58	2.84	2.73	2.99	2.75	3.21	2.94	3.43	2.91
	34	2.02	1.94	2.36	2.27	2.66	2.55	2.80	2.69	2.95	2.74	3.16	2.92	3.37	2.90
	35	2.02	1.94	2.35	2.26	2.64	2.53	2.80	2.69	2.93	2.73	3.14	2.92	3.35	2.89
	36	2.02	1.94	2.34	2.24	2.62	2.52	2.77	2.66	2.91	2.72	3.12	2.91	3.32	2.88
	38	2.01	1.93	2.31	2.21	2.59	2.49	2.73	2.62	2.87	2.71	3.07	2.90	3.26	2.87
	39	2.01	1.93	2.29	2.20	2.57	2.47	2.71	2.60	2.85	2.70	3.05	2.89	3.24	2.86

### Model FDTSA36KXE4R

Model FDT350RXL241																
Air Flow	Outdoor Temp	Indoor Temp														
		14°CWB		16°CWB		18°CWB		19°CWB		20°CWB		22°CWB		24°CWB		
		°CDB	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
Hi	10	—	—	3.12	2.87	3.54	3.17	3.75	3.19	3.97	3.21	4.34	3.43	4.72	3.42	
	12	—	—	3.12	2.87	3.54	3.17	3.75	3.19	3.97	3.21	4.34	3.43	4.72	3.42	
	14	—	—	3.12	2.87	3.54	3.17	3.75	3.19	3.97	3.21	4.34	3.43	4.72	3.42	
	16	—	—	3.12	2.87	3.54	3.17	3.75	3.19	3.97	3.21	4.34	3.43	4.72	3.42	
	18	—	—	3.12	2.87	3.54	3.17	3.75	3.19	3.97	3.21	4.34	3.43	4.72	3.42	
	20	—	—	3.11	2.87	3.54	3.17	3.75	3.19	3.97	3.21	4.34	3.43	4.71	3.42	
	22	—	—	3.11	2.87	3.54	3.17	3.75	3.19	3.97	3.21	4.34	3.43	4.71	3.42	
	24	—	—	3.11	2.87	3.54	3.16	3.75	3.19	3.96	3.21	4.32	3.43	4.68	3.41	
	26	2.62	2.52	3.11	2.87	3.53	3.16	3.74	3.19	3.95	3.20	4.30	3.42	4.64	3.40	
	28	2.61	2.51	3.11	2.87	3.52	3.16	3.72	3.18	3.92	3.19	4.25	3.40	4.57	3.38	
	30	2.61	2.51	3.10	2.87	3.50	3.15	3.70	3.17	3.90	3.18	4.19	3.38	4.50	3.35	
	32	2.60	2.50	3.07	2.85	3.46	3.13	3.65	3.15	3.84	3.17	4.13	3.36	4.41	3.33	
	34	2.60	2.49	3.04	2.84	3.42	3.12	3.60	3.13	3.79	3.15	4.06	3.34	4.33	3.30	
	35	2.59	2.49	3.02	2.83	3.39	3.11	3.60	3.13	3.77	3.14	4.04	3.33	4.30	3.29	
	36	2.59	2.49	3.00	2.82	3.37	3.10	3.56	3.12	3.74	3.13	4.01	3.32	4.27	3.28	
	38	2.58	2.48	2.97	2.81	3.33	3.08	3.51	3.10	3.69	3.11	3.95	3.30	4.20	3.26	
	39	2.58	2.48	2.95	2.80	3.31	3.08	3.49	3.09	3.67	3.10	3.92	3.29	4.17	3.25	

### Model FDTSA45KXE4R

Air Flow	Outdoor Temp	Indoor Temp													
		14°CWB		16°CWB		18°CWB		19°CWB		20°CWB		22°CWB		24°CWB	
	°CDB	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
Hi	10	—	—	3.90	3.44	4.43	3.79	4.69	3.83	4.96	3.86	5.43	4.13	5.90	4.12
	12	—	—	3.90	3.44	4.43	3.79	4.69	3.83	4.96	3.86	5.43	4.13	5.90	4.12
	14	—	—	3.90	3.44	4.43	3.79	4.69	3.83	4.96	3.86	5.43	4.13	5.90	4.12
	16	—	—	3.90	3.44	4.43	3.79	4.69	3.83	4.96	3.86	5.43	4.13	5.90	4.12
	18	—	—	3.90	3.44	4.43	3.79	4.69	3.83	4.96	3.86	5.43	4.13	5.90	4.12
	20	—	—	3.89	3.44	4.43	3.79	4.69	3.83	4.96	3.86	5.43	4.13	5.89	4.12
	22	—	—	3.89	3.44	4.42	3.79	4.69	3.83	4.96	3.86	5.43	4.13	5.89	4.12
	24	—	—	3.89	3.44	4.42	3.79	4.68	3.82	4.95	3.85	5.40	4.12	5.85	4.11
	26	3.28	3.14	3.89	3.44	4.41	3.79	4.68	3.82	4.94	3.85	5.37	4.11	5.80	4.09
	28	3.27	3.14	3.88	3.43	4.40	3.78	4.65	3.81	4.91	3.84	5.31	4.09	5.71	4.06
	30	3.26	3.13	3.88	3.43	4.37	3.77	4.62	3.80	4.87	3.82	5.24	4.07	5.62	4.03
	32	3.25	3.12	3.84	3.41	4.32	3.75	4.56	3.77	4.81	3.79	5.16	4.04	5.52	4.00
	34	3.24	3.11	3.80	3.40	4.27	3.73	4.50	3.75	4.74	3.77	5.08	4.00	5.42	3.97
	35	3.24	3.11	3.78	3.39	4.24	3.72	4.50	3.75	4.71	3.76	5.04	3.99	5.38	3.96
	36	3.24	3.11	3.75	3.38	4.22	3.71	4.45	3.73	4.68	3.75	5.01	3.98	5.33	3.94
	38	3.23	3.10	3.71	3.36	4.16	3.69	4.39	3.71	4.62	3.72	4.93	3.95	5.25	3.91
	39	3.23	3.10	3.69	3.35	4.14	3.68	4.36	3.70	4.59	3.71	4.90	3.94	5.21	3.90

Note (1) Symbols are as follows :

**TC** :Total cooling capacity (kw)  
**SHC** :Sensible heat capacity (kw)

### Model FDTSA71KXE4R

Air Flow	Outdoor Temp	Indoor Temp													
		14°CWB		16°CWB		18°CWB		19°CWB		20°CWB		22°CWB		24°CWB	
	°CDB	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
Hi	10	—	—	6.15	4.93	6.99	5.42	7.41	5.47	7.82	5.52	8.56	5.89	9.30	5.89
	12	—	—	6.15	4.93	6.99	5.42	7.41	5.47	7.82	5.52	8.56	5.89	9.30	5.89
	14	—	—	6.15	4.93	6.99	5.42	7.41	5.47	7.82	5.52	8.56	5.89	9.30	5.89
	16	—	—	6.15	4.93	6.99	5.42	7.41	5.47	7.82	5.52	8.56	5.89	9.30	5.89
	18	—	—	6.15	4.93	6.99	5.42	7.41	5.47	7.82	5.52	8.56	5.89	9.30	5.89
	20	—	—	6.14	4.92	6.99	5.42	7.41	5.47	7.82	5.52	8.56	5.89	9.29	5.89
	22	—	—	6.13	4.92	6.98	5.42	7.41	5.47	7.82	5.52	8.56	5.89	9.29	5.89
	24	—	—	6.13	4.92	6.97	5.41	7.39	5.47	7.81	5.51	8.52	5.87	9.22	5.86
	26	5.17	4.66	6.13	4.92	6.97	5.41	7.38	5.47	7.80	5.51	8.48	5.86	9.15	5.83
	28	5.15	4.66	6.13	4.92	6.94	5.40	7.33	5.45	7.74	5.48	8.38	5.82	9.01	5.79
	30	5.15	4.65	6.12	4.92	6.90	5.38	7.29	5.43	7.68	5.46	8.27	5.78	8.87	5.74
	32	5.13	4.65	6.06	4.89	6.82	5.35	7.20	5.39	7.58	5.42	8.14	5.74	8.70	5.68
	34	5.12	4.64	5.99	4.86	6.74	5.32	7.11	5.35	7.48	5.39	8.02	5.69	8.55	5.63
	35	5.11	4.64	5.96	4.84	6.70	5.30	7.10	5.35	7.43	5.37	7.96	5.67	8.48	5.61
	36	5.11	4.64	5.92	4.83	6.65	5.28	7.02	5.32	7.38	5.35	7.90	5.64	8.41	5.59
	38	5.10	4.63	5.85	4.80	6.57	5.25	6.93	5.28	7.28	5.31	7.78	5.60	8.28	5.53
	39	5.09	4.63	5.81	4.78	6.52	5.23	6.88	5.26	7.23	5.29	7.72	5.58	8.21	5.51

### (f) FDU Series

#### Model FDUA224KXE4R

Air Flow		Outdoor Temp	Indoor Temp													
			14°CWB		16°CWB		18°CWB		19°CWB		20°CWB		22°CWB		24°CWB	
			°CDB	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC
Hi	10	—	—	19.40	14.89	22.04	16.37	23.36	16.56	24.68	16.71	27.01	17.73	29.34	17.80	
	12	—	—	19.40	14.89	22.04	16.37	23.36	16.56	24.68	16.71	27.01	17.73	29.34	17.80	
	14	—	—	19.40	14.89	22.04	16.37	23.36	16.56	24.68	16.71	27.01	17.73	29.34	17.80	
	16	—	—	19.40	14.89	22.04	16.37	23.36	16.56	24.68	16.71	27.01	17.73	29.34	17.80	
	18	—	—	19.40	14.89	22.04	16.37	23.36	16.56	24.68	16.71	27.01	17.73	29.34	17.80	
	20	—	—	19.38	14.88	22.04	16.37	23.36	16.56	24.68	16.71	27.01	17.73	29.32	17.80	
	22	—	—	19.35	14.87	22.02	16.36	23.36	16.56	24.68	16.71	27.01	17.73	29.32	17.80	
	24	—	—	19.35	14.87	22.00	16.35	23.32	16.54	24.64	16.69	26.88	17.68	29.10	17.71	
	26	16.31	14.07	19.35	14.87	21.97	16.34	23.30	16.53	24.60	16.67	26.75	17.63	28.87	17.55	
	28	16.26	14.05	19.33	14.86	21.88	16.30	23.14	16.46	24.42	16.60	26.43	17.51	28.43	17.40	
	30	16.24	14.04	19.31	14.85	21.77	16.26	23.00	16.41	24.24	16.53	26.10	17.38	27.98	17.24	
	32	16.20	14.02	19.11	14.76	21.50	16.12	22.71	16.28	23.92	16.40	25.69	17.23	27.46	17.06	
	34	16.15	14.00	18.91	14.67	21.26	16.01	22.42	16.16	23.61	16.27	25.29	17.07	26.97	16.89	
	35	16.13	13.99	18.79	14.61	21.12	15.95	22.40	16.15	23.45	16.21	25.11	17.01	26.77	16.82	
	36	16.13	13.99	18.68	14.56	20.99	15.90	22.15	16.05	23.30	16.15	24.93	16.94	26.54	16.74	
	38	16.08	13.97	18.46	14.46	20.72	15.78	21.86	15.91	22.98	16.02	24.55	16.80	26.12	16.60	
	39	16.06	13.96	18.35	14.41	20.59	15.72	21.71	15.84	22.83	15.96	24.37	16.74	25.92	16.53	

#### Model FDUA280KXE4R

Model F-D0A200R2W1															
Air Flow	Outdoor Temp	Indoor Temp													
		14°CWB		16°CWB		18°CWB		19°CWB		20°CWB		22°CWB		24°CWB	
		°CDB	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC
Hi	10	—	—	24.25	18.96	27.55	20.82	29.20	21.03	30.86	21.21	33.77	22.65	36.68	22.67
	12	—	—	24.25	18.96	27.55	20.82	29.20	21.03	30.86	21.21	33.77	22.65	36.68	22.67
	14	—	—	24.25	18.96	27.55	20.82	29.20	21.03	30.86	21.21	33.77	22.65	36.68	22.67
	16	—	—	24.25	18.96	27.55	20.82	29.20	21.03	30.86	21.21	33.77	22.65	36.68	22.67
	18	—	—	24.25	18.96	27.55	20.82	29.20	21.03	30.86	21.21	33.77	22.65	36.68	22.67
	20	—	—	24.22	18.95	27.55	20.82	29.20	21.03	30.86	21.21	33.77	22.65	36.65	22.66
	22	—	—	24.19	18.94	27.52	20.80	29.20	21.03	30.86	21.21	33.77	22.65	36.65	22.66
	24	—	—	24.19	18.94	27.50	20.79	29.15	21.01	30.80	21.19	33.60	22.59	36.37	22.56
	26	20.38	17.95	24.19	18.94	27.47	20.78	29.12	21.00	30.74	21.17	33.43	22.53	36.09	22.47
	28	20.33	17.92	24.16	18.93	27.36	20.73	28.92	20.92	30.52	21.08	33.04	22.39	35.53	22.24
	30	20.30	17.91	24.14	18.92	27.22	20.68	28.76	20.85	30.30	20.99	32.62	22.23	34.97	22.05
	32	20.24	17.88	23.88	18.80	26.88	20.53	28.39	20.70	29.90	20.84	32.12	22.04	34.33	21.84
	34	20.19	17.86	23.63	18.69	26.57	20.41	28.03	20.55	29.51	20.68	31.61	21.83	33.71	21.63
	35	20.16	17.84	23.49	18.63	26.40	20.33	28.00	20.55	29.32	20.61	31.39	21.75	33.46	21.51
	36	20.16	17.84	23.35	18.57	26.24	20.27	27.69	20.42	29.12	20.53	31.16	21.66	33.18	21.42
	38	20.10	17.82	23.07	18.45	25.90	20.13	27.33	20.28	28.73	20.38	30.69	21.50	32.65	21.24
	39	20.08	17.81	22.93	18.38	25.73	20.06	27.13	20.20	28.53	20.30	30.46	21.42	32.40	21.16

Note (1) Symbols are as follows :

**TC** :Total cooling capacity (kw)  
**SHC** :Sensible heat capacity (kw)

**(g) FDUM Series**  
**Model FDUMA36KXE4R**

Air Flow	Outdoor Temp °CDB	Indoor Temp													
		14°CWB		16°CWB		18°CWB		19°CWB		20°CWB		22°CWB		24°CWB	
		TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
Hi	10	—	—	3.12	2.77	3.54	3.06	3.75	3.08	3.97	3.11	4.34	3.31	4.72	3.30
	12	—	—	3.12	2.77	3.54	3.06	3.75	3.08	3.97	3.11	4.34	3.31	4.72	3.30
	14	—	—	3.12	2.77	3.54	3.06	3.75	3.08	3.97	3.11	4.34	3.31	4.72	3.30
	16	—	—	3.12	2.77	3.54	3.06	3.75	3.08	3.97	3.11	4.34	3.31	4.72	3.30
	18	—	—	3.12	2.77	3.54	3.06	3.75	3.08	3.97	3.11	4.34	3.31	4.72	3.30
	20	—	—	3.11	2.77	3.54	3.06	3.75	3.08	3.97	3.11	4.34	3.31	4.71	3.30
	22	—	—	3.11	2.77	3.54	3.06	3.75	3.08	3.97	3.11	4.34	3.31	4.71	3.30
	24	—	—	3.11	2.77	3.54	3.06	3.75	3.08	3.96	3.10	4.32	3.31	4.68	3.29
	26	2.62	2.52	3.11	2.77	3.53	3.05	3.74	3.08	3.95	3.10	4.30	3.30	4.64	3.28
	28	2.61	2.51	3.11	2.77	3.52	3.05	3.72	3.07	3.92	3.09	4.25	3.28	4.57	3.26
	30	2.61	2.51	3.10	2.77	3.50	3.04	3.70	3.06	3.90	3.08	4.19	3.26	4.50	3.24
	32	2.60	2.50	3.07	2.75	3.46	3.03	3.65	3.04	3.84	3.06	4.13	3.24	4.41	3.21
	34	2.60	2.49	3.04	2.74	3.42	3.01	3.60	3.03	3.79	3.04	4.06	3.22	4.33	3.19
	35	2.59	2.49	3.02	2.73	3.39	3.00	3.60	3.02	3.77	3.03	4.04	3.21	4.30	3.18
	36	2.59	2.49	3.00	2.73	3.37	2.99	3.56	3.01	3.74	3.02	4.01	3.20	4.27	3.17
	38	2.58	2.48	2.97	2.71	3.33	2.97	3.51	2.99	3.69	3.00	3.95	3.18	4.20	3.15
	39	2.58	2.48	2.95	2.70	3.31	2.96	3.49	2.98	3.67	2.99	3.92	3.17	4.17	3.14

**Model FDUMA45KXE4R**

Air Flow	Outdoor Temp °CDB	Indoor Temp													
		14°CWB		16°CWB		18°CWB		19°CWB		20°CWB		22°CWB		24°CWB	
		TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
Hi	10	—	—	3.90	3.32	4.43	3.65	4.69	3.69	4.96	3.72	5.43	3.97	5.90	3.96
	12	—	—	3.90	3.32	4.43	3.65	4.69	3.69	4.96	3.72	5.43	3.97	5.90	3.96
	14	—	—	3.90	3.32	4.43	3.65	4.69	3.69	4.96	3.72	5.43	3.97	5.90	3.96
	16	—	—	3.90	3.32	4.43	3.65	4.69	3.69	4.96	3.72	5.43	3.97	5.90	3.96
	18	—	—	3.90	3.32	4.43	3.65	4.69	3.69	4.96	3.72	5.43	3.97	5.90	3.96
	20	—	—	3.89	3.32	4.43	3.65	4.69	3.69	4.96	3.72	5.43	3.97	5.89	3.96
	22	—	—	3.89	3.32	4.42	3.65	4.69	3.69	4.96	3.72	5.43	3.97	5.89	3.96
	24	—	—	3.89	3.32	4.42	3.65	4.68	3.69	4.95	3.72	5.40	3.96	5.85	3.95
	26	3.28	3.14	3.89	3.32	4.41	3.65	4.68	3.68	4.94	3.71	5.37	3.95	5.80	3.93
	28	3.27	3.14	3.88	3.31	4.40	3.64	4.65	3.67	4.91	3.69	5.31	3.93	5.71	3.91
	30	3.26	3.13	3.88	3.31	4.37	3.63	4.62	3.66	4.87	3.68	5.24	3.91	5.62	3.88
	32	3.25	3.12	3.84	3.30	4.32	3.61	4.56	3.64	4.81	3.66	5.16	3.88	5.52	3.85
	34	3.24	3.11	3.80	3.28	4.27	3.59	4.50	3.61	4.74	3.64	5.08	3.85	5.42	3.81
	35	3.24	3.11	3.78	3.27	4.24	3.58	4.50	3.61	4.71	3.62	5.04	3.84	5.38	3.80
	36	3.24	3.11	3.75	3.26	4.22	3.57	4.45	3.59	4.68	3.61	5.01	3.83	5.33	3.78
	38	3.23	3.10	3.71	3.24	4.16	3.54	4.39	3.57	4.62	3.58	4.93	3.80	5.25	3.76
	39	3.23	3.10	3.69	3.23	4.14	3.53	4.36	3.56	4.59	3.57	4.90	3.79	5.21	3.75

**Model FDUMA56KXE4R**

Air Flow	Outdoor Temp °CDB	Indoor Temp													
		14°CWB		16°CWB		18°CWB		19°CWB		20°CWB		22°CWB		24°CWB	
		TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
Hi	10	—	—	4.85	3.85	5.51	4.25	5.84	4.29	6.17	4.33	6.75	4.62	7.34	4.61
	12	—	—	4.85	3.85	5.51	4.25	5.84	4.29	6.17	4.33	6.75	4.62	7.34	4.61
	14	—	—	4.85	3.85	5.51	4.25	5.84	4.29	6.17	4.33	6.75	4.62	7.34	4.61
	16	—	—	4.85	3.85	5.51	4.25	5.84	4.29	6.17	4.33	6.75	4.62	7.34	4.61
	18	—	—	4.85	3.85	5.51	4.25	5.84	4.29	6.17	4.33	6.75	4.62	7.34	4.61
	20	—	—	4.84	3.85	5.51	4.25	5.84	4.29	6.17	4.33	6.75	4.62	7.33	4.61
	22	—	—	4.84	3.85	5.50	4.24	5.84	4.29	6.17	4.33	6.75	4.62	7.33	4.61
	24	—	—	4.84	3.85	5.50	4.24	5.83	4.29	6.16	4.33	6.72	4.60	7.27	4.59
	26	4.08	3.66	4.84	3.85	5.49	4.24	5.82	4.28	6.15	4.32	6.69	4.59	7.22	4.57
	28	4.07	3.65	4.83	3.85	5.47	4.23	5.78	4.27	6.10	4.30	6.61	4.56	7.11	4.53
	30	4.06	3.65	4.83	3.84	5.44	4.22	5.75	4.25	6.06	4.28	6.52	4.52	6.99	4.50
	32	4.05	3.64	4.78	3.82	5.38	4.19	5.68	4.22	5.98	4.25	6.42	4.49	6.87	4.44
	34	4.04	3.64	4.73	3.80	5.31	4.16	5.61	4.19	5.90	4.22	6.32	4.45	6.74	4.40
	35	4.03	3.64	4.70	3.79	5.28	4.15	5.60	4.19	5.86	4.20	6.28	4.43	6.69	4.39
	36	4.03	3.64	4.67	3.78	5.25	4.13	5.54	4.17	5.82	4.19	6.23	4.42	6.64	4.37
	38	4.02	3.63	4.61	3.75	5.18	4.10	5.47	4.14	5.75	4.16	6.14	4.38	6.53	4.33
	39	4.02	3.63	4.59	3.74	5.15	4.09	5.43	4.12	5.71	4.14	6.09	4.37	6.48	4.32

Note (1) Symbols are as follows :

**TC** :Total cooling capacity (kw)  
**SHC** :Sensible heat capacity (kw)

### Model FDUMA71KXE4R

Air Flow	Outdoor Temp	Indoor Temp													
		14°CWB		16°CWB		18°CWB		19°CWB		20°CWB		22°CWB		24°CWB	
		°CDB	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC
Hi	10	—	—	6.15	4.93	6.99	5.42	7.41	5.47	7.82	5.52	8.56	5.89	9.30	5.89
	12	—	—	6.15	4.93	6.99	5.42	7.41	5.47	7.82	5.52	8.56	5.89	9.30	5.89
	14	—	—	6.15	4.93	6.99	5.42	7.41	5.47	7.82	5.52	8.56	5.89	9.30	5.89
	16	—	—	6.15	4.93	6.99	5.42	7.41	5.47	7.82	5.52	8.56	5.89	9.30	5.89
	18	—	—	6.15	4.93	6.99	5.42	7.41	5.47	7.82	5.52	8.56	5.89	9.30	5.89
	20	—	—	6.14	4.92	6.99	5.42	7.41	5.47	7.82	5.52	8.56	5.89	9.29	5.89
	22	—	—	6.13	4.92	6.98	5.42	7.41	5.47	7.82	5.52	8.56	5.89	9.29	5.89
	24	—	—	6.13	4.92	6.97	5.41	7.39	5.47	7.81	5.51	8.52	5.87	9.22	5.86
	26	5.17	4.66	6.13	4.92	6.97	5.41	7.38	5.47	7.80	5.51	8.48	5.86	9.15	5.83
	28	5.15	4.66	6.13	4.92	6.94	5.40	7.33	5.45	7.74	5.48	8.38	5.82	9.01	5.79
	30	5.15	4.65	6.12	4.92	6.90	5.38	7.29	5.43	7.68	5.46	8.27	5.78	8.87	5.74
	32	5.13	4.65	6.06	4.89	6.82	5.35	7.20	5.39	7.58	5.42	8.14	5.74	8.70	5.68
	34	5.12	4.64	5.99	4.86	6.74	5.32	7.11	5.35	7.48	5.39	8.02	5.69	8.55	5.63
	35	5.11	4.64	5.96	4.84	6.70	5.30	7.10	5.35	7.43	5.37	7.96	5.67	8.48	5.61
	36	5.11	4.64	5.92	4.83	6.65	5.28	7.02	5.32	7.38	5.35	7.90	5.64	8.41	5.59
	38	5.10	4.63	5.85	4.80	6.57	5.25	6.93	5.28	7.28	5.31	7.78	5.60	8.28	5.53
	39	5.09	4.63	5.81	4.78	6.52	5.23	6.88	5.26	7.23	5.29	7.72	5.58	8.21	5.51

### Model FDUMA90KXE4R

Air Flow	Outdoor Temp	Indoor Temp													
		14°CWB		16°CWB		18°CWB		19°CWB		20°CWB		22°CWB		24°CWB	
		°CDB	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC
Hi	10	—	—	7.79	5.91	8.86	6.48	9.39	6.56	9.92	6.63	10.85	7.05	11.79	7.05
	12	—	—	7.79	5.91	8.86	6.48	9.39	6.56	9.92	6.63	10.85	7.05	11.79	7.05
	14	—	—	7.79	5.91	8.86	6.48	9.39	6.56	9.92	6.63	10.85	7.05	11.79	7.05
	16	—	—	7.79	5.91	8.86	6.48	9.39	6.56	9.92	6.63	10.85	7.05	11.79	7.05
	18	—	—	7.79	5.91	8.86	6.48	9.39	6.56	9.92	6.63	10.85	7.05	11.79	7.05
	20	—	—	7.79	5.90	8.86	6.48	9.39	6.56	9.92	6.63	10.85	7.05	11.78	7.05
	22	—	—	7.78	5.90	8.85	6.48	9.39	6.56	9.92	6.63	10.85	7.05	11.78	7.05
	24	—	—	7.78	5.90	8.84	6.47	9.37	6.56	9.90	6.62	10.80	7.02	11.69	7.02
	26	6.55	5.57	7.78	5.90	8.83	6.47	9.36	6.55	9.88	6.61	10.75	7.00	11.60	6.99
	28	6.53	6.56	7.77	5.89	8.79	6.45	9.30	6.53	9.81	6.58	10.62	6.96	11.42	6.92
	30	6.53	6.56	7.76	5.89	8.75	6.44	9.24	6.50	9.74	6.55	10.49	6.90	11.24	6.85
	32	6.51	5.55	7.68	5.85	8.64	6.39	9.13	6.46	9.61	6.50	10.32	6.84	11.03	6.78
	34	6.49	5.54	7.60	5.82	8.54	6.35	9.01	6.40	9.49	6.45	10.16	6.78	10.84	6.71
	35	6.48	5.54	7.55	5.80	8.49	6.32	9.00	6.39	9.42	6.43	10.09	6.75	10.76	6.68
	36	6.48	5.54	7.51	5.78	8.43	6.30	8.90	6.35	9.36	6.40	10.02	6.72	10.67	6.65
	38	6.46	5.53	7.42	5.73	8.33	6.25	8.78	6.30	9.23	6.34	9.86	6.66	10.49	6.58
	39	6.45	5.52	7.37	5.71	8.27	6.23	8.72	6.28	9.17	6.32	9.79	6.64	10.41	6.55

### Model FDUMA112KXE4R

Air Flow	Outdoor Temp	Indoor Temp													
		14°CWB		16°CWB		18°CWB		19°CWB		20°CWB		22°CWB		24°CWB	
	°CDB	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
Hi	10	—	—	9.70	7.75	11.02	8.53	11.68	8.62	12.34	8.69	13.51	9.26	14.67	9.27
	12	—	—	9.70	7.75	11.02	8.53	11.68	8.62	12.34	8.69	13.51	9.26	14.67	9.27
	14	—	—	9.70	7.75	11.02	8.53	11.68	8.62	12.34	8.69	13.51	9.26	14.67	9.27
	16	—	—	9.70	7.75	11.02	8.53	11.68	8.62	12.34	8.69	13.51	9.26	14.67	9.27
	18	—	—	9.70	7.75	11.02	8.53	11.68	8.62	12.34	8.69	13.51	9.26	14.67	9.27
	20	—	—	9.69	7.75	11.02	8.53	11.68	8.62	12.34	8.69	13.51	9.26	14.66	9.27
	22	—	—	9.68	7.74	11.01	8.53	11.68	8.62	12.34	8.69	13.51	9.26	14.66	9.27
	24	—	—	9.68	7.74	11.00	8.52	11.66	8.61	12.32	8.68	13.44	9.24	14.55	9.23
	26	8.15	7.36	9.68	7.74	10.99	8.52	11.65	8.61	12.30	8.67	13.37	9.22	14.44	9.18
	28	8.13	7.35	9.67	7.74	10.94	8.50	11.57	8.57	12.21	8.64	13.22	9.16	14.21	9.10
	30	8.12	7.35	9.65	7.74	10.89	8.48	11.50	8.55	12.12	8.60	13.05	9.10	13.99	9.02
	32	8.10	7.33	9.55	7.69	10.75	8.42	11.36	8.49	11.96	8.54	12.85	9.02	13.73	8.94
	34	8.08	7.32	9.45	7.65	10.63	8.36	11.21	8.43	11.80	8.48	12.64	8.95	13.48	8.85
	35	8.06	7.32	9.40	7.62	10.56	8.33	11.20	8.42	11.73	8.45	12.56	8.92	13.38	8.82
	36	8.06	7.32	9.34	7.60	10.49	8.30	11.08	8.37	11.65	8.42	12.47	8.88	13.27	8.78
	38	8.04	7.31	9.23	7.55	10.36	8.24	10.93	8.32	11.49	8.36	12.28	8.82	13.06	8.71
	39	8.03	7.30	9.17	7.52	10.29	8.22	10.85	8.29	11.41	8.33	12.19	8.78	12.96	8.68

Note (1) Symbols are as follows :

**TC** :Total cooling capacity (kw)  
**SHC** :Sensible heat capacity (kw)



### Model FDUMA140KXE4R

Air Flow	Outdoor Temp	Indoor Temp													
		14°CWB		16°CWB		18°CWB		19°CWB		20°CWB		22°CWB		24°CWB	
	°CDB	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
Hi	10	—	—	12.12	9.54	13.78	10.49	14.60	10.60	15.43	10.69	16.88	11.40	18.34	11.39
	12	—	—	12.12	9.54	13.78	10.49	14.60	10.60	15.43	10.69	16.88	11.40	18.34	11.39
	14	—	—	12.12	9.54	13.78	10.49	14.60	10.60	15.43	10.69	16.88	11.40	18.34	11.39
	16	—	—	12.12	9.54	13.78	10.49	14.60	10.60	15.43	10.69	16.88	11.40	18.34	11.39
	18	—	—	12.12	9.54	13.78	10.49	14.60	10.60	15.43	10.69	16.88	11.40	18.34	11.39
	20	—	—	12.11	9.53	13.78	10.49	14.60	10.60	15.43	10.69	16.88	11.40	18.33	11.38
	22	—	—	12.10	9.53	13.76	10.48	14.60	10.60	15.43	10.69	16.88	11.40	18.33	11.38
	24	—	—	12.10	9.53	13.75	10.48	14.57	10.59	15.40	10.68	16.80	11.36	18.19	11.34
	26	10.19	9.01	12.10	9.53	13.73	10.47	14.56	10.58	15.37	10.67	16.72	11.33	18.05	11.29
	28	10.16	9.00	12.08	9.52	13.68	10.45	14.46	10.54	15.26	10.62	16.52	11.26	17.77	11.19
	30	10.15	9.00	12.07	9.51	13.61	10.42	14.38	10.51	15.15	10.58	16.31	11.18	17.49	11.10
	32	10.12	8.98	11.94	9.46	13.44	10.35	14.20	10.43	14.95	10.50	16.06	11.07	17.16	10.99
	34	10.09	8.97	11.82	9.40	13.29	10.27	14.01	10.36	14.76	10.42	15.81	10.98	16.86	10.86
	35	10.08	8.96	11.75	9.37	13.20	10.23	14.00	10.35	14.66	10.38	15.69	10.94	16.73	10.82
	36	10.08	8.96	11.68	9.31	13.12	10.20	13.85	10.29	14.56	10.35	15.58	10.90	16.59	10.78
	38	10.05	8.95	11.54	9.25	12.95	10.13	13.66	10.22	14.36	10.27	15.34	10.82	16.32	10.69
	39	10.04	8.94	11.47	9.22	12.87	10.09	13.57	10.18	14.27	10.23	15.23	10.77	16.20	10.64

### (h) FDUR Series

#### Model FDURA45KXE4R

Model F-D01A43RX2-L1																
Air Flow	Outdoor Temp	Indoor Temp														
		14°CWB		16°CWB		18°CWB		19°CWB		20°CWB		22°CWB		24°CWB		
		°CDB	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
Hi	10	—	—	3.90	3.74	4.43	4.22	4.69	4.25	4.96	4.28	5.43	4.58	5.90	4.57	
	12	—	—	3.90	3.74	4.43	4.22	4.69	4.25	4.96	4.28	5.43	4.58	5.90	4.57	
	14	—	—	3.90	3.74	4.43	4.22	4.69	4.25	4.96	4.28	5.43	4.58	5.90	4.57	
	16	—	—	3.90	3.74	4.43	4.22	4.69	4.25	4.96	4.28	5.43	4.58	5.90	4.57	
	18	—	—	3.90	3.74	4.43	4.22	4.69	4.25	4.96	4.28	5.43	4.58	5.90	4.57	
	20	—	—	3.89	3.74	4.43	4.22	4.69	4.25	4.96	4.28	5.43	4.58	5.89	4.56	
	22	—	—	3.89	3.73	4.42	4.22	4.69	4.25	4.96	4.28	5.43	4.58	5.89	4.56	
	24	—	—	3.89	3.73	4.42	4.22	4.68	4.25	4.95	4.28	5.40	4.57	5.85	4.55	
	26	3.28	3.14	3.89	3.73	4.41	4.22	4.68	4.25	4.94	4.28	5.37	4.56	5.80	4.54	
	28	3.27	3.14	3.88	3.73	4.40	4.21	4.65	4.23	4.91	4.26	5.31	4.54	5.71	4.51	
	30	3.26	3.13	3.88	3.72	4.37	4.20	4.62	4.22	4.87	4.24	5.24	4.52	5.62	4.48	
	32	3.25	3.12	3.84	3.68	4.32	4.15	4.56	4.20	4.81	4.22	5.16	4.49	5.52	4.45	
	34	3.24	3.11	3.80	3.65	4.27	4.10	4.50	4.18	4.74	4.20	5.08	4.47	5.42	4.42	
	35	3.24	3.11	3.78	3.62	4.24	4.07	4.50	4.18	4.71	4.18	5.04	4.45	5.38	4.41	
	36	3.24	3.11	3.75	3.60	4.22	4.05	4.45	4.16	4.68	4.17	5.01	4.44	5.33	4.39	
	38	3.23	3.10	3.71	3.56	4.16	4.00	4.39	4.14	4.62	4.15	4.93	4.42	5.25	4.37	
	39	3.23	3.10	3.69	3.54	4.14	3.97	4.36	4.13	4.59	4.14	4.90	4.41	5.21	4.36	

#### Model FDURA56KXE4R

Air Flow	Outdoor Temp	Indoor Temp													
		14°CWB		16°CWB		18°CWB		19°CWB		20°CWB		22°CWB		24°CWB	
	°CDB	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
Hi	10	—	—	4.85	4.66	5.51	5.20	5.84	5.23	6.17	5.26	6.75	5.64	7.34	5.62
	12	—	—	4.85	4.66	5.51	5.20	5.84	5.23	6.17	5.26	6.75	5.64	7.34	5.62
	14	—	—	4.85	4.66	5.51	5.20	5.84	5.23	6.17	5.26	6.75	5.64	7.34	5.62
	16	—	—	4.85	4.66	5.51	5.20	5.84	5.23	6.17	5.26	6.75	5.64	7.34	5.62
	18	—	—	4.85	4.66	5.51	5.20	5.84	5.23	6.17	5.26	6.75	5.64	7.34	5.62
	20	—	—	4.84	4.65	5.51	5.20	5.84	5.23	6.17	5.26	6.75	5.64	7.33	5.62
	22	—	—	4.84	4.64	5.50	5.19	5.84	5.23	6.17	5.26	6.75	5.64	7.33	5.62
	24	—	—	4.84	4.64	5.50	5.19	5.83	5.23	6.16	5.26	6.72	5.63	7.27	5.60
	26	4.08	3.91	4.84	4.64	5.49	5.18	5.82	5.23	6.15	5.25	6.69	5.62	7.22	5.59
	28	4.07	3.90	4.83	4.64	5.47	5.17	5.78	5.21	6.10	5.24	6.61	5.59	7.11	5.55
	30	4.06	3.90	4.83	4.63	5.44	5.16	5.75	5.20	6.06	5.22	6.52	5.56	6.99	5.52
	32	4.05	3.89	4.78	4.59	5.38	5.14	5.68	5.18	5.98	5.19	6.42	5.53	6.87	5.48
	34	4.04	3.88	4.73	4.54	5.31	5.10	5.61	5.15	5.90	5.17	6.32	5.50	6.74	5.44
	35	4.03	3.87	4.70	4.51	5.28	5.07	5.60	5.15	5.86	5.15	6.28	5.48	6.69	5.43
	36	4.03	3.87	4.67	4.48	5.25	5.04	5.54	5.11	5.82	5.14	6.23	5.47	6.64	5.41
	38	4.02	3.86	4.61	4.43	5.18	4.97	5.47	5.09	5.75	5.11	6.14	5.44	6.53	5.38
	39	4.02	3.85	4.59	4.40	5.15	4.94	5.43	5.07	5.71	5.10	6.09	5.42	6.48	5.36

Note (1) Symbols are as follows :

**TC** :Total cooling capacity (kw)  
**SHC** :Sensible heat capacity (kw)



### Model FDURA71KXE4R

Air Flow	Outdoor Temp	Indoor Temp													
		14°CWB		16°CWB		18°CWB		19°CWB		20°CWB		22°CWB		24°CWB	
	°CDB	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
Hi	10	—	—	6.15	5.69	6.99	6.30	7.41	6.35	7.82	6.39	8.56	6.84	9.30	6.83
	12	—	—	6.15	5.69	6.99	6.30	7.41	6.35	7.82	6.39	8.56	6.84	9.30	6.83
	14	—	—	6.15	5.69	6.99	6.30	7.41	6.35	7.82	6.39	8.56	6.84	9.30	6.83
	16	—	—	6.15	5.69	6.99	6.30	7.41	6.35	7.82	6.39	8.56	6.84	9.30	6.83
	18	—	—	6.15	5.69	6.99	6.30	7.41	6.35	7.82	6.39	8.56	6.84	9.30	6.83
	20	—	—	6.14	5.69	6.99	6.30	7.41	6.35	7.82	6.39	8.56	6.84	9.29	6.82
	22	—	—	6.13	5.69	6.98	6.30	7.41	6.35	7.82	6.39	8.56	6.84	9.29	6.82
	24	—	—	6.13	5.69	6.97	6.30	7.39	6.34	7.81	6.39	8.52	6.83	9.22	6.80
	26	5.17	4.96	6.13	5.69	6.97	6.29	7.38	6.34	7.80	6.38	8.48	6.82	9.15	6.78
	28	5.15	4.95	6.13	5.69	6.94	6.28	7.33	6.32	7.74	6.36	8.38	6.78	9.01	6.74
	30	5.15	4.94	6.12	5.68	6.90	6.27	7.29	6.30	7.68	6.34	8.27	6.75	8.87	6.69
	32	5.13	4.93	6.06	5.66	6.82	6.24	7.20	6.27	7.58	6.29	8.14	6.71	8.70	6.64
	34	5.12	4.91	5.99	5.63	6.74	6.21	7.11	6.24	7.48	6.26	8.02	6.66	8.55	6.60
	35	5.11	4.91	5.96	5.62	6.70	6.19	7.10	6.23	7.43	6.24	7.96	6.64	8.48	6.58
	36	5.11	4.91	5.92	5.60	6.65	6.17	7.02	6.20	7.38	6.22	7.90	6.63	8.41	6.56
	38	5.10	4.89	5.85	5.57	6.57	6.14	6.93	6.17	7.28	6.19	7.78	6.59	8.28	6.52
	39	5.09	4.89	5.81	5.56	6.52	6.13	6.88	6.15	7.23	6.17	7.72	6.57	8.21	6.50

### Model FDURA90KXE4R

Air Flow		Outdoor Temp	Indoor Temp													
			14°CWB		16°CWB		18°CWB		19°CWB		20°CWB		22°CWB		24°CWB	
			°CDB	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC
Hi	10	—	—	7.79	7.48	8.86	8.48	9.39	8.53	9.92	8.57	10.85	9.23	11.79	9.20	
	12	—	—	7.79	7.48	8.86	8.48	9.39	8.53	9.92	8.57	10.85	9.23	11.79	9.20	
	14	—	—	7.79	7.48	8.86	8.48	9.39	8.53	9.92	8.57	10.85	9.23	11.79	9.20	
	16	—	—	7.79	7.48	8.86	8.48	9.39	8.53	9.92	8.57	10.85	9.23	11.79	9.20	
	18	—	—	7.79	7.48	8.86	8.48	9.39	8.53	9.92	8.57	10.85	9.23	11.79	9.20	
	20	—	—	7.79	7.47	8.86	8.48	9.39	8.53	9.92	8.57	10.85	9.23	11.78	9.20	
	22	—	—	7.78	7.46	8.85	8.47	9.39	8.53	9.92	8.57	10.85	9.23	11.78	9.20	
	24	—	—	7.78	7.46	8.84	8.47	9.37	8.52	9.90	8.57	10.80	9.21	11.69	9.17	
	26	6.55	6.29	7.78	7.46	8.83	8.47	9.36	8.52	9.88	8.56	10.75	9.19	11.60	9.14	
	28	6.53	6.27	7.77	7.46	8.79	8.44	9.30	8.50	9.81	8.53	10.62	9.15	11.42	9.09	
	30	6.53	6.26	7.76	7.45	8.75	8.40	9.24	8.48	9.74	8.51	10.49	9.10	11.24	9.03	
	32	6.51	6.25	7.68	7.37	8.64	8.29	9.13	8.43	9.61	8.47	10.32	9.05	11.03	8.97	
	34	6.49	6.23	7.60	7.29	8.54	8.20	9.01	8.39	9.49	8.42	10.16	9.00	10.84	8.91	
	35	6.48	6.22	7.55	7.25	8.49	8.15	9.00	8.39	9.42	8.40	10.09	8.97	10.76	8.89	
	36	6.48	6.22	7.51	7.21	8.43	8.10	8.90	8.35	9.36	8.38	10.02	8.95	10.67	8.86	
	38	6.46	6.20	7.42	7.12	8.33	7.99	8.78	8.29	9.23	8.33	9.86	8.90	10.49	8.81	
	39	6.45	6.19	7.37	7.08	8.27	7.94	8.72	8.27	9.17	8.31	9.79	8.88	10.41	8.78	

### Model FDURA112KXE4R

Air Flow	Outdoor Temp	Indoor Temp													
		14°CWB		16°CWB		18°CWB		19°CWB		20°CWB		22°CWB		24°CWB	
		°CDB	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC
Hi	10	—	—	9.70	8.45	11.02	9.32	11.68	9.42	12.34	9.48	13.51	10.14	14.67	10.13
	12	—	—	9.70	8.45	11.02	9.32	11.68	9.42	12.34	9.48	13.51	10.14	14.67	10.13
	14	—	—	9.70	8.45	11.02	9.32	11.68	9.42	12.34	9.48	13.51	10.14	14.67	10.13
	16	—	—	9.70	8.45	11.02	9.32	11.68	9.42	12.34	9.48	13.51	10.14	14.67	10.13
	18	—	—	9.70	8.45	11.02	9.32	11.68	9.42	12.34	9.48	13.51	10.14	14.67	10.13
	20	—	—	9.69	8.45	11.02	9.32	11.68	9.42	12.34	9.48	13.51	10.14	14.66	10.12
	22	—	—	9.68	8.44	11.01	9.32	11.68	9.42	12.34	9.48	13.51	10.14	14.66	10.12
	24	—	—	9.68	8.44	11.00	9.31	11.66	9.41	12.32	9.47	13.44	10.12	14.55	10.09
	26	8.15	7.83	9.68	8.44	10.99	9.31	11.65	9.40	12.30	9.46	13.37	10.10	14.44	10.05
	28	8.13	7.81	9.67	8.44	10.94	9.29	11.57	9.37	12.21	9.43	13.22	10.05	14.21	9.98
	30	8.12	7.80	9.65	8.43	10.89	9.27	11.50	9.33	12.12	9.39	13.05	9.99	13.99	9.91
	32	8.10	7.77	9.55	8.39	10.75	9.22	11.36	9.27	11.96	9.34	12.85	9.92	13.73	9.82
	34	8.08	7.75	9.45	8.35	10.63	9.17	11.21	9.22	11.80	9.28	12.64	9.85	13.48	9.75
	35	8.06	7.74	9.40	8.33	10.56	9.14	11.20	9.21	11.73	9.23	12.56	9.82	13.38	9.71
	36	8.06	7.74	9.34	8.30	10.49	9.11	11.08	9.17	11.65	9.20	12.47	9.79	13.27	9.68
	38	8.04	7.72	9.23	8.25	10.36	9.06	10.93	9.11	11.49	9.15	12.28	9.70	13.06	9.61
	39	8.03	7.71	9.17	8.23	10.29	9.03	10.85	9.08	11.41	9.12	12.19	9.67	12.96	9.56

Note (1) Symbols are as follows :

**TC** :Total cooling capacity (kw)  
**SHC** :Sensible heat capacity (kw)

### Model FDURA140KXE4R

Air Flow	Outdoor Temp	Indoor Temp													
		14°CWB		16°CWB		18°CWB		19°CWB		20°CWB		22°CWB		24°CWB	
	°CDB	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
Hi	10	—	—	12.12	10.46	13.78	11.51	14.60	11.61	15.43	11.70	16.88	12.53	18.34	12.50
	12	—	—	12.12	10.46	13.78	11.51	14.60	11.61	15.43	11.70	16.88	12.53	18.34	12.50
	14	—	—	12.12	10.46	13.78	11.51	14.60	11.61	15.43	11.70	16.88	12.53	18.34	12.50
	16	—	—	12.12	10.46	13.78	11.51	14.60	11.61	15.43	11.70	16.88	12.53	18.34	12.50
	18	—	—	12.12	10.46	13.78	11.51	14.60	11.61	15.43	11.70	16.88	12.53	18.34	12.50
	20	—	—	12.11	10.45	13.78	11.51	14.60	11.61	15.43	11.70	16.88	12.53	18.33	12.50
	22	—	—	12.10	10.45	13.76	11.50	14.60	11.61	15.43	11.70	16.88	12.53	18.33	12.50
	24	—	—	12.10	10.45	13.75	11.50	14.57	11.59	15.40	11.69	16.80	12.50	18.19	12.45
	26	10.19	9.78	12.10	10.45	13.73	11.49	14.56	11.59	15.37	11.68	16.72	12.47	18.05	12.41
	28	10.16	9.76	12.08	10.44	13.68	11.47	14.46	11.55	15.26	11.64	16.52	12.37	17.77	12.32
	30	10.15	9.74	12.07	10.43	13.61	11.44	14.38	11.52	15.15	11.58	16.31	12.30	17.49	12.23
	32	10.12	9.72	11.94	10.38	13.44	11.38	14.20	11.45	14.95	11.51	16.06	12.22	17.16	12.10
	34	10.09	9.69	11.82	10.33	13.29	11.32	14.01	11.38	14.76	11.43	15.81	12.13	16.86	12.01
	35	10.08	9.68	11.75	10.30	13.20	11.28	14.00	11.37	14.66	11.40	15.69	12.09	16.73	11.97
	36	10.08	9.68	11.68	10.27	13.12	11.25	13.85	11.32	14.56	11.36	15.58	12.05	16.59	11.92
	38	10.05	9.65	11.54	10.19	12.95	11.18	13.66	11.25	14.36	11.29	15.34	11.97	16.32	11.84
	39	10.04	9.64	11.47	10.16	12.87	11.15	13.57	11.21	14.27	11.25	15.23	11.94	16.20	11.80

### (i) FDE Series

#### Model FDEA36KXE4R

MODEL T-DAS00X2-71																
Air Flow	Outdoor Temp	Indoor Temp														
		14°CWB		16°CWB		18°CWB		19°CWB		20°CWB		22°CWB		24°CWB		
		°CDB	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
Hi	10	—	—	3.12	2.69	3.54	2.96	3.75	2.99	3.97	3.01	4.34	3.22	4.72	3.22	
	12	—	—	3.12	2.69	3.54	2.96	3.75	2.99	3.97	3.01	4.34	3.22	4.72	3.22	
	14	—	—	3.12	2.69	3.54	2.96	3.75	2.99	3.97	3.01	4.34	3.22	4.72	3.22	
	16	—	—	3.12	2.69	3.54	2.96	3.75	2.99	3.97	3.01	4.34	3.22	4.72	3.22	
	18	—	—	3.12	2.69	3.54	2.96	3.75	2.99	3.97	3.01	4.34	3.22	4.72	3.22	
	20	—	—	3.11	2.69	3.54	2.96	3.75	2.99	3.97	3.01	4.34	3.22	4.71	3.22	
	22	—	—	3.11	2.69	3.54	2.96	3.75	2.99	3.97	3.01	4.34	3.22	4.71	3.22	
	24	—	—	3.11	2.69	3.54	2.96	3.75	2.98	3.96	3.01	4.32	3.21	4.68	3.21	
	26	2.62	2.52	3.11	2.69	3.53	2.96	3.74	2.98	3.95	3.01	4.30	3.21	4.64	3.20	
	28	2.61	2.51	3.11	2.69	3.52	2.95	3.72	2.97	3.92	3.00	4.25	3.19	4.57	3.17	
	30	2.61	2.51	3.10	2.68	3.50	2.95	3.70	2.97	3.90	2.99	4.19	3.17	4.50	3.14	
	32	2.60	2.50	3.07	2.67	3.46	2.93	3.65	2.95	3.84	2.96	4.13	3.15	4.41	3.12	
	34	2.60	2.49	3.04	2.66	3.42	2.91	3.60	2.93	3.79	2.94	4.06	3.13	4.33	3.09	
	35	2.59	2.49	3.02	2.65	3.39	2.91	3.60	2.93	3.77	2.93	4.04	3.12	4.30	3.08	
	36	2.59	2.49	3.00	2.64	3.37	2.90	3.56	2.91	3.74	2.93	4.01	3.09	4.27	3.05	
	38	2.58	2.48	2.97	2.63	3.33	2.88	3.51	2.90	3.69	2.91	3.95	3.07	4.20	3.03	
	39	2.58	2.48	2.95	2.62	3.31	2.87	3.49	2.89	3.67	2.90	3.92	3.06	4.17	3.02	

#### Model FDEA45KXE4R

Air Flow	Outdoor Temp	Indoor Temp													
		14°CWB		16°CWB		18°CWB		19°CWB		20°CWB		22°CWB		24°CWB	
		°CDB	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC
Hi	10	—	—	3.90	3.04	4.43	3.33	4.69	3.37	4.96	3.41	5.43	3.63	5.90	3.63
	12	—	—	3.90	3.04	4.43	3.33	4.69	3.37	4.96	3.41	5.43	3.63	5.90	3.63
	14	—	—	3.90	3.04	4.43	3.33	4.69	3.37	4.96	3.41	5.43	3.63	5.90	3.63
	16	—	—	3.90	3.04	4.43	3.33	4.69	3.37	4.96	3.41	5.43	3.63	5.90	3.63
	18	—	—	3.90	3.04	4.43	3.33	4.69	3.37	4.96	3.41	5.43	3.63	5.90	3.63
	20	—	—	3.89	3.03	4.43	3.33	4.69	3.37	4.96	3.41	5.43	3.63	5.89	3.63
	22	—	—	3.89	3.03	4.42	3.33	4.69	3.37	4.96	3.41	5.43	3.63	5.89	3.63
	24	—	—	3.89	3.03	4.42	3.33	4.68	3.36	4.95	3.39	5.40	3.62	5.85	3.61
	26	3.28	2.87	3.89	3.03	4.41	3.33	4.68	3.36	4.94	3.39	5.37	3.61	5.80	3.60
	28	3.27	2.87	3.88	3.03	4.40	3.32	4.65	3.35	4.91	3.37	5.31	3.58	5.71	3.56
	30	3.26	2.87	3.88	3.03	4.37	3.31	4.62	3.34	4.87	3.36	5.24	3.56	5.62	3.53
	32	3.25	2.86	3.84	3.01	4.32	3.29	4.56	3.31	4.81	3.34	5.16	3.53	5.52	3.50
	34	3.24	2.86	3.80	2.99	4.27	3.27	4.50	3.29	4.74	3.31	5.08	3.50	5.42	3.46
	35	3.24	2.86	3.78	2.98	4.24	3.26	4.50	3.29	4.71	3.30	5.04	3.48	5.38	3.45
	36	3.24	2.86	3.75	2.97	4.22	3.25	4.45	3.27	4.68	3.29	5.01	3.47	5.33	3.43
	38	3.23	2.85	3.71	2.95	4.16	3.22	4.39	3.25	4.62	3.26	4.93	3.44	5.25	3.40
	39	3.23	2.85	3.69	2.94	4.14	3.21	4.36	3.23	4.59	3.25	4.90	3.42	5.21	3.38

Note (1) Symbols are as follows :

**TC** :Total cooling capacity (kw)  
**SHC** :Sensible heat capacity (kw)

### Model FDEA56KXE4R

Air Flow	Outdoor Temp	Indoor Temp													
		14°CWB		16°CWB		18°CWB		19°CWB		20°CWB		22°CWB		24°CWB	
	°CDB	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
Hi	10	—	—	4.85	3.54	5.51	3.89	5.84	3.94	6.17	3.99	6.75	4.22	7.34	4.22
	12	—	—	4.85	3.54	5.51	3.89	5.84	3.94	6.17	3.99	6.75	4.22	7.34	4.22
	14	—	—	4.85	3.54	5.51	3.89	5.84	3.94	6.17	3.99	6.75	4.22	7.34	4.22
	16	—	—	4.85	3.54	5.51	3.89	5.84	3.94	6.17	3.99	6.75	4.22	7.34	4.22
	18	—	—	4.85	3.54	5.51	3.89	5.84	3.94	6.17	3.99	6.75	4.22	7.34	4.22
	20	—	—	4.84	3.54	5.51	3.89	5.84	3.94	6.17	3.99	6.75	4.22	7.33	4.22
	22	—	—	4.84	3.54	5.50	3.88	5.84	3.94	6.17	3.99	6.75	4.22	7.33	4.22
	24	—	—	4.84	3.54	5.50	3.88	5.83	3.93	6.16	3.98	6.72	4.21	7.27	4.20
	26	4.08	3.32	4.84	3.54	5.49	3.88	5.82	3.93	6.15	3.98	6.69	4.19	7.22	4.18
	28	4.07	3.32	4.83	3.53	5.47	3.87	5.78	3.91	6.10	3.96	6.61	4.16	7.11	4.14
	30	4.06	3.31	4.83	3.53	5.44	3.86	5.75	3.90	6.06	3.94	6.52	4.13	6.99	4.09
	32	4.05	3.31	4.78	3.51	5.38	3.83	5.68	3.87	5.98	3.90	6.42	4.09	6.87	4.05
	34	4.04	3.30	4.73	3.48	5.31	3.80	5.61	3.83	5.90	3.87	6.32	4.05	6.74	4.00
	35	4.03	3.30	4.70	3.47	5.28	3.78	5.60	3.83	5.86	3.85	6.28	4.03	6.69	3.98
	36	4.03	3.30	4.67	3.46	5.25	3.77	5.54	3.80	5.82	3.83	6.23	4.01	6.64	3.96
	38	4.02	3.29	4.61	3.43	5.18	3.74	5.47	3.77	5.75	3.80	6.14	3.97	6.53	3.92
	39	4.02	3.29	4.59	3.42	5.15	3.71	5.43	3.76	5.71	3.78	6.09	3.95	6.48	3.90

### Model FDEA71KXE4R

Model F-DEA7-RXLE4H															
Air Flow	Outdoor Temp	Indoor Temp													
		14°CWB		16°CWB		18°CWB		19°CWB		20°CWB		22°CWB		24°CWB	
		°CDB	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC
Hi	10	—	—	6.15	4.95	6.99	5.44	7.41	5.50	7.82	5.54	8.56	5.91	9.30	5.92
	12	—	—	6.15	4.95	6.99	5.44	7.41	5.50	7.82	5.54	8.56	5.91	9.30	5.92
	14	—	—	6.15	4.95	6.99	5.44	7.41	5.50	7.82	5.54	8.56	5.91	9.30	5.92
	16	—	—	6.15	4.95	6.99	5.44	7.41	5.50	7.82	5.54	8.56	5.91	9.30	5.92
	18	—	—	6.15	4.95	6.99	5.44	7.41	5.50	7.82	5.54	8.56	5.91	9.30	5.92
	20	—	—	6.14	4.94	6.99	5.44	7.41	5.50	7.82	5.54	8.56	5.91	9.29	5.90
	22	—	—	6.13	4.94	6.98	5.44	7.41	5.50	7.82	5.54	8.56	5.91	9.29	5.90
	24	—	—	6.13	4.94	6.97	5.44	7.39	5.49	7.81	5.54	8.52	5.90	9.22	5.88
	26	5.17	4.70	6.13	4.94	6.97	5.44	7.38	5.49	7.80	5.53	8.48	5.88	9.15	5.86
	28	5.15	4.69	6.13	4.94	6.94	5.42	7.33	5.47	7.74	5.51	8.38	5.84	9.01	5.81
	30	5.15	4.69	6.12	4.93	6.90	5.41	7.29	5.45	7.68	5.49	8.27	5.80	8.87	5.76
	32	5.13	4.68	6.06	4.91	6.82	5.36	7.20	5.42	7.58	5.45	8.14	5.76	8.70	5.70
	34	5.12	4.67	5.99	4.88	6.74	5.33	7.11	5.38	7.48	5.41	8.02	5.71	8.55	5.65
	35	5.11	4.67	5.96	4.86	6.70	5.31	7.10	5.38	7.43	5.39	7.96	5.69	8.48	5.63
	36	5.11	4.67	5.92	4.85	6.65	5.30	7.02	5.34	7.38	5.37	7.90	5.67	8.41	5.61
	38	5.10	4.67	5.85	4.82	6.57	5.26	6.93	5.30	7.28	5.33	7.78	5.63	8.28	5.56
	39	5.09	4.66	5.81	4.80	6.52	5.24	6.88	5.28	7.23	5.31	7.72	5.61	8.21	5.54

### Model FDEA112KXE4R

Air Flow	Outdoor Temp	Indoor Temp													
		14°CWB		16°CWB		18°CWB		19°CWB		20°CWB		22°CWB		24°CWB	
	°CDB	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
Hi	10	—	—	9.70	7.52	11.02	8.28	11.68	8.37	12.34	8.45	13.51	9.00	14.67	9.01
	12	—	—	9.70	7.52	11.02	8.28	11.68	8.37	12.34	8.45	13.51	9.00	14.67	9.01
	14	—	—	9.70	7.52	11.02	8.28	11.68	8.37	12.34	8.45	13.51	9.00	14.67	9.01
	16	—	—	9.70	7.52	11.02	8.28	11.68	8.37	12.34	8.45	13.51	9.00	14.67	9.01
	18	—	—	9.70	7.52	11.02	8.28	11.68	8.37	12.34	8.45	13.51	9.00	14.67	9.01
	20	—	—	9.69	7.52	11.02	8.28	11.68	8.37	12.34	8.45	13.51	9.00	14.66	9.00
	22	—	—	9.68	7.51	11.01	8.28	11.68	8.37	12.34	8.45	13.51	9.00	14.66	9.00
	24	—	—	9.68	7.51	11.00	8.27	11.66	8.36	12.32	8.44	13.44	8.97	14.55	8.95
	26	8.15	7.12	9.68	7.51	10.99	8.27	11.65	8.36	12.30	8.43	13.37	8.95	14.44	8.91
	28	8.13	7.11	9.67	7.51	10.94	8.25	11.57	8.32	12.21	8.39	13.22	8.89	14.21	8.83
	30	8.12	7.10	9.65	7.50	10.89	8.22	11.50	8.30	12.12	8.36	13.05	8.82	13.99	8.75
	32	8.10	7.09	9.55	7.46	10.75	8.17	11.36	8.24	11.96	8.29	12.85	8.75	13.73	8.66
	34	8.08	7.08	9.45	7.41	10.63	8.11	11.21	8.18	11.80	8.23	12.64	8.67	13.48	8.58
	35	8.06	7.08	9.40	7.39	10.56	8.08	11.20	8.17	11.73	8.20	12.56	8.64	13.38	8.54
	36	8.06	7.08	9.34	7.36	10.49	8.05	11.08	8.12	11.65	8.17	12.47	8.60	13.27	8.51
	38	8.04	7.07	9.23	7.31	10.36	8.00	10.93	8.06	11.49	8.11	12.28	8.53	13.06	8.43
	39	8.03	7.06	9.17	7.29	10.29	7.97	10.85	8.03	11.41	8.07	12.19	8.50	12.96	8.40

Note (1) Symbols are as follows :

**TC** :Total cooling capacity (kw)  
**SHC** :Sensible heat capacity (kw)

### Model FDEA140KXE4R

Air Flow	Outdoor Temp	Indoor Temp													
		14°CWB		16°CWB		18°CWB		19°CWB		20°CWB		22°CWB		24°CWB	
	°CDB	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
Hi	10	—	—	12.12	9.00	13.78	9.88	14.60	10.02	15.43	10.12	16.88	10.74	18.34	10.76
	12	—	—	12.12	9.00	13.78	9.88	14.60	10.02	15.43	10.12	16.88	10.74	18.34	10.76
	14	—	—	12.12	9.00	13.78	9.88	14.60	10.02	15.43	10.12	16.88	10.74	18.34	10.76
	16	—	—	12.12	9.00	13.78	9.88	14.60	10.02	15.43	10.12	16.88	10.74	18.34	10.76
	18	—	—	12.12	9.00	13.78	9.88	14.60	10.02	15.43	10.12	16.88	10.74	18.34	10.76
	20	—	—	12.11	8.99	13.78	9.88	14.60	10.02	15.43	10.12	16.88	10.74	18.33	10.76
	22	—	—	12.10	8.99	13.76	9.88	14.60	10.02	15.43	10.12	16.88	10.74	18.33	10.76
	24	—	—	12.10	8.99	13.75	9.87	14.57	10.01	15.40	10.11	16.80	10.71	18.19	10.70
	26	10.19	8.47	12.10	8.99	13.73	9.86	14.56	10.00	15.37	10.10	16.72	10.67	18.05	10.65
	28	10.16	8.46	12.08	8.98	13.68	9.84	14.46	9.94	15.26	10.05	16.52	10.60	17.77	10.53
	30	10.15	8.45	12.07	8.97	13.61	9.81	14.38	9.91	15.15	10.00	16.31	10.51	17.49	10.43
	32	10.12	8.44	11.94	8.91	13.44	9.73	14.20	9.83	14.95	9.92	16.06	10.42	17.16	10.32
	34	10.09	8.42	11.82	8.86	13.29	9.66	14.01	9.75	14.76	9.83	15.81	10.32	16.86	10.20
	35	10.08	8.41	11.75	8.82	13.20	9.63	14.00	9.74	14.66	9.78	15.69	10.27	16.73	10.16
	36	10.08	8.41	11.68	8.79	13.12	9.59	13.85	9.68	14.56	9.74	15.58	10.23	16.59	10.11
	38	10.05	8.40	11.54	8.72	12.95	9.52	13.66	9.60	14.36	9.66	15.34	10.14	16.32	10.01
	39	10.04	8.39	11.47	8.69	12.87	9.48	13.57	9.56	14.27	9.62	15.23	10.08	16.20	9.97

### (j) FDK Series

#### Model FDKA22KXE4R

Air Flow	Outdoor Temp	Indoor Temp													
		14°CWB		16°CWB		18°CWB		19°CWB		20°CWB		22°CWB		24°CWB	
	°CDB	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
Hi	10	—	—	1.91	1.83	2.16	2.03	2.29	2.04	2.42	2.05	2.65	2.20	2.88	2.20
	12	—	—	1.91	1.83	2.16	2.03	2.29	2.04	2.42	2.05	2.65	2.20	2.88	2.20
	14	—	—	1.91	1.83	2.16	2.03	2.29	2.04	2.42	2.05	2.65	2.20	2.88	2.20
	16	—	—	1.91	1.83	2.16	2.03	2.29	2.04	2.42	2.05	2.65	2.20	2.88	2.20
	18	—	—	1.91	1.83	2.16	2.03	2.29	2.04	2.42	2.05	2.65	2.20	2.88	2.20
	20	—	—	1.90	1.83	2.16	2.03	2.29	2.04	2.42	2.05	2.65	2.20	2.88	2.20
	22	—	—	1.90	1.82	2.16	2.02	2.29	2.04	2.42	2.05	2.65	2.20	2.88	2.20
	24	—	—	1.90	1.82	2.16	2.02	2.29	2.04	2.42	2.05	2.64	2.20	2.86	2.19
	26	1.60	1.54	1.90	1.82	2.16	2.02	2.29	2.04	2.42	2.05	2.63	2.19	2.84	2.18
	28	1.60	1.53	1.90	1.82	2.15	2.02	2.27	2.03	2.40	2.04	2.60	2.18	2.79	2.17
	30	1.60	1.53	1.90	1.82	2.14	2.02	2.26	2.03	2.38	2.03	2.56	2.17	2.75	2.16
	32	1.59	1.53	1.88	1.80	2.11	2.01	2.23	2.02	2.35	2.02	2.52	2.16	2.70	2.14
	34	1.59	1.52	1.86	1.78	2.09	2.00	2.20	2.01	2.32	2.01	2.48	2.15	2.65	2.13
	35	1.58	1.52	1.85	1.77	2.07	1.99	2.20	2.00	2.30	2.01	2.47	2.14	2.63	2.12
	36	1.58	1.52	1.83	1.76	2.06	1.98	2.18	2.00	2.29	2.00	2.45	2.14	2.61	2.11
	38	1.58	1.52	1.81	1.74	2.04	1.95	2.15	1.98	2.26	1.99	2.41	2.12	2.57	2.10
	39	1.58	1.51	1.80	1.73	2.02	1.94	2.13	1.98	2.24	1.98	2.39	2.12	2.55	2.10

#### Model FDKA28KXE4R

Air Flow	Outdoor Temp	Indoor Temp													
		14°CWB		16°CWB		18°CWB		19°CWB		20°CWB		22°CWB		24°CWB	
	°CDB	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
Hi	10	—	—	2.42	2.05	2.76	2.26	2.92	2.28	3.09	2.30	3.38	2.46	3.67	2.46
	12	—	—	2.42	2.05	2.76	2.26	2.92	2.28	3.09	2.30	3.38	2.46	3.67	2.46
	14	—	—	2.42	2.05	2.76	2.26	2.92	2.28	3.09	2.30	3.38	2.46	3.67	2.46
	16	—	—	2.42	2.05	2.76	2.26	2.92	2.28	3.09	2.30	3.38	2.46	3.67	2.46
	18	—	—	2.42	2.05	2.76	2.26	2.92	2.28	3.09	2.30	3.38	2.46	3.67	2.46
	20	—	—	2.42	2.05	2.76	2.26	2.92	2.28	3.09	2.30	3.38	2.46	3.67	2.46
	22	—	—	2.42	2.05	2.75	2.26	2.92	2.28	3.09	2.30	3.38	2.46	3.67	2.46
	24	—	—	2.42	2.05	2.75	2.26	2.91	2.28	3.08	2.30	3.36	2.45	3.64	2.45
	26	2.04	1.96	2.42	2.05	2.75	2.26	2.91	2.28	3.07	2.29	3.34	2.45	3.61	2.44
	28	2.03	1.95	2.42	2.05	2.74	2.25	2.89	2.27	3.05	2.29	3.30	2.43	3.55	2.42
	30	2.03	1.95	2.41	2.05	2.72	2.25	2.88	2.27	3.03	2.28	3.26	2.42	3.50	2.40
	32	2.02	1.94	2.39	2.03	2.69	2.24	2.84	2.25	2.99	2.26	3.21	2.40	3.43	2.38
	34	2.02	1.94	2.36	2.02	2.66	2.22	2.80	2.24	2.95	2.25	3.16	2.38	3.37	2.36
	35	2.02	1.94	2.35	2.02	2.64	2.21	2.80	2.24	2.93	2.24	3.14	2.37	3.35	2.35
	36	2.02	1.94	2.34	2.01	2.62	2.21	2.77	2.22	2.91	2.23	3.12	2.37	3.32	2.34
	38	2.01	1.93	2.31	2.00	2.59	2.19	2.73	2.21	2.87	2.22	3.07	2.35	3.26	2.32
	39	2.01	1.93	2.29	1.99	2.57	2.19	2.71	2.20	2.85	2.21	3.05	2.34	3.24	2.31

Note (1) Symbols are as follows :

**TC** :Total cooling capacity (kw)  
**SHC** :Sensible heat capacity (kw)

### Model FDKA36KXE4R

Air Flow	Outdoor Temp °CDB	Indoor Temp													
		14°CWB		16°CWB		18°CWB		19°CWB		20°CWB		22°CWB		24°CWB	
		TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
Hi	10	—	—	3.12	2.59	3.54	2.85	3.75	2.88	3.97	2.90	4.34	3.09	4.72	3.10
	12	—	—	3.12	2.59	3.54	2.85	3.75	2.88	3.97	2.90	4.34	3.09	4.72	3.10
	14	—	—	3.12	2.59	3.54	2.85	3.75	2.88	3.97	2.90	4.34	3.09	4.72	3.10
	16	—	—	3.12	2.59	3.54	2.85	3.75	2.88	3.97	2.90	4.34	3.09	4.72	3.10
	18	—	—	3.12	2.59	3.54	2.85	3.75	2.88	3.97	2.90	4.34	3.09	4.72	3.10
	20	—	—	3.11	2.59	3.54	2.85	3.75	2.88	3.97	2.90	4.34	3.09	4.71	3.09
	22	—	—	3.11	2.59	3.54	2.85	3.75	2.88	3.97	2.90	4.34	3.09	4.71	3.09
	24	—	—	3.11	2.59	3.54	2.85	3.75	2.87	3.96	2.89	4.32	3.09	4.68	3.08
	26	2.62	2.46	3.11	2.59	3.53	2.85	3.74	2.87	3.95	2.89	4.30	3.08	4.64	3.07
	28	2.61	2.46	3.11	2.58	3.52	2.84	3.72	2.86	3.92	2.88	4.25	3.06	4.57	3.04
	30	2.61	2.46	3.10	2.58	3.50	2.83	3.70	2.85	3.90	2.87	4.19	3.04	4.50	3.02
	32	2.60	2.45	3.07	2.57	3.46	2.81	3.65	2.84	3.84	2.85	4.13	3.02	4.41	2.99
	34	2.60	2.45	3.04	2.55	3.42	2.80	3.60	2.82	3.79	2.83	4.06	3.00	4.33	2.97
	35	2.59	2.45	3.02	2.55	3.39	2.79	3.60	2.82	3.77	2.82	4.04	2.99	4.30	2.96
	36	2.59	2.45	3.00	2.54	3.37	2.78	3.56	2.80	3.74	2.81	4.01	2.98	4.27	2.94
	38	2.58	2.45	2.97	2.52	3.33	2.76	3.51	2.78	3.69	2.79	3.95	2.95	4.20	2.92
	39	2.58	2.44	2.95	2.52	3.31	2.75	3.49	2.77	3.67	2.78	3.92	2.94	4.17	2.91

### Model FDKA45KXE4R

Air Flow	Outdoor Temp °CDB	Indoor Temp													
		14°CWB		16°CWB		18°CWB		19°CWB		20°CWB		22°CWB		24°CWB	
		TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
Hi	10	—	—	3.90	3.11	4.43	3.41	4.69	3.45	4.96	3.48	5.43	3.71	5.90	3.71
	12	—	—	3.90	3.11	4.43	3.41	4.69	3.45	4.96	3.48	5.43	3.71	5.90	3.71
	14	—	—	3.90	3.11	4.43	3.41	4.69	3.45	4.96	3.48	5.43	3.71	5.90	3.71
	16	—	—	3.90	3.11	4.43	3.41	4.69	3.45	4.96	3.48	5.43	3.71	5.90	3.71
	18	—	—	3.90	3.11	4.43	3.41	4.69	3.45	4.96	3.48	5.43	3.71	5.90	3.71
	20	—	—	3.89	3.10	4.43	3.41	4.69	3.45	4.96	3.48	5.43	3.71	5.89	3.71
	22	—	—	3.89	3.10	4.42	3.41	4.69	3.45	4.96	3.48	5.43	3.71	5.89	3.71
	24	—	—	3.89	3.10	4.42	3.41	4.68	3.44	4.95	3.48	5.40	3.70	5.85	3.69
	26	3.28	2.95	3.89	3.10	4.41	3.41	4.68	3.44	4.94	3.48	5.37	3.69	5.80	3.68
	28	3.27	2.94	3.88	3.10	4.40	3.40	4.65	3.43	4.91	3.46	5.31	3.67	5.71	3.64
	30	3.26	2.94	3.88	3.10	4.37	3.39	4.62	3.42	4.87	3.45	5.24	3.64	5.62	3.61
	32	3.25	2.94	3.84	3.08	4.32	3.37	4.56	3.39	4.81	3.42	5.16	3.61	5.52	3.58
	34	3.24	2.93	3.80	3.06	4.27	3.35	4.50	3.37	4.74	3.39	5.08	3.58	5.42	3.54
	35	3.24	2.93	3.78	3.05	4.24	3.33	4.50	3.37	4.71	3.38	5.04	3.57	5.38	3.53
	36	3.24	2.93	3.75	3.04	4.22	3.32	4.45	3.35	4.68	3.37	5.01	3.55	5.33	3.51
	38	3.23	2.93	3.71	3.02	4.16	3.30	4.39	3.32	4.62	3.34	4.93	3.53	5.25	3.49
	39	3.23	2.92	3.69	3.01	4.14	3.29	4.36	3.31	4.59	3.33	4.90	3.51	5.21	3.47

### Model FDKA56KXE4R

Air Flow	Outdoor Temp °CDB	Indoor Temp													
		14°CWB		16°CWB		18°CWB		19°CWB		20°CWB		22°CWB		24°CWB	
		TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
Hi	10	—	—	4.85	3.90	5.51	4.27	5.84	4.31	6.17	4.35	6.75	4.65	7.34	4.64
	12	—	—	4.85	3.90	5.51	4.27	5.84	4.31	6.17	4.35	6.75	4.65	7.34	4.64
	14	—	—	4.85	3.90	5.51	4.27	5.84	4.31	6.17	4.35	6.75	4.65	7.34	4.64
	16	—	—	4.85	3.90	5.51	4.27	5.84	4.31	6.17	4.35	6.75	4.65	7.34	4.64
	18	—	—	4.85	3.90	5.51	4.27	5.84	4.31	6.17	4.35	6.75	4.65	7.34	4.64
	20	—	—	4.84	3.89	5.51	4.27	5.84	4.31	6.17	4.35	6.75	4.65	7.33	4.64
	22	—	—	4.84	3.89	5.50	4.27	5.84	4.31	6.17	4.35	6.75	4.65	7.33	4.64
	24	—	—	4.84	3.89	5.50	4.26	5.83	4.31	6.16	4.35	6.72	4.63	7.27	4.62
	26	4.08	3.69	4.84	3.89	5.49	4.26	5.82	4.31	6.15	4.34	6.69	4.62	7.22	4.60
	28	4.07	3.69	4.83	3.89	5.47	4.25	5.78	4.29	6.10	4.32	6.61	4.59	7.11	4.56
	30	4.06	3.68	4.83	3.89	5.44	4.24	5.75	4.28	6.06	4.31	6.52	4.56	6.99	4.52
	32	4.05	3.68	4.78	3.86	5.38	4.21	5.68	4.25	5.98	4.27	6.42	4.52	6.87	4.48
	34	4.04	3.67	4.73	3.84	5.31	4.19	5.61	4.22	5.90	4.24	6.32	4.49	6.74	4.44
	35	4.03	3.67	4.70	3.83	5.28	4.17	5.60	4.21	5.86	4.23	6.28	4.47	6.69	4.42
	36	4.03	3.67	4.67	3.82	5.25	4.16	5.54	4.19	5.82	4.21	6.23	4.45	6.64	4.40
	38	4.02	3.67	4.61	3.79	5.18	4.13	5.47	4.16	5.75	4.18	6.14	4.42	6.53	4.37
	39	4.02	3.66	4.59	3.78	5.15	4.12	5.43	4.14	5.71	4.17	6.09	4.40	6.48	4.35

Note (1) Symbols are as follows :

**TC** :Total cooling capacity (kw)  
**SHC** :Sensible heat capacity (kw)

### Model FDKA71KXE5R

Air Flow	Outdoor Temp	Indoor Temp													
		14°CWB		16°CWB		18°CWB		19°CWB		20°CWB		22°CWB		24°CWB	
	°CDB	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
Hi	10	—	—	6.15	4.94	6.99	5.45	7.41	5.51	7.82	5.55	8.56	5.93	9.30	5.93
	12	—	—	6.15	4.94	6.99	5.45	7.41	5.51	7.82	5.55	8.56	5.93	9.30	5.93
	14	—	—	6.15	4.94	6.99	5.45	7.41	5.51	7.82	5.55	8.56	5.93	9.30	5.93
	16	—	—	6.15	4.94	6.99	5.45	7.41	5.51	7.82	5.55	8.56	5.93	9.30	5.93
	18	—	—	6.15	4.94	6.99	5.45	7.41	5.51	7.82	5.55	8.56	5.93	9.30	5.93
	20	—	—	6.14	4.94	6.99	5.45	7.41	5.51	7.82	5.55	8.56	5.93	9.29	5.93
	22	—	—	6.13	4.94	6.98	5.45	7.41	5.51	7.82	5.55	8.56	5.93	9.29	5.93
	24	—	—	6.13	4.94	6.97	5.45	7.39	5.50	7.81	5.55	8.52	5.91	9.22	5.90
	26	5.17	4.70	6.13	4.94	6.97	5.44	7.38	5.50	7.80	5.54	8.48	5.90	9.15	5.88
	28	5.15	4.70	6.13	4.94	6.94	5.43	7.33	5.48	7.74	5.52	8.38	5.86	9.01	5.82
	30	5.15	4.69	6.12	4.93	6.90	5.42	7.29	5.47	7.68	5.50	8.27	5.82	8.87	5.78
	32	5.13	4.69	6.06	4.91	6.82	5.38	7.20	5.42	7.58	5.46	8.14	5.77	8.70	5.72
	34	5.12	4.68	5.99	4.88	6.74	5.35	7.11	5.39	7.48	5.42	8.02	5.73	8.55	5.67
	35	5.11	4.68	5.96	4.87	6.70	5.33	7.10	5.39	7.43	5.41	7.96	5.71	8.48	5.65
	36	5.11	4.68	5.92	4.85	6.65	5.31	7.02	5.36	7.38	5.39	7.90	5.68	8.41	5.63
	38	5.10	4.67	5.85	4.82	6.57	5.27	6.93	5.31	7.28	5.34	7.78	5.64	8.28	5.58
	39	5.09	4.67	5.81	4.81	6.52	5.26	6.88	5.29	7.23	5.33	7.72	5.59	8.21	5.52

### (k) FDFL , FDFU Series

#### Model FDFLA28KXE4R , FDFUA28KXE4R

Air Flow	Outdoor Temp	Indoor Temp													
		14°CWB		16°CWB		18°CWB		19°CWB		20°CWB		22°CWB		24°CWB	
	°CDB	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
Hi	10	—	—	2.42	2.33	2.76	2.64	2.92	2.74	3.09	2.75	3.38	2.97	3.67	2.96
	12	—	—	2.42	2.33	2.76	2.64	2.92	2.74	3.09	2.75	3.38	2.97	3.67	2.96
	14	—	—	2.42	2.33	2.76	2.64	2.92	2.74	3.09	2.75	3.38	2.97	3.67	2.96
	16	—	—	2.42	2.33	2.76	2.64	2.92	2.74	3.09	2.75	3.38	2.97	3.67	2.96
	18	—	—	2.42	2.33	2.76	2.64	2.92	2.74	3.09	2.75	3.38	2.97	3.67	2.96
	20	—	—	2.42	2.33	2.76	2.64	2.92	2.74	3.09	2.75	3.38	2.97	3.67	2.96
	22	—	—	2.42	2.32	2.75	2.64	2.92	2.74	3.09	2.75	3.38	2.97	3.67	2.96
	24	—	—	2.42	2.32	2.75	2.64	2.91	2.74	3.08	2.75	3.36	2.96	3.64	2.95
	26	2.04	1.96	2.42	2.32	2.75	2.64	2.91	2.73	3.07	2.75	3.34	2.96	3.61	2.94
	28	2.03	1.95	2.42	2.32	2.74	2.63	2.89	2.73	3.05	2.74	3.30	2.94	3.55	2.92
	30	2.03	1.95	2.41	2.32	2.72	2.61	2.88	2.72	3.03	2.73	3.26	2.92	3.50	2.91
	32	2.02	1.94	2.39	2.29	2.69	2.58	2.84	2.71	2.99	2.72	3.21	2.91	3.43	2.88
	34	2.02	1.94	2.36	2.27	2.66	2.55	2.80	2.69	2.95	2.70	3.16	2.89	3.37	2.86
	35	2.02	1.94	2.35	2.26	2.64	2.53	2.80	2.69	2.93	2.70	3.14	2.88	3.35	2.86
	36	2.02	1.94	2.34	2.24	2.62	2.52	2.77	2.66	2.91	2.69	3.12	2.88	3.32	2.85
	38	2.01	1.93	2.31	2.21	2.59	2.49	2.73	2.62	2.87	2.68	3.07	2.86	3.26	2.83
	39	2.01	1.93	2.29	2.20	2.57	2.47	2.71	2.60	2.85	2.67	3.05	2.86	3.24	2.83

#### Model FDFLA45KXE4R , FDFUA45KXE4R

Air Flow	Outdoor Temp	Indoor Temp													
		14°CWB		16°CWB		18°CWB		19°CWB		20°CWB		22°CWB		24°CWB	
	°CDB	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
Hi	10	—	—	3.90	3.42	4.43	3.77	4.69	3.80	4.96	3.82	5.43	4.11	5.90	4.10
	12	—	—	3.90	3.42	4.43	3.77	4.69	3.80	4.96	3.82	5.43	4.11	5.90	4.10
	14	—	—	3.90	3.42	4.43	3.77	4.69	3.80	4.96	3.82	5.43	4.11	5.90	4.10
	16	—	—	3.90	3.42	4.43	3.77	4.69	3.80	4.96	3.82	5.43	4.11	5.90	4.10
	18	—	—	3.90	3.42	4.43	3.77	4.69	3.80	4.96	3.82	5.43	4.11	5.90	4.10
	20	—	—	3.89	3.42	4.43	3.77	4.69	3.80	4.96	3.82	5.43	4.11	5.89	4.10
	22	—	—	3.89	3.42	4.42	3.77	4.69	3.80	4.96	3.82	5.43	4.11	5.89	4.10
	24	—	—	3.89	3.42	4.42	3.77	4.68	3.80	4.95	3.82	5.40	4.10	5.85	4.08
	26	3.28	3.14	3.89	3.42	4.41	3.76	4.68	3.79	4.94	3.82	5.37	4.09	5.80	4.07
	28	3.27	3.14	3.88	3.42	4.40	3.76	4.65	3.78	4.91	3.80	5.31	4.07	5.71	4.04
	30	3.26	3.13	3.88	3.42	4.37	3.75	4.62	3.77	4.87	3.79	5.24	4.04	5.62	4.01
	32	3.25	3.12	3.84	3.40	4.32	3.73	4.56	3.75	4.81	3.77	5.16	4.01	5.52	3.98
	34	3.24	3.11	3.80	3.38	4.27	3.71	4.50	3.73	4.74	3.74	5.08	3.98	5.42	3.94
	35	3.24	3.11	3.78	3.37	4.24	3.70	4.50	3.73	4.71	3.73	5.04	3.97	5.38	3.93
	36	3.24	3.11	3.75	3.36	4.22	3.69	4.45	3.71	4.68	3.72	5.01	3.96	5.33	3.92
	38	3.23	3.10	3.71	3.35	4.16	3.66	4.39	3.68	4.62	3.70	4.93	3.93	5.25	3.89
	39	3.23	3.10	3.69	3.34	4.14	3.65	4.36	3.67	4.59	3.69	4.90	3.92	5.21	3.88

Note (1) Symbols are as follows :

**TC** :Total cooling capacity (kw)  
**SHC** :Sensible heat capacity (kw)

### Model FDFUA56KXE4R

Air Flow	Outdoor Temp	Indoor Temp													
		14°CWB		16°CWB		18°CWB		19°CWB		20°CWB		22°CWB		24°CWB	
	°CDB	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
Hi	10	—	—	4.85	3.85	5.51	4.23	5.84	4.27	6.17	4.32	6.75	4.59	7.34	4.59
	12	—	—	4.85	3.85	5.51	4.23	5.84	4.27	6.17	4.32	6.75	4.59	7.34	4.59
	14	—	—	4.85	3.85	5.51	4.23	5.84	4.27	6.17	4.32	6.75	4.59	7.34	4.59
	16	—	—	4.85	3.85	5.51	4.23	5.84	4.27	6.17	4.32	6.75	4.59	7.34	4.59
	18	—	—	4.85	3.85	5.51	4.23	5.84	4.27	6.17	4.32	6.75	4.59	7.34	4.59
	20	—	—	4.84	3.85	5.51	4.23	5.84	4.27	6.17	4.32	6.75	4.59	7.33	4.59
	22	—	—	4.84	3.84	5.50	4.23	5.84	4.27	6.17	4.32	6.75	4.59	7.33	4.59
	24	—	—	4.84	3.84	5.50	4.23	5.83	4.27	6.16	4.31	6.72	4.58	7.27	4.57
	26	4.08	3.65	4.84	3.84	5.49	4.22	5.82	4.27	6.15	4.31	6.69	4.57	7.22	4.55
	28	4.07	3.64	4.83	3.84	5.47	4.21	5.78	4.25	6.10	4.28	6.61	4.54	7.11	4.51
	30	4.06	3.64	4.83	3.84	5.44	4.20	5.75	4.24	6.06	4.26	6.52	4.51	6.99	4.47
	32	4.05	3.63	4.78	3.82	5.38	4.17	5.68	4.21	5.98	4.23	6.42	4.47	6.87	4.43
	34	4.04	3.63	4.73	3.79	5.31	4.14	5.61	4.18	5.90	4.20	6.32	4.43	6.74	4.38
	35	4.03	3.63	4.70	3.78	5.28	4.13	5.60	4.18	5.86	4.19	6.28	4.41	6.69	4.37
	36	4.03	3.63	4.67	3.77	5.25	4.11	5.54	4.15	5.82	4.17	6.23	4.40	6.64	4.35
	38	4.02	3.62	4.61	3.74	5.18	4.09	5.47	4.12	5.75	4.14	6.14	4.36	6.53	4.31
	39	4.02	3.62	4.59	3.73	5.15	4.06	5.43	4.10	5.71	4.13	6.09	4.35	6.48	4.30

### Model FDFLA71KXE4R , FDFUA71KXE4R

Model T DLEA7/1RXE4H , T DLEA7/1RXE4H															
Air Flow	Outdoor Temp	Indoor Temp													
		14°CWB		16°CWB		18°CWB		19°CWB		20°CWB		22°CWB		24°CWB	
	°CDB	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
Hi	10	—	—	6.15	4.92	6.99	5.41	7.41	5.47	7.82	5.52	8.56	5.88	9.30	5.88
	12	—	—	6.15	4.92	6.99	5.41	7.41	5.47	7.82	5.52	8.56	5.88	9.30	5.88
	14	—	—	6.15	4.92	6.99	5.41	7.41	5.47	7.82	5.52	8.56	5.88	9.30	5.88
	16	—	—	6.15	4.92	6.99	5.41	7.41	5.47	7.82	5.52	8.56	5.88	9.30	5.88
	18	—	—	6.15	4.92	6.99	5.41	7.41	5.47	7.82	5.52	8.56	5.88	9.30	5.88
	20	—	—	6.14	4.92	6.99	5.41	7.41	5.47	7.82	5.52	8.56	5.88	9.29	5.88
	22	—	—	6.13	4.91	6.98	5.41	7.41	5.47	7.82	5.52	8.56	5.88	9.29	5.88
	24	—	—	6.13	4.91	6.97	5.41	7.39	5.46	7.81	5.52	8.52	5.87	9.22	5.85
	26	5.17	4.67	6.13	4.91	6.97	5.40	7.38	5.46	7.80	5.51	8.48	5.85	9.15	5.83
	28	5.15	4.67	6.13	4.91	6.94	5.39	7.33	5.44	7.74	5.49	8.38	5.82	9.01	5.78
	30	5.15	4.66	6.12	4.91	6.90	5.38	7.29	5.42	7.68	5.47	8.27	5.78	8.87	5.73
	32	5.13	4.66	6.06	4.88	6.82	5.34	7.20	5.38	7.58	5.42	8.14	5.72	8.70	5.68
	34	5.12	4.65	5.99	4.85	6.74	5.31	7.11	5.35	7.48	5.38	8.02	5.68	8.55	5.62
	35	5.11	4.65	5.96	4.84	6.70	5.29	7.10	5.34	7.43	5.36	7.96	5.66	8.48	5.60
	36	5.11	4.65	5.92	4.82	6.65	5.27	7.02	5.31	7.38	5.34	7.90	5.64	8.41	5.57
	38	5.10	4.64	5.85	4.79	6.57	5.24	6.93	5.28	7.28	5.30	7.78	5.59	8.28	5.53
	39	5.09	4.64	5.81	4.77	6.52	5.22	6.88	5.26	7.23	5.28	7.72	5.57	8.21	5.51





Note (1) Symbols are as follows :

**TC** :Total cooling capacity (kw)  
**SHC** :Sensible heat capacity (kw)



## 4.5 APPLICATION DATA

# SAFETY PRECAUTIONS

- Please read these “Safety Precautions” first then accurately execute the installation work.
- Though the precautionary points indicated herein are divided under two headings,  **WARNING** and  **CAUTION**, those points which are related to the strong possibility of an installation done in error resulting in death or serious injury are listed in the  **WARNING** section. However, there is also a possibility of serious consequences in relationship to the points listed in the  **CAUTION** section as well.


In either case, important safety related information is indicated, so by all means, properly observe all that is mentioned.

- After completing the installation, along with confirming that no abnormalities were seen from the operation tests, please explain operating methods as well as maintenance methods to the user (customer) of this equipment, based on the owner’s manual. Moreover, ask the customer to keep this sheet together with the owner’s manual.

### **WARNING**

- Installation should be performed by the dealer or a company specializing in this type of installation. If you install the equipment yourself, installation errors could result in water leaks, electric shock, and/or a fire, as well as other hazards.
- Conduct installation work in accordance with the instructions in this installation manual. Installation errors could result in water leaks, electric shock, or fire.
- Sling the unit at the specified points with ropes properly rated for the weight in lifting it for portage. An improper manner of portage can result in a fail of the unit resulting in an accident involving personal death or injury.
- When installing a unit in a small room, take measure so that if the refrigerant leaks, it does not exceed the concentration limit. For information regarding measures to prevent the concentration limit from being exceeded, please contact the dealer.
- If refrigerant leaks and the concentration limit is exceeded, suffocation could occur.
- Install the equipment in a location that can sufficiently support the weight of the equipment. If the area is not strong enough, an accident could result from the unit falling.
- Install the equipment in a location that can withstand strong winds, such as typhoons, and earthquakes. If the installation is not secure, an accident could result from the unit falling.
- Always turn off power before work is performed inside the unit such as for installation or servicing. A failure to observe this instruction can cause a danger or electric shock.
- Electrical work should be done by a licensed electrician who shall do the work in accordance with the Technical Standards Regarding Electrical Equipment, Indoor Wiring Provisions, and this installation manual. The electrician shall use specified circuits for the equipment. If the power supply circuit capacity is insufficient or the work is not done correctly, it could result in electric shock or a fire.
- For wiring, the specified cable should be used, the connections should be secure, and the fixtures shall be strong enough to prevent cables from being pulled out from the terminal connections. Incorrect connections or work fixtures could result in heat generation or a fire.
- In cabling, arrange cables suitably so that they may not get off their support and then fix the service panel securely. Improper installation can cause heat generation and a resultant fire. Please prevent any substance other than the specified refrigerant (R410A) such as air from entering the refrigerant cycle in installing or moving the air conditioning system. Contamination by air or a foreign substance can cause an abnormal pressure build-up inside the refrigerant cycle and a resultant explosion and personal injury.
- Use only parts supplied with the unit and specified supply parts for installation. The use of unauthorized parts may cause the leaking of water or electricity causing a danger of electric shock or a fire, a refrigerant leak, performance degradation, and control failures.
- Do not open operation valves (either liquid or gas or both) until refrigerant piping, an air-tightness test and an air purge are completed. When a leak of refrigerant gas occurs during piping work, stop brazing pipes and ventilate the room. Refrigerant gas, when it comes into contact with bare fire, can generate a toxic gas.
- When installation is completed, check for refrigerant gas leaks. If the refrigerant gas leaks indoors, it could come in contact with a fan heater, burner, or hot plate, which could generate a poisonous gas.

### **CAUTION**

- Ground the equipment. Do not connect the ground wire to gas piping, water piping, a lightning rod, or telephone ground wires. If grounding is not performed correctly electric shock could occur. 
- Depending on the installation location, a circuit breaker may need to be installed. If a circuit breaker is not installed, electric shock may occur.
- Please follow this manual faithfully in performing installation work. Improper installation work can cause abnormal vibrations and noise generation.
- Do not install the equipment in areas where there is danger of flammable gas leaks. If such gas does leak it could collect around the units and cause a fire.
- Install the drain piping in accordance with the installation manual so that it properly discharges waste water and is maintained at a temperature that prevents condensation.
- Do not install the outdoor unit where winds from its fan blow directly onto a plant, etc. Winds can affect adversely to the plant, etc.
- Secure a space for inspection and maintenance as specified in the manual. An insufficient space can result in an accident such as a fall from the installation point and a resultant personal injury.
- When the outdoor unit is installed on a roof or at an elevated point, provide permanent ladders and handrails along the access route and fences and handrails around the outdoor unit.
- In tightening a flare nut, use a double spanner and observe the specified tightening torque. Care must be taken so as not to over-tighten a nut and damage the flare part. (Please refer to the tightening torque) The loosening or damage of the flare part can cause a refrigerant gas leak and a resultant lack-of-oxygen accident.
- Please dress the refrigerant piping with a heat insulation material for prevention of dew condensation. Improper heat insulation for prevention of dew condensation can cause the leaking or dripping of water and a resultant soaking of household effects.
- When refrigerant piping is completed, check its air-tightness with nitrogen gas to make sure it does not have a leak. A leak of refrigerant gas in a narrow room beyond the safety limit concentration can cause a lack-of oxygen accident.
- If the humidity exceeds 80% or the drain or piping become clogged, condensation from the indoor unit could drip and cause damage. Please do not install the indoor units above items of furniture, etc. that you do not want to get wet. Also, do not place items that you do not want to get wet underneath the indoor units.



# (1) Installation of indoor unit

## (a) Ceiling recessed compact type (FDTC)


### (i) Selection of installation location

- 1) Select location where the space above ceiling is larger than those mentioned below and perfect draining can be assured.
  - 2) With the customer's consent, select a location with following suitable conditions.
    - a) Where cool air or hot air can easily pass through.  
If the height of the location exceeds 3 m, hot air will gather in the ceiling. Suggest to the customer to also install a circulator.
    - b) Where water can be completely drained. A sloping location for drainage.
    - c) Where there are no wind disturbances to the air return air supply, where the fire alarm will not be set off erroneously, where no air circulation short circuits occur.
    - d) Where there is no direct sunlight.
    - e) If the humidity above the ceiling exceeds 80% or the condensation temperature above the ceiling exceeds 28°C, affix polyurethane foam (with a thickness to 10 or greater) above the insulation in the ceiling panels.
- ( Carry out tests of the main unit under the above conditions and confirm that there is no failure. However, if the environment where the unit is installed exceeds the above conditions and the unit is operated in high humidity conditions, there is danger of condensate dripping down. If there is a possibility that the unit will be used under such conditions, dress 10 to 20 mm of insulation material on the main unit, piping and drain pipes. )
- 3) Consider the supporting strength of the location. If the strength is not sufficient to sustain the unit weight, use reinforcing materials.

### (ii) Installation space for unit






- a) When a sufficient interval cannot be secured between the unit and a wall or another unit, shut up diffusers on that port to block air supply and make sure that no air short-circuiting is occurring. (A air supply port blocking material is available as an optional part)
- Do not use the unit in the "Lo" wind mode, when air is blown into two or three directions.

### • Installation space



Note (1) This shows the installation interval dimensions between units centered on the units.

Unit:mm





### (iii) Suspension




- Please arrange four sets of a suspension bolt (M10 or M8), a nut matching the bolt, a flat washers and a spring washer at the installation site.

#### When suspended from the ceiling


- 1) This unit is designed for installation on a  $2 \times 2$  grid ceiling.  
If necessary, please detach the T bar temporarily before you install it.  
(When it is installed on a ceiling other than  $2 \times 2$  grid ceiling, please do not fail to provide an inspection port on the control box side.)
- 2) Determine the positions of suspension bolts ( $530 \times 530$ ).
- 3) Use four suspension bolts, each fastened in such a manner that it can withstand pull force of 490N.
- 4) Make suspension bolts to the length that leaves approximately 45mm of them above the ceiling. In hoisting the unit main body in, temporarily fasten the four lower nuts of the suspension bolts approx. 93 mm from the ceiling and the four upper nuts at positions sufficiently far from the lower nuts so that they may not hamper installation work when the unit is hoisted in or the height is adjusted.
- 5) Put in the unit on an angle.



- 6) After hoisting in the unit, attach level gauges supplied as accessories and determine the unit position (height). To adjust height, use the four lower nuts with the four upper nuts left loose. Please make sure that the unit's four hanging fixtures touch the four lower nuts and washers evenly without any play.




Touch the lower nut and washer without any play



Play is left between the fixture and the lower nut and washer

- 7) Please make sure that the unit main body is installed levelly. Level must be checked with a level or a clear hose filled with water. (A tolerable height difference at an end of the unit is within 3 mm)
- 8) After you have adjusted the height and level of the unit, fasten the four upper nuts to fix the unit.  
Note (1) Do not adjust the height with the upper nuts. It may cause deformation due to excessive force working on the unit main body, which can result in such problems that you cannot attach the panel or noises are generated from the interfering fan.




#### When embedded into ceiling


- 1) Determine the positions of hanging bolts ( $530 \times 530$ ).  
The pitch center of a suspension bolt must accord with the center of the unit.
- 2) Use four suspension bolts, each fastened in such a manner that it can withstand pull force of 490N.
- 3) Fix the unit as per (iii) 5) and 7) above.  
Note (1): When a suspension bolt exceeds 1.3 m in length, use an M10 bolt and give it reinforcements such as braces.

### (iv) Drain Piping

- 1) Glue the drain hose supplied as an accessory and a VP-25 joint before lifting the unit.
- 2) The drain hose is to provide a buffer to absorb a slight dislocation of the unit or the drain piping during installation work. If it is subject to abuse such as being bent or pulled deliberately, it may break, which will result in a water leak.



- 3) Care must be taken so as not to allow an adhesive to run into the drain hose. When it is hardened, it can cause a breakage of a flexible part, if the flexible part receives stress.
- 4) Use VP-25 general-purpose hard PVC pipes for drain piping.
- 5) Insert the drain hose supplied as an accessory (soft PVC end) to the stepped part of the unit's drain socket and then fasten it with the clamp also supplied as an accessory.
- 6) Adhesive must not be used.
  - a) Attach a VP-25 joint (to be procured locally) to joint it with the drain hose (hard PVC end) and then attach a VP-25 (to be procured locally) to the joint.
  - b) Give the drain piping a descending grade (1/50-1/100) and never create a bump to go over or a trap.
  - c) In connecting drain pipes, care must be taken so as not to apply force to the unit side piping and fix the pipe at a point as close to the unit as possible.
  - d) Do not create an air vent under any circumstances.
  - e) When drain piping is implemented for more than one unit, provide a collecting main about 100 mm below the units' drain outlets from which it collects drain. Use a VP-30 or larger pipe for a collecting main.
  - f) Do not fail to provide heat insulation at the following two points because they can cause dew condensation and a resultant water leak.




#### 7) Drain socket

After a drain test is completed, apply a pipe cover (small: accessory) onto the drain socket, cover the pipe cover (small), the clamp and part of the drain hose with a pipe cover (large: accessory) and wrap it with a tape completely without leaving any gaps.

(Cut pipe covers into appropriate shapes)


#### 8) Hard PVC pipes laid indoor

- a) Since a drain pipe outlet can be raised up to 600 mm from the ceiling, use elbows, etc. to install drain pipes, if there are obstacles preventing normal drain pipe arrangement. When the drain pipe is raised at a point far from a unit, it can cause an overflow due to a back flow of drain upon stoppage, so arrange piping to keep the dimensions specified in the illustration shown on the left.
- b) Install the drain pipe outlet where no odor is likely to be generated.
- c) Do not lead the drain pipe into a ditch where the generation of harmful gas such as sulfuric gas or flammable gas is expected. A failure to observe this instruction may cause such harmful or flammable gas to flow into the room.



### Drainage test

- ① Check that water is draining thoroughly during test run, and that there are no water leaks from the joints and the drain pan.
- ② The test has to be performed even if the unit is installed in the season when the unit is used for heating.
- ③ In a new house, perform the test before the ceiling is fitted.
  - Using a water pump, pour about 1000 cc of water to the drain pan through the supply outlet.
  - Check the transparent drain-out section of the drain hose for normal flow of drainage.
    - \* While observing the noise from the drain motor, test drain operation.
  - Take off the drain plug to release the water. After the water is drained, place the drain plug back where it was.
    - \* Be careful not to get splashed when pulling the drain plug.



### Forced drain pump operation

- ◆ Set up from a unit side.
  - ① Turn on DIP switch SW5-1 on the PCB of the indoor unit. The drain pump operates continuously.
  - ② After the test, be sure to turn off the DIP switch.
- (When electrical work is not completed, connect a convex joint to the drain pipe joint area, arrange an inlet and check leaks and drain connections of the pipe)

◆ Setup from a remote controller side.

Drain pump operation from a remote controller unit is possible. Operate a remote controller unit by following the steps described below.

1. To start a forced drain pump operation.

- ① Press the TEST button for three seconds or longer.

The display will change from “◆ SELECT ITEM” → “○ SET” → “※ TEST RUN ▼”

- ② Press the ▼ button once while “※ TEST RUN ▼” is displayed, and cause “DRAIN PUMP ◆” to be displayed.

- ③ When the SET button is pressed, a drain pump operation will start.

Display: “DRAIN PUMP RUN” → “○ → STOP”






2. To cancel a drain pump operation.

- ① If either SET or ON/OFF button is pressed, a forced drain pump operation will stop.

The air conditioning system will become OFF.

(v) Panel installation


1) Accessories (It is attached to the panel)

1	Hook		1 piece	For fixing temporarily
2	Chain		2 piece	
3	Screw		4 piece	For hoisting the panel
4	Screw		1 piece	For attaching a hook
5	Screw		2 piece	For attaching a chain


- 2) Make sure that the unit main body is positioned at the correct height and the opening on the ceiling is made to the correct dimensions with the level gauge supplied with the main body.

Remove the level gauge before you attach the panel.

- 3) Screw in two bolts out of the four supplied with the panel by about slightly less than 5mm. (● mark (A), (B)) [Figure 1]




[Figure 1]




[Figure 2]

- 4) Attach the hook supplied with the panel to the main body with the hook fixing screw (1 screw). [Figure 2]
- 5) Open the air return grille.
- 6) Please remove the screw of a corner panel and remove a corner panel. (four places) [Figure 3]



[Figure 3]

7) A panel is hooked on two bolts (● mark (A), (B)) [Figure 4]




8) Please rotate a hook, put in the slot on the panel, and carry out fixing the panel temporarily. [Figure 5]

9) Tighten the two bolts used for fixing the panel temporarily and the other two.


10) Please open the lid of a control box.

11) Like drain pump wiring, please band together by the clamp and put in louver motor wiring into a control box. [Figure 6]

12) Please connect a louver motor connector. [Figure 6]



13) Attach two chains to the air return grille with two screws. [Figure 7]



14) Replace the corner panels. Please also close a chain with a screw together then.

15) Close the air return grille.

## (b) Ceiling recessed type (FDT)

### (i) Selection of installation location

- 1) Select location where the space above ceiling is larger than those mentioned below and perfect draining can be assured.
- 2) With the customer's consent, select a location with following suitable conditions.
  - a) Where cool air or hot air can easily pass through.  
If the height of the location exceeds 3 m, hot air will gather in the ceiling. Suggest to the customer to also install a circulator.
  - b) Where water can be completely drained. A sloping location for drainage.
  - c) Where there are no wind disturbances to the air return and air supply, where the fire alarm will not be set off erroneously, where no air circulation short circuits occur.
  - d) Where there is no direct sunlight.
  - e) If the humidity above the ceiling exceeds 80% or the condensation temperature above the ceiling exceeds 28°C, affix polyurethane foam (with a thickness to 10 or greater) above the insulation in the ceiling panels.

Model	Space above ceiling (h)
<b>FDT28, 36, 45, 56, 71</b>	Over 290mm
<b>FDT90</b>	Over 315mm
<b>FDT112, 140</b>	Over 385mm


Carry out tests of the main unit under the above conditions and confirm that there is no failure. However, if the environment where the unit is installed exceeds the above conditions and the unit is operated in high humidity conditions, there is danger of condensate dripping down. If there is a possibility that the unit will be used under such conditions, dress 10 to 20 mm of insulation material to the main unit, piping and drain pipes.

- 3) Consider the supporting strength of the location. If the strength is not sufficient to sustain the unit weight, use reinforcing materials.

### (ii) Installation space for unit



- a) When a sufficient interval cannot be secured between the unit and a wall or another unit, shut up diffusers on that port to block air supply and make sure that no short-circuiting is occurring. (A air supply port blocking material is available as an optional part)
- Do not use the unit in the "LO" wind mode, when air is blown into two or three directions.
- b) When the unit has 2500 mm or less clearance, attach a fan guard (option part) on the intake side of the fan.

#### • Installation space



Note (1) This shows the installation interval dimensions between units centered on the units.

Unit:mm



A	Gas pipe connecting port
B	Liquid pipe connecting port
C	Drain line connecting port
D	Hole for wiring
E	Suspension bolt
F	Outside air opening for ducting
G	Outlet air opening for ducting

Model	a	b
FDT 28~71	212	270
FDT 90	212	295
FDT 112, 140	269	365

### (iii) Suspension

- Please arrange four sets of a suspension bolt (M10 or M8), a nut matching the bolt, a flat washers and a spring washer at the installation site.


#### When suspended from the ceiling

- 1) Cut and opening of □860~□890.


In cutting an opening on the ceiling, use the unit's cardboard container for shipment as a reference of the size of opening.

The center of the opening on the ceiling must accord with the center of the unit.

- 2) Determine the positions of suspension bolts (675×780).
- 3) Use four suspension bolts, each fastened in such a manner that it can withstand pull force of 490N.
- 4) Make suspension bolts to the length that leaves approximately 70 mm of them above the ceiling.
- 5) After hoisting in the unit, attach level gauges supplied as accessories and determine the unit position (height).



- 6) Use a transparent tube with water filled inside to check the level of the unit. (A tolerable height difference at an end of the unit is within 3 mm)



#### When embedded into ceiling

- 1) Determine the positions of suspension bolts (675×780).

The pitch center of a suspension bolt must accord with the center of the unit.

- 2) Use four suspension bolts, each fastened in such a manner that it can withstand pull force of 490N.
- 3) In cutting an opening on the ceiling, use the unit's cardboard container for shipment as a reference of the size of opening.
- 4) Fix the unit as per 5) and 6) above.

The unit's cardboard container for shipment can be used to cover the indoor unit.


Note (1): When a hanging bolt exceeds 1.3 m in length, use an M10 bolt and give it reinforcements such as braces.




#### (iv) Drain Piping

- 1) Drain piping should always be in downhill decline ( $1/50 \sim 1/100$ ) and avoid riding across an elevation or making traps.




##### • Good piping



##### • Improper piping




- 2) When connecting the drain pipe to unit, pay sufficient attention not to apply excess force to the piping on the unit side. Also, fix the piping at a point as close as possible to the unit.
- 3) For drain pipe, use hard PVC general purpose pipe VP-25(I.D.1") which can be purchased locally. When connecting, insert a PVC pipe end securely into the drain socket before tightening securely using the attached drain hose and clamp. Adhesive must not be used connection of the drain socket and drain hose (accessory).
- 4) When constructing drain piping for several units, position the common pipe about 100 mm below the drain outlet of each unit as shown in the sketch. Use VP-30(1 1/4") or thicker pipe for this purposes.
- 5) Be sure to provide heat insulation to hard PVC pipes of indoor placement.
- 6) Do not ever provide an air vent.
- 7) The height of the drain head can be elevated up to a point 700 mm above the ceiling and, when an obstacle exists in the ceiling space, elevate the piping to avoid the obstacle using an elbow or corresponding gadget. When doing this, if the stretch for the needed height is too high, the back-flow quantity of drain at the event of interruption of the operation gets too much and it may cause overflow at the drain pan. Therefore, make the height of the drain pipe within the distance given in the sketch below.
- 8) Avoid positioning the drain piping outlet at a place where generation of odor may be stimulated. Do not lead the drain piping direct into a sewer from where sulfur gas may generate.
- 9) The purpose of drain hose is to absorb minute discrepancy of the unit or the drain piping occurred when they are installed. Therefore, when it is bent intentionally or used under expanded condition, it may be damaged and result in water leakage.



#### Drainage test

- ① Check that water is draining thoroughly during test run, and that there are no water leaks from the joints and the drain pan.
- ② The test has to be performed even if the unit is installed in the season when the unit is used for heating.
- ③ In a new house, perform the test before the ceiling is fitted.
  - Using a water pump, pour about 1000 cc of water to the drain pan through the supply outlet.
  - Check the transparent drain-out section of the drain hose for normal flow of drainage.
    - \* While observing the noise from the drain motor, test drain operation.
  - Take off the drain plug to release the water. After the water is drained, place the drain plug back where it was..
    - \* While observing the noise from the drain motor, test drain operation.



#### Forced drain pump operation

- ◆ Set up from a unit side.
  - ① Turn on DIP switch SW5-1 on the PCB of the indoor unit. The drain pump operates continuously.
  - ② After the test, be sure to turn off the DIP switch.
- (When electrical work is not completed, connect a convex joint to the drain pipe joint area, arrange an inlet and check leaks and drain connections of the pipe)



◆ Setup from a remote controller side.

Drain pump operation from a remote controller unit is possible. Operate a remote controller unit by following the steps described below.

1. To start a forced drain pump operation.

- ① Press the TEST button for three seconds or longer.

The display will change from “◆ SELECT ITEM” → “○ SET” → “※ TEST RUN ▼”

- ② Press the ▼ button once while “※ TEST RUN ▼” is displayed, and cause “DRAIN PUMP ◆” to be displayed.

- ③ When the SET button is pressed, a drain pump operation will start.

Display: “DRAIN PUMP RUN” → “○ SET → STOP”

2. To cancel a drain pump operation.

- ① If either SET or ON/OFF button is pressed, a forced drain pump operation will stop.

The air conditioning system will become OFF.


(v) Panel installation

1) Accessories

Name	Quantity	Remarks
Air inlet grille	1	
Air filter	1	
Suspension bolts	4	For panel installation

2) Confirm the unit's installation level.

- Make sure from the level gauge (insulation) packed with the air conditioner unit that the installation height of the unit and the dimensions of the opening in the ceiling are correct.
- Confirm the installation level of the air conditioner unit and ceiling material.
- Affix the level gauge included with the air conditioner unit and fix the unit's installation height.
- Remove the level gauge before installing the unit.
- The unit's installation height can be minutely adjusted by means of the corner openings after the panel is installed. (For details, see 6) “Installing the Panel.”)



Note (1) : If the installation level of the air conditioner unit and ceiling material exceed the proper range, it will cause an undue load to be borne during installation of the panel and could cause damage.

3) Unit installation direction and panel and air return grille direction

- (a) The unit and panel installation orientation is directional.

- Match up the outlet (small) parts with the refrigerant piping direction.
- Make sure of the motor and switch connector connection directions. (For details, see 6) “Installing the Panel.”)

- (b) The panel and air return grille installation orientation is not directional.


If you are changing the direction of the air return grille, change the panel's striker installation position to the “Pull” character position direction on the surface of the grille.

#### 4) Removing the air return grille

- ① Raise up the notched portion of the air return grille and open it.
- ② With the air return grille open, remove the air return grille hinge from the decorator panel.

#### 5) Removing the corner panel


- Take out the screw in the corner, then lift up the corner panel in the arrow direction and remove it.




#### 6) Panel installation

- ① Screw in lightly 2 of the 4 air conditioner unit suspension bolts in opposite corners from each other by about 5 mm.  
(Fasten the drain piping side and the opposite corner temporarily.)
- ② Hang the panel on the two suspension bolts to install it temporarily.
- ③ Install the two remaining suspension bolts and tighten all four of the bolts.


Notes (1) : If the suspension bolts are not tightened sufficiently, it could cause the following trouble, so tighten the bolts securely.



(2) : If there is still a gap between the ceiling and the decorator panel even after the suspension bolts are tightened, readjust the height of the indoor unit.



(3) : The unit's installation height can be minutely adjusted with the decorator panel as long as the indoor unit is level and drain piping are not affected.




Carry out minute adjustments by turning the indoor unit's nut using a spanner or similar tool from the corner opening.

- ④ Connect the (white, 5p) louver motor connector.

- ⑤ Place each of the connectors inside the control box.


Note (1) : If the air supply louver does not operate using the remote controller, check the connector's connection, then turn the main power supply OFF for 10 seconds or longer and turn the power ON again.



## 7) If the vertical air-flow direction is fixed

- This decorator panel is designed so that you can fix the vertical air-flow direction at each air outlet to match the environment at your installation location. Set it as required by the customer. Furthermore, when the vertical air-flow direction is fixed, remote control operation and all automatic controls are disabled. The actual setting may also differ from the LCD display in the remote controller.

- Turn off the main power supply (turn it off at the ground fault circuit breaker).
- Disconnect the connector to the louver motor at the air outlet you want to fix the position of.  
Wrap vinyl electrical tape around the disconnected connector to insulate it.
- Slowly move the vertical air-flow louver you want to fix the position of by hand and set the vertical air-flow direction so that it is within the range shown in the table below.





\* It can be set anywhere desires as long as it is within a range of 22.5 and 36.5 mm.

Note (1) : Do not set the position outside this range.

Doing so causes condensate to drip and to form as well as dirtying of the ceiling surface, and could cause abnormal operation.

## 8) Corner panel installation

- ① Hook the corner panel strap to the pin on the decorator panel as shown in the figure.
- ② Insert part a on the corner panel in part A on the decorator panel, then fit the 2 claws and fasten the corner panel screw.



## 9) Installing the air return grille

- Install the air return grille by following the removal procedure (item 4) in reverse order.

Note (1) : Match up the installation position of the panel's striker and the "Pull" character position direction on the surface of the grille. If these do not match, the striker could be damaged.


### (c) 2-way outlet ceiling recessed type (FDTW)

#### (i) Selection of installation location

1) This unit is a ceiling surface direct return air and direct supply air type.


Install the unit a place the allows air to reach every part of the room, in accordance with the shape and height of the room.

#### • Installation space



Note (1) This shows the installation interval dimensions between units.

2) This unit permits connecting a branch duct ( $\phi 200$  mm) according to the method shown in the figure below so that air distribution may be improved to the shape of the room. (For the connecting port of the duct, refer to the exterior dimension on page 78 ~ 80.)



#### 3) Cold air throw

Unit : m

Models	FDTW28, 45, 56	FDTW71, 90	FDTW112	FDTW140
Item				
Standard	4.0	4.5	4.7	5.0
UHi	4.5	5.0	5.2	5.5

Note (1) The cold air throw is the same in 2 directions.

Conditions:

1. Unit height: 3.0 m above the floor
2. Fan speed: Hi
3. Location: Free space without obstacle
4. The throw is as the per the table above.
5. Air velocity at the throw: 0.3(m/s)

- 4) Places where cool or heated air circulates freely. When the installation height exceeds 3.0m, warmed air stays close to the ceiling. In such cases, suggest your client users to install air circulators.
- 5) Places where perfect drainage can be prepared and sufficient drainage gradient is available.
- 6) Places free from air disturbances to the return air port and supply hole of the indoor unit, places where the fire alarm may not malfunction to short circuit.
- 7) If the humidity above the ceiling exceeds 80% or the condensation temperature above the ceiling exceeds 28°C, affix polyurethane foam (with a thickness to 10 or greater) above the insulation in the ceiling panels.

( Carry out tests of the main unit under the above conditions and confirm that there is no failure. However, if the environment where the unit is installed exceeds the above conditions and the unit is operated in high humidity conditions, there is danger of condensate dripping down. If there is a possibility that the unit will be used under such conditions, dress 10 to 20 mm of insulation material to the main unit, piping and drain pipes. )

8) Places exposed to oil splashes or steam (e.g. kitchens and machine plants.)

Installation and use at such places will incur deteriorations in the performance or corrosion with the heat exchanger or damage in molded synthetic resin parts.

9) Places where corrosive gas (such as sulfurous acid gas) or inflammable gas (thinner, gasoline, etc.) is generated or remains.

Installation and use at such places will cause corrosion in the heat exchanger and damage in molded synthetic resin parts.


10) Place adjacent to equipment generating electromagnetic waves or high-frequency waves such as in hospitals. Generated noise may cause malfunctioning of the controller.

## (ii) Preparations for installation

1) Ceiling hole and suspension bolt positions

a) The pattern sheet shrinks or expands as humidity changes, so check the actual size before use.

b) The ceiling hole sizes and suspension bolt sizes are shown in the following figure.



Dimension table

Unit : mm

Mark Models	①	②	③	④	⑤	⑥
FDTW28, 45, 56	1015	885	468	417	70	60
FDTW71, 90	1260	1130	590	540	82.5	65
FDTW112, 140	1730	1600	825	775	80.5	70




## (iii) Installation

For the suspension bolt, use four M10 or W 3/8 bolts and secure so that each bolt can withstand a 490N pullout load.

Use a suspension bolt length that extends approximately 95 mm from the ceiling surface.


### A. If there is a ceiling

- 1) Open the hole in the installation location to the ceiling opening dimensions.
- 2) Install the suspension bolts (procured locally) at the designated locations.  
(Use care as the center of the spacing for the suspension bolts is not at the center of the panel.)
- 3) Hang the unit, use the four bolts to mount the pattern paper provided to the panel mounting section and adjust the height.
- 4) Use a level or transparent hose with water in it to confirm that the unit is level. If the unit is not level, problems such as water leakage or improper operation of the float switch could occur.
- 5) After confirming the above, secure the unit in position.



### B. If ceiling is to be installed later


- 1) Follow steps A2) to A4) in the previous section "A. If there is a ceiling" to install the unit and mount the pattern paper.
- 2) When the ceiling is installed, the outer perimeter of the pattern paper can be referred to for making the opening in the ceiling.
- 3) After checking the height and that the unit is level, secure the unit in position.




### (iv) Drain piping

- 1) Drain piping should always be in a downhill grade (1/50-1/100) and avoid riding across an elevation or making traps.


#### • Good piping



#### • Improper piping



- 
- Diagram illustrating the connection of a drain hose to a drain socket. The diagram shows a cross-section of the drain socket and the drain hose. The drain socket is labeled "Drain socket" and the drain hose is labeled "Drain hose". The connection point is labeled "Size different part".




- 
- Secure the elevation as high as possible (approx. 100 mm)
- A downhill grade of 1/100 or more
- VP30
- The diagram illustrates a cable connection setup for a downhill grade. It shows a cable (VP30) being connected to a device. The cable is secured at the top of the connection point, with a note indicating it should be secured as high as possible (approximately 100 mm). The cable then runs horizontally to the right, where it is connected to another device. A note indicates that a downhill grade of 1/100 or more is required for this setup. The cable is labeled VP30.

- 
- Diagram illustrating the correct installation of a drain hose for the VP-25 unit. The diagram shows the unit mounted on a wall, with the drain hose connected to a drain pipe. The distance from the wall to the drain pipe is indicated as 295~325 mm. The distance from the drain pipe to the unit is indicated as 100 mm or less. The height from the floor to the drain pipe is indicated as 750 mm or less. The label "Drain hose (accessory)" points to the hose, and the label "Joints for VP-25 (field procurement)" points to the connection points.

- 1) Remove the heat insulating material and rubber plug of the natural drain port.
- 2) By using the natural drain connecting tube (option), connect the drain pipe (VP-20) and completely clamp it with a clamp.  
Note (1) If the drain pipe is directly connected to the natural drain port, the drain pan becomes unremovable.
- 3) Disconnect the connector CNR (blue, 2P) for the drain motor.




Note (1) If the connector remains connected, drain water is discharged from the standard pipe connecting port, leading to water leakage.



### Drainage test

When using the standard drain port, execute a drainage test after completion of electric work.

- ① During the test run, make sure that drain flows properly through the piping and that no water leaks from connections.
- ② Be sure to conduct this test even when the unit is installed in the heating season.
- ③ In case of a new building, conduct the test before it is furnished with the ceiling.



- 1) Inject about 1,000cc by using a feed water pump from the grommet on the drain pump side.
- 2) At the drain port (transparent portion), check if drainage is performed.
- 3) After completion of the drain test, completely perform heat insulation for the drain pipe up to the indoor unit.

### Forced drain pump operation

◆ Setup from a unit side.

- ① Turn on DIP switch SW5-1 on the PCB of the indoor unit. The drain pump operates continuously.
- ② After the test, be sure to turn off the DIP switch.

( When electrical work is not completed, connect a convex joint to the drain pipe joint area, arrange an inlet )  
and check for leaks and drain conditions of the pipe.

◆ Setup from a remote controller side.

Drain pump operation from a remote controller unit is possible. Operate a remote controller unit by following the steps described below.

1. To start a forced drain pump operation

- ① Press the TEST button for three seconds or longer.

The display will change from “◆ SELECT ITEM” → “○ SET” → “※ TEST RUN ▼”

- ② Press the [ ] button once while “※ TEST RUN ▼” is displayed, and cause “DRAIN PUMP ◆” to be displayed.

- ③ When the SET button is pressed, a drain pump operation will start.

Display: “DRAIN PUMP RUN” → “○ SET → STOP”

2. To cancel a drain pump operation.

- ① If either SET or ON/OFF button is pressed, a forced drain pump operation will stop.

The air conditioning system will become OFF.

**(d) Ceiling recessed single air supply port type (FDTQ)**


**(i) Avoid the following locations for installation and uses**

- 1) Locations where oil splashes and moisture are abundant (e.g., kitchens, mechanical workshops).

These locations may result in corrosion and lower performance of the heat exchanger and cause damage to plastic parts.

- 2) Locations with corrosive gases (such as sulfurous acid gas), flammable gases (such as thinners, gasoline) and areas where there are possibilities of gas accumulation. These locations can result in corrosion of the heat exchanger and damage plastic parts. Also, the flammable gas could cause a fire.
- 3) Locations near medical equipment radiating electromagnetic waves in hospitals or other facilities, and around appliances emitting high frequencies. The electromagnetic noise may cause the controller to malfunction.
- 4) Locations exposed to sea breezes (seaside areas). Sea breezes may cause corrosion of the outer frame and the heat exchanger.

**(ii) Installation space for the indoor unit**



Note (1) ※1 shows the case of direct blow.

- 1) With the customer's consent, select a suitable location according to the following conditions.

- Where cool air or hot air can easily pass through.

If the height of the location exceeds 3 m, hot air will gather below the ceiling. Suggest to the customer to also install a circulation fan.

- Where wiring and plumbing to outdoor areas may easily be conducted.
- Where water can be completely drained. A sloping location for drainage.
- Where there is no wind disturbance to the air return and air supply, the fire alarm will not be set off erroneously, and no air short circuits occur.
- Where there is no direct sunlight.
- If the humidity above the ceiling exceeds 80% or the condensation temperature above the ceiling exceeds 28°C, affix polyurethane foam (with a thickness to 10 or greater) above the insulation in the ceiling panels.

( Carry out tests of the main unit under the above conditions and confirm that there is no failure. However, if the environment where the unit is installed exceeds the above conditions and the unit is operated in high humidity conditions, there is danger of condensate dripping down. If there is a possibility that the unit will be used under such conditions, dress 10 to 20 mm of insulation material on the main unit, piping and drain pipes. )


- 2) Consider the supporting strength of the location. If the strength is not sufficient to sustain the unit weight, use reinforcing materials.

### (iii) Suspending the unit


Use four (4) M10 or W3/8 suspension bolts. Secure them firmly so that each can withstand a pull-out load of 490N.

Adjust their length to approximately 40 mm from the ceiling.

#### ● For TQ-PSA-14W-ER panel



#### ● For TQ-PSB-14W-ER panel



#### 1) When hanging from the ceiling

a) The panel has two types: for 2 × 2 grid ceiling and for conventional ceiling.

- ① When installing on a 2 × 2 grid ceiling, put in the unit on an angle, or hang the unit with the T bar temporarily removed.

When installing on a conventional ceiling, cut an installation opening (740 mm × 600 mm) in the ceiling, and hang the unit.

b) Set the suspension bolts (to be prepared at job site) in place.


c) Adjust the unit's height so that the bottom surface of the unit is on the same level as the ceiling (bottom surface of the T bar). (The blow outlet is contained in the ceiling.)

The allowable difference in height between the bottom surface of the ceiling and that of the indoor unit is when the indoor unit face is no higher than 5 mm.


#### Caution

Do not install the indoor unit lower than the bottom surface of the ceiling.


#### ● For TQ-PSA-14W-ER panel



#### ● For TQ-PSB-14W-ER panel



- d) Level the unit using a hose filled with water. If the unit is out of level, water leaks or malfunctioning of the floating switch may occur.



- e) After ensuring the above, secure the unit.


2) When embedded into ceiling

- Install the unit following steps b) and c) of the above part 1).
- When installing on a conventional ceiling, cut an installation opening (740 mm × 600 mm) in the ceiling.
- Check the installation height and level, and after that, secure the unit.


**(iv) Drain piping**

- 1) Drain piping should always be in a downhill grade (1/50-1/100) and avoid riding across an elevation or making traps.

● **Good piping**




● **Improper piping**




- 2) When connecting the drain pipe to the unit, pay sufficient attention not to apply excess force to the piping on the unit side. Also, fix the piping at a point as close as possible to the unit.


- 3) For drain pipe, use hard PVC general purpose pipe VP-25 (I.D.1") which can be purchased locally. When connecting, insert a PVC pipe end securely into the drain socket before tightening securely using the attached drain hose and clamp. Adhesive must not be used connection of the drain socket and drain hose (accessory).



- 4) When constructing drain piping for several units, position the common pipe about 100mm below the drain outlet of each unit as shown in the sketch below. Use VP-30 or thicker pipe for this purpose.





- 5) Be sure to provide heat insulation to hard PVC pipes of indoor placement.
- 6) Do not ever provide an air vent.
- 7) The height of the drain head may be elevated up to a point 600mm above the ceiling and, when an obstacle exists in the ceiling space, elevate the piping to avoid the obstacle using an elbow or corresponding gadget. When doing this, if the stretch for the needed height is too high, the back-flow quantity of drain at the time of interruption of the operation gets too much and it may cause overflow at the drain pan. Therefore, make the height of the drain pipe within the distance given in the drawing below.



- 8) Avoid positioning the drain piping outlet at a place where generation of odor may be stimulated. Do not lead the drain piping direct into a sewer from where sulfur gas may generate.

**(v) Drain test (Perform the drain test after the electrical wiring work has been finished.)**

- Check that water is draining thoroughly during the test run, and that there are no water leaks from the joints.
- The test has to be performed even if the unit is installed in a season when the unit is used for heating.
- In a new house, perform the test before the ceiling is fitted.



- 1) Remove the grommet, and using a water pump, pour about 1000cc of water, from the position shown in the left figure.

**Caution**

When pouring water, be sure to perform the drain pump forced operation.

- 2) Check the drain-out section (transparent section) for normal flow of drainage.
- 3) Take off the drain plug to release the water. After water release has been confirmed, replace the drain plug as it was.
  - \* Be careful not to get splashed when pulling the drain plug.
- 4) After the drain test, thoroughly insulate the drain pipe, up to the main unit.

**Forced drain pump operation**

◆ Setup from a unit side.

- Turn on DIP switch SW5-1 on the PCB of the indoor unit. The drain pump will operate continuously.
- After the drain test, be sure to turn off the DIP switch.

( When electrical work is not completed, connect a convex joint to the drain pipe joint area, arrange an inlet )  
( and check for leaks and drain conditions of the pipe. )

◆ Setup from a remote controller side.

Drain pump operation from a remote controller unit is possible. Operate a remote controller unit by following the steps described below.

1. To start a forced drain pump operation

- ① Press the TEST button for three seconds or longer.

The display will change from “◆ SELECT ITEM” → “○ SET” → “※ TEST RUN ▼”

- ② Press the ▼ button once while “※ TEST RUN ▼” is displayed, and cause “DRAIN PUMP ◆” to be displayed.

- ③ When the SET button is pressed, a drain pump operation will start.

Display: “DRAIN PUMP RUN” → “○ SET → STOP”

2. To cancel a drain pump operation.

- ① If either SET or ON/OFF button is pressed, a forced drain pump operation will stop.

The air conditioning system will become OFF.

**(vi) Panel installation (Panel installing bolts are attached to the panel.)**

- ① Check that the indoor unit's height and opening dimensions in the ceiling are correct.

- ② Check that level is ensured.

- ③ Open the air return grill.

- ④ Screw in two of the four suspension bolts attached to the panel, on the piping side and at its opposite angle, by a little less than 5 mm (● marks).

- ⑤ Hook the panel into two of the suspension bolts to pre-install it.

With pre-installation is performed, first hook the panel to bolt A, then to bolt B while rotating the panel.

(Take care so that the unit does not rotate during pre-installation.)


- ⑥ Tighten the pre-installed suspension bolts and two remaining suspension bolts.

- ⑦ Attach the louver motor connector (white, 4P) and the limit switch connector (white, 2P).

- ⑧ Use the provided screws to tighten chains to the panel. Chain installing screws is contained in the same bag as suspension bolts.

- ⑨ Close the air return grill. Now installation is complete.

- ⑩ When the louver motor does not operate with the remote control, check connections of the connectors, turn off the power for more than 10 seconds and reset.




## (vii) Indoor unit repair procedure for duct connection


### 1) Drill hole for duct

- While referring to the following dimensions, notch the insulation. (The insulation is equipped with the marks in advance.)
- Cut joints for the hole, and drill hole.
- Connect the duct joint using screws attached to the panel.

Unit : mm



- Connect the bottom plate using screws attached to the panel.



### e) Blower fan tap switch

The following two methods are available in switching the blower fan tap. Switch to the high-speed tap with one of these methods.

SW9-4	ON	Fan control,high speed (High ceiling)
	OFF	Fan control,standard

- Set SW9-4 provided on the indoor unit PCB to ON.
- By means of function setting from the remote control unit, set the setting ③ of “I/U FUNCTION ▲” (indoor unit function) to “Hi CEILING 1” (high-speed tap) as shown right.

Function number ①	Function description ②	Setting ③
01	Hi CEILING SET	Hi CEILING 1

For the details of operating procedures, please refer to the installation manual of your remote control unit.

### f) LOUVER switch disabled setting

By means of function setting from the remote control unit, set the setting ③ of “FUNCTION ▲” (remote control unit function) to “INVALID” (LOUVER switch disabled) as shown right.

Function number ①	Function description ②	Setting ③
07	LOUVER S/W	INVALID

For the details of operating procedures, please refer to the installation manual of your remote control unit.


## 2) Duct work

- a) Calculate air flow volume and the outside static pressure to select the duct's length and shape, and air supply outlet.


Caution

Take care that the outside static pressure does not exceed 30 Pa.


The unit has condensation owing to the decrease in air capacity, possibly causing the ceiling and household goods to become wet.



- b) Reduce the number of bends as much as possible. (Corner R should be as large as possible.)



- c) Connecting the air return duct



- d) Outside air intake

- Use the intake, which is easier for work, either at the rear or the side.

- e) Duct connection

- Connect the 125 mm diameter round duct, using the air return/supply duct flange separately sold (for connecting the 125 mm diameter round duct). (Band clamp)
- Keep the duct warm to protect from condensation.

- f) Checking of indoor unit installation level

- ① There are two kinds of panel, which are TQ-PSA-14W-ER panel and TQ-PSB-14W-ER panel. When installing to the existing ceiling, check that opening dimensions in the ceiling are correct.


Check the installation level of the air-conditioner indoor unit and the ceiling members.

- ② Adjust the air-conditioner indoor unit height so that the under surface of the indoor unit and the under surface of the ceiling agree with each other. (The air supply port shall be housed in the ceiling.)
- ③ The allowable height difference between the under surface of the ceiling and the under surface of the indoor unit is less than 5 mm upward shift of the indoor unit.


Do not install the indoor unit lower than the bottom surface of the ceiling.



● For TQ-PSA-14W-ER panel





● For TQ-PSB-14W-ER panel



g) Panel installation



- ① Insert a flat head screw driver, etc. into the slot on the air supply port cover of the panel to remove the cover from the panel.
- ② Open air return grill.
- ③ Screw in two of the four suspension bolts attached to the panel, on the piping side and at its opposite angle, by a little less than 5 mm (● marks).
- ④ Hook the panel into two of the suspension bolts to pre-install it.  
With pre-installation is performed, first hook the panel on the bolt A Then to the bolt B .While rotating the panel.  
(Take care so that the unit does not rotate during pre-installation.)
- ⑤ Tighten the pre-installed suspension bolts and tow remaining suspension bolts.
- ⑥ Use the provided screws to tighten chains to the panel. Chain installing screws is contained in the same bag as suspension bolts.
- ⑦ Close the air return grill. (Check whether the chain is installed securely.)
- ⑧ Push the air supply cover into place from the bottom of the panel, and fit it as it was.  
Check that the air supply cover is securely fitted and does not fall.



### (e) 1-way outlet ceiling recessed type (FDTS)

#### Preparation of indoor unit

It can be installed by either one of the following methods. Select the most adequate method for your particular case.


	Ⓐ Standard installation	Ⓑ Higher ceiling
Installation example and limitation		

Note (1) In the case of installing on the high ceiling, part of indoor unit requires some modification.

#### Procedures of rework

##### Installation on higher ceiling

Adhere the insulation materials attached to the direct blow panel on the blow outlet of indoor unit.



#### (i) Selection of installation location

- 1) Where cool and hot air will be distributed sufficiently.

Where the installation height exceeds 3m, warmed air is likely to concentrate close to the ceiling. In such case, you should install also a circulator.

#### Reference

##### • Cold air throw

Unit : m

Item	Reaching distance	
	Standard	Higher ceiling
All models	7	

#### [ Conditions ] 1. Unit height

Standard ceiling: 2.4~3.0(m) above floor      Higher ceiling: 3.0~4.0(m) above floor

2. Kind of operation: Hi

3. Place: Free space without obstruction;

4. Reaching distance means the horizontal distance for the wind to reach the floor.

5. Wind velocity at the reaching distance: 0.5m/s

Note (1) Wind capacity is UHi in case of a higher ceiling. It is value of Hi for other cases.


- 2) Where the ceiling has sufficient rigidity.

- 3) Where there is no obstacles in front of the suction inlet and blow outlet.

- 4) It should be avoided such places as kitchen, machine factory, etc. where there profuse liquid splashes or thick steam.

- 5) Where the height of ceiling exceeds 200mm.

- 6) Where a space as shown below can be secured.



- 7) It should be avoided where a machine generating high frequency waves is installed.  
 8) Select a place to branch the piping so that same distance will be obtained for each of one way piping.  
 9) If the humidity above the ceiling exceeds 80% or the condensation temperature above the ceiling exceeds 28°C, affix polyurethane foam (with a thickness to 10 or greater) above the insulation in the ceiling panels.


Carry out tests of the main unit under the above conditions and confirm that there is no failure. However, if the environment where the unit is installed exceeds the above conditions and the unit is operated in high humidity conditions, there is danger of condensate dripping down. If there is a possibility that the unit will be used under such conditions, dress 10 to 20 mm of insulation material to the main unit, piping and drain pipes.

- 10) Where it is convenient for the piping and wiring to the outdoor.  
 11) Where protected from direct exposure to sun beams.  
 12) Where it is free from volatile gas generation.

## (ii) Standard location

### 1) Installation

#### a) Ceiling hole size and position of suspension bolt




Unit : mm


Models \ Mark	①	②	③	④
FDTS22, 28, 36, 45	990	1230	1290	180
FDTS71	1250	1440	1500	145

#### b) Length of fixed suspension bolt (customer order parts M10)


[Reference] Suspension bolt pitch is adjustable within  $\pm 10$ mm in sidewise direction. Since there is no adjustment allowance in back and forth direction, determine the position exactly with a measure. (Lap margin between ceiling and panel is 30mm.)



**c) Fixing of Suspension bolt.** Fix the bolts securely as shown below or by any other adequate means.




**d) Installation**



### Procedures


- ① Install nuts on the Suspension bolts at outside. Suspension the suspension fixtures on the Suspension bolts first and then insert the remaining fixtures on the remaining Suspension bolts at and lock them with nuts.
- ② Since the indoor unit and the panel height cannot be adjusted, adjust the height using an attached pattern before fixing the indoor unit.



## Check of levelness

Check the levelness as follows. Use a level gauge or adjust the levelness with the following method.


- Adjust the bottom of indoor unit and the water level as shown below.




## 2) Drain pipe

- a) Set the drain pipe as a declining gradient ( $1/50 \sim 1/100$ ) and avoid to cross an over-hand ridge or to allow a trap on the way.



### • Good piping




### • Improper piping



- b) When connecting the drain pipe to the unit, pay sufficient attention not to apply excess force to the piping on the unit side. Also, fix the piping at a point as close as possible to the unit.
- c) For drain pipe, use hard PVC general purpose pipe VP-25 (I.D.1") which can be purchased locally. When connecting, insert a PVC pipe end securely into the drain socket before tightening securely using the attached drain hose and clamp. Adhesive must not be used connection of the drain socket and drain hose (accessory).




- d) When there are plural number of drain pipes, arrange to position the converging pipe at about 100mm below the drain outlet as shown below. Use a pipe of VP-30 or higher for the converging pipe.



- e) Make sure to provide the thermal insulation for the hard vinyl chloride pipe and drain socket provided indoor.

f) Air bleed should not be provided in any event.



- When it is necessary to raise the drain head, the limitation is up to 600mm below the bottom face of ceiling where the unit is installed. The distance is the dimension of the pipe which is installed perpendicularly from a point close to the output for drain pipe connection.



### Drain test


[Perform this before installing the ornament panel]

- Perform this upon completion of electrical work.
- Gradually introduce 2,000~3,000cc of water as shown below.



( If the electrical work has not been completed, connect a convex joint in the drain pipe connection to provide a water inlet. Then, check if water leaks from the piping system and that drain flows through the drain pipe normally. )

- Connect the remote control switch and set to cooling operation. The drain pump will operate with the compressor on.
- Test whether or not the water is draining while listening to the operating sounds of the electric motor for the drain water.



Check the drainage condition by using the transparent socket.

Drain hose (provided)

- Check that water is draining smoothly and that there is no water dripping from the connections or other areas.

### Forced drain pump operation

◆ Setup from a unit side.

- ① Turn on DIP switch SW5-1 on the PCB of the indoor unit. The drain pump operates continuously.
- ② After the test, be sure to turn off the DIP switch.

( When electrical work is not completed, connect a convex joint to the drain pipe joint area, arrange an inlet and check leaks and drain conditions of the pipe. )

◆ Setup from a remote controller side.

Drain pump operation from a remote controller unit is possible. Operate a remote controller unit by following the steps described below.

1. To start a forced drain pump operation

- ① Press the TEST button for three seconds or longer.

The display will change from “ SELECT ITEM” → “ SET” → “ TEST RUN ▼”


- ② Press the button once while “ TEST RUN ▼” is displayed, and cause “DRAIN PUMP ◆” to be displayed.

- ③ When the SET button is pressed, a drain pump operation will start.

Display: “DRAIN PUMP RUN” → “ → STOP”

2. To cancel a drain pump operation.

- ① If either SET or ON/OFF button is pressed, a forced drain pump operation will stop. The air conditioning system will become OFF.




Air block panel


### Mounting the Panel

- ① Open the air return grille and remove the air block panel from the inside. (Remove the 2 screws.)


- ② Mount the two (M5 x 35) panel mounting screws to the indoor unit



- ③ Hang the panel on the two mounting screws on the indoor unit by using the two shaped holes. Slide the panel approximately 10 mm. Use the 5 panel mounting screws to secure the panel.



- ④ Use the opening to connect the connectors for the louver motor and limit switches.



- ⑤ Reinstall the wind shield plate.

### (iii) Installation on higher ceiling

Adhere the insulation materials on the blow outlet of the indoor unit. All others are same as the standard installation.

**(f) Medium static pressure ducted type (FDQM)**

**(i) Selection of installation location**

1) Avoid installation and use at those places listed below.

a) Places exposed to oil splashes or steam (e.g. kitchens and machine plants).

Installation and use at such places will incur deteriorations in the performance or corrosion with the heat exchanger or damage in molded synthetic resin parts.

b) Places where corrosive gas (such as sulfurous acid gas) or inflammable gas (thinner, gasoline, etc.) is generated or remains. Installation and use at such places will cause corrosion in the heat exchanger and damage in molded synthetic resin parts.

c) Places adjacent to equipment generating electromagnetic waves or high-frequency waves such as in hospitals. Generated noise may cause malfunctioning of the controller.

2) Select places for installation satisfying the following conditions and, at the same time, obtain the consent on the part of your client user,.

a) Places where chilled or heated air circulates freely. When the installation height exceeds 3m, warmed air stays close to the ceiling. In such cases, suggest your client users to install air circulators.

b) Places where perfect drainage can be prepared and sufficient drainage gradient is available.


c) Places free from air disturbances to the return air port and supply hole of the indoor unit, places where the fire alarm may not malfunction to short circuit.

d) If the humidity above the ceiling exceeds 80% or the condensation temperature above the ceiling exceeds 28°C, affix polyurethane foam (with a thickness to 10 or greater) above the insulation in the ceiling panels.

Carry out tests of the main unit under the above conditions and confirm that there is no failure. However, if the environment where the unit is installed exceeds the above conditions and the unit is operated in high humidity conditions, there is danger of condensate dripping down. If there is a possibility that the unit will be used under such conditions, dress 10 to 20 mm of insulation material to the main unit, piping and drain pipes.

3) Check if the selected place for installation is rigid enough to stand the weight of the unit.


Otherwise, apply reinforcement using boards and beams before starting the installation work.






## (ii) Suspension the Unit

Use four (4) M10 or W3/8 suspension bolts. Secure them firmly so that each can withstand a pull-out load of 490N.




1) Adjust suspension bolts length to the following dimension.




2) Set the suspension bolts (to be prepared at job site) in place.

3) Level the unit using a level or a hose filled with water. If the unit is out of level, water leaks or malfunctioning of the floating switch may occur.



4) After ensuring the above, secure the unit.

## (iii) Duct installation




- 1) Calculate air flow volume and the outside static pressure to select the duct's length and shape, and air supply port.

**Caution**

Take care that the outside static pressure does not exceed 30 Pa. The unit has condensation owing to the decrease in air capacity, possibly causing the ceiling and household goods to become wet.

- 2) The indoor unit is not provided with an air filter. Assemble it into the air return grill for which cleaning is easy.
- 3) Make the duct the shortest in length.




- 4) Make the bend radius large
- 5) When connecting the indoor unit to the duct flange of the blow outlet, attach the insulation material to the fixed portion to protect it from condensation.
- 6) Conduct the duct work before ceiling attachment.
- 7) Make sure to keep the air return duct warm to protect it from condensation.
- 8) Install the air supply hole where air can flow all over the room.
- 9) Make sure to install the inspection opening in the ceiling. It is needed for the maintenance of electrical parts, the motor and other parts.


**(iv) Drain piping**

- 1) Drain piping should always be in a downhill grade (1/50-1/100) and avoid riding across an elevation or making traps.

• **Good piping**




• **Improper piping**




- 2) When connecting the drain pipe to the unit, pay sufficient attention not to apply excess force to the piping on the unit side. Also, fix the piping at a point as close as possible to the unit.


- 3) For drain pipe, use hard PVC general purpose pipe VP-25 which can be purchased locally. When connecting, insert a PVC pipe end securely into the drain socket before tightening securely using the attached drain hose and clamp. Adhesive must not be used connection of the drain socket and drain hose (accessory).



- 4) When constructing drain piping for several units, position the common pipe about 100 mm below the drain outlet of each unit as shown in the sketch below. Use VP-30 or thicker pipe for this purpose.



- 5) Be sure to provide heat insulation to hard PVC pipes of indoor placement.
- 6) Do not ever provide an air vent.
- 7) The height of the drain head may be elevated up to a point 600 mm from the bottom of unit and, when an obstacle exists in the ceiling space, elevate the piping to avoid the obstacle using an elbow or corresponding gadget. When doing this, if the stretch for the needed height is too high, the back-flow quantity of drain at the time of interruption of the operation gets too much and it may cause overflow at the drain pan. Therefore, make the height of the drain pipe within the distance given in the drawing below.



- 8) Avoid positioning the drain piping outlet at a place where generation of odor may be stimulated. Do not lead the drain piping direct into a sewer from where sulfur gas may generate.

**(v) Drain test (Perform the drain test after the electrical wiring work has been finished.)**

- Check that water is draining thoroughly during the test run, and that there are no water leaks from the joints.
- The test has to be performed even if the unit is installed in a season when the unit is used for heating.
- In a new house, perform the test before the ceiling is fitted.

**Forced drain pump operation**

- ◆ Setup from a unit side.

- ① Turn on DIP switch SW5-1 on the PCB of the indoor unit. The drain pump operates continuously.
- ② After the test, be sure to turn off the DIP switch.

( When electrical work is not completed, connect a convex joint to the drain pipe joint area, arrange an inlet )  
and check leaks and drain conditions of the pipe.

- ◆ Setup from a remote controller side.

Drain pump operation from a remote controller unit is possible. Operate a remote controller unit by following the steps described below.

1. To start a forced drain pump operation

- ① Press the TEST button for three seconds or longer.

The display will change from “◆ SELECT ITEM” → “○ SET” → “※ TEST RUN ▼”

- ② Press the ▼ button once while “※ TEST RUN ▼” is displayed, and cause [DRAIN PUMP ◆] to be displayed.



- ③ When the SET button is pressed, a drain pump operation will start.

Display: “DRAIN PUMP RUN” → “○ SET → STOP”

2. To cancel a drain pump operation.

- ① If either SET or ON/OFF button is pressed, a forced drain pump operation will stop.

The air conditioning system will become OFF.



- 1) Remove the piping through cover, and using a water pump, pour about 1000cc of water, from the position shown in the left figure.

Caution

When pouring water, be sure to perform the drain pump forced operation.

- 2) Check the drain-out section (transparent section) for normal flow of drainage.
- 3) Take off the drain plug to release the water. After water release has been confirmed, replace the drain plug as it was.


\* Be careful not to get splashed when pulling the drain plug.

- 4) After the drain test, thoroughly insulate the drain pipe, up to the indoor unit.

**(g) High static pressure duct type (FDU)**

**(i) Selection of installation location**

- 1) Install the unit at a place as shown below and which meets the conditions as shown by the following table.



**Air conditions, limitation of air volume**

	Air volume (m <sup>3</sup> /min)			Indoor unit return air temperature		Ambient temperature around indoor unit
	Rating	Lower limit	Upper limit	Cooling	Heating	
224model	51	38	65	Upper limit 26°CWB When outdoor temperature is 35°C	Upper limit 27°CDB Outdoor temperature is below 20°CWB	Dew point temperature below 23°C
280model	68	51	87	Lower limit 16.5°CWB When outdoor temperature is 15°C	Lower limit 10°CDB Outdoor temperature is above 10°CWB	
				For further details refer to the engineering data which		

- 2) Places where perfect drainage can be prepared and sufficient drainage gradient is available.
- 3) Places free from air disturbances to the air return and air supply of the indoor unit.
- 4) If the humidity above the ceiling exceeds 80% or the condensation temperature above the ceiling exceeds 28°C, affix polyurethane foam (with a thickness to 10 or greater) above the insulation in the ceiling panels.
 


Carry out tests of the main unit under the above conditions and confirm that there is no failure. However, if the environment where the unit is installed exceeds the above conditions and the unit is operated in high humidity conditions, there is danger of condensate dripping down. If there is a possibility that the unit will be used under such conditions, dress 10 to 20 mm of insulation material to the main unit, piping and drain pipes.
- 5) Do not place where the unit is exposed to oil splashes or steam (e.g. kitchens and machine plants).  
(Installation and use at such places will cause the performance drop, corrosion in the heat exchanger and damage in molded synthetic resin parts.)
- 6) Do not place where corrosive gas (such as sulfurous acid gas) or inflammable gas (thinner, gasoline, etc.) is generated or remains.  
Installation and use at such places will cause corrosion in the heat exchanger and damage in molded synthetic resin parts.
- 7) Do not place adjacent to equipment generating electromagnetic waves or high-frequency waves such as in hospitals, Generated noise may cause malfunctioning of the controller.

## (ii) Installation

### <Delivery>

- When delivering the package, move the package to the installation as close as possible.
- When it is unpacked and then moved to the installation place, sufficient care must be taken not to damage the unit during transfer.

### <Hanging bolt location>




- To adjust the level, use a level gauge or adjust as shown by the left figure.

Note: Unless the level is adjusted properly, the float switch may malfunction or operate improperly.

### <Packing hardware>


Four pieces of packing hardware are used.

Discard them after unpacking.




### <Securing of Hanging Bolt>

Secure the hanging bolts by either one of following methods.




### <Adjustment level>



Adjust the piping side a little lower than the opposite side.


## (iii) Duct work



- ① Air filter is not installed in the main unit of air conditioner. Air filter should be installed in the suction grill which allows an ample access for cleaning.
- ② Silencer chamber(s) may be necessary depending on the noise level allowed in the room where the air conditioner is installed. Additional silencer may be necessary where a particularly low noise is required. (Provision of silencer is a must at offices and a meeting room.)

- ③ In order not to transmit vibration from the main unit of air conditioner to the ceiling or slab, it is necessary to provide means to prevent vibration, for example, a canvas coupling on the duct or rubber cushion on the main unit of air conditioner.
- ④ A damper to control air volume should be installed on the joint of OA duct to facilitate control of air capacity after the installation.
- ⑤ Location and from of blow outlet should be selected so that air from the outlet will be distributed all over the room, and equipped with a device to control air volume.
- ⑥ Make sure to provide an inspection hole on the ceiling. It is indispensable to service electric equipment, motor, functional components and cleaning of heat exchanger.
- ⑦ Make sure to insulate the duct to prevent dewing on it. Thickness of insulating material is 65 mm minimum.

### Bad example of duct work



- ① If a duct is not provided at the suction side but it is substituted with the space over the ceiling, humidity in the space will increase by the influence of capacity of ventilation fan, strength of wind blowing against the outdoor air louver, weather (rainy day) and others.

- a) Moisture in air is likely to condense over the external plates of the unit and to drip on the ceiling.

Unit should be operated under the conditions as listed in the above table and within the limitation of air flow volume.


When the building is a concrete structure, especially immediately after the construction, humidity tends to rise even if the space over the ceiling is not substituted in place of a duct.

In such occasion, it is necessary to insulate the entire unit with glass wool (25 mm). (Use a wire net or equivalent to hold the glass wool in place.)

- b) It may run out the allowable limit of unit operation (Example: When outdoor air temperature is 35°CDB, return air temperature is 27°CWB) and it could result in such troubles as compressor overload, etc.
  - c) There is a possibility that the supply air volume may exceed the allowable range of operation due to the capacity of ventilation fan or strength of wind blowing against external air louver so that drainage from the heat exchanger may fail to reach the drain pan but leak outside (e.g. drip onto the ceiling) with consequential water leakage in the room.
- ② Unless vibration isolation is provided between the unit and duct and between the unit and the slab, vibration will be transmitted to the duct so that vibration noise may generate from between the ceiling and supply outlet or vibration may be transmitted to the slab. Make sure to provide an effective vibration prevention means.

### <Simplified method for determination of duct dimensions>

In the following method, it is assumed that the friction resistance per unit length of duct is 1 Pa/m (0.1 mm Aq/m) and a side of duct is 250 mm.  
Air volume rating is assumed to be FDUA280KXE4R.



○ Calculation of duct resistance  
(Use following simplified calculations.)

	Air volume	Duct (mm × mm)
Section A	4080m³/h (68m³/min)	250 × 830
Section B	1020m³/h (17m³/min)	250 × 270

Linear pipe section	Calculate based on 1 Pa per 1 m in length 1 Pa/m.
Curved pipe section	Take a curved section as equivalent to 3 ~4 m in straight line.
Blowout section	Calculate based on 25 Pa.
Chamber	Calculate by taking 1 pc. as 50Pa.
Suction grill (with filter)	Calculate by taking 1 pc. as 40Pa.


<Table of simplified selection of duct dimensions>

Air volume	Duct form	
	Item	Square duct
m³/h(m³/min)		Dimensions (mm × mm)
100		250 × 60
200		250 × 90
300		250 × 120
400		250 × 140
500		250 × 170
600(10)		250 × 190
800		250 × 230
1,000		250 × 270
1,200(20)		250 × 310
1,400		250 × 350
1,600		250 × 390
1,800(30)		250 × 430
2,000		250 × 470
2,400		250 × 560
3,000(50)		250 × 650
3,500		250 × 740
4,000		250 × 830
4,500		250 × 920
5,000		250 × 1000
5,500		250 × 1090
6,000(100)		250 × 1180


### (iv) Drain Piping

1) Drain piping should always be in a downhill grade (1/50~1/100) and avoid riding across an elevation or making traps.

#### • Good piping




#### • Improper piping




- 2) When connecting the drain pipe to unit, pay sufficient attention not to apply excess force to the piping on the unit side. Also, fix the piping at a point as close as possible to the unit.
- 3) For drain pipe, use hard PVC general purpose pipe VP-25(I.D.1") which can be purchased locally.

- 4) When constructing drain piping for several units, position the common pipe about 100 mm below the drain outlet of each unit as shown in the sketch. Use VP-30 (1 1/4") or thicker pipe this purpose.
- 5) Be sure to provide heat insulation to hard PVC pipes of indoor placement.
- 6) Do not ever provide an air vent.
- 7) Avoid positioning the drain piping outlet at a place where generation of odor may be stimulated. Do not lead the drain piping direct into a sewer from where sulfur gas may generate.



**If the duct is connected and then the blower is operated, inside air pressure will become negative compared with the atmospheric pressure.**




Example: If the pressure loss at the suction side, such as the air return grill, air filter and duct, is 100 Pa, the level of drain water will rise approx. 10 mm higher than the state of operation stop.

### <Provision of trap>

Since the drain outlet is disposed at a position that makes the pressure negative, it is necessary to provide a trap (during the piping work) in order to prevent water leakage due to rising of water level in the drain pan.

Trap must be so constructed to facilitate cleaning. It should be better to employ a "T" joint as shown below. In addition, the height of trap should be as specified below. The trap should be provided close to the unit.




- Provide a trap on way of the drain pipe as shown at left.
- H<sub>1</sub>=100 mm or static pressure of blower
- H<sub>2</sub>=1/2 H<sub>1</sub> or 50 ~ 100 mm

#### (v) Drain Test

When the drain piping work is over, inject water to inspect if the piping is arranged properly or not.

- Remove the side panel and supply gradually 1,000 cc of water to see if water is drained smoothly or not. Check also for water leakage.



#### (vi) Operating method of fan controller


- This unit allows to continuously adjust the air volume with the fan controller switch which is built in the electric equipment box.

It is not necessary to control the air volume (outside unit static pressure adjustment) with the damper, etc. at the duct side. Select the point of operation so that it will be within the range of air volume withch can be operated. (Refer to the limitation of air capacity as shown below.)

Location of the fan controller in the electric equipment box and the operating method are shown below.

- Refer in advance to the blower characteristics quoted in the separate engineering data, and select the number on the scale of fan controller switch.

Referring to the figure below, adjust the number on the scale of fan controller switch at the number selected during the test run after completion of electrical work and check if the intended air volume is obtained or not.



#### Operation of fan controller

Note(1) Make sure to turn power off before operating the fan controller because there is risk of contacting charged sections.

#### (h) Satellite ducted type (FDUM)

##### (i) Selection of installation location

- 1) Avoid installation and use at those places listed below.

- a) Places exposed to oil splashes or steam (e.g. kitchens and machine plants).

Installation and use at such places will incur deteriorations in the performance or corrosion with the heat exchanger or damage in molded synthetic resin parts.

- b) Places where corrosive gas (such as sulfurous acid gas) or inflammable gas (thinner, gasoline, etc.) is generated or remains. Installation and use at such places will cause corrosion in the heat exchanger and damage in molded synthetic resin parts.

- c) Places adjacent to equipment generating electromagnetic waves or high-frequency waves such as in hospitals. Generated noise may cause malfunctioning of the controller.




2) Select places for installation satisfying the following conditions and, at the same time, obtain the consent on the part of your client user,.

- Places where cooled or heated air circulates freely. When the installation height exceeds 3m, warmed air stays close to the ceiling. In such cases, suggest your client users to install air circulators.
- Places where perfect drainage can be prepared and sufficient drainage gradient is available.
- Places free from air disturbances to the return air port and supply hole of the indoor unit, places where the fire alarm may not malfunction to short circuit.
- If the humidity above the ceiling exceeds 80% or the condensation temperature above the ceiling exceeds 28°C, affix polyurethane foam (with a thickness to 10 or greater) above the insulation in the ceiling panels.

Carry out tests of the main unit under the above conditions and confirm that there is no failure. However, if the environment where the unit is installed exceeds the above conditions and the unit is operated in high humidity conditions, there is danger of condensate dripping down. If there is a possibility that the unit will be used under such conditions, dress 10 to 20 mm of insulation material to the main unit, piping and drain pipes.

3) Check if the selected place for installation is rigid enough to stand the weight of the unit.

Otherwise, apply reinforcement using boards and beams before starting the installation work.




Unit : mm

Models \ Mark	A	B
FDUM36, 45, 56	1100	630
FDUM71, 90	1300	830
FDUM112, 140	1720	1250

## (ii) Suspension

Be sure to observe the finished length of the suspension bolts given below.


Unit : mm



Models \ Mark	A
FDUM36, 45, 56	786
FDUM71, 90	986
FDUM112, 140	1406

## 1) Fixing the suspension bolt (customer ordered parts M10)


Securely fix the suspension bolt as illustrated below or in another way.



## 2) Adjusting the unit's levelness

a) Adjust the out-levelness using a level vial or by the following method.

- Make adjustment so that the relation between the lower surface of the indoor unit proper and water level in the hose becomes given below.



b) Unless the levelness is adjusted properly, the malfunction of the float switch will occur.

## 3) Blower fan tap switch

The following two methods are available in switching the blower fan tap. Switch to the high-speed tap with one of these methods.


SW9-4	ON	Fan control,high speed (High ceiling)
	OFF	Fan control,standard

- ① Set SW9-4 provided on the indoor unit PCB to ON.
- ② By means of function setting from the remote control unit, set the setting ③ of "I/U FUNCTION ▲" (indoor unit function) to "Hi CEILING 1" (high-speed tap) as shown right.

Function number ①	Function description ②	Setting ③
01	Hi CEILING SET	Hi CEILING 1

For the details of operating procedures, please refer to the installation manual of your remote control unit.

## (iii) Duct installation



### ① Supply air duct


- 2-spot, 3-spot and 4-spot with  $\varnothing 200$  type duct are the standard specifications. Determine the number of spots based on following table.

FDUMA36, 45, 56	FDUMA71, 90	FDUMA112, 140
2-spot	2 ~ 3-spot <sup>(1)</sup>	3 ~ 4-spot <sup>(2)</sup>

Notes (1) Shield the central supply air port for 2-spot.

(2) Shield the supply air port around the center for 3-spot.

- Limit the difference in length between spots at less than 2:1.
- Reduce the length of duct as much as possible.
- Reduce the number of bends as much as possible. (Corner R should be as larger as possible.)



- Use a band, etc. to connect the indoor unit and the supply air duct flange.
- Conduct the duct installation work before finishing the ceiling.

## ② Access door

Access door must be provided without fail.

### ● Dimensions of access door and service space

( See exterior dimensions in page 89 to 91.)


## ③ Return air port

An air filter is not included in the indoor unit. Use the return air port with air filter.

## ④ Return air duct: Use square duct.

## ⑤ Return air port with canvas duct

### 1) Connection of outside air intake and exhaust ducts.



### 2) Duct connecting position.

#### < Outside air intake >

- Use side air intake port.
- In case of simultaneous outside air intake and exhaust, the side air intake port cannot be used, therefore, take air from the midway air intake port along the intake duct.

#### < Exhaust > Make sure to use air return as well.

- Use a side exhaust port.


### 3) Duct connection

Use outside air intake and exhaust duct flange of separately sold (for connection of  $\varnothing 125\text{mm}$  round duct) to connect  $\varnothing 125\text{mm}$  round duct. The duct clamped by bands must be thermally insulated to prevent dew condensation.


#### (iv) Drain piping

- 1) Drain piping should always be in a downhill grade (1/50-1/100) and avoid riding across an elevation or making traps.

##### • Good piping




##### • Improper piping




- 2) When connecting the drain pipe to the unit, pay sufficient attention not to apply excess force to the piping on the unit side. Also, fix the piping at a point as close as possible to the unit.


- 3) For drain pipe, use hard PVC general purpose pipe VP-25 which can be purchased locally. When connecting, insert a PVC pipe end securely into the drain socket before tightening securely using the attached drain hose and clamp. Adhesive must not be used connection of the drain socket and drain hose (accessory).



- 4) When constructing drain piping for several units, position the common pipe about 100 mm below the drain outlet of each unit as shown in the sketch below. Use VP-30 or thicker pipe for this purpose.




- 5) Be sure to provide heat insulation to hard PVC pipes of indoor placement.
- 6) Do not ever provide an air vent.
- 7) The height of the drain head may be elevated up to a point 600 mm from the bottom of unit and, when an obstacle exists in the ceiling space, elevate the piping to avoid the obstacle using an elbow or corresponding gadget. When doing this, if the stretch for the needed height is too high, the back-flow quantity of drain at the time of interruption of the operation gets too much and it may cause overflow at the drain pan. Therefore, make the height of the drain pipe withing the distance given in the drawing below.



- 8) Avoid positioning the drain piping outlet at a place where generation of odor may stimulated. Do not lead the drain piping direct into a sewer from where sulfur gas may generate.

## 9) Drainage test

- During trial operation, make sure that drainage is properly executed and check that leakage is not found at connections.
- Be sure to carry out a drainage test when installing the system during a heating season.
- When installing the system in a building under construction, carry out the drainage test before ceiling tiles are installed.



- Supply approx 1000cc of water through the outlet of the unit using a feed water pump.
- Make sure that drainage is proceeding properly at the see-through outlet of the unit.  
\* Also confirm the revolving sound of the condensate motor when checking the drainage.
- Then remove the drain plug at lower section of the unit to drain water off. After making sure water is not left, restore the drain plug to the original position.

### Forced drain pump operation

#### ◆ Setup from a unit side.

- Turn on DIP switch SW5-1 on the PCB of the indoor unit. The drain pump operates continuously.
- After the test, be sure to turn off the DIP switch.

(When electrical work is not completed, connect a convex joint to the drain pipe joint area, arrange an inlet and check leaks and drain conditions of the pipe.)

#### ◆ Setup from a remote controller side.

Drain pump operation from a remote controller unit is possible. Operate a remote controller unit by following the steps described below.

##### 1. To start a forced drain pump operation

- Press the TEST button for three seconds or longer.

The display will change from “ SELECT ITEM” → “ SET” → “ TEST RUN ▼”

- Press the button once while “ TEST RUN ▼” is displayed, and cause “DRAIN PUMP ◆” to be displayed.
- When the SET button is pressed, a drain pump operation will start.

Display: “DRAIN PUMP RUN” → “ → STOP”

##### 2. To cancel a drain pump operation.

- If either SET or ON/OFF button is pressed, a forced drain pump operation will stop.

The air conditioning system will become OFF.



## 10) Drainage from the lower drain socket

Only if the drain pipe can be installed in a downhill grade (1/50-1/100), the lower drain socket can be used for connecting to the drain pipe as illustrated.

(Disconnect the connector for the drain motor)

As shown in the sketch to the right, disconnect the drain motor connector CnR (blue color coding).

If the system is started with this connector connected as is, drain water is discharged out of the upper drain socket causing a heavy water leakage.




**(i) Ceiling mounted duct type (FDUR)**

**(i) Selection of installation location**

- 1) Avoid installation and use at those places listed below.
  - a) Places exposed to oil splashes or steam (e.g. kitchens and machine plants).  
Installation and use at such places will incur deteriorations in the performance or corrosion with the heat exchanger or damage in molded synthetic resin parts.
  - b) Places where corrosive gas (such as sulfurous acid gas) or inflammable gas (thinner, gasoline, etc.) is generated or remains. Installation and use at such places will cause corrosion in the heat exchanger and damage in molded synthetic resin parts.
  - c) Places adjacent to equipment generating electromagnetic waves or high-frequency waves such as in hospitals. Generated noise may cause malfunctioning of the controller.
  
- 2) Select places for installation satisfying the following conditions and, at the same time, obtain the consent on the part of your client user,
  - a) Places where chilled or heated air circulates freely. When the installation height exceeds 3m, warmed air stays close to the ceiling. In such cases, suggest your client users to install air circulators.
  - b) Places where perfect drainage can be prepared and sufficient drainage gradient is available.
  - c) Places free from air disturbances to the return air port and supply hole of the indoor unit, places where the fire alarm may not malfunction to short circuit.
  - d) If the humidity above the ceiling exceeds 80% or the condensation temperature above the ceiling exceeds 28°C, affix polyurethane foam (with a thickness to 10 or greater) above the insulation in the ceiling panels.
 

Carry out tests of the main unit under the above conditions and confirm that there is no failure. However, if the environment where the unit is installed exceeds the above conditions and the unit is operated in high humidity conditions, there is danger of condensate dripping down. If there is a possibility that the unit will be used under such conditions, dress 10 to 20 mm of insulation material to the main unit, piping and drain pipes.
  
- 3) Check if the selected place for installation is rigid enough to stand the weight of the unit.  
Otherwise, apply reinforcement using boards and beams before starting the installation work.




Unit : mm

Models	Mark	A
FDUR45, 56, 71		1200
FDUR90, 112, 140		1720

**(ii) Suspension**

Be sure to observe the finished length of the suspension bolts given below.




Unit : mm

Models	Mark	A
FDUR45, 56, 71		886
FDUR90, 112, 140		1406

## 1) Fixing the suspension bolt (customer ordered parts M10)

Securely fix the suspension bolt as illustrated below or in another way.



### (iii) Installation of indoor unit

#### Packing hardware


Two pieces of packing hardware are used.

Discard them after unpacking.

- Fix the indoor unit to the hanger bolts.

If required, it is possible to suspend the unit to the beam, etc.

Directly by use of the bolts without using the hanger bolts.




#### Note

When the dimensions of indoor unit and ceiling holes does not match, it can be adjusted with the slot holes of hanging bracket.

### 1) Adjusting the unit's levelness

a) Adjust the out-levelness using a level vial or by the following method.

- Make adjustment so that the relation between the lower surface of the unit proper and water level in the hose becomes given below.



Bring the piping side slightly lower

b) Unless the levelness is adjusted properly, the malfunction of the float switch will occur.

### 2) Blower fan tap switch

The following two methods are available in switching the blower fan tap. Switch to the high-speed tap with one of these methods.

- Set SW9-4 provided on the indoor unit PCB to ON.
- By means of function setting from the remote control unit, set the setting ③ of "I/U FUNCTION ▲" (indoor unit function) to "Hi CEILING 1" (high-speed tap) as shown right.

SW9-4	ON	Fan control, high speed (High ceiling)
	OFF	Fan control, standard

Function number ①	Function description ②	Setting ③
01	Hi CEILING SET	Hi CEILING 1

For the details of operating procedures, please refer to the installation manual of your remote control unit.

Unit : Pa

Models	Static Pressure	
	Standard tap	High tap
FDUR45, 56	50	85
FDUR71, 90, 112, 140	50	130


### ⚠ CAUTION

- Traps should not be used under static pressure outside the unit mentioned above. Dew condensation may occur with the unit and wet the ceiling or furniture.
- Do not use under static pressure outside the unit of 50Pa or less. Water drops may be blown from the diffuser outlet of the unit and wet the ceiling or furniture.


#### (iv) Drain piping

1) Drain piping should always be in a downhill grade (1/50-1/100) and avoid riding across an elevation or making traps.

##### • Good piping




##### • Improper piping




2) When connecting the drain pipe to the unit, pay sufficient attention not to apply excess force to the piping on the unit side. Also, fix the piping at a point as close as possible to the unit.

3) For drain pipe, use hard PVC general purpose pipe VP-25 which can be purchased locally. When connecting, insert a PVC pipe end securely into the drain socket before tightening securely using the attached drain hose and clamp. Adhesive must not be used connection of the drain socket and drain hose ( accessory).




4) When constructing drain piping for several units, position the common pipe about 100 mm below the drain outlet of each unit as shown in the sketch below. Use VP-30 or thicker pipe for this purpose.



5) Be sure to provide heat insulation to hard PVC pipes of indoor placement.

6) Do not ever provide an air vent.

7) The height of the drain head may be elevated up to a point 600 mm from the bottom of unit and, when an obstacle exists in the ceiling space, elevate the piping to avoid the obstacle using an elbow or corresponding gadget. When doing this, if the stretch for the needed height is too high, the back-flow quantity of drain at the time of interruption of the operation gets too much and it may cause overflow at the drain pan. Therefore, make the height of the drain pipe withing the length given in the drawing below.






8) Avoid positioning the drain piping outlet at a place where generation of odor may be stimulated. Do not lead the drain piping direct into a sewer from where sulfur gas may generate.

#### 9) Drainage test

- 1) Conduct a drainage test after completion of the electrical work.
- 2) During the trial, make sure that drain flows properly through the piping and that no water leaks from connections.
- 3) In case of a new building, conduct the test before it is furnished with the ceiling.
- 4) Be sure to conduct this test even when the unit is installed in the heating season.

##### Procedures

- ① Supply about 1000 cc of water to the unit through the air outlet by using a feed water pump.
- ② Check the drain while cooling operation.




#### 10) Outline of bottom drain piping work


- a) If the bottom drain piping can be done with a descending gradient (1/50-1/100), it is possible to connect the pipes as shown in the drawing below.

##### 【Connection of pipes】

(Removing drain motor connector) Remove drain motor connector CNP (blue) as shown in the drawing on the right. (Note: If the connector is left connected, drain water is discharged from the connecting port of top pipes, causing leakage.)



- b) Do not use acetone-based adhesives to connect to the drain socket.



#### Forced drain pump operation

◆ Setup from a unit side.

- ① Turn on DIP switch SW5-1 on the PCB of the indoor unit. The drain pump operates continuously.
- ② After the test, be sure to turn off the DIP switch.

(When electrical work is not completed, connect a convex joint to the drain pipe joint area, arrange an inlet and check leaks and drain conditions of the pipe.)

◆ Setup from a remote controller side.

Drain pump operation from a remote controller unit is possible. Operate a remote controller unit by following the steps described below.

1. To start a forced drain pump operation

- ① Press the TEST button for three seconds or longer.

The display will change from “SELECT ITEM” → “SET” → “TEST RUN ▼”

- ② Press the ▼ button once while “TEST RUN ▼” is displayed, and cause “DRAIN PUMP ◆” to be displayed.

- ③ When the SET button is pressed, a drain pump operation will start.



Display: “DRAIN PUMP RUN” → “STOP”

2. To cancel a drain pump operation.

- ① If either SET or ON/OFF button is pressed, a forced drain pump operation will stop.

The air conditioning system will become OFF.

(v) Duct work




- 1) A corrugated board (for preventing sputtering) is attached to the main body of the air conditioner (on the outlet port). Do not remove it until connecting the duct.

- a) An air filter is provided on the main body of the air conditioner (on the inlet port). Remove it when connecting the duct on the inlet port.

2) Blowout duct


- a) Reduce the length of duct as much as possible.  
 b) Reduce the number of bends as much as possible.  
 c) (Corner R should be as large as possible.)




- d) Conduct the duct installation work before finishing the ceiling.

### 3) Inlet port


- When shipped, the inlet port lies on the back.
  - When connecting the duct to the inlet port, remove the air filter fitted to the inlet port.
  - When placing the inlet port to carry out suction from the bottom side, use the following procedure to replace the air return duct joint and the bottom plate.
- Make sure to insulate the duct to prevent dewing on it.
  - Location and form of air supply outlet should be selected so that air from the outlet will be distributed all over the room, and equipped with a device to control air volume.
  - Make sure provide an inspection hole on the ceiling. It is indispensable to service electric equipment, motor, functional components and cleaning of heat exchanger.




- Remove the screws which fasten the bottom plate and the duct joint on the inlet port side of the unit.



- Replace the removed bottom plate and duct joint



- Fit the duct joint with a screw, fit the bottom plate.



- If a duct is not provided at the air return side but it is substituted with the space over the ceiling, humidity in the space will increase by the influence of capacity of ventilation fan, strength of wind blowing against the outdoor air louver, weather (rainy day) and others.

- Moisture in air is likely to condense over the external plates of the unit and to drip on the ceiling.

Unit should be operated under the conditions as listed in the above table and within the limitation of wind volume.

When the building is a concrete structure, especially immediately after the construction, humidity tends to rise even if the space over the ceiling is not substituted in place of a duct.


In such occasion, it is necessary to insulate the entire unit with glass wool (25mm). (Use a wire net or equivalent to hold the glass wool in place.)

- It may run out the allowable limit of unit operation (Example: When outdoor air temperature is 35°C DB, return air temperature is 27°C WB) and it could result in such troubles as compressor overload, etc..
- There is a possibility that the supply air volume may exceed the allowable range of operation due to the capacity of ventilation fan or strength of wind blowing against external air louver so that drainage from the heat exchanger may fail to reach the drain pan but leak outside (e. g. drip on to the ceiling) with consequential water leakage in the room.

**(vi) Control box (Only case of FDUR90, 112, 140)**

- During bottom side air return, the orientation of the control box can be changed to allow the control box to be maintained from the inlet port.

1) Remove the bottom plate (on the inlet port side), and all wiring connectors from the control box.



- Before shipment from the plant, arrangements are made to enable maintenance from the sides of the unit.

2) Remove the three screws that fasten the cabinet inside the control box.



3) Pull the control box toward the outside of the unit.

4) Change the wiring route of the wiring inside the control box.

5) Fit the control box from the inside of the unit.

6) Fit the three screws that fasten the cabinet.

7) Correctly connect all wiring connectors.



**(j) Ceiling suspended type (FDE)**

**(i) Selection of installation location**

1) A place where good air circulation and delivery can be obtained.

**Cold air throw**

Unit : m

Models	FDE36, 45	FDE56, 71	FDE112, 140
Air throw	7.5	8	9

**Conditions**

(1) Installation height: 2.4 ~ 3.0 m above the floor

(2) Fan speed: Hi

(3) Location: Free space without obstacles

(4) Distance of reach indicates the horizontal distance after the wind touched down on the floor.

(5) Air velocity at the throw: 0.5 ( m/sec.)

2) A place where ceiling has enough strength to support the unit.


3) A place where there is no obstruction to the return air inlet and supply air outlet ports.

4) Places exposed to oil splashes or steam (e.g. kitchens and machine plants).

Installation and use at such places will incur deteriorations in the performance or corrosion with the heat exchanger or damage in molded synthetic resin parts.

- 5) A place where the space shown below may be secured.

### Ceiling mounting installation





Note (1) This shows the installation interval dimensions between units.

- 6) This unit uses a microcomputer as a control device. Therefore avoid installing the unit near the equipment that generates strong electromagnetic waves and noise.

## (ii) Installation preparation

### 1) Remove the air return grille.


Slide the stoppers (4 places).



Take out the pins (4 or 6 places).



### 2) Remove the side panels.

Take out the screws, then slide the side panels in the arrow direction to remove them.




### 3) Remove the suspension lug.

Take out the screws, then loosen the installation bolt.





#### 4) Suspension Bolt Position

- Using the paper pattern supplied as an accessory as a criterion, select suspension bolt positions and piping hole positions, then install the suspension bolts and make holes for piping. After positioning, remove the paper pattern.
- Keep strictly to the suspension bolt lengths specified below.




Unit : mm

Model	A	B
FDE 36, 45	1070	1022
FDE 56, 71	1320	1272
FDE 112, 140	1620	1572




#### (iii) Installation

##### 1) Fasten the suspension lugs to the suspension bolts.




<If there is ceiling material>




\*Fasten it securely with double nuts.

<If there is no ceiling material>



##### 2) Attach the unit to the suspension lugs.


- Slide the unit onto the suspension lugs from the front, hanging it on the bolts.
- Fasten the unit securely on the left and right sides with 4 suspension bolts (M8).
- Tighten the 2 screws (M4) on the left and right sides.




⚠ After sliding the side panels on from the front to rear, fasten them securely with the screws.

3) IN order to make it easier for water to drain out. install the unit so that the water drain side slopes downward.

● Left-right direction




● Front-rear direction



⚠ If the slope is reversed, there is danger of water leaking out.

(iv) Refrigerant Piping


1) Piping Position



2) Piping Connection Position

Piping can be connection from 3 different directions. Remove the cutout from hole where the piping will be connected using side cutters or similar tool. Cut a hole for the piping connection in the back cover according to the cutting margin shown. Cut a hole in the ceiling side in accordance with the position of the piping. Also, after the piping is installed, seal the space around the piping with putty, etc. to keep dust from getting inside the unit.

(In order to prevent damage to wires from the edges, be sure to use the back and top covers.)



(v) Drain Piping

1) Drain piping can be connected from the back, right and left sides.

2) When installing drain piping, be sure to use the insulating material supplied for the drain hose and drain hose clamp.

- Connect the drain hose fully all the way to the base of the fitting.
- Fasten the hose securely with the drain hose clamp.
- Keep strictly within the lengths specified below for the suspension bolts.


3) If drain piping is installed on the left side, change the rubber plug and insulating material (tubular) from the left side piping connection port to the right side.

⚠ Be careful that water doesn't pour out when the drain plug is removed.

## ⚠ WARNING


Use the fitting supplied with the unit to connect the drain hose, fastening it at the lowest point so that there is no slack, and establishing a 10 mm drain slope.

\* Keep electrical wiring from running beneath the drain hose.



⚠ Be sure to fasten the drain hose down with a clamp.

There is danger of water overflowing the drain hose.




After piping has been installed, check to make sure water drains well and that there is no overflow.

## (k) Wall mounted type (FDK)

Models FDKA22~56KXE4R

### (i) Selection of installation location




- 1) Select the installation location that meets the following conditions and obtain the customer's consent.
  - a) Location where cold and warm air spread all over the room
  - b) Location where piping and wiring to the outdoors can easily be laid down.
  - c) Location where the drain can be discharged completely.
  - d) Location where the wall to mount the unit is rigid.
  - e) Location where there is no wind obstruction to the return air and supply air grills.
  - f) Location not exposed to direct sunshine.
  - g) Avoid the location exposed to oil splash or vapor.
  - h) Avoid the location near to the machine emitting high-frequency radio wave.
  - i) Avoid the location where the receiver of remote control is subject to strong illumination.
  - j) Select the location where the unit can securely be operated by the wireless remote controller referring to the Article "Effective distance of wireless remote controller" indicated at the backside.
  - k) Secure the space for inspection and maintenance work.




## (ii) Attaching of mounting plate

- 1) The indoor unit weighs approx, FDK22~56 model : 12kg. Therefore, check whether the portion to install the unit can bear the weight of unit. If it seems to be danger, reinforce the portion by a plate or a beam before installing the unit. It is not allowed to install the unit directly on the wall. Whenever you install the unit, use the attached mounting plate.
- 2) Find structural members (Intermediate pillar, etc.) suitable for mounting the unit, then install the unit firmly while checking levelness.



- 3) Adjust the level of mounting plate under the condition that four screws are tightened temporarily.



- 4) Turn the mounting plate around the reference hole to adjust the levelness.

### ⚠ WARNING

Install the unit where it can bear the weight with sufficient strength margin. In the case of insufficient strength or insufficient installation work, the unit may fall and cause injury.

## (iii) Procedure for making hole on the wall


- Make a downgrade (5°) from the indoors toward the outdoors.



## (iv) Forming of piping and drain hose


- 1) Rear take out case

### a) Forming of piping



- Hold the root portion of piping, change the direction then expand and make forming.

### b) Tape winding



- Wind the tape on the portion which passes through the hole on the wall.
- Always make taping on the wiring which crosses with the piping, if any.


Note(1) After forming of piping and before tape winding, confirm that the connecting wire is securely fixed to the terminal block.

- 2) Cautions for left take-out and rear take-out case





### a) Looking down

For left running horizontal piping For left rear take-out piping	For right running horizontal piping For right rear take-out piping
For left running horizontal piping	For right running horizontal piping

- b) The piping can be taken out from the rear, left, left rear, right and down.





### b) Procedure for changing drain hose

<p>1. Remove the drain hose.</p> 	<p>2. Remove the drain cap.</p> 	<p>3. Insert the drain cap.</p> 	<p>4. Connect the drain hose.</p> 
<ul style="list-style-type: none"> <li>• Pull the drain hose off while turning the end around.</li> </ul>	<ul style="list-style-type: none"> <li>• Remove by hand or pliers.</li> </ul>	<ul style="list-style-type: none"> <li>• Insert the drain cap which was removed in procedure 2 securely using a hexagonal wrench, etc.</li> </ul> <p>Note(1) When it is not inserted securely, water leakage may occur.</p>	<ul style="list-style-type: none"> <li>• Push the end of the drain hose onto the fitting while turning it around.</li> </ul> <p>Note(1) When it is not inserted securely, water leakage may occur.</p>

### (v) Installation of unit

- To remove the unit from the mounting plate, remove the right and left lids then remove the claw at the lower portion of base.



### (vi) Drain piping

- 1) Lay the drain piping with downgrade to facilitate flow of drain, and do not make a trap or chevron-shaped bend. (The drain piping can be taken out from the unit to the left, right, rear and down direction.)
- 2) Wrap the thermal insulator on the hard vinyl chloride pipe (VP-16) laid in the room.
- 3) Run the drain piping in a place where there is no fear of abnormal odors being generated at the end of the drain hose.
- 4) Do not run the drain piping directly into a sewer where sulfur-based poisonous or flammable gases are generated. There is danger of poisonous or flammable gases penetrating into the building through the drain piping.
- 5) Pour water into the drain pan below the heat exchanger to check that water is drained outdoors.






Illustration showing the end of drain hose



## Model FDKA71KXE5R


### (i) Selection of installation location




- 1) Select the installation location that meets the following conditions and obtain the customer's consent.
  - a) Location where cold and warm air spread all over the room
  - b) Location where piping and wiring to the outdoors can easily be laid down.
  - c) Location where the drain can be discharged completely.
  - d) Location where the wall to mount the unit is rigid.
  - e) Location where there is no wind obstruction to the return air and supply air grills.
  - f) Location not exposed to direct sunshine.
  - g) Avoid the location exposed to oil splash or vapor.
  - h) Avoid the location near to the machine emitting high-frequency radio wave.
  - i) Avoid the location where the receiver of remote control is subject to strong illumination.
  - j) Select the location where the unit can securely be operated by the wireless remote controller referring to the Article "Effective distance of wireless remote controller" indicated at the backside.
  - k) Secure the space for inspection and maintenance work.

### (ii) Attaching of mounting plate

- 1) The indoor unit weighs approx, FDK71 model : 18kg. Therefore, check whether the portion to install the unit can bear the weight of unit. If it seems to be dangerous, reinforce the portion by a plate or a beam before installing the unit. It is not allowed to install the unit directly on the wall. Whenever you install the unit, use the attached mounting plate.
- 2) Find structural members (Intermediate pillar, etc.) suitable for mounting the unit, then install the unit firmly while checking levelness.



- 3) Adjust the level of mounting plate under the condition that four screws are tightened temporarily.




- 4) Turn the mounting plate around the reference hole to adjust the levelness.

### **WARNING**

Install the unit where it can bear the weight with sufficient strength margin. In the case of insufficient strength or insufficient installation work, the unit may fall and cause injury.

### (iii) Procedure for making hole on the wall


- Make a downgrade (5°) from the indoors toward the outdoors.



#### (iv) Forming of piping and drain hose


##### 1) Rear take out case

##### a) Forming of piping



- Hold the root portion of piping, change the direction then expand and make forming.

##### b) Tape winding




- Wind the tape on the portion which passes through the hole on the wall.
- Always make taping on the wiring which crosses with the piping, if any.


Note (1) After forming of piping and before tape winding, confirm that the connecting wire is securely fixed to the terminal block.

##### 2) Cautions for left take-out and rear take-out case


##### a) Looking down



##### b) The piping can be taken out from the rear, left, left rear, right and down.



##### c) Procedure for changing drain hose



- Pull the drain hose off while turning the end around.

- Remove by hand or pliers.


- Insert the drain cap which was removed in procedure 2 securely using a hexagonal wrench, etc.

Note (1) When it is not inserted securely, water leakage may occur.

- Push the end of the drain hose onto the fitting while turning it around.


Note (1) When it is not inserted securely, water leakage may occur.

- d) This air conditioner is designed to collect dew formed on its back in the drain pan for discharging, so please do not lay power cables, etc. in any part above the gutter.




#### (v) Installation of unit

- To remove the unit from the mounting plate, remove the right and left lids then remove the claw at the lower portion of base.



#### Installation work procedure



#### (vi) Drain piping

- 1) Lay the drain piping with downgrade to facilitate flow of drain, and do not make a trap or chevron-shaped bend. (The drain piping can be taken out from the unit to the left, right, rear and down direction.)
- 2) Wrap the thermal insulator on the hard vinyl chloride pipe (VP-16) laid in the room.
- 3) Run the drain piping in a place where there is no fear of abnormal odors being generated at the end of the drain hose.
- 4) Do not run the drain piping directly into a sewer where sulfur-based poisonous or flammable gases are generated. There is danger of poisonous or flammable gases penetrating into the building through the drain piping.
- 5) Pour water into the drain pan below the heat exchanger to check that water is drained outdoors.





Illustration showing the end of drain hose



## (I) Floor standing exposed type (FDFL)

Model: All models

### (i) Selection of installation location

- 1) A place where good air circulation and delivery can be obtained.

#### • Cold air throw

Unit : m

Models	All models
Air throw	4



#### [Conditions]

- (1) Fan speed: Hi
  - (2) Location: Free space without obstacles
  - (3) Distance of reach indicates the horizontal distance after the wind touched down the floor.
  - (4) Air velocity at the throw: 0.5 (m/sec.)
- 2) Where there is no obstacle around the Air inlet port or Air outlet port.
  - 3) Where a sufficient space can be reserved for the service of air filter and the attachment/removal of panels.
  - 4) Places exposed to oil splashes or steam (e.g. kitchens and machine plants).  
Installation and use at such places will incur deteriorations in the performance or corrosion with the heat exchanger or damage in molded synthetic resin parts.
  - 5) Where pipes and wires can be arranged conveniently.
  - 6) On the solid floor
  - 7) Where the unit is not exposed directly to sun light.
  - 8) Places where corrosive gas (such as sulfurous acid gas) or inflammable gas ( thinner, gasoline, etc.) is generated or remains.  
Installation and use at such place will cause corrosion in the heat exchanger and damage in molded synthetic resin parts.
  - 9) Where a complete draining can be assured.
  - 10) Where a sufficient space can be reserved for service.

### Floor standing installation

#### • Floor fixation

#### • Wall fixation




Unit : mm

### (ii) Bolt positions

- 1) Bolt positions for metal settings used for floor fixation.


#### • Metal fitting used for floor fixation (accessories).



Note (1) Value in ( ) indicates 71 type.

- 2) Bolt positions for wall fixation



Unit : mm



### (iii) Installation of unit



#### 1) Floor standing installation

- a) Position of mounting bracket fixing bolts Drill holes by referring to figures below.





Note (1) Be sure to use a bolt of the length for wall mounting.

- b) The method of drilling the wall is as follows.




- c) Remove the front and side panels.




- d) Level the unit using the level adjusting screw. Installation will be completed after attaching side and front panel.

- e) Execute fixation following the directions described below.

- When fixed on the floor




- When fixed on the wall



#### (iv) Drain piping

The drain piping can be directed to the floor or rear sides as follows.

- Connect a drain piping to the drain outlet and fix it by use of tigghening band.
- Indoor side drain piping must be thermally insulated.
- After finishing the drain piping, check the drainage by pouring some water in the drain pan.




#### (v) Installation of remote controller ( on the indoor unit )

Attached remote controller may be installed on the indoor unit as shown below. The work can be done on the spot when the customer asks so or by other reasons.

Refer to the page 274 when it is instralled on the wall.

##### 1) Detach the front panel.

Unit: mm




##### 2) Remote controller installation.

- Attach the lower case with the screws (M4 × 12) accessory.


##### 3) Remote controller wiring.

- Connect the terminals between the remote controller and the control box as per these wire color codes:[ (X) (red). (Y) (white), (Z) (black)], using the wires included in the kit.
- The wires should have a surplus length of approximately 30 cm. (Necessary when servicing with the front panel detached.)
- In case of stranded wire strip and solder as shown below when cutting the wire. (Omitting the soldering process may cause looseness of the wiring.)



#### 4) Wiring route.

- Wire from the wiring hole through the rear side of the control box to the terminal block.
- Any surplus wires should be tied up with a cable tie.



#### (m) Floor standing hidden type (FDFU)

Model: All models

##### (i) Selection of installation hidden location

- A place where good air circulation and delivery can be obtained.

##### • Cold air throw Unit : m


Models	All models
Air throw	4

##### [Conditions]


- Fan speed: Hi
  - Location: Free space without obstacles
  - Distance of reach indicates the horizontal distance after the wind touched down the floor.
  - Air velocity at the throw: 0.5 (m/sec.)
- Where there is no obstacle around the Air inlet port or Air outlet port.
  - Where a sufficient space can be reserved for the service of air filter and the attachment/removal of panels.
  - Places exposed to oil splashes or steam (e.g. kitchens and machine plants).  
Installation and use at such places will incur deteriorations in the performance or corrosion with the heat exchanger or damage in molded synthetic resin parts.
  - Where pipes and wires can be arranged conveniently.
  - On the solid floor
  - Where the unit is not exposed directly to sun light.
  - Places where corrosive gas (such as sulfurous acid gas) or inflammable gas ( thinner, gasoline, etc.) is generated or remains.  
Installation and use at such place will cause corrosion in the heat exchanger and damage in molded synthtic resin parts.
  - Where a complete draining can be assured.
  - Where a sufficient space can be reserved for service.

##### Floor standing installation

##### • Floor fixation



##### • Wall fixation



Unit : mm






#### (iv) Drain piping

The drain piping can be directed to the floor or rear sides as follows.

- (a) Connect a drain piping to the drain outlet and fix it by use of tigghening band.
- (b) Indoor side drain piping must be thermally insulated.
- (c) After finishing the drain piping, check the drainage by pouring some water in the drain pan.



## (2) Installation of remote controller (Option parts)

### (a) Selection of installation location


Avoid the following locations

- 1) Direct sunlight.
- 2) Close to heating device.
- 3) Highly humid or water splashing area.
- 4) Uneven surface.


### (b) Installation procedure

#### a) Exposed fitting


- 1) Open the remote controller case.



- Put a screw driver (flat-head) into the concavity made on the upper part of a remote controller and twist it lightly to open the casing.
- 2) The cord of a remote controller can only be pulled out in the upward direction.




- Cut off with nippers or a knife a thin walled part made on the upper end of the remote controller bottom casing, and then remove burrs with a file or the like.
- 3) Fix the remote controller bottom casing onto a wall with two wood screws supplied as accessories.




- 4) Connect the remote controller to the terminal block. Connect the terminals of the remote controller to the indoor unit with the same numbers. Because the terminal block has polarity, the device becomes inoperative if there are wrong connections.

Terminals: (X) Red wire, (Y) White wire, (Z) Black wire



- Use a cord of 0.3mm<sup>2</sup> (recommended) - 0.5mm<sup>2</sup> (maximum) for a remote controller cord. Remove a sheath of the remote controller cord for the section laid within the remote controller casing.

The length of each wire that should be left after a sheath is removed is as follows:






Black: 195mm, White: 205mm, Red: 215mm

- 5) Replace the top casing as before.
- 6) Use a cord clamp to attach the remote controller cord to the wall.
- 7) Set the functions according to the types of indoor unit. See section "Setting function". Refer to page 287.

### (c) Recessed fitting


- 1) The Electrical box and remote controller (shield wire must be use in case of extension) are first embedded.



- 2) Remove the upper case to the remote controller.
- 3) Attach the lower case to the Electrical box with two M4 screws. (Head diameter must be 8 mm). Choose either of the following two positions in fixing it with screws.
- 4) Connect the remote controller cord to the remote controller.

Refer to [Exposed Fitting].

- 5) Installation work is completed by replacing the top casing onto the bottom casing as before.
- 6) Set the functions according to the types of indoor unit. See section "Setting function". Refer to page 310.



### Precision in extending the remote controller cord

- ▶ Maximum total extension 600m.


The cord should be a shielded wire.

- For all types : 0.3mm<sup>2</sup> × 3 cores

Note (1) Use cables up to 0.5mm<sup>2</sup> (maximum) for those laid inside the remote controller casing and connect to a different size cable at a vicinity point outside the remote controller, if necessary.

Within 100-200m.....	0.5 mm <sup>2</sup> × 3 cores
Within 300m.....	0.75 mm <sup>2</sup> × 3 cores
Within 400m.....	1.25 mm <sup>2</sup> × 3 cores
Within 600m.....	2.0 mm <sup>2</sup> × 3 cores

- The shielded wire should be grounded at one side only.



### (3) Installation of outdoor unit

#### ◆ Models FDCA140HKXEN4R, 140HKXES4R, 160HKXES4R

##### (a) Accessories

Confirm accessories shown below are attached in the bag with this installation manual.

- 1) "Edging" for protection of electric wires from opening edge.

##### (b) Selecting installation location

(Obtain approval from the customer when selecting the installation area.)

- 1) Please install with the customer's consent in a location that follows the conditions listed below.

- a) A location which can sustain the weight of the unit.
- b) Where there is no possibility of flammable gas leaks.
- c) Where air is not trapped.
- d) Out of the heat range of other heat sources.
- e) Where noise and hot air will not bother neighboring residents.
- f) Where wind does not hinder the intake and outlet pipes.

- g) If a unit is installed into a special environment as shown below, there will be a danger that the corrosion of the outdoor unit or its malfunctioning is caused. If this is the case, please consult with the distributor from whom you have purchased the unit.


- Where corrosive gas is generated (such as a hot-spring resort area).
- Where the unit is subject to sea breezes (coastal area).
- Where the unit is subject to oil mists.
- Where equipment generating electromagnetic waves exists in the vicinity.

- 2) Minimum installation space (Please select an installation point with due attention to the direction of installation of the refrigerant pipe)

- a) The height of a wall facing the diffuser must not exceed the height of the unit.
- b) Walls surrounding the unit in the four sides are not acceptable. There must be a 1-meter or larger space in the above.
- c) When units are installed side by side, leave a 10- mm or wider service space between the units.
- d) When more than one unit are installed, provide sufficient intake space consciously so that short circuiting may not occur.
- e) Where piling snow can bury the outdoor unit, provide proper snow guards.

Unit : mm


Sample Size	I	II	III
L <sub>1</sub>	Open	Open	500
L <sub>2</sub>	300	5	Open
L <sub>3</sub>	100	300	150
L <sub>4</sub>	5	5	5




- 3) When strong winds occur

- Where it is likely that the unit is subjected to strong winds, provide wind guards according to the following guidelines. Strong winds can cause performance degradation, an accidental stop due to a rise of high pressure and a broken fan.


- ① Place the unit outlet pipe perpendicular to the wind direction.



- ② Please install so the direction of the air from the blowing outlet will be perpendicular to the direction of the wind.



- ③ Where the foundation is not level, use wires to tie down the unit.



### (c) Unit delivery and installation.


(Take particular care in carrying in or moving the unit, and always perform such an operation with two or more persons.)



**When you sling the unit for portage, do not fail to take into consideration the deviation of the gravity center from its center.  
Improper slinging may cause the unit to lose balance and fall.**

#### 1) Delivery



- Delivery the unit as close as possible to the installation site before removing it from the packaging.
- If unpacked and delivery cannot be avoided, use a nylon sling or a rope with pads placed where the rope contacts the unit so it is not scratched.




#### 2) Portage

- The right hand side of the unit as viewed from the front (diffuser side) is heavier. A person carrying the right hand side must take heed of this fact. A person carrying the left hand side must hold with his right hand the handle provided on the front panel of the unit and with his left hand the corner column section.

#### 3) Bolt fastening positions



- a) In installing the unit, fix the unit's legs with bolts specified below.



- b) The protrusion of an anchor bolt on the front side must be kept within 15 mm.  
 c) Securely install the unit so that it does not fall over during earthquakes or strong winds, etc.  
 d) Refer to the above illustrations for information regarding concrete foundations.  
 e) Install the unit in a level area. (With a gradient of 5 mm or less). Improper installation can result in a compressor failure, broken piping within the unit and abnormal noise generation.

### ◆ Models FDCA224~1360HKXE4R FDCA224~1360HKXRE4R

#### (a) Selecting the installation location

- |   |   |
|---|---|
| 1) Where air is not trapped.                                      | 8) Where strong winds will not blow against the outlet pipe.  |
| 2) Where the installation fittings can be firmly installed.       | 9) A place where stringent regulation of electric noises is applicable.   |
| 3) Where wind does not hinder the intake and outlet pipes.        | 10) A place where TV set or radio receiver is placed within 5m. (If electrical interference is caused, seek a place less likely to cause the problem) |
| 4) Out the heat range of other heat sources.                      |   |
| 5) Where it is safe for the drain water to be discharged.         |   |
| 6) Where noise and hot air will not bother neighboring residents. |   |
| 7) Where snow will not accumulate.                                |   |

Notes(1) A four-sided enclosure cannot be used. Leave a space of at least 1m above the unit.

(2) If there is a danger of a short-circuit, then install a wind direction variable adapter.

(3) When installing multiple units, provide sufficient intake space so that a short-circuit does not occur.

(4) In areas where there is snowfall, install the unit in a frame or under a snow hood to prevent snow from accumulating on it.  
(Inhibition of collective drain discharge in a snowy country)


(5) Do not install the equipment in areas where there is a danger of flammable gas leaks.

\* Please ask your distributor about optional parts such as wind vane adapters, snow guard hoods, etc.

(b) Installation space (service space) example

Please secure sufficient clearance (room for maintenance work, passage, draft and piping). (If your installation site does not fulfill the installation condition requirements set out on this drawing, please consult with your distributor or the manufacturer)

1) When one unit is installed



※ 2m clearance above the unit

Unit: mm


Example installation Dimensions	I	II
L1	500	Open
L2	10	10
L3	100	100
L4	10	Open
H1	1500	—
H2	No limit	No limit
H3	1000	No limit
H4	No limit	—

2) When more than one unit are installed.

Items with a ★ mark show the service panel side.

[In ordinary construction, assure a space of 10 mm or greater in front of the unit in consideration of the needed work space.]

① Example of installation of 3 units in a row




※ 2m clearance above the unit

Unit: mm

Example installation Dimensions	I	II
L1	500	Open
L2	10	200
L3	100	300
L4	10	Open
L5	10 (0)	400
L6	10 (0)	400
H1	1500	No limit
H2	No limit	No limit
H3	1000	No limit
H4	No limit	No limit

② Example of installation of 2 units in a row:


In the case of a wall in back of the units.



Open


③ Example of installation of 3 units in a row:

In the case of a wall in back of the units.



Open


④ Example of installation of 4 rows with 6 units each.



Unit: mm

⑤ Example of installation of 4 rows with 8 units each.

Unit: mm




(c) Notabilia for installation

1) Anchor bolt positions


- Use four anchor bolts (M10) to fix an outdoor unit's anchoring legs at all times. Ideally, an anchor bolt should protrude 20mm.

Unit : mm




2) Base


- 1) Please install a unit after ascertaining that the bases have been made to sufficient strength and level to ensure the unit against vibration or noise generation.
- 2) Please construct a base to the size of a shadowed area (the entire bottom area of an outdoor unit's anchoring leg) shown on the above drawing or larger.



Normally, it is desirable that a base as specified in the drawing above is provided.




A base used for a former model is wrongly oriented and not acceptable.




Please use it for renewal installation. (Please add a base on the center)

3) Vibration isolating rubber

- 1) A vibration isolating rubber must support an outdoor unit's anchoring leg by its entire bottom area.



Install a vibration isolating rubber in such a manner that the entire bottom area of an outdoor unit's anchoring leg will rest on it.



Do not install an outdoor unit in such a manner that a part of the bottom area of its anchoring leg is off a vibration isolating rubber.

## (4) Refrigerant piping

### (a) Refrigerant piping restrictions

#### ◆ Models FDCA140HKXEN4R, 140HKXES4R, 160HKXES4R

Please do not fail to observe the following pipe sizes and limitations of use.

A failure to observe this instruction can result in a compressor failure or performance degradation.

- 1) Total pipe length (Combined total length of pipes) ..... Within 100m
- 2) Maximum length (To the farthest indoor unit) ..... Within 70m
- 3)  $\phi$  9.52 total liquid pipe length ..... Within 50m
- 4) Head
  - a) When the outdoor unit above the indoor unit ..... Within 30m
  - b) When the outdoor unit is below the indoor unit ..... Within 15m
  - c) Height difference between indoor units in the same system ..... Within 4m

#### ◆ Models FDCA224~1360HKXE4R

- 1) Maximum length (from an outdoor unit to the farthest indoor unit)  
..... 160 m or less as actual pipe length (185 m or less as equivalent pipe length)  
(When an actual pipe length exceeds 90 m, however, it is necessary to change the pipe size. Please determine the main pipe size by consulting with the Main Selection Reference Table set out in Section (c). 2))
- 2) Total pipe length ..... 510 m or less
- 3) Main pipe length ..... 130 m or less
- 4) Allowable pipe length from the first branching ..... 40 m or less
- 5) Allowable elevation difference (head difference)
  - a) When an outdoor unit is installed above ..... 50 m or less
  - b) When an outdoor unit is installed below ..... 40 m or less
  - c) Difference in the elevation of indoor units in a system ..... 15 m or less
- 6) Restrictions on piping applicable to the section between an outdoor unit and an outdoor unit side branching pipe (combination unit)
  - a) Difference in the elevation ..... 1 m or less
  - b) Distance between an outdoor unit and an outdoor unit side branching pipe ..... 5 m or less
  - c) Length of oil equalization piping ..... 10 m or less

#### ◆ Models FDCA224~1360HKXRE4R

- 1) Maximum length (from an outdoor unit to the farthest indoor unit)  
..... 160 m or less as actual pipe length (185 m or less as equivalent pipe length)  
(When an actual pipe length exceeds 90 m, however, it is necessary to change the pipe size. Please determine the main pipe size by consulting with the Main Selection Reference Table set out in Section (3). (b))
- 2) Total pipe length ..... 510 m or less
- 3) Main pipe length ..... 130 m or less
- 4) Allowable pipe length from the first branching ..... 40 m or less
- 5) Allowable elevation difference (head difference)
  - a) When an outdoor unit is installed above ..... 50 m or less
  - b) When an outdoor unit is installed below ..... 40 m or less
  - c) Elevation difference between indoor units or between branching controllers within a system .... 15 m or less
  - d) Elevation difference between the first branch and the branching controller ..... 15 m or less
  - e) Elevation difference between the branching controller and the indoor unit.
    - i) When above indoor unit ..... 1 m or less
    - ii) When below indoor unit ..... 4 m or less
- 6) Restrictions on piping applicable to the section between an outdoor unit and an outdoor unit side branching pipe (combination unit)
  - a) Difference in the elevation ..... 1 m or less
  - b) Distance between an outdoor unit and an outdoor unit side branching pipe ..... 5 m or less
  - c) Length of oil equalization piping ..... 10 m or less

### (b) Piping material selection

- 1) Please use pipes clean on both the inside and outside and free from contaminants harmful to operation such as sulfur, oxides, dust, chips, oil, fat and water.
- 2) Use the following material for refrigerant piping.  
Material: phosphorus deoxidized seamless copper pipe (C1120T-0, 1/2H, JIS H3300)  
Use C1120T-1/2H for  $\phi$ 19.05 or larger, or C1120T-0 for  $\phi$ 15.88 or smaller
- 3) Do not use  $\phi$ 28.58  $\times$  t1.0 and  $\phi$ 34.92  $\times$  t1.2 as a bent pipe.
- 4) Thickness and size: Please select proper pipes according to the pipe size selection guideline.  
(Since this used R410A, always use 1/2H pipes of a specified minimum thickness or thicker for all pipes of  $\phi$ 19.05 or larger, because the pressure resistance requirement is not satisfied with O-type pipes).
- 5) For branching pipes, use a genuine branching pipe set or header set at all times. (optional parts)
- 6) For the handling of service valves, please refer to Section (d). (iv): Handling of service valves.
- 7) In installing pipes, observe the restrictions on the use of pipes set out in Section (a) (Maximum length, total pipe length, allowable pipe length from the first branching, allowable elevation difference (head difference)) without fail.
- 8) Install a branching pipe set and a branching controller, playing attention to the direction of attachment, after your have perused through the installation manual supplied with it..

### (c) Pipe size selection

- 1) Outdoor unit-Outdoor unit side branching pipe  
Please use a pipe conforming to the pipe size specified for outdoor unit connection.



a) KX series

Outdoor unit	Outdoor unit outlet pipe specifications					
	Gas pipe	Connection method	Liquid pipe	Connection method	Oil equalizing(1) pipe	Connection method
FDCA140	ø15.88 × t1.0	Flare	ø9.52 × t0.8	Flare	—	—
FDCA224	ø19.05 × t1.0	Braze				
FDCA280	ø22.22 × t1.0					
FDCA335	ø25.4(ø22.22) × t1.0					
FDCA335-K						
FDCA400	ø25.4(ø28.58) × t1.0		ø12.7 × t0.8		ø9.52 × t0.8	Flare
FDCA450-680	ø28.58 × t1.0					

Note (1) Please connect the master and slave unit with an oil equalizing pipe, when they are used in a combined installation. (It is not required, when a unit is used as a standalone installation)

b) KXR series

Outdoor unit	Outdoor unit outlet pipe specifications							
	Suction gas pipe	Connection method	Discharge gas pipe	Connection method	Liquid pipe	Connection method	Oil equalizing(1) pipe	Connection method
FDCA224	ø19.05 × t1.0	Brazed	ø15.88 × t1.0	Brazed	ø9.52 × t0.8	Flare	—	—
FDCA280	ø22.22 × t1.0		ø19.05 × t1.0		ø12.7 × t0.8			
FDCA335								
FDCA335-K								
FDCA400	ø28.58 × t1.0		ø22.22 × t1.0		ø9.52 × t0.8		Flare	
FDCA450~680								

Note (1) Please connect the master and slave unit with an oil equalizing pipe, when they are used in a combined installation. (It is not required, when a unit is used as a standalone installation)

2) Main (Outdoor unit side branching pipe – Indoor unit side first branching pipe)

If the longest distance (measured between the outdoor unit and the farthest indoor unit) is 90m or longer (actual length), please change the main pipe size according to the table below.

a) KX series

Outdoor unit	Main pipe size (normal)		Pipe size for an actual length of 90m or longer	
	Gas pipe	Liquid pipe	Gas pipe	Liquid pipe
FDCA224	ø19.05 × t1.0	ø9.52 × t0.8	ø22.22 × t1.0	ø12.7 × t0.8
FDCA280	ø22.22 × t1.0		ø25.4×t1.0 (ø22.22)	
FDCA335	ø25.4(ø22.22) × t1.0			
FDCA400	ø25.4(ø28.58) × t1.0	ø12.7 × t0.8		ø28.58 × t1.0
FDCA450	ø28.58 × t1.0			
FDCA504				
FDCA560				
FDCA615				
FDCA680				
FDCA735	ø31.8 × t1.1 (ø28.58 × t1.0)	ø15.88 × t1.0	ø31.8 × t1.1 (ø28.58 × t1.0)	ø15.88 × t1.0
FDCA800				
FDCA850				
FDCA900				
FDCA960				
FDCA1010	ø31.8 × t1.1 (ø34.92 × t1.2)	ø15.88 × t1.0	ø31.8 × t1.1 (ø28.58 × t1.0)	ø15.88 × t1.0
FDCA1065				
FDCA1130				
FDCA1180				
FDCA1235				
FDCA1300	ø38.1 × t1.35 (ø34.92 × t1.2)	ø19.05 × t1.0	ø38.1 × t1.35 (ø34.92 × t1.2)	ø22.22 × t1.0
FDCA1360				

Note (1) Values ( ) show piping sizes in the case that models for Europe are used.

b) KXR series

Outdoor unit	Main pipe size (normal)			Pipe size for an actual length of 90m or longer		
	Suction gas pipe	Discharge gas pipe	Liquid pipe	Suction gas pipe	Discharge gas pipe	Liquid pipe
FDCA224	ø19.05 × t1.0	ø15.88 × t1.0	ø9.52 × t0.8	ø22.22 × t1.0	ø15.88 × t1.0	ø12.7 × t0.8
FDCA280	ø22.22 × t1.0	ø19.05 × t1.0			ø22.22 × t1.0	
FDCA335			ø28.58 × t1.0	ø22.22 × t1.0		
FDCA400						
FDCA450						
FDCA504						
FDCA560						
FDCA615						
FDCA680	ø34.92 × t1.0	ø28.58 × t1.0	ø15.88 × t1.0	ø34.92 × t1.0	ø28.58 × t1.0	ø15.88 × t1.0
FDCA735						
FDCA800						
FDCA850						
FDCA900						
FDCA960						
FDCA1010	ø34.92 × t1.0	ø28.58 × t1.0	ø15.88 × t1.0	ø34.92 × t1.0	ø28.58 × t1.0	ø19.05 × t1.0
FDCA1065						
FDCA1130						
FDCA1180						
FDCA1235						
FDCA1300						
FDCA1360	ø34.92 × t1.0	ø28.58 × t1.0	ø19.05 × t1.0	ø34.92 × t1.0	ø28.58 × t1.0	ø22.22 × t1.0
FDCA1360						

3) Indoor unit side first branching pipe – Indoor unit side branching pipe

Please choose from the table below an appropriate pipe size as determined by the total capacity of indoor units connected downstream, provided, however, that the pipe size for this section should not exceed the main size .

a) KX series

Total capacity of indoor units	Gas pipe	Liquid pipe
Less than 70	ø 12.7 × t1.0	ø 9.52 × t0.8
70 or more but less than 180	ø 15.88 × t1.0	
180 or more but less than 371	ø 19.05 × t1.0	ø 12.7 × t0.8
371 or more but less than 540	ø 25.4 × t1.0(ø28.58 × t1.0)	ø15.88 × t1.0
540 or more but less than 700	ø 28.58 × t1.0	
700 or more but less than 1100	ø 31.8 × t1.1(ø34.92 × t1.2)	ø 19.05 × t1.0
1100 or more	ø 31.8 × t1.1(ø34.92 × t1.2)	

Note (1) Values in ( ) show piping sizes in the case that models for Europe are used.

b) KXR series

Total capacity of indoor units	Section gas pipe	Discharge gas pipe	Liquid pipe
Less than 70	ø 12.7 × t0.8	ø 9.52 × t0.8	ø 9.52 × t0.8
70 or more but less than 180	ø 15.88 × t1.0	ø 12.7 × t0.8	
180 or more but less than 371	ø 19.05 × t1.0	ø 15.88 × t1.0	ø 12.7 × t0.8
371 or more but less than 540	ø 28.58 × t1.0	ø 22.22 × t1.0	ø15.88 × t1.0
540 or more but less than 700			
700 or more but less than 1100	ø 34.92 × t1.2	ø 28.58 × t1.0	ø 19.05 × t1.0
1100 or more			

4) Indoor unit side branching pipe – Indoor unit

Indoor unit connection pipe size table

- In the downstream of a branching controller, no discharge gas pipe needs to be connected.

a) KX series

Indoor unit	Gas pipe	Liquid pipe
22, 28	ø 9.52 × t 0.8	ø 6.35 × t0.8
36, 45, 56	ø 12.7 × t 0.8	
71, 80, 90, 112, 140, 160	ø 15.88 × t 1.0	ø 9.52 × t0.8
224	ø 19.05 × t 1.0	
280	ø 22.22 × t 1.0	

b) KXR series

- In the downstream of a branching controller, no discharge gas pipe needs to be connected.

Indoor unit	Suction gas pipe	Discharge gas pipe	Liquid pipe
22, 28	ø 9.52 × t0.8	ø 6.35 × t0.8	ø 6.35 × t0.8
36, 45, 56	ø 12.7 × t0.8	ø 9.52 × t0.8	
71, 80, 90, 112, 140	ø 15.88 × t1.0	ø 12.7 × t0.8	ø 9.52 × t0.8
224	ø 19.05 × t1.0	ø 15.88 × t1.0	
280	ø 22.22 × t1.0	ø 19.05 × t1.0	

5) Selection of an outdoor unit side branch pipe set

This branch pipe set will always become necessary when units are used in combination. (When a unit is used as a standalone installation, it is not required.)

Outdoor unit	Branch pipe set
FDCA735~1360HKXE4R	DOS-2A-1
FDCA735~1360HKXRE4R	DOS-2A-1-R

- Notes (1) In connecting an outdoor unit, please use a pipe conforming to the pipe size specified for outdoor unit connection.  
 (2) Choose a different-diameter pipe joint matching a main pipe size specified in the following section in installing pipes (main pipes) on the outdoor unit side.  
 (3) Always install branching joints (for both gas and liquid) in such a manner that they form either correct horizontal or vertical branch.

- Branch pipe set shapes  
KX series

Model	Item	Branch pipe	Item	Branch pipe
DOS-2A-1	Gas line		Liquid line	

KXR series


Model	Item	Branch pipe	Item	Branch pipe	Item	Branch pipe
DOS-2A-1-R	Suction gas line		Discharge gas line		Liquid line	

6) Selecting the piping size of combined outdoor units.

a) KX series

#### Model FDCA735HKXE4R


Combination: FDCA335HKXE4R-K + FDCA400HKXE4R  
[Branch piping Set: DOS-2A-1]



If the main pipe exceeds 90m in length (actual length),  
\*1 becomes ø38.1 and \*2 becomes ø19.05.

#### Model FDCA800HKXE4R


Combination: FDCA400HKXE4R + FDCA400HKXE4R  
[Branch piping Set: DOS-2A-1]



If the main pipe exceeds 90m in length (actual length),  
\*1 becomes ø38.1 and \*2 becomes ø19.05.

#### Model FDCA850HKXE4R


Combination: FDCA400HKXE4R + FDCA450HKXE4R  
[Branch piping Set: DOS-2A-1]



If the main pipe exceeds 90m in length (actual length),  
\*1 becomes ø38.1 and \*2 becomes ø19.05.

#### Model FDCA900HKXE4R


Combination: FDCA450HKXE4R + FDCA400HKXE4R  
[Branch piping Set: DOS-2A-1]



If the main pipe exceeds 90m in length (actual length),  
\*1 becomes ø38.1 and \*2 becomes ø19.05.

**Model FDCA960HKXE4R**


Combination: FDCA450HKXE4R + FDCA504HKXE4R  
 [Branch Piping Set: DOS-2A-1]



If the main pipe exceeds 90m in length (actual length),  
 \*1 becomes ø19.05.

**Model FDCA1010HKXE4R**


Combination: FDCA504HKXE4R + FDCA504HKXE4R  
 [Branch Piping Set: DOS-2A-1]



If the main pipe exceeds 90m in length (actual length),  
 \*1 becomes ø22.22.

**Model FDCA1065HKXE4R**


Combination: FDCA504HKXE4R + FDCA560HKXE4R  
 [Branch Piping Set: DOS-2A-1]



If the main pipe exceeds 90m in length (actual length),  
 \*1 becomes ø22.22.

**Model FDCA1130HKXE4R**


Combination: FDCA560HKXE4R + FDCA560HKXE4R  
 [Branch Piping Set: DOS-2A-1]



If the main pipe exceeds 90m in length (actual length),  
 \*1 becomes ø22.22.

**Model FDCA1180HKXE4R**


Combination: FDCA560HKXE4R + FDCA615HKXE4R  
 [Branch Piping Set: DOS-2A-1]



If the main pipe exceeds 90m in length (actual length),  
 \*1 becomes ø22.22.

**Model FDCA1235HKXE4R**


Combination: FDCA615HKXE4R + FDCA615HKXE4R  
 [Branch Piping Set: DOS-2A-1]



If the main pipe exceeds 90m in length (actual length),  
 \*1 becomes ø22.22.

**Model FDCA1300HKXE4R**


Combination: FDCA615HKXE4R + FDCA680HKXE4R  
 [Branch Piping Set: DOS-2A-1]



If the main pipe exceeds 90m in length (actual length),  
 \*1 becomes ø22.22.

**Model FDCA1360HKXE4R**

Combination: FDCA680HKXE4R + FDCA680HKXE4R  
 [Branch Piping Set: DOS-2A-1]



If the main pipe exceeds 90m in length (actual length),  
 \*1 becomes ø22.22.


Note (1) Values in ( ) show piping sizes in the case that models for Europe are used.

(2) If a ø34.92 piping size is used in Europe, branch piping is necessary. Please procure the necessary piping locally.

## 7) KXR series

### Model FDCA735HKXRE4R


Combination: FDCA335HKXRE4R-K + FDCA400HKXRE4R  
[Branch Piping Set: DOS-2A-1-R]



If the main pipe exceeds 90m in length (actual length),  
\*1 becomes ø19.05.

### Model FDCA850HKXRE4R


Combination: FDCA400HKXRE4R + FDCA450HKXRE4R  
[Branch Piping Set: DOS-2A-1-R]



If the main pipe exceeds 90m in length (actual length),  
\*1 becomes ø19.05.

### Model FDCA960HKXRE4R


Combination: FDCA450HKXRE4R + FDCA504HKXRE4R  
[Branch Piping Set: DOS-2A-1-R]



If the main pipe exceeds 90m in length (actual length),  
\*1 becomes ø19.05.

### Model FDCA800HKXRE4R


Combination: FDCA400HKXRE4R + FDCA400HKXRE4R  
[Branch Piping Set: DOS-2A-1-R]



If the main pipe exceeds 90m in length (actual length),  
\*1 becomes ø19.05.

### Model FDCA900HKXRE4R


Combination: FDCA450HKXRE4R + FDCA450HKXRE4R  
[Branch Piping Set: DOS-2A-1-R]



If the main pipe exceeds 90m in length (actual length),  
\*1 becomes ø19.05.

### Model FDCA1010HKXRE4R


Combination: FDCA504HKXRE4R + FDCA504HKXRE4R  
[Branch Piping Set: DOS-2A-1-R]



If the main pipe exceeds 90m in length (actual length),  
\*1 becomes ø19.05.

**Model FDCA1065HKXRE4R**


Combination: FDCA504HKXRE4R + FDCA560HKXRE4R  
 [Branch Piping Set: DOS-2A-1-R]



If the main pipe exceeds 90m in length (actual length),  
 \*1 becomes ø22.22.

**Model FDCA1130HKXRE4R**


Combination: FDCA560HKXRE4R + FDCA560HKXRE4R  
 [Branch Piping Set: DOS-2A-1-R]



If the main pipe exceeds 90m in length (actual length),  
 \*1 becomes ø22.22.

**Model FDCA1180HKXRE4R**


Combination: FDCA560HKXRE4R + FDCA615HKXRE4R  
 [Branch Piping Set: DOS-2A-1-R]



If the main pipe exceeds 90m in length (actual length),  
 \*1 becomes ø22.22.

**Model FDCA1235HKXRE4R**


Combination: FDCA615HKXRE4R + FDCA615HKXRE4R  
 [Branch Piping Set: DOS-2A-1-R]



If the main pipe exceeds 90m in length (actual length),  
 \*1 becomes ø22.22.

**Model FDCA1300HKXRE4R**


Combination: FDCA615HKXRE4R + FDCA680HKXRE4R  
 [Branch Piping Set: DOS-2A-1-R]



If the main pipe exceeds 90m in length (actual length),  
 \*1 becomes ø22.22.

**Model FDCA1360HKXRE4R**

Combination: FDCA680HKXRE4R + FDCA680HKXRE4R  
 [Branch Piping Set: DOS-2A-1-R]



If the main pipe exceeds 90m in length (actual length),  
 \*1 becomes ø22.22.

8) Selection of on indoor unit side branching pipe set

Method of selecting a branching pipe set

- As an appropriate branching pipe size varies with the connected capacity (total capacity connected downstream), determine a size from the following table.

a) KX series

Total capacity downstream	Branching pipe set
Less than 180	DIS-22-1
180 or more but less than 371	DIS-180-1
371 or more but less than 540	DIS-371-1
540 or more	DIS-540-1

b) KXR series

- In the upstream of a branching controller

Total capacity downstream	Branching pipe set model type
Less than 180	DIS-22-1-R
180 or more but less than 371	DIS-180-1-R
371 or more but less than 540	DIS-371-1-R
540 or more	DIS-540-1-R

- In the downstream of a branching controller



















Total capacity downstream	Branching pipe set model type
Less than 180	DIS-22-1
180 or more but less than 371	DIS-180-1
371 or more but less than 540	DIS-371-1
540 or more	DIS-540-1

Notes (1) In connecting an indoor unit with the indoor unit side branching pipe set, please use a pipe conforming to the pipe size specified for indoor unit connection.

(2) Always install branching joints (for suction gas, discharge gas and liquid) in such a manner that they form either correct horizontal or vertical branch.

- Branch pipe set shapes

Unit: mm

Model	Item	Branch pipe	Reducer	Item	Branch pipe	Reducer
DIS-22-1	Gas line		—	Liquid line		—
DIS-180-1	Gas line		  	Liquid line		—
DIS-371-1	Gas line		  	Liquid line		—
DIS-540-1	Gas line		  	Liquid line		











Notes: (1) Insulation is provided with the branch pipes.

(2) Pipes should be cut to the installation site requirements, with the pipe being severed at the center part of the desired diameter.

(3) Branch joints (gas & liquid) must be installed as either a "horizontal branch" or a "vertical branch".

- Branch pipe set shapes

Unit: mm

Model Item	DIS-22-1-R	DIS-180-1-R
Suction gas line		
		
Discharge gas line		
		
Liquid line		

- Notes: (1) Insulation is provided with the branch pipes.  
 (2) Pipes should be cut to the installation site requirements, with the pipe being severed at the center part of the desired diameter.  
 (3) Branch joints (gas & liquid) must be installed as either a "horizontal branch" or a "vertical branch".



Unit: mm

Model Item	DIS-371-1-R	DIS-540-1-R
Suction gas line		
	<p>Reducer</p>	<p>Reducer</p>
Discharge gas line		
	<p>Reducer</p>	<p>Reducer</p>
Liquid line		
	<p>Reducer</p>	<p>Reducer</p>

- Notes: (1) Insulation is provided with the branch pipes.  
(2) Pipes should be cut to the installation site requirements, with the pipe being severed at the center part of the desired diameter.  
(3) Branch joints (gas & liquid) must be installed as either a "horizontal branch" or a "vertical branch".

#### 9) Header Method (KX series only)

- Depending on the number of units connected, connect plugged pipes (to be procured on the installer's part) at a branching point (on the indoor unit connection side).
- For determination of appropriate header, different diameter pipe joint and blind pipe sizes, please refer to "Header Set," (which can be purchased separately).

Total capacity downstream	Header set model type	Number of branches
Less than 180	HEAD4-22-1	4 branches at the most
180 or more but less than 371	HEAD6-180-1	6 branches at the most
371 or more but less than 540	HEAD8-371-1	8 branches at the most
540 or more	HEAD8-540-1	8 branches at the most

- Header pipe set shapes

Unit: mm

Model	Item	Header pipe	Reducer	Item	Header pipe
HEAD4-22-1	Gas line			Liquid line	
HEAD6-180-1	Gas line			Liquid line	
HEAD8-371-1	Gas line			Liquid line	
HEAD8-540-1	Gas line			Liquid line	

- Notes: (1) Insulation is provided with the branch pipes.  
 (2) Pipes should be cut to the installation site requirements, with the pipe being severed at the center part of the desired diameter.  
 (3) Branch joints (gas & liquid) must be installed as either a "horizontal branch" or a "vertical branch".  
 (4) Indoor units 224 and 280 can not connected to the header.

#### 10) Selection of a branching controller (KXR series only)

- Selection an appropriate one according to the combined total capacity of the indoor units connected downstream.
- The number of indoor units that can be connected to branching controllers are depicted in the below.
- No liquid pipe needs to be connected to a branching controller.
- In the downstream of a branching controller, no gas discharge pipe needs to be connected.
- Do not run the unit, while a branching unit is yet to be connected with indoor units.

Total capacity downstream	Branching controller model type	Number of connectable units
Less than 112	PFD112-ER	1~5
112 or more but less than 180	PFD180-ER	1~8
180 or more but 280 or more	PFD280-ER	1~10

## 11) Integrated branching controller(KXR series only)

### a) Before beginning installation




- ① Indoor units "should not be connected" to a branching controller, when they exceed a range specified for either combined total capacity or number in the table below.

Branching controller model	Total of four branches		Per branch	
	Capacity restrictions	Maximum number of units connectable	Capacity restrictions	Maximum number of units connectable
PFD112X4-ER	Less than 371	16 units	Less than 112	5 units

Notes (1) **When multiple indoor units are connected to one branch, use one remote controller for control, or enable remote control sensor.**

- (2) When there is any branch that is not connected with an indoor unit, securely tighten the flare at the refrigerant piping connection port, or make use from the right side (from No. 4 circuit) towards the connection port.  
 (3) An indoor unit with a capacity up to 112 can be connected.

### ② Make sure that no accessory is missing.

Different diameter pipe joint		Flange joint
For outdoor unit - gas discharge pipe For indoor unit gas pipe	For outdoor unit - gas discharge pipe	For outdoor unit - gas discharge pipe
<b>A</b> 	<b>B</b> 	


### b) Installation of a branching controller

#### ① Selecting the installation location.

- A branching controller sometimes generates noises during control operations whether the system is in operation or stands still. When it is installed in a place with a low background noise level, please take appropriate precautions such as installing it away from the indoor unit.
- The position where you can install refrigerant pipes within the specified restrictions on length.
- The position where you can install hanger bolts and secure a required level of strength.  
(The position where pulling force of 20 kg per bolt is endured)
- The position where a service space conforming to the requirements shown in the drawing on the right can be secured.

Notes (1) Do not fail to provide an inspection port at the specified position.

- (2) A branching controller cannot be installed upside down.  
 Please install it in such a manner that the main body is held level.




Notes (1) Heat insulating materials are supplied with the unit. Please use them.

- (2) Please cut off a pipe suitably on the installation site at the middle of a section of a diameter to be used.  
 (3) Please install a header in such a manner that it will branch horizontally.

#### ② The positions of hanger bolts.

Use four M10 bolts for the hanging bolts. (to be procured from a local supplier)  
 Please fasten securely as illustrated in the drawing below.



When you install the main body, but you cannot position it properly to the opening of the ceiling, please adjust the position by moving it along a fixing metal's oblong hole.



### ③ Cautions when carrying a unit.

- In carrying the unit, please hold it by the hooks. Holding pipes can result in pipe deformation and unit failure.
- Do not put your hand in the notch area for fear that you should get hurt.
- Since the unit is heavy (30kg), take care in handling it.

### c) Refrigerant piping


- A branching controller has on its main body beneath the connection ports such indications as “S.G (OUT),” “D.G (OUT)” and “I.G (IN)” provided for the outdoor unit gas suction pipe, the outdoor unit gas discharge pipe and indoor unit gas pipes respectively, so please make sure that you connect correct pipes to correct ports.
- No liquid pipe needs to be connected to a branching controller.
- In connecting pipes to a branching controller or an indoor unit, always tighten a flare joint with two spanners applied at a time.
- Please use a flange joint supplied with the unit to connect an intake gas pipe. Tighten two bolts evenly with a gasket for flange connection inserted securely in the middle.  
(Fastening torque: 35 +/- 4N-m)

\* observe the following tightening torque in tightening a flare nut.

Ø6.35	14~18(N-m)
Ø9.52	34~42(N-m)
Ø12.7	49~61(N-m)
Ø15.88	68~82(N-m)


### ① Refrigerant pipe connection.

- Please heat-insulate a pipe connection with a pipe cover or a flange cover supplied with the unit without fail.



### d) Electrical wiring work

- Please implement cabling according to the instructions contained in the drawing below.




Notes (1) Please connect a signal wire from a relay kit to the connector of the same connection port number with the coolant pipe.

- (2) Please connect the power cable of a branching controller to the indoor unit's unit CnU. (at one place)
- (3) Do not extend the signal wire between an indoor unit and a relay kit beyond a 2 m cable supplied as an accessory.
- (4) To extend signal cables connecting between a relay kit and a branching controller and a power cable connecting between an indoor unit and a branching controller, please use the cables specified below. In extending these cables, make sure that the consistency of cable colors is maintained. (When you extend signal and power cables, do not forget to extend a grounding wire accordingly as well.)

Signal wire	2.0/2.0(mm <sup>2</sup> ) × 4(pieces)
Power wire	2.0/2.0(mm <sup>2</sup> ) × 2(pieces)

○ Appearance drawing of a relay kit



- (5) Please connect the earth wire from a branching controller to an indoor unit and relay kits.
- (6) Please fix a relay kit with 2 screws (to be procured on the installer's part) on the back of the ceiling or a wall in the proximity of an indoor unit.
- (7) When installation work is completed, please check the above-mentioned points for any connection errors.

### Example of piping

#### ◆ KX series


#### ■ Branch system

Outdoor unit: FDCA335HKXE4R

Indoor unit: Combination of 8 units

[Branch pipe set : DIS-371-1 × 1 set, DIS-180-1 × 4 set, DIS-22-1 × 2 set]

[Total capacity: 433]



#### • Selecting piping size

Item	Selection procedure	Piping size (mm)	
		Gas line	Liquid line
A	Same as the outdoor unit piping size	ø25.4	ø12.7
B	Total capacity of the connected indoor units 321	ø19.05	ø12.7
C	Total capacity of the connected indoor units 285	ø19.05	ø12.7
D	Total capacity of the connected indoor units 249	ø19.05	ø12.7
E	Total capacity of the connected indoor units 213	ø19.05	ø12.7
F	Total capacity of the connected indoor units 142	ø15.88	ø9.52
G	Total capacity of the connected indoor units 112	ø15.88	ø9.52
a	Indoor unit piping size (56).	ø12.7	ø6.35
b	Indoor unit piping size (56).	ø12.7	ø6.35
c	Indoor unit piping size (36).	ø12.7	ø6.35
d	Indoor unit piping size (36).	ø12.7	ø6.35
e	Indoor unit piping size (36).	ø12.7	ø6.35
f	Indoor unit piping size (71).	ø15.88	ø9.52
g	Indoor unit piping size (71).	ø15.88	ø9.52
h	Indoor unit piping size (71).	ø15.88	ø9.52

#### • Selection of branch piping size.

Item	Selection procedure	Branch piping set
Branch piping 1	Total capacity of the connected indoor units 433	DIS-371-1
Branch piping 2	Total capacity of the connected indoor units 321	DIS-180-1
Branch piping 3	Total capacity of the connected indoor units 285	DIS-180-1
Branch piping 4	Total capacity of the connected indoor units 249	DIS-180-1
Branch piping 5	Total capacity of the connected indoor units 213	DIS-180-1
Branch piping 6	Total capacity of the connected indoor units 142	DIS-22-1
Branch piping 7	Total capacity of the connected indoor units 112	DIS-22-1


Notes (1) Make the selection based on the size of each piping for branch piping sets with different size connections.

(2) If diameter adjustment is need for branch connection and on the indoor unit side, always makes the adjustment at the branch connection.

Notes (1) Use the designated piping size for the piping between the outdoor unit and the first branch.

(2) Choose the appropriate sized reducer for piping between the branch pipe and the indoor unit.  
The size of reducer should match the piping size of the indoor unit.

(3) Locate the branch pipe horizontally or vertically as illustrated on the right.




## ■ Header system

Outdoor unit: FDCA335HKXE4R

Indoor unit: Combination of 8 units

[ Header pipe set : HEAD8-371-1 × 1 set]

[Total capacity: 416]




### • Selecting piping size

Item	Selection procedure	Piping size (mm)	
		Gas line	Liquid line
A	Same as the outdoor unit piping size	ø25.4	ø12.7
a	Indoor unit piping size (90)	ø15.88	ø9.52
b	Indoor unit piping size (90)	ø15.88	ø9.52
c		ø12.7	ø6.35
d	Indoor unit piping size (36)	ø12.7	ø6.35
e			
f			
g			
h			

### • Selection header pipe size

Item	Selection point	Model
Header	Total indoor unit capacity	HEAD8-371-1

Remarks1. Install the header so that both the gas pipe and liquid pipe are horizontal and so that branches are horizontal.



2. It is not necessary to install a trap in the stand pipe.

Notes(1) Select the appropriate size of each pipe for the offset pipe joints included with the header set.

(2) If it is necessary to adjust the diameter of the header and indoor unit side piping, be sure to do so on the header side.

## Example of piping


### ■ Branch system (When piping length exceeds 90m)

Outdoor unit: FDCA450HKXE4R

Indoor unit: Combination of 8 units

[Branch pipe set : DIS-540-1 × 1 set, DIS-371 × 3 set, DIS-180 × 2 set, DIS-22-1 × 1 set]

[Total capacity: 556]



#### • Selecting piping size

Item	Selection procedure	Piping size (mm)	
		Gas line	Liquid line
A	Outdoor unit side piping size(see page 664)	ø31.8	ø12.7
B	Total capacity of the connected indoor units 444	ø25.4	ø12.7 ※1
C	Total capacity of the connected indoor units 408	ø25.4	ø12.7 ※2
D	Total capacity of the connected indoor units 372	ø25.4	ø12.7 ※3
E	Total capacity of the connected indoor units 336	ø19.05	ø12.7
F	Total capacity of the connected indoor units 224	ø19.05	ø12.7
G	Total capacity of the connected indoor units 112	ø15.88	ø9.52
a	Indoor unit piping size (56).	ø12.7	ø6.35
b	Indoor unit piping size (56).	ø12.7	ø6.35
c	Indoor unit piping size (36).	ø12.7	ø6.35
d	Indoor unit piping size (36).	ø12.7	ø6.35
e	Indoor unit piping size (36).	ø12.7	ø6.35
f	Indoor unit piping size (112).	ø15.88	ø9.52
g	Indoor unit piping size (112).	ø15.88	ø9.52
h	Indoor unit piping size (112).	ø15.88	ø9.52

Note (1) Piping sizes for ※1, ※2, ※3 are as follows: When the total indoor unit capacity is 444 for ※1, 408 for ※2, and 372 for ※3, the gas side will be ø 25.4 and the liquid side will be ø15.88. Because the upstream liquid side is ø12.7, however, an adjustment must be made upstream.

#### • Selection of branch piping size.

Item	Selection procedure	Branch piping set
Branch piping 1	Total capacity of the connected indoor units 556	DIS-540-1
Branch piping 2	Total capacity of the connected indoor units 444	DIS-371-1
Branch piping 3	Total capacity of the connected indoor units 408	DIS-371-1
Branch piping 4	Total capacity of the connected indoor units 372	DIS-371-1
Branch piping 5	Total capacity of the connected indoor units 336	DIS-180-1
Branch piping 6	Total capacity of the connected indoor units 224	DIS-180-1
Branch piping 7	Total capacity of the connected indoor units 112	DIS-22-1


Notes (1) Make the selection based on the size of each piping for branch piping sets with different size connections.

(2) If diameter adjustment is need for branch connection and on the indoor unit side, always makes the adjustment at the branch connection.

Notes (1) Use the designated piping size for the piping between the outdoor unit and the first branch.

(2) Choose the appropriate sized reducer for piping between the branch pipe and the indoor unit.  
The size of reducer should match the piping size of the indoor unit.

(3) Locate the branch pipe horizontally or vertically as illustrated to the right.



◆ KXR series


■ Branch system (Total piping length: 120 m)

Outdoor unit: FDCA450HKXRE4R

Indoor unit: Combination of 8 units

[Branch pipe set : DIS-540-1-R × 1 set, DIS-371-1-R × 3 set, DIS-180-1 × 2 set]

[Total capacity: 583]



• Selecting piping size

Item	Selection procedure	Piping size (mm)		
		Suction gas line	Discharge gas line	Liquid line
A	Outdoor unit side piping size (see page 664)	ø28.58	ø22.22	ø12.7
B	Total capacity of the connected indoor units 538	ø28.58	ø22.22	ø12.7
C	Total capacity of the connected indoor units 493	ø28.58	ø22.22	ø12.7
D	Total capacity of the connected indoor units 448	ø28.58	ø22.22	ø12.7
E	Total capacity of the connected indoor units 224	ø19.05	ø15.88	ø12.7
F	Total capacity of the connected indoor units 224	ø19.05	ø15.88	ø12.7
a	Indoor unit piping size (45).	ø12.7	ø6.35	
b	Indoor unit piping size (45).			
c	Indoor unit piping size (45).			
d	Indoor unit piping size (112).	ø15.88	ø9.52	
e	Indoor unit piping size (112).			
f	Indoor unit piping size (112).			
g	Indoor unit piping size (112).			

Notes (1) The sizes of piping marked \* are indoor unit total capacity: 538 for \*1, 493 for \*2 and 448 for \*3, and ø15.88 on the liquid line side in the case of downstream. However, since the liquid line side upstream pipe is ø12.7, it matches with that.

• Selection of branch piping size.


Item	Selection procedure	Branch piping set
Branch piping 1	Total capacity of the connected indoor units 583	DIS-540-1-R
Branch piping 2	Total capacity of the connected indoor units 538	DIS-371-1-R
Branch piping 3	Total capacity of the connected indoor units 493	DIS-371-1-R
Branch piping 4	Total capacity of the connected indoor units 448	DIS-371-1-R
Branch piping 5	Total capacity of the connected indoor units 224	DIS-180-1
Branch piping 6	Total capacity of the connected indoor units 224	DIS-180-1

Notes (1) Make the selection based on the size of each piping for branch piping sets with different size connections.  
(2) If diameter adjustment is need for branch connection and on the indoor unit side, always makes the adjustment at the branch connection.

Item	Selection procedure	Branching controller model
Branch controller 1	Total capacity of the connected indoor units 45	PFD112-ER
Branch controller 2	Total capacity of the connected indoor units 45	PED112-ER
Branch controller 3	Total capacity of the connected indoor units 45	PED112-ER
Branch controller 4	Total capacity of the connected indoor units 224	PED280-ER
Branch controller 5	Total capacity of the connected indoor units 224	PED280-ER


Notes (1) Please select appropriate irregular joints for the branch controller (PFD112-ER, 280-ER) according to the pipe sizes to each indoor unit.

- Notes (1) Use the designated piping size for the piping between the outdoor unit and the first branch.  
(2) Choose the appropriate sized reducer for piping between the branch pipe and the indoor unit. The size of reducer should match the piping size of the indoor unit.  
(3) Locate the branch pipe horizontally or vertically as illustrated to the below.






**■ Integrated branching controller (Total piping length: 80 m)**  
**Outdoor unit: FDCA450HKXRE4R**  
**Indoor unit: Combination of 8 units**  
**[Branch pipe set : DIS-180-1-R × 1 set, DIS-22-1 × 2 set]**  
**[Total capacity: 280]**



• Selecting piping size

Item	Selection procedure	Piping size (mm)		
		Suction gas line	Discharge gas line	Liquid line
A	Outdoor unit side piping size	ø28.58	ø22.22	ø12.7
B	Total capacity of the connected indoor units 280	ø19.05	ø15.88	ø12.7
C	Total capacity of the connected indoor units 192	ø19.05	ø15.88	ø12.7
D	Total capacity of the connected indoor units 84	ø12.7	ø9.52	ø9.52
E	Total capacity of the connected indoor units 56	ø12.7	ø9.52	ø9.52
a	Indoor unit piping size (36).	ø12.7	ø9.52	ø6.35
b	Indoor unit piping size (36).			
c	Indoor unit piping size (36).			
d	Indoor unit piping size (22).			
e	Indoor unit piping size (22).			
f	Indoor unit piping size (22).			
g	Indoor unit piping size (22).			
h	Indoor unit piping size (28).			
i	Indoor unit piping size (28).			
j	Indoor unit piping size (28).			

- Notes (1) Use the designated piping size for the piping between the outdoor unit and the first branch.
- (2) Choose the appropriate sized reducer for piping between the branch pipe and the indoor unit. The size of reducer should match the piping size of the indoor unit.
- (3) Locate the branch pipe horizontally or vertically as illustrated to the below.



• Selection of branch piping size.

Item	Selection procedure	Branch piping set
Branch piping 1	Total capacity of the connected indoor units 280	DIS-180-1-R
Branch piping 2	Total capacity of the connected indoor units 84	DIS-22-1
Branch piping 3	Total capacity of the connected indoor units 56	DIS-22-1


- Notes (1) Make the selection based on the size of each piping for branch piping sets with different size connections.
- (2) If diameter adjustment is need for branch connection and on the indoor unit side, always makes the adjustment at the branch connection.

## (d) Piping work


### (i) On-site piping work

#### 1) Important

- Please take care so that installed pipes may not touch components within a unit.
- Keep service valves closed while pipe installation work is underway.
- Give sufficient protections (compressed and brazed or by an adhesive tape) to pipe ends so that any water or foreign matters enter the pipes.
- In bending a pipe, bend it to the largest possible radius (at least four times the pipe diameter). Do not bend a pipe repeatedly to correct its form.
- Pipes are to be flare connected at the following points : between an outdoor unit's liquid pipe and liquid refrigerant piping and between a branching controller and refrigerant piping. Flare a pipe after engaging a flare nut onto it. A flare size for R410A is different from that for conventional R407C. Although we recommend the use of flaring tools developed specifically for R410A, conventional flaring tools can also be used by adjusting the measurement of protrusion B with a protrusion control gauge.
- As it is a unit designed for R410A, the use of ester oil as flare joint oil is recommended.
- Tighten a flare joint securely with double spanners. Observe flare nut tightening torque specified in the table below.




Flared pipe end: A (mm)	
Copper pipe outer diameter	A
	0 -0.4
ø6.35	9.1
ø9.52	13.2
ø12.7	16.6
ø15.88	19.7




Copper pipe protrusion for flaring: B (mm)		
Copper pipe outer diameter	In the case of a rigid (clutch) type	
	With an R410A tool	With a conventional tool
ø6.35	0~0.5	0.7~1.3
ø9.52		
ø12.7		
ø15.88		

Tightening torque	
ø6.35	14 ~ 18N·m (1.4 ~ 1.8 kg·m)
ø9.52	34 ~ 42N·m (3.4 ~ 4.2 kg·m)
ø12.7	49 ~ 61N·m (4.9 ~ 6.1 kg·m)
ø15.88	68 ~ 82N·m (6.8 ~ 8.2 kg·m)


- Pipes are to be brazed to connect an outdoor unit's gas pipe with refrigerant piping or refrigerant piping with a branching pipe set.
  - Brazing must be performed under a nitrogen gas flow. Without nitrogen gas, a large quantity of foreign matters (oxidized film) are created, causing a critical failure from capillary tube or expansion valve clogging.
  - Brazing of the service valve and the pipes should be performed while cooling the valve body with a wet towel.
  - Perform flushing. To flush the piping, charge nitrogen gas at about 0.02 MPa with a pipe end closed with a hand. When pressure inside builds up to a sufficient level, remove the hand to flush. (in flushing a pipe, close the other end of the pipe with a plug).
- 2) Operation procedure
- Brazing must be performed under a nitrogen gas flow. Without nitrogen gas, a large quantity of foreign matters (oxidized film) are created, causing a critical failure from capillary tube or expansion valve clogging.



- Give sufficient protections (compressed and brazing or with an adhesive tape) so that water or foreign matters may not enter the piping.



- c) Perform flushing. To flush the piping, charge nitrogen gas at about 0.02 MPa with a pipe end closed with a hand. When pressure inside builds up to a sufficient level, remove the hand to flush. (in flushing a pipe, close the other end of the pipe with a plug).




- d) In laying pipes on the installation site, keep the service valves shut all the time.  
e) In brazing an service valve and a pipe, braze them by cooling the valve main body with a wet towel or the like.

## (ii) Air tightness test

### ◆ KX series

- 1) Although an outdoor unit itself has been tested for air tightness at the factory, please check the connected pipes and indoor units for air tightness from the check joint of the service valve on the outdoor unit side. While conducting a test, keep the service valve shut all the time.
- 2) Since refrigerant piping is pressurized to the design pressure of a unit with nitrogen gas for testing air tightness, please connect instruments according the drawing below.  
Under no circumstances should chlorine-based refrigerant, oxygen or any other combustible gas be used to pressurize a system keep the service valve shut all the time. Do not open it under any circumstances.  
Pressurize all of the liquid, gas and oil equalizing pipes.
- 3) In pressurizing the piping, do not apply the specified level of pressure all at once, but gradually raise pressure.
  - a) Raise the pressure to 0.5 MPa, and stop. Leave it for five minutes to see if the pressure drops.
  - b) Then raise the pressure to 1.5 MPa, and stop. Leave it for five more minutes to see if the pressure drops.
  - c) Then raise the pressure to the specified level (4.15 MPa), and record the ambient temperature and the pressure.
  - d) If no pressure drop is observed with an installation pressurized to the specified level and left for about one day, It is acceptable. When the ambient temperature changes 1°C, the pressure also changes approximately 0.01 MPa. The pressure, if changed, should be compensated for.
  - e) If a pressure drop is observed in checking e) and a) - d), a leak exists somewhere. Find a leak by applying bubble test liquid to welded parts and flare joints and repair it. After repair, conduct an air-tightness test again.
- 4) Always evacuate the pipes after the airtightness test.




### ◆ KXR series

- 1) Although an outdoor unit itself has been tested for air tightness at the factory, please check the connected pipes and indoor units for air tightness from the check joint of the service valve on the outdoor unit side. While conducting a test, keep the service valve shut all the time.
- 2) Since refrigerant piping is pressurized to the design pressure of a unit with nitrogen gas for testing air tightness, please connect instruments according to the drawing below.

Under no circumstances should chlorine-based refrigerant, oxygen or any other combustible gas be used to pressurize a system keep the service valve shut all the time. Do not open it under any circumstances.

Pressurize all of the liquid and suction gas, discharge gas and oil equalizing pipes.

- 3) In pressurizing the piping, do not apply the specified level of pressure all at once, but gradually raise pressure.
  - a) Raise the pressure to 0.5 MPa, and stop. Leave it for five minutes to see if the pressure drops.
  - b) Then raise the pressure to 1.5 MPa, and stop. Leave it for five more minutes to see if the pressure drops.
  - c) Then raise the pressure to the specified level (4.15 MPa), and record the ambient temperature and the pressure.
  - d) If no pressure drop is observed with an installation pressurized to the specified level and left for about one day, It is acceptable. When the ambient temperature changes 1°C, the pressure also changes approximately 0.01 MPa. The pressure, if changed, should be compensated for.
  - e) If a pressure drop is observed in checking e) and a) - d), a leak exists somewhere. Find a leak by applying bubble test liquid to welded parts and flare joints and repair it. After repair, conduct an air-tightness test again.
- 4) Always evacuate the pipes after the airtightness test.




### (iii) EVACUATION

Please pull air from the check joints of the service valves on both gas and liquid pipe(KX series) or suction and discharge gas(KXR series) sides.

Please also pull air from the oil equalizing pipe. (Please pull air separately from the rest of the piping by using the oil equalizing valve check joint)

<Work flow>



Pay attention to the following points in addition to the above for the R410A and compatible machines.

- To prevent a different oil from entering, please assign dedicated tools, etc. to each refrigerant type. Under no circumstances must a gauge manifold and a charge hose in particular be shared with other refrigerant types (R22, R470C, etc.).
- Use a counterflow prevention adapter to prevent vacuum pump oil from entering the refrigerant system.


### (iv) Method of operating service valves

#### ◆ Models FDCA140HKXEN4R, 140HKXES4R, 160HKXES4R

- 1) When a vacuum air purge is completed, remove the valve rod cap nuts and open the service valves (both liquid and gas sides) as illustrated below. After you have made sure that the valves are in the full-open position, tighten the cap nuts (for the valve rods and charge ports).

##### ► Hexagonal wrench type


Hexagonal Head Wrench  
(Size M4)



- Open the valve rod until it touches the stopper.
- You need not apply force to push it further.
- When an operation is completed, replace the cap nut and tighten it as before.

##### ► Pin type

Remove the hexagon cap nut, set it as illustrated in the drawing below.




- When a pin setting operation is completed, replace the cap nut and tighten it as before.

#### ◆ Models FDCA224~1360HKXE4R, 224~1360HKXRE4R

Method of opening/closing a valve

- 1) Remove the cap, turn the gas pipe side until comes to the "Closed" position as indicated in the drawing on the right.
- 2) For the liquid side pipe and oil equalizing pipe side, turn with a hexagonal wrench until the shaft stops. If excessive force is applied, the valve main body can be damaged. Always use a dedicated special tool.
- 3) Tighten the cap securely.

For tightening torque, refer to the table next page.




- 3) Tighten the cap securely.

For tightening torque, refer to the table below.


	Tightening torque N · m		
	Shaft (valve main body)	Cap (lid)	Cap nut (check joint section)
For gas pipes	7 or less	30 or less	13
For liquid pipes	7.85 (MAX 15.7)	29.4 (MAX 39.2)	8.8 (MAX 14.7)
For oil equalizing pipes	4.9 (MAX 11.8)	16.2 (MAX 24.5)	8.8 (MAX 14.7)

For flare nut tightening torque, please refer to Section (d)–(i) Piping work on the installation site.

#### ◆ KX series



#### ◆ KXR series



#### (v) Additional refrigerant charge

Charge additional refrigerant in the liquid state.

Be sure to use a scale to measure the filling amount when adding refrigerant. If you cannot charge all refrigerant with the outdoor unit lying idle, charge it with the unit running in the test run mode. If operated for a long time with insufficient refrigerant the compressor will be damaged. (In particular, when adding refrigerant during operation, complete the job within 30 min.)

Fill this unit only with the standard amount of refrigerant (piping length 0 m fill quantity).

Determine the amount of refrigerant to be charged additionally using the following formula and put down the amount of refrigerant added on the refrigerant charge volume recording plate provided on the back of the side panel.

- 1) Additional charge amount

Item	Additional charge amount per 1 m of liquid pipe						Factory charge amount at time of shipment	
	ø22.2	ø19.05	ø15.88	ø12.7	ø9.52	ø6.35	Outdoor unit	Remarks
Model								
FDCA140	–	–	–	–	–	–	7.5kg	Supplemental charges unnecessary
FDCA160								
FDCA224	0.35 kg/m	0.25 kg/m	0.17 kg/m	0.11 kg/m	0.054 kg/m	0.022 kg/m	14.2 kg	Additional refrigerant Charge is not required
FDCA280								
FDCA335								
FDCA335-K								
FDCA400							17.0 kg	
FDCA450								
FDCA504								
FDCA560							19.4 kg	
FDCA615								
FDCA680							26.2 kg	

Correction coefficient in accordance with the outdoor unit capacity.(KXR series only)

Outdoor unit capacity	FDCA224~680	FDCA735~1360
A	1.3	1.2

#### Calculation of amount of refrigerant to be charged in local piping

The amount refrigerant additionally charged in local piping depends on connection pipe size but not on indoor unit type.

**[Amount of refrigerant to be charged in the local piping = Actual length of liquid pipe Amount of refrigerant additionally charged per meter of liquid pipe ]**

**[Example] Amount of refrigerant additionally charged = {(  $\ell 1 \times 0.35$ ) + (  $\ell 2 \times 0.25$ ) + (  $\ell 3 \times 0.17$ ) + (  $\ell 4 \times 0.11$ ) + (  $\ell 5 \times 0.054$ ) + (  $\ell 6 \times 0.022$ ) }  $\times A$**

$\ell 1$ : Overall length (m) of  $\phi 22.22$  liquid pipe

$\ell 2$ : Overall length (m) of  $\phi 19.05$  liquid pipe

$\ell 3$ : Overall length (m) of  $\phi 15.88$  liquid pipe

$\ell 4$ : Overall length (m) of  $\phi 12.7$  liquid pipe

$\ell 5$ : Overall length (m) of  $\phi 9.52$  liquid pipe

$\ell 6$ : Overall length (m) of  $\phi 6.35$  liquid pipe


A: Factor determined by the outdoor unit capacity

Pay attention to the following points in addition to the above for the R410A and compatible machines.

- To prevent a different oil from entering, please assign dedicated tools, etc. to each refrigerant type. Under no circumstances must a gauge manifold and a charge hose in particular be shared with other refrigerant types (R22, R470C, etc.).
- Do not use a charge cylinder under any circumstances. There is a danger that the composition of the refrigerant will change when R410A is transferred to a cylinder.
- When charging refrigerant, use liquid refrigerant from a cylinder from liquid side service valve. If refrigerant is charged in a gas form, the composition may change considerably.



### Please note

Put down on the refrigerant charge volume recording plate provided on the back of the side panel the amount of refrigerant calculated from the pipe length and the amount charged.




### (vi) Heating and condensation prevention

- 1) Dress refrigerant pipes (both gas and liquid pipes) for heat insulation and prevention of dew condensation. Improper heat insulation/anti-dew dressing can result in a water leak or dripping causing damage to household effects, etc.
- 2) Use a heat insulating material that can withstand 120°C or a higher temperature. Poor heat insulating capacity can cause heat insulation problems or cable deterioration.
- a) The suction gas pipe can cause during a cooling operation dew condensation, which will become drain water causing a possible water-leak accident, while the discharge gas pipe can reach during a heating operation as high a temperature as 60°C to 110°C, posing a risk of burns, when touched accidentally. So, do not fail to dress them with heat insulation material.
- b) Wrap all flare joints for indoor units and branching controller with heat insulating parts (pipe cover) for heat insulation (both gas and liquid pipes).
- c) Give heat insulation to suction gas and discharge gas pipes and liquid side pipes. Bundle a heat insulating material and a pipe tightly together so that no gaps may be left between them and wrap them together with a connecting cable by a dressing tape.
- d) Although this air conditioning unit has been tested under the ISO condensation test conditions, the dripping of water may occur when it is operated in a high-humidity atmosphere (28°C or a higher dew point temperature). In such a case, apply an additional heat insulation material of 10 to 20 mm thick to dress an indoor unit body, piping and drain pipes.



### (e) Drainage (Model FDCA140 and FDCA160 only)

- 1) Where drain water from the outdoor unit causes problems, implement drain piping with drain elbows and drain grommets, which are supplied separately as option parts.
- 2) There are 3 holes in the bottom panel of the outdoor unit to drain condensation.
- 3) Where condensate is guided to a drain, install the unit on a flat base (an option part supplied separately) or concrete blocks.
- 4) Connect a drain elbow as illustrated and plug the other holes with grommets.





## (5) Electric wiring

Electrical installation work must be performed by an electrical installation service provider qualified by a power provider of the country.

Electrical installation work must be executed according to the technical standards and other regulations applicable to electrical installations in the country.

**⚠ Please install an earth leakage breaker without fail. The installation of an earth leakage breaker is compulsory in order to prevent electric shocks or fire accidents.**

### Please note

① Use only copper wires.

Do not use any supply cord lighter than one specified in parentheses for each type below.

- braided cord (cde designation 60245 IEC 51), if allowed in the relevant part 2;
- ordinary tough rubber sheathed cord (code designation 60245 IEC 53);
- flat twin tinsel cord (code designation 60227 IEC 41)
- ordinary polyvinyl chloride sheathed cord (code designation 60227 IEC 53).

Please do not use anything lighter than polychloroprene sheathed flexible cord (cord designation 60245 IEC 57) for supply cords of parts of appliances for outdoor use.

② Use separate power supplies for the indoor and outdoor units.

③ Ground the unit. Do not connect the grounding wire to a gas pipe, water pipe, lightning rod or telephone grounding wire.

If improperly grounded, an electric shock or malfunction may result.

④ A grounding wire must be connected before connecting the power cable. Provide a grounding wire longer than the power cable.

⑤ The installation of an impulse withstanding type earth leakage breaker is necessary. A failure to install an earth leakage breaker can result in an accident such as an electric shock or a fire. Do not turn on the power until the electrical work is completed. Be sure to turn off the power when servicing.

⑥ Please do not use a condensive capacitor for power factor improvement under any circumstances. (It does not improve power factor, while it can cause an abnormal overheat accident)

⑦ For power supply cables, use conduits.

⑧ Please do not lay electronic control cables (remote control and signaling wires) and other cables together outside the unit. Laying them together can result in malfunctioning or a failure of the unit due to electric noises.


⑨ Power cables and signaling wires must always be connected to the power cable terminal block and secured by cable fastening clamps provided in the unit.

⑩ Fasten cable so that they may not touch the piping etc.

⑪ When cables are connected, please make sure that all electrical components within the electrical component box are free of loose connector coupling or terminal connection and then attach the cover securely. (Improper cover attachment can result in malfunctioning or a failure of the unit, if water penetrates into the box.)

⑫ A grounding wire must be connected before connecting the power cable. Provide a grounding wire longer than the power cable.

### (a) Wiring system diagrams



### (b) Method of connecting power cables

#### (i) Method of leading out cables


- 1) Cables can be laid through the front, right, left (FDCA224~1360 only), bottom or rear (FDCA140, 160 only) casing.
- 2) In wiring on the installation site, cut off a knock-out [ø50 or oblong hole measuring 40 × 80 (FDCA224~1360 only) ] covering a penetration of the casing with nippers.

## (ii) Notabilia in connecting power cables

Power cables must always be connected to the power cable terminal block and clamped outside the electrical component box.

In connecting to the power cable terminal block, use round solderless terminals.

- 1) Use specified wires in wiring, and fasten them securely in such a manner that the terminal blocks are not subject to external force.
- 2) In fastening a screw of a terminal block, use a correct-size drive.  
Fastening a screw of a terminal block with excessive force can break the screw.
- 3) When electrical installation work is completed, make sure that all electrical components within the electrical component box are free of loose connector coupling or terminal connection.



Tightening torque (N·m)		
M4	Terminal block for signal wires	0.68 ~ 0.82
M8	Grounding wire	5.97 ~ 7.25
M12	Power supply terminal block	22.05 ~ 26.46

## (iii) Outdoor unit power supply specifications

Model	Power source	Cable size for power source (mm <sup>2</sup> )	Wire length (m)	Moulded-case circuit breaker (A)		Earth leakage breaker	Earth wire	
				Rated current	Switch capacity		Size (mm <sup>2</sup> )	Screw type
FDCA140	1-phase 2 wire 220/240V 50Hz  3-phase 4 wire 380/415V 50Hz	3.5	13	30	30	30A30mA less than 0.1 sec	2.0	M5
FDCA140		3.5	35	30	30	30A30mA less than 0.1 sec	2.0	M5
FDCA160								
FDCA224		5.5	54	40	50	60A100mA less than 0.1 sec	3.5	M5
FDCA280		5.5	54	40	50	60A100mA less than 0.1 sec	3.5	M5
FDCA335		5.5	54	40	50	60A100mA less than 0.1 sec	3.5	M5
FDCA335-K		14	76	60	60	60A100mA less than 0.1 sec	5.5	M5
FDCA400 ~680		14	76	60	60	60A100mA less than 0.1 sec	5.5	M5

### Please note

- ① The method of laying cables has been determined pursuant to the Japanese indoor wiring regulations (JEAC8001).  
(Please adapt it to the regulations in effect in each country)
- ② In the case of distributed, separate power supply system, the listed data represent those of an outdoor unit.
- ③ For details, please refer to the installation manual supplied with the indoor.

## (iv) Indoor unit power supply specifications

Combined total capacity of indoor units	Cable size for power source (mm <sup>2</sup> )	Wire length (m)	Moulded-case circuit breaker (For ground fault, overload) and short circuit protection	Signal wire size (mm <sup>2</sup> )	
				Outdoor-Indoor	Indoor-Indoor
Less than 7A	2	21	20A100mA less than 0.1 sec	2cores × 0.75-2.0	2cores × 0.75-2.0
Less than 11A	3.5	21	20A100mA less than 0.1 sec		
Less than 12A	5.5	33	20A100mA less than 0.1 sec		
Less than 16A	5.5	24	30A100mA less than 0.1 sec		
Less than 19A	5.5	20	40A100mA less than 0.1 sec		
Less than 22A	8	27	40A100mA less than 0.1 sec		
Less than 28A	8	21	50A100mA less than 0.1 sec		


### Please note

- ① The method of laying cables has been determined pursuant to the Japanese indoor wiring regulations (JEAC8001).  
(Please adapt it to the regulations in effect in each country)
- ② Wire length in the table above is the value for when the indoor unit is connect to the power cable in series also the wire size and minimum length when the power drop is less than 2% are shown. If the current exceeds the value in the table above, change the wire size according to the indoor wiring regulations. (Please adapt it to the regulations in effect in each country)
- ③ For details, please refer to the installation manual supplied with the indoor unit.

### (c) Method of connecting signaling wires


- The signal wires are 5VDC, so absolutely do not connect them to a 220/240V wire. If such a connection is mistakenly made, all the printed circuit boards will be burned out. Signal wires do not have a polarity. Connect them between the indoor and outdoor units, between indoor units, between indoor units, and between the same terminal Nos. (Connection between (A) and (A), (B) and (B).)
- Please use shielded cords for signaling wires. (For grounding of a shielded cord, find a point of connection to the metal casing in the proximity of the terminal block for the AB lines)

Indoor and outdoor signal wires



- (i) The maximum number of indoor units that can be connected in a system is 48 and it is possible to configure outdoor units and/or indoor units as an outdoor or indoor unit group connected with each other with two connecting wires.

- (ii) The signal wires can also be connected using the method shown below.



### (d) Remote controller wiring specifications

- (i) For the remote controller the standard wire is 0.3mm<sup>2</sup>  $\times$  3 cores. The max. length is up to 600m. When the wire is more than 100m long, use the wire shown in the following table.

Length (m)	Wire size
100 to 200	0.5mm <sup>2</sup> $\times$ 3 cores
To 300	0.75mm <sup>2</sup> $\times$ 3 cores
To 400	1.25mm <sup>2</sup> $\times$ 3 cores
To 600	2.0mm <sup>2</sup> $\times$ 3 cores

- (ii) When the remote controller wire runs parallel to another power supply wire or when it is subject to outside noise, such as from a high-frequency device, use shielded wire. (Be sure to ground only one end of the shielded wire.)

### (e) Unit address setting

This control system controls the controllers of more than one air conditioner's outdoor unit, indoor unit and remote control unit through communication control, using the microcomputers built in the respective controllers. Address setting needs to be done for both outdoor and indoor units. Turn on power in the order of the units and then the indoor units. Use 1 minute as the rule of thumb for an interval between them.

## (i) Outdoor unit address setting

In setting an address to an outdoor unit, use the rotary switches for setting an outdoor unit number to be used in communications with indoor units and the dipswitch for master/slave setting. (When an outdoor unit is used as a standalone installation, it is not necessary to set the dipswitch for master/slave setting)

There are rotary switches for outdoor unit number setting and a dipswitch for master/slave setting provided on the controller board.


SW1: Outdoor No. switch (tens digit) [0-4]

SW2: Outdoor No. switch (units digit) [0-9]


SW4-7: Master/slave setting switches

[OFF is for setting as a master unit and ON, a slave unit

The factory setting for shipment is OFF.]




For tens digit



For units digit

By inserting a flat driver (Precision screw drive) into this groove and turn the arrow to point a desired number.

Outdoor unit rotary switches (SW)



Outdoor unit dip switches (SW)

When outdoor units are used in combination, it is essential to specify the master and slave. Set one of the two outdoor units to the master and other to the slave.

(You can whichever one for the master)

### 1) Automatic address setting

Set as follows before power is turned on: Turning on power will cause the address to be registered with the outdoor unit.

- Set the rotary switches for outdoor unit number setting to “49” or “48”, the default setting for shipment.
- Similarly, set the rotary switches for outdoor unit number setting to “49” or “48”, the default setting for shipment, for the master unit used in a combined installation. Dip switch SW4-7 should be set to OFF.
- Similarly, set the rotary switches for outdoor unit number setting to “49” or “48”, the default setting for shipment, for the slave unit used in a combined installation.

Then, set the dipswitch SW4-7 for master/slave setting to ON.

Outdoor unit	SW1	SW2	SW4-7	Address on a network
Master unit	4	8 or 9	OFF	49
Slave unit	4	8 or 9	ON	00

The master unit will be registered as “49” regardless of the SW1 and SW2 setting (48 or 49)

The slave unit will be registered as “00” as indicated in the table above because of the SW4-7 setting.

### 2) Manual or remote control address setting

Set as follows before power is turned on: Turning on power will cause the address to be registered with the outdoor unit.

- Set the rotary switches for outdoor unit number setting to a number within the range of 00 to 47.  
In setting a number, care must be taken so that no duplicating outdoor unit number is assigned in the same network.
- Similarly, set the rotary switches for master outdoor unit number setting to a number within the range of 00 to 47 for the master unit used in a combined installation.
- For the slave unit used in a combined installation, set the rotary switches for outdoor unit number setting to the same number with the master unit and then set the dipswitch SW4-7 for master/slave setting to ON.

Refrigerant system	Outdoor unit	SW1	SW2	SW4-7	Address on a network
A	Master unit	3	2	OFF	32
	Slave unit	3	2	ON	33
B	Master unit	3	4	OFF	34
	Slave unit	3	4	ON	35


This table shows the examples of address settings. The network address of a slave unit is set to the master unit address+1. When the network address of a slave unit exceeds 47, then it will be set from 00 in the ascending order. When successive addresses are set, care must be taken so that an address duplicating with one used for a slave unit in the refrigerant system A is not used for the master unit of refrigerant system B.

## (ii) Indoor unit address setting

In setting an address to an indoor unit, use the switches for setting an indoor unit number to be used in communications with outdoor units and the switches for outdoor unit number setting.

An indoor unit has two sets of switches (four in total) to set indoor unit and outdoor unit numbers.

- SW1: Indoor No. switch (tens digit) [0-4]  
SW2: Indoor No. switch (units digit) [0-9]  
SW3: Outdoor No. switch (tens digit) [0-4]  
SW4: Outdoor No. switch (units digit) [0-9]



### 1) Automatic address setting

Set as follows before power is turned on: Turning on power will cause the address to be registered with the indoor unit.

- Set the rotary switches for indoor unit number setting to “49” or “48”, “49” is the default setting for shipment.
- Set the rotary switches for outdoor unit number setting to “49” or “48”, “49” is the default setting for shipment.

Turn on power in the order of the outdoor units and the indoor units. Use over 1 minute as the rule of thumb for interval between them.

#### Please note

Turn on power to centralized controls when addresses are set.

When power is turned on in the wrong order, a failure to recognize addresses may occur.

### 2) Manual address setting

Set as follows before power is turned on: Turning on power will cause the address to be registered with the indoor unit.

- Set the rotary switches for indoor unit number setting to a number within the range of 00 to 47.  
In setting a number, care must be taken so that no duplicating indoor unit number is assigned in the same network.
- Set the rotary switches for outdoor unit number setting to the corresponding outdoor unit's address number within the range of 00 to 47.

Turn on power in the order of the outdoor units and then the indoor units. Use over 1 minute as the rule of thumb for an interval between them.

#### Please note

You can set addresses when one or more refrigerant systems are connected in a network.

When more than one unit are controlled from a remote control unit, care must be taken so that duplicating indoor unit number is assigned within the group of units placed under the remote control unit.

When the outdoor units are used in combination, set the rotary switches for outdoor unit number setting to the corresponding master outdoor unit's address number within the range of 00 to 47.

### 3) Remote control address setting

Set as follows before power is turned on. (Same as automatic address setting)

- Set the rotary switches for indoor unit number setting to “49” to “48”, “49” is the default setting for shipment.
- Set the rotary switches for outdoor unit number setting to “49” to “48”, “49” is the default setting for shipment.  
After completing of the above-mentioned switch setting, turn on power in the order of the outdoor units and then the indoor units. Use over 1 minute as the rule of thumb for an interval between them.

Press down the “Air conditioner No.” switch of the remote control unit for 3 seconds or longer. “Outdoor No. setting” will appear on the dot display of the remote control unit.

Set an outdoor number by pressing either ▲ or ▼ switch on the remote control unit. When the outdoor number is set, press the “Set” switch of the remote control unit.

This completes outdoor unit number setting, so move to indoor unit number setting. As with outdoor unit number setting, press either ▲ or ▼ switch on the remote control unit to set an indoor unit number

When the indoor number is set, press the “Set” switch of the remote control unit. The number accepted by the remote control unit as an entry blinks on the dot display for about 2 seconds and then the display returns to its normal screen.

#### Please note

You can set address when one or more refrigerant systems are connected in a network.

It is possible when an indoor unit and a remote control unit are connected in a one-to-one configuration. (It is not allowed to control more than one unit from one remote control unit)

When two remote control units are connected to an indoor unit, it is allowed to set from the master remote control unit only.

Address setting is accepted only when the unit is not in operation. Addresses cannot be set from a slave control unit.

#### Please note

Turn on power to centralized controls when addresses are set.

When power is turned on in the wrong order, a failure to recognize addresses may occur.

**(iii) Error indication associated with address setting**

- 1) When more than one module using automatic address setting exist on a network, E31 will be displayed on a remote control unit as an error code indicating a duplicating outdoor unit address.
- 2) When 49 or more indoor units are connected, E2 will be displayed on a remote control unit as an error code indicating a duplicating indoor unit address, because the network bounds to involve a duplicating indoor unit address.
- 3) When addresses set automatically and addresses set with a remote control unit exist on a network, E46 will be displayed on a remote control unit as an error code indicating incorrect address setting.
- 4) When an outdoor unit number that does not exist on the network is specified in remote control address setting, E3 will be displayed on a remote control unit as an error code indicating incorrect pairing of indoor-outdoor units.
- 5) When more than one indoor unit are connected to a remote control unit in remote control address setting, E11 will be displayed on a remote control unit.
- 6) When an indoor unit number that has been registered with the network is specified in remote control address setting, E2 will be displayed on a remote control unit as an error code indicating a duplicating indoor unit address.
- 7) When no unit designated as the master exist in an outdoor unit group, E3 will be displayed on a remote control unit as an error code indicating a network communication error.
- 8) When more than one unit designated as a master exist in an outdoor unit group, E31 will be displayed on a remote control unit an error code indicating incorrect outdoor unit address setting.
- 9) When more than one unit designated as a slave exist in an outdoor unit group, E31 will be displayed on a remote control unit as an error code indicating incorrect outdoor unit address setting.
- 10) When the outdoor units are used in combination and you have forgotten master/slave setting (SW4-7), E31 will be displayed as an error code indicating a duplicating address.

Method for clearing addresses stored in the memory by automatic or remote control address setting.


- Press the “Fan Speed” switch while the “Check” and “Timer” switches are depressed. (Depress three switches at a time) This will clear the addresses stored in the memory.























When the indoor units and outdoor units are turned off and then on again, they will return to the state before address setting, allowing you to set addresses again.

## (6) Setting function with the remote controller




- (a) The factory settings of this unit's functions are as follows: If you want to charge a setting, follow the procedure found in the installation manual and set to your desired setting.

**For the method of setting, please refer to the installation manual of a remote control unit.**

Remote control unit functions (  FUNCTION ▼ )

Function number (A)	Function description (B)	Setting (C)	Factory setting
01	GRILLE ↑↓ SET (Grille lift panel setting)	↑↓ INVALID	○
		50Hz AREA ONLY	
		60Hz AREA ONLY	
02	AUTO RUN SET	AUTO RUN ON	※
		AUTO RUN OFF	
03	 TEMP S/W	 VALID	○
		 INVALID	
04	 MODE S/W	 VALID	○
		 INVALID	
05	 ON/OFF S/W	 VALID	○
		 INVALID	
06	 FANSPEED S/W	 VALID	○
		 INVALID	
07	 LOUVER S/W	 VALID	※
		 INVALID	
08	 TIMER S/W	 VALID	○
		 INVALID	
09	 SENSOR S/W (Remote control sensor setting)	 INSENSOR OFF (Invalid)	○
		 SENSOR ON (Valid)	
10	POWER FAILURE COMPENSATION SET	INVALID	○
		VALID	
11	VENTI SET	NO VENTI	○
		VENTI LINK SET	
		NO VENTI LINK	
12	TEMP RANGE SET	DISP CHARGE	
		NO DISP CHARGE	○
13	I/U FAN SPEED (Indoor unit fan speed setting)	3 FAN SPEED	※
		2 FAN SPEED	
		1 FAN SPEED	
14	MODEL TYPE	HEAT PUMP	※
		COOLING ONLY	
15	EXTERNAL CONTROL SET	INDIVIDUAL OPERATION	○
		SAME OPERATION FOR ALL UNITS	
16	ERROR DISP SET	ERROR DISP	○
		NO ERROR DISP	
17	 POSITION (Louver control setting)	FIX (1 OF 4) (4 position stop)	○
		IN MOTION (Free stop)	
18	°C/°F SET	°C	○
		°F	

Indoor unit functions (I/U FUNCTION ▲ )

Function number (A)	Function description (B)	Setting (C)	Factory setting
01	Hi CEILING SET	STANDARD	○
		Hi CEILING 1	
03	FILTER SIGN SET	NO DISPLAY	
		AFTER 180H	
		AFTER 600H	○
		AFTER 1000H	
04	 POSITION (Louver control setting)	1000H→STOP	
		FIX (1 OF 4) (4 position stop)	○
05	EXTERNAL INPUT SET	IN MOTION (Free stop)	
		LE VEL INPUT	○
06	OPERATION PERMISSION PROHIBITED	PULSE INPUT	○
		NORMAL OPERATION	
07	 ROOM TEMP OFF SET (Heating room temperature off set)	VALID	○
		NORMAL OPERATION	
08	 FAN CONTROL (Heating fan control)	TEMP SHIFT +3°C	
		LOW FAN	※
09	FREEZE PREVENT TEMP	STOP→LOW FAN (Intermittent operation)	
		TEMP Hi	
10	FREEZE PREVENT CONTROL	TEMP Lo	○
		FAN CONTROL ON	○
		FAN CONTROL OFF	

Notes (1) Setting marked with [○] are the default settings.



- (2) Setting marked with [※] are those that are set automatically according to an indoor unit or an outdoor unit connected.

Please check default settings with the indoor unit's installation manual.

Notes (1) Setting marked with [○] are the default settings.

- (2) Setting marked with [※] are those that are set automatically according to an indoor unit or an outdoor unit connected.

Please check default settings with the indoor unit's installation manual.

- (3) When Item 17 “ POSITION” is changed, please also change Item 04 “ POSITION” setting found in “Indoor unit functions.”



## (b) Function setting method

- 1) Stop the air conditioner
- 2) Press the SET and MODE buttons simultaneously for 3 seconds or longer.

The screen display will be switched as follows:

“ SELECT ITEM” → “ SET” → “FUNCTION SET ▼”



- 3) Press the SET button.  
The unit will enter the function setting mode. The screen display will change to “ FUNCTION ▼” (Remote controller unit function)” or “I/U FUNCTION ▲” (Indoor unit function).
- 4) Check which category your desired setting belongs to, “ FUNCTION ▼ (Remote controller unit function)” or “I/U FUNCTION ▲” (Indoor unit function).
- 5) Press either or button.  
Select either “ FUNCTION ▼” or “I/U FUNCTION ▲”.





- 6) Press the SET button.

**When “ FUNCTION ▼” is selected.**

- ① “DATA LOADING” (blinking) → “ FUNCTION” → “GRILLE ↑↓ SET” (Function number: ①, Function description: ②)  
The screen display will be switched like this.
- ② Press either or button.  
“Function number: ①, Function description: ②” from the list of remote controller unit functions will be displayed one by one. Select a desired function.
- ③ Press the SET button.  
The screen display will be switched as follows:  
“ SETTING” → “Setting: ③” (ex. “AUTO RUN ON”)
- ④ Press either or button.  
A list of “Settings: ③” will be displayed one by one. Select your desired setting.
- ⑤ Press the SET button.  
The selected setting is displayed for 2 seconds, then followed by “SET COMPLETE” and the function setting process is completed. Then the screen display will be switched to “Function number: ①, Function description: ②,” so if you want to continue to set another function, repeat the steps as explained above.  
To finish the function setting process, please proceed to Step (c).

\* When “02 AUTO RUN SET” is selected.






**When “I/U FUNCTION ▲” is selected.**

- ① The screen display will be switched as follows:

“ I/U SELECT” → “ SET” → “I/U No.00” (blinking)



- ② Press either or button.

Select the indoor unit number that you want to change settings. If only one indoor unit is connected, the indoor unit number will not change, so please proceed to Step ③.

If “ALL I/U ▼” is selected while indoor group control is in effect, you can set all units to the same settings.

- ③ Press the SET button.

Indoor unit number indication will change from blinking to lit continuously, The screen display will be switched as follows:

“DATA LOADING” (blinking for about 2 to 23 seconds) → “ FUNCTION” → “Hi CEILING SET” (Function number: ①, Function description: ②)

\* When “ Hi CEILING SET” is selected.



- ④ Press either or button.

“Function number: ①, Function description: ②” from the list of indoor unit functions will be displayed one by one. Select a desired function.

- ⑤ Press the SET button.

The screen display will be switched as follows: “ SETTING” → “Setting: ③” (ex. “STANDARD”)



- ⑥ Press either or button.

A list “Setting: ③” will be displayed one by one. Select your desired setting.

- ⑦ Press the SET button.

The selected setting is displayed for 2 seconds, then followed by “SET COMPLETE” and the function setting process is completed.

Then the screen display will be switched to “Function number: ①, Function description: ②” so if you want to continue to set another function, repeat the steps as explained above. To finish the function setting process, please proceed to Step 8.

- ⑧ Press AIR CON No. button.

The screen display will go back to the indoor unit selection screen (ex. “I/U No.00”).

If you want to continue to set another indoor unit, please follow the steps explained above.

**(c) Press the ON/OFF button.**

This ends a function setting process. Even if a function setting process is not completed, this ends the process. Please note that any setting that is not completed will become void.

- **Pressing the RESET button during a function setting process will allow you to go back the previous step.**

**Please note that any setting that is not completed will become void.**

- **Method of checking the current setting**

While following the above mentioned step, the setting that appears when the SET button is pressed for each “Function number: ①, Function description: ②” is the current setting “Setting: ③”. (When “ALL I/U ▼” is selected, the setting of the indoor unit with the lowest number is displayed)

- **Settings are stored in the controller and not lost even a power outage occurs.**

**(d) Changing the remote controller’s temperature setting range**

- 1) The temperature setting range of the remote controller can be changed.

Through remote controller button operations, the upper limit and lower limit set temperature values can be changed individually. During heating operation, the changed upper limit value becomes valid and at times other than during heating operation, (during cooling, dehumidification, auto and fan operation), the changed lower limit value becomes valid.

Range of Possible Changes

Upper Limit Value: 22~30°C (valid during heating) Lower Limit Value: 18 ~ 26°C (valid at times other than during heating)

## 2) Operation

a) With the remote controller in the stopped state, press the SET and MODE buttons simultaneously for 3 seconds or longer.

The display will change from “ SELECT ITEM” → “ SET ” → “FUNCTION SET ”

b) Press the button once. The display will change to “TEMP RANGE .”

c) Press the SET button to enter the temperature range setting mode.

d) Using the or button, select “Hi LIMIT SET ” or “Lo LIMIT SET ,” the press the SET button.

e) If “Hi LIMIT SET” is selected,

① The display changes from “ SET UP ” → “Hi LIMIT 22°C ” (flashing).

② Using the “ TEMP S/W” button, select the upper limit value. Display example: “Hi LIMIT 22°C ” (flashing)

③ Press the SET button to fix the setting. Display example: “Hi LIMIT 22°C” (lighted up)

f) If “Lo LIMIT SET” is selected,

① The display changes from “ SET UP” → “Lo LIMIT 26°C ” (flashing).

② Using the TEMP S/W button, select the upper limit value. Display example: “Lo LIMIT 26°C ” (flashing)

③ Press the SET button to fix the setting. Display example: “Lo LIMIT 26°C” (lighted up)

g) Press the ON/OFF button to end the setting procedure.

(The procedure also ends if the ON/OFF button is pressed during the setting operation. However, settings which have not been fixed become invalid, so exercise caution.)

- If the RESET button is pressed during a setting operation, the display returns to the previously displayed setting screen. However, settings which have not been fixed become invalid, so exercise caution.

\* If “NO DISP CHANGE” is selected in No. 12, “TEMP RANGE SET” of the remote controller’s functions, No. ① of the function setting modes, the remote controller’s display does not change even if the temperature range has been changed.

(Example) If the upper limit is set at 28°C

Function No. A	Function Contents B	Setting Contents C	Control Contents
12	TEMP RANGE SET	DISP CHANGE	The remote controller’s display and sent data upper limit changes to 28°C.
		NO DISP CHANGE	The remote controller’s display upper limit remains at 30°C and only the upper limit of the sent data is changed to 28°C.

## (7) Pump down operation

A pump down operation occurs when specified by Dip Switch settings (SW5-1, 2, 3). (Pump down operation is not possible when indoor units are running.) Connected units should be controlled from the master unit.

### (a) Pump down procedure

- (i) Close the outdoor unit's liquid side control valve.
- (ii) Turn SW5-2 (trial run mode) ON (cooling).
- (iii) Turn SW5-3 (pump down switch) ON.
- (iv) Turn SW5-1 (trial run switch) ON.
- (v) The red and green LEDs on the outdoor control PCB begin to blink continuously, and "PoS" displays at the 7-segment display.

#### Cautions regarding refrigerant recovery by pump down operation

- All refrigerant is not recovered even if a pump down operation is performed. Depending on the piping length or the temperature, some refrigerant will not be recovered, although the residual level will be such that less time is required for a final refrigerant recovery by the recovery unit.
- As a general guideline, a refrigerant recovery is possible by performing a 20kg pump down at 12~16 horsepower.

## (8) Test run

### (a) Before beginning operation

- (i) Measure the electric component terminal and ground with a 500 V megger to check that it is more than 1 MΩ.
- (ii) Be sure to turn on the power to the crank case heater 6 hours before operation.
- (iii) Confirm that the bottom of the compressor has become warm.
- (iv) Be sure to fully open the service valves (liquid, gas and oil equalizing pipe) for the outdoor unit.  
Operating the outdoor unit with the valves closed may damage the compressor.
- (v) Check that the power to all indoor units has been turned on. If not, water leakage may occur.

### (b) Test operation

- (i) Test run from an outdoor unit.

Whether CnS1 is set to ON or OFF, you can start a test run by using the SW5-1 and SW5-2 switches provided on the outdoor unit PCB.

Select the test run mode first.

Please set SW5-2 to ON for a cooling test run or OFF for a heating test run. (It is set to OFF at the factory for shipment)

Turning SW5-1 from OFF to ON next will cause all connected indoor units to start.

When a test run is completed, please set SW5-1 to OFF.

Note During a test run, an indoor unit cannot be operated from the remote control unit (to change settings). ("Under centralized control" is indicated)

- (ii) Carry out the following test operation procedure using the remote controller.

#### 1) Starting the Cooling Test Operation

- ① Press the ON/OFF button to start operation.
- ② Press the MODE button and select "❄️ (COOL)".
- ③ Press the TEST button continuously for 3 seconds or longer.

The display changes from "❄️ SELECT ITEM" → "❄️ SET" → "❄️ TEST RUN ▼".

- ④ When "❄️ TEST RUN ▼" is displayed, press the SET button to begin the cooling test operation. The display shows "❄️ TEST RUN."

#### 2) Canceling the Cooling Test Operation

Pressing the ON/OFF button or the TEMP (▼) (▲) button ends the cooling test operation.

The "❄️ TEST RUN" display is cleared.

### Checking Operation Data

Operation data can be checked with remote controller operation.

- ① Press the CHECK button.

The display change from "❄️ SELECT ITEM" → "❄️ SET" → "OPERATION DATA ▼".

- ② Press the SET button while "OPERATION DATA ▼" is displayed.



- ③ The display will change to "I/U No. 00 ▲" (blinking indication).

Select the indoor unit number you want to have data displayed with the (▲) (▼) button.

(When only one indoor unit is connected, the indoor unit number displayed on the screen will not change)

- ④ Determine the indoor unit number with the SET button.  
 (The indoor unit number changes from blinking indication to continuous indication)  
 “DATA LOADING” (A blinking indication appears while data is loaded)


“OPERATION DATA ◆” appears and data number 01 is displayed.

- ⑤ Upon operation of the   button, the current operation data is displayed in order from Data number 01.  
 The items displayed are as follows.

\* Depending on models, the items that do not have corresponding data are not displayed.

- ⑥ To display the data of a different indoor unit, press the AIR CON No. button, which allows you to go back to the indoor unit selection screen.  
 ⑦ Pressing the ON/OFF button will stop displaying data.

Pressing the RESET button during remote controller operation will undo your last operation and allow you to go back to the previous screen.

Number	Data item	
01		(Operation mode)
02	SET TEMP	
03	RETURN AIR	
04	I/U HEAT EXCH 1	(Indoor unit heat exchanger temperature 1)
05	I/U HEAT EXCH 2	(Indoor unit heat exchanger temperature 2)
07	I/U FAN	(Indoor unit fan speed)
08	REQUEST FREQUENCY	
09	RESPONSE FREQUENCY	
10	EXPANSION VALVE OPENING ANGLE	
11	INDOOR OPERATION TIME	
11	TOTAL I/U RAN	(Indoor unit operation hours)
21	OUTDOOR	
22	O/U HEAT EXCH 1	(Outdoor unit heat exchanger temperature 1)
23	O/U HEAT EXCH 2	(Outdoor unit heat exchanger temperature 2)
24	COMP HERTZ	
25	HIGH PRESSURE	
26	LOW PRESSURE	
27	DISCHARGE	(Discharge pipe temperature)
28	DOME BOTTOM	
29	CT	
31	O/U FAN	(Outdoor unit fan speed)
32	SILENT MODE ON/OFF	
34	63H1 ON/OFF	
35	DEFROST ON/OFF	
36	TOTAL COMP RUN	(Compressor operation hours)
37	EEV 1	(Expansion valve opening 1)
38	EEV 2	(Expansion valve opening 2)

## (9) Notabilia as a unit designed for R410A

- (a) Do not use any refrigerant other than R410A.  
 R410A will rise to pressure about 1.6 times higher than that of a conventional refrigerant.
- (b) A unit designed for R410A has adopted a different size indoor unit operation valve charge port and a different size check joint provided in the unit to prevent the charging of a wrong refrigerant by mistake. The processed dimension of the flared part of a refrigerant pipe and a flare nut's parallel side measurement have also been altered to raise strength against pressure. Accordingly, you are required to arrange dedicated R410A tools listed in the table below before installing or servicing this unit.
- (c) Do not use a charge cylinder. The use of a charge cylinder will cause the refrigerant composition to charge, which results in performance degradation.
- (d) In charging refrigerant, always take it out from a cylinder in the liquid phase.
- (e) All indoor units must be models designed exclusively for R410A. Please check connectable indoor unit models in a catalog, etc. (A wrong indoor unit, if connected into the system, will impair proper system operation)

	Dedicated R410A tools
a)	Gauge manifold
b)	Charge hose
c)	Electronic scale for refrigerant charging
d)	Torque wrench
e)	Flare tool
f)	Protrusion control copper pipe gauge
g)	Vaccum pump adapter
h)	Gas leak detector

## 4.6 OUTLINE OF OPERATION CONTROL BY MICROCOMPUTER

### 4.6.1 Wired remote controller (Optional parts)

The figure below shows the remote controller with the cover opened. Note that all the items that may be displayed in the liquid crystal display area are shown in the figure for the sake of explanation.

Characters displayed with dots in the liquid crystal display area are abbreviated.

**Pull the cover downward to open it.**

#### Central control display

Displayed when the air conditioning system is controlled by the option controller.

#### Timer operation display

Displays the settings related to timer operation.

#### Temperature setting switches

These switches are used to set the temperature of the room.


#### TIMER switch

This switch is used to select a timer mode.

#### Timer setting switches

These switches are used to set the timer mode and time.

#### GRILL switch

This switch has no function. When this switch is pressed,  INVALID OPER (Invalid Operation) is displayed, but it does not mean a failure.

#### AIR CON No. (Air conditioning system No.) switch

Displays the number of the connected air conditioning system.

#### CHECK switch

This switch is used at servicing.

#### TEST switch

This switch is used during test operation.

#### Vent Indicator

Indicates operation in the Ventilation mode.

#### Weekly timer display

Displays the settings of the weekly timer.

#### Operation setting display area

Displays setting temperature, airflow volume, operation mode and operation message.

#### Operation/Check indicator light

During operation: Lit in green  
In case of error: Flashing in red

#### Operation/Stop switch

This switch is used to operate and stop the air conditioning system. Press the switch once to operate the system and press it once again to stop the system.

#### MODE switch

This switch is used to switch between operation modes.

#### FAN SPEED switch

This switch is used to set the airflow volume.

#### VENT switch

Switch that operates the connected ventilator.

#### LOUVER switch

This switch is used to operate/stop the swing louver.

#### SET switch

This switch is used to apply the timer operation setting.  
This switch is also used to make silent mode operation settings.

#### RESET switch


Press this switch while making settings to go back to the previous operation. This switch is also used to reset the "FILTER CLEANING" message display. (Press this switch after cleaning the air filter.)

\* If you press any of the switches above and  INVALID OPER is display, the switch has no function. But it does not mean a failure.

## 4.6.2 Operation control function by the indoor controller

### (1) Automatic operation (Heat recovery type only)

Once the [Auto] mode is selected by remote control, the operating mode is automatically selected according to the setting temperature and the intake air temperature of the indoor unit and cooling or heating operation is performed. The determination is performed when the thermostat has been in the OFF mode for 10 minutes or more continuously.



Notes (1) No determination is made if the mode setting is cooling, dehumidify or heating and the cooling and heating thermostats have been in the off mode for 10 minutes in the automatic operation mode.

(2) If set to automatic operation mode when the intake temperature is within  $\pm 2$  in relation to the setting temperature, the same operation as the previous automatic operation will be performed. (Note that it will be the heating mode when first turned on after the power has been turned off.)

### (2) Cooling operation

#### (a) Cooling

- “Cooling” is started by a “Cool” mode signal being received from the remote control or optional remote control unit (hereafter, remote control).
- During cooling, operation of the cooling thermostat sends the required frequency to the outdoor unit.  
When operation is stopped, the required frequency is sent to the outdoor units after 5 seconds have passed since operation started.  
However, in the case of FDE, louver reference position control is performed when operation starts, then 5 seconds after reference position control ends, the required frequency is sent to the outdoor unit.
- Operation of each device during cooling.

			When the compressor is ON	When the compressor is OFF
Indoor unit required Hz	Thermostat ON	Indoor unit	Fuzzy calculation	0 Hz
	Thermostat OFF	Indoor unit	0 Hz	
Indoor fan	Thermostat ON	Indoor unit	Predetermined <sup>(1)</sup>	Predetermined <sup>(1)</sup>
	Thermostat OFF	Indoor unit	Predetermined <sup>(1)</sup>	
Indoor expansion valve	Thermostat ON <sup>(3)</sup>	Indoor unit	Overheating control	Fully closed
	Thermostat OFF <sup>(3)</sup>	Indoor unit	0 pulse <sup>(2)</sup>	

Notes (1) Depends on the fan speed mode item.


(2) Oil return control has priority.

(3) Includes stop and blower (including unmatched).

- After cooling stops, the fan continues to run (Lo) for 15 seconds.

#### (b) Cooling thermostat off

- Fan control operates the thermostat as shown in the following diagram.  
If the thermostat goes ON, even if the thermostat is OFF as shown in the following diagram, the thermostat does not go OFF for 2 minutes after the compressor goes ON. If the thermostat goes OFF within 2 minutes, a minimum required frequency other than 0 Hz is output.
- If all the thermostats for indoor units in a module go OFF, outdoor units carry out cooling thermostat OFF operation in modular units.



### (3) Dehumidifying (Thermal dry)

- 1) This cooling operation is mainly for dehumidifying, with which the compressor, indoor and outdoor fans are operated in the patterns as listed in the following table and in accordance with operation blocks switched with the room temperature sensor. The operation blocks are selected by checking the return air temperature at 4-minute intervals. Respective functional items are operated in each operation block as shown by the following table.

**Operation block**

D	C	B	A
---	---	---	---

Low -2      +2      High

Room temperature setting point

- Indoor unit fan will be operated in D block as shown below.

Temperature check      Temperature check

Operation block		A	B	C	D
Indoor unit frequency (Hz)	22 model	10	10	10	0
	28 model	15	10	10	0
	36 model	20	15	10	0
	45 model	20	15	10	0
	56 model	25	15	15	0
	71 model	30	20	15	0
	90 model	45	30	25	0
	112 model	50	40	35	0
	140 model	60	45	35	0
	224 model	95	70	50	0
280 model	120	85	55	0	
Compressor		Sum of frequencies on combined indoor units			
Indoor unit electronic expansion valve		Superheat control			
Indoor unit fan	3 speed model	Me	Lo	Lo	Lo↔OFF
	2 speed model	Hi	Lo	Lo	Lo↔OFF
	1 speed model	Hi	Hi	Hi	Hi↔OFF
Outdoor unit fan		Operation	Operation	Operation	Stop

- 2) After dehumidification ends, the fan continues to run (Lo) for 15 seconds.

Note: For the FDK Series and indoor unit capacity types 22~56 data show for when the fan is stopped.

### (4) Heating operation

#### (a) Heating

- 1) If the "Heat" mode is received from the remote control, etc., heating operation begins.
- 2) During heating, the required frequency is sent to the outdoor unit in accordance with the heating thermostat operation.
- 3) Operation of each device during heating.

			When the compressor is ON	When the compressor is OFF
Indoor unit required Hz	Thermostat ON	Indoor unit	Fuzzy calculation	0 Hz
	Thermostat OFF	Indoor unit	0 Hz	
Indoor fan	Thermostat ON	Indoor unit	Predetermined <sup>(1)</sup>	Runs on Lo <sup>(1)</sup>
	Thermostat OFF	Indoor unit	Predetermined <sup>(1)</sup>	
Indoor expansion valve	Thermostat ON <sup>(3)</sup>	Indoor unit	Heating outlet temperature control	60 pulse
	Thermostat OFF <sup>(3)</sup>	Indoor unit	Heating stop unit expansion valve control 2 <sup>(2)</sup>	

Notes (1) It depends on the fan speed switch setting. However, hot start has priority.

(2) Oil return control has priority.

(3) Includes stop and blower (including unmatched).


(4) The settings of J3 and J4 make intermittent operation and stop possible.

- 4) The required indoor unit frequency is the same as for cooling.
- 5) Heating preparation means during heating thermostat OFF control, hot start control and during defrost control.
- 6) The remote control's LCD displays "Heating preparation" during hot start control or defrost control.

## (b) Heating operation with thermostat OFF

- 1) The thermostat operates as shown in the following diagram through fuzzy control.

If the thermostat goes ON, even if the thermostat is off in the following diagram, it doesn't go OFF for 2 minutes after the compressor goes ON. If the thermostat goes OFF within 2 minutes, a minimum required frequency other than 0 Hz is output.



- 2) If all the thermostats for indoor units in a module go OFF, outdoor units carry out heating thermostat OFF operation in modular units.
- 3) Intermittent fan operation control
  - a) When the jumper wire J3 (SW7-3), J4 (SW7-4) on the indoor PCB is shorted (installed at shipping), the fan of the unit of which the thermostat is turned OFF during heating is operated in the Lo mode, and the indoor fan is turned OFF if the temperature rises 1°C or more than the return air temperature at the thermostat OFF.
  - b) Indoor fan OFF condition is maintained for 5 minutes and then the operation is reset at the Lo mode again. After operating for 2 minutes in the Lo mode, return air temperature is checked and, if it is 1°C or higher, the indoor fan is turned OFF or, if it is not higher than 1°C, the Lo mode operation continues.

Notes (1) If the heating thermostat has been turned OFF, the temperature is indicated on the remote controller only when the indoor fan is operated in the Lo mode. When it is OFF, the room temperature at the end of Lo operation is indicated.

(2) If the operation is changed to the defrosting mode while the heating thermostat is at OFF or the thermostat is turned OFF during defrosting, the indoor fan is turned OFF.

- 4) Fan Lo Operation Control


If jumper wire J3 (SW7-3) and J4 (SW7-4) on the indoor PCB (set at shipping) is disconnected, indoor units with the thermostat turned OFF during heating operation will operate with the fan on Lo.

- 5) Fan stop control


- a) If the jumper wire J3 (SW7-3) on the indoor PCB (installed at shipment) is opened or the thermostat is turned OFF during heating operation with the remote control sensor operating, the fan on the indoor unit is turned OFF.

## (c) Hot start (Prevention of cold draft during heating)

When a heating operation is starting, and when the answer frequency has changed from 0 Hz, the expansion valve is fixed at 200 pulses for 1 minute.



- 1) If the required frequency in the room is other than 0 Hz at the start of heating operation, the indoor fan is controlled in accordance with the temperature of indoor air heat exchanger (detected with Thi-R1, R2).



Note (1) When the hot start (the compressor is operating and the indoor unit fan is not operating at the setting blow rate) is going on, the heating preparation is displayed (LCD on the remote controller).


- 2) During heating, the required frequency becomes 0 Hz (heating thermostat OFF), then afterward, if the required frequency is other than 0 Hz, and the answer back frequency from the outdoor unit is other than 0 Hz (during thermostat reset), hot start control is carried out.
- 3) If the indoor fan motor is OFF continuously for 7 minutes due to hot start control, the indoor fan motor goes ON regardless of the temperature detected by the heat exchanger temperature thermistor (Thi-R1, R2) and "Heating Preparation" LCD goes off.
- 4) Even if the fan motor is stopped continuously for 7 minutes during defrosting, it is not turned ON forcibly, but after defrosting is completed, if the fan motor is OFF continuously for 7 minutes, it is turned ON regardless of the temperature detected by the heat exchanger temperature thermistor (Thi-R1, R2).



## (5) Value shift adjustment of room air temperature detection in heating

Under the standard specifications, the room temperature is adjusted at the setting temperature by controlling the indoor unit capacity based on the setting temperature of thermostat and the suction air temperature.

However, where the unit is installed in the ceiling and warm air tends to stay around the ceiling, temperature in the living space may not be adjusted at the setting temperature. If “ROOM TEMP OFFSET” (heating space temperature compensation) is set in the remote controller’s functions, the thermostat is set to go OFF at a temperature which is 3 degrees higher than the space temperature setting, enabling an improved feeling of warmth in the room.



## (6) FILTER sign

- (a) If cumulative operating time (the time the Run/Stop switch is ON) reaches 600 hours, “FILTER CLEANING” is displayed in the remote controller.



Note (1) If jumper wire J1 (SW7-1) on the indoor PCB is disconnected, this function is deactivated.

- (b) The functions of the remote controller can be set to display 180 hours, 600 hours, 1,000 hours, 1,000 hours & Forced Stop, and no display.
- (c) If it is set on 1,000 hours & Forced Stop, after 1,000 hours of operation, there is a forced stop after an additional 24 hours have passed. (If the filter sign is not reset, operation cannot be resumed.)


Resetting from the remote controller is possible at all times (while running, while stopped and before time up) when a filter reset signal is received. It is also reset when the power is turned OFF.

## (7) Auto swing control (FDTc, FDT, FDTW, FDTQ, FDTs, FDE and FDK only)

- (a) Louver Control


- (i) When the air conditioner is operating, press the “LOUVER” switch to move the swing louvers. “AUTO  ” is displayed for 3 seconds, then the swing louvers begin moving up and down continuously.
- (ii) When you desire to fix the position of the swing louvers, press the “LOUVER” switch while the swing louvers are moving, and 4 stop positions will be displayed one at a time in 1 second intervals. When the position you desire to louvers to stop at is displayed, press the “LOUVER” switch again. The display will stop message (ex. “STOP 1-”) will be displayed for 3 seconds and the swing louvers will stop.
- (iii) Louver operation when the power to the 4-position louver controller is turned on.

When the power is turned on, the louvers automatically swing 1 (2) time (without remote controller operation). This operation inputs the position of the louver motor (LM) in the microcomputer so it can confirm the louver position.

Notes (1) The louver position LCD displays the swing operation for 10 seconds when the “LOUVER” switch is turned ON. After that, “AUTO  ” is displayed for 3 seconds in the LCD.

Notes (2) Values in ( ) show in cases other than the FDT, FDE and FDK 22~56 models.

- (b) Louver auto horizontal set during heating

The louvers are in the horizontal position regardless of whether the auto swing switch is operated (auto swing or louver stop) while “ (Heating Preparation)” is displayed (during hot start and when the heating thermostat is OFF). (This is to prevent cold drafts), and the display that was in the louver position display LCD before this control was activated continues. If the “Heating Preparation” display goes off, both the louvers and the LCD display return to their original setting.

- (c) Louver free stop control

If “IN MOTION (louver free stop)” is set in the remote controller’s function settings, the louver motor stops if there is a stop signal from the remote control unit and the stop position is stored in memory. Also, if there is an auto swing signal from the remote control unit, auto swing control starts from the position the louvers were in before being stopped.

### (8) Condensate pump motor (DM) control (Only FDTC, FDT, FDTW, FDTQ, FDTs, FDR, FDQM, FDUM models)

- 1) This operates if the inverter frequency is other than 0 Hz during cooling, auto cooling and dehumidification.
- 2) If the drain motor goes on, then goes OFF in accordance with the conditions in item 1), the motor continues to run for 5 minutes, then stops. Also, in the case of an abnormal stop, the motor also continues to run for 5 minutes.
- 3) If the compressor is ON and goes OFF, the drain motor continues to run for 5 minutes.
- 4) Even in states other than the above states (heating, blower, stop, heating thermostat OFF), drain motor control is enacted by the drain sensor.
- 5) When expansion valve control opens the expansion valve during cooling as in item 1) of oil return control, the drain motor for that unit continues to run with a 5-minute delay in addition to the oil return control time.

### (9) High ceiling control

In the case of indoor units installed in high ceilings, air flow mode control can be changed using DIP switch SW9-4 on the indoor PCB, or by using the remote controller indoor function setting (see page 448).

DIP SW	SW9-4 OFF (Normal Control)	SW9-4 ON (High Ceiling Control)
Item		
Air Flow Mode	Hi, Me, Lo	UHi, Hi, Me


Notes (1) When the unit is shipped, SW9-4 is turned OFF.

(2) If SW9-4 is ON, the fan operates in Me even during hot start and when the heating thermostat is OFF.

### (10) Frost prevention during cooling, dehumidifying

Thermostat OFF control

- 1) During “Cooling” and “Dehumidification,” the thermostat is turned OFF in accordance with the temperature sensed by the heat exchanger sensors (Thi-R1, 2).



- 2) For 4 minutes after the thermostat goes ON, forced thermostat OFF control of anti-frost doesn't operate.
  - a) At the point when 4 minutes have passed since the thermostat went ON, if either heat exchanger sensor Thi-R1 or R2 senses that the temperature is higher than the anti-frost temperature, sensing begins when the sensor is in the ON ready state.
- 3) After 4 minutes have passed since the thermostat went ON, if either heat exchanger sensor Thi-R1 or R2 senses that the temperature is lower than the anti-frost temperature (-0.5°C) continuously for 5 minutes, the thermostat is turned OFF forcibly.

Also, the thermostat is turned ON if the temperature sensed by Thi-R1 and R2 enters the thermostat ON ready range.

- 4) An “Anti-frost” signal is sent to the outdoor unit.

### (11) Indoor expansion valve control

#### (a) Cooling superheat control

1 minute after the thermostat switches ON during a cooling or dehumidifying operation, superheating is maintained at a suitable level by expansion valve aperture control based on the difference between the indoor heat exchanger's inlet and outlet temperatures (detected by Thi-R3 and Thi-R1 or R2), and the amount of deviation from the superheat setting value. Cooling superheat control ends when operation stops, or when the thermostat switches OFF.

#### (b) Heating paused unit refrigerant control

In order to control the amount of refrigerant collected in a heating paused unit during outdoor unit heating operation, paused unit refrigerant control occurs individually at the paused units that satisfy the following conditions.

##### (i) Start conditions

- |   |   |                        |
|---|---|------------------------|
| <ul style="list-style-type: none"><li>① After thermostat switches OFF</li><li>② After heating → stop, or stop → blow switching</li><li>③ After outdoor unit heating begins during a stop (including error stops)</li><li>④ After electronic expansion valve full-closed control</li><li>⑤ After receiving a "refrigerant recovery" signal from the outdoor unit</li></ul> | } | After 12 hours elapses |
|---|---|------------------------|

##### (ii) Control description

The electronic expansion valve opens to the setting aperture for 1 minutes.

##### (iii) Control termination conditions.

- ① When the outdoor unit stops
- ② When a defrost operation begins
- ③ When the thermostat switches ON
- ④ When the indoor heat exchanger sensor (Thi-R1 or Thi-R2) detects a temperature exceeding 55°C.

### (12) Thermistor (Return air, heat exchanger) disconnected

#### (a) Return air temperature thermistor (Thi-A)

Disconnection sensed: If the temperature is -20°C or lower continuously for 5 seconds.

Short circuit sensed: If the temperature is 48°C or higher continuously for 5 seconds.

Anomaly display: E7

#### (b) Indoor heat exchanger temperature thermistor (Thi-R1, R2, R3)

Disconnection sensed: If the temperature is -40°C or lower continuously for 5 seconds.

Short circuit sensed: If the temperature is 70°C or higher continuously for 5 seconds.

Anomaly display: E6

### (13) Indoor fan anomaly [FDTC, FDTA112, 140 or FDKA22 ~ 56 types only]

If the indoor unit fan speed is less than 200 rpm continuously for 30 seconds after a n indoor unit fan run command is output, it stops for 2 seconds. After 2 seconds, it restarts, but if this operation is repeated 4 times within 60 seconds, an anomalous stop is performed.

### (14) External control (remote display)/control of input signal

Make sure to connect the standard remote control unit. Control of input signal is not available without the standard remote control unit.


#### (a) External control (remote display) output

**Following output connectors (CNT) are provided on the printed circuit board of indoor unit.**

- (i) Operation output: Power to engage DC 12V relay (provided by the customer) is outputted during operation.
- (ii) Heating output: Power to engage DC 12V relay (provided by the customer) is outputted during the heating operation.
- (iii) Compressor ON output: Power to engage DC 12V relay (provided by the customer) is outputted while the compressor is operating.
- (iv) Error output: When any error occurs, the power to engage DC 12V relay (provided by the customer) is outputted.


### (b) Control of input signal

- 1) The mode is switched to the remote operation input processing mode by nonvolatile memory (EEPROM) on the indoor unit's circuit board.
- 2) SW5-3 on the indoor unit's circuit board is turned OFF (factory setting).  
The air conditioner goes ON when the signal input to CNT-6 changes from OFF to ON. The air conditioner goes OFF when it changes from ON to OFF. There is no reverse operation.



It is possible to turn the air conditioner ON or OFF using the remote control or center console, etc.

- 3) SW 5-3 on the indoor unit's circuit board is turned ON (when set locally)  
This is enabled only when the input signal to CnT-6 is turned from OFF to ON. Air conditioner operation is reversed.



- 4) CNT-6 input is enabled only when in the center mode.
- 5) When the "Cooling" (heating) mode is stored in memory, if the remote control signal line or the remote start/stop input terminal (Cn-T) receives an operation start signal from the HA terminal, a cooling operation (heating operation) begins.
- 6) During operation, the compressor operation signal is output from the outdoor unit to the remote control line and the remote monitor terminal (Cn-T).
- 7) If "Level Input" is received in accordance with the wired remote control's indoor function setting "external input switching," the control in item 2) is activated. If "Edge Input" is received, the control in item 3) is activated.

## (15) Multiple units control-simultaneous control of 16 unit with one remote controller


### (a) Function

Multiple units (even of outdoor different systems, 16 units maximum) can be simultaneously controlled by using a remote controller. The remote controller is used to set the "operation mode", and all the unit can be operated and stopped. Thermostat and protective functions of each unit functions independently.

Note(1) When part of the group gets out of order (the protective device operates), the relevant unit comes to an abnormal stop, but other normal units keep operating.

### (b) Wiring Procedures

- (i) Lay power cable of each unit and signal wire as usual. (Remove the remote control switches from all units excluding only one unit.)  
Lay wiring for the remote controller separately from power cable and wires for all other electrical equipment.
- (ii) Arrange the terminal block (X, Y, Z) of the remote controller as shown below for the simultaneous control, and lay cross over in each indoor unit.



- Notes (1) The overall length of the signal wire shall be less than 1000m.  
(2) The length of remote control signal wire and crossover for remote controller between room shall be less than 600m.

## 4.6.3 Operation control function by the outdoor controller

### ■ KX series


#### All-in-one type

#### ◆ Models FDCA140HKXEN4R, 140HKXES4R, 160HKXES4R

##### (1) Compressor operating frequency


The compressor's maximum operating frequency during cooling and heating is as shown below. The minimum operating frequency is 20 Hz during both cooling and heating.

##### Maximum operating frequency during cooling



Note (1) The values in parentheses are for FDCA140, 160HKXES4R.

##### Maximum operating frequency during heating



##### (2) Compressor starting control

##### (a) 4-way valve switching assurance start

- 1) If the compressor starts under any conditions other than the following conditions, a 4-way valve switching protection start is performed.

In the second and consecutive starts of the compressor after its power is turned ON, if the thermostat ON conditions are established and it goes ON before 6 hours have passed since it went OFF. However, if there is a change in the operation mode after the thermostat goes OFF (heating, fan or remote control stop after cooling or dehumidification, or cooling, dehumidification, fan or remote control stop after heating), a 4-way valve switching protection start is performed the next time the compressor is started.

- 2) When the compressor starts, it starts at the command speed of 60 Hz, and not at the target speed.
- 3) 4-way valve switching protection start ends 30 seconds after the compressor starts and control changes to compressor protective start control.

##### (b) Compressor protective start

The following compressor protective start is performed after 4-way valve switching protection.

	Initial start (remote controller ON, abnormal release)	Thermostat ON start	
		Change to thermostat OFF operation mode	No change to thermostat OFF operation mode
First time of cumulative compressor ON operations.	Compressor protective start B depending on crankcase heater power on time	Compressor protective start B depending on crankcase heater power on time	Compressor protective start B depending on crankcase heater power on time
Second or subsequent time of cumulative compressor ON operations.	Protective start	Protective start	Inching protective start

##### 1) Protective start

- a) The actual compressor operating frequency after 4-way valve switching protection is completed is a command frequency of 38Hz until 2 minutes after the compressor starts, and when the frequency increases, its maximum rate of increase is 6 Hz/30 sec.

- b) Control is based on the target speed when 2 minutes have passed after starting.

##### 2) Starting Inching Protection

- a) When the thermostat goes ON after the unit stops while the thermostat is OFF, the specified compressor operating frequency is set at 38 Hz until 2 minutes have passed since compressor operation started, and the upper limit during increases in frequency is set at 6 Hz / 30 seconds.

Note (1) If an attempt is made to change the operating mode while the thermostat is stopped, inching protective start when the compressor starts again is not carried out, but 4-way valve switching protective start is carried out.


- b) It follows the target frequency when 2 minutes have passed after starting.

##### 3) Compressor Protection Start B by Crankcase Heater On Time

- a) Compressor protective start is carried out when any of the following conditions is satisfied.

##### ◆ When SW3-4 is OFF

- ① When the cumulative number of compressor starts since the power was turned ON is one start, and 30 minutes or more have passed since the power was turned ON.
- ② When the cumulative number of compressor protective starts since the power was turned ON is one start and the outdoor temperature and under-dome temperature are outside the range indicated by the shaded portion of the graph below.



##### ◆ When SW3-4 is ON

When the cumulative number of compressor starts since the power was turned ON is one start.

[Control Content]

- ① The compressor's speed increases are kept within an upper limit of 6 Hz / 5 min. for 30 minutes after starting.
  - ② Between 30 minutes and 40 minutes after starting, the compressor's speed increases are kept within an upper limit of 6 Hz / 2 min.
  - ③ When the compressor stops within 40 minutes after starting, the next time it starts, the frequency increase upper limit method used in this control continues until a cumulative time of 40 minutes has passed.
- b) If the outdoor temperature and under-dome temperature are within the range indicated by the shaded portion of the above graph during compressor protective start B control, the following control is carried out and the compressor is not started.
- ① The following data are displayed in the 7-segment display.  
Display Data: "30" is displayed after the power ON value then this value decreases by "1" every minute thereafter.
  - ② It is possible to start the compressor after 30 minutes have passed since the power was turned ON.
  - ③ If the temperatures change so that they are outside the range indicated by the shaded portion of the above graph before 30 minutes have passed since the power was turned ON, it is possible to start the compressor.

### (3) Outdoor fan control

#### (a) Fan tap and fan motor control contents during control

Fan tap	FM01	FM02
6 speed	UHi	UHi
5 speed	UHi	Hi
4 speed	Hi	Hi
3 speed	Hi	Lo
2 speed	Lo	Lo
1 speed	Lo	OFF
0 speed	OFF	OFF



- (b) When the fan motor starts, it runs at speed 4, and after it has been running for 20 seconds, it moves to the various controls. (Heating only)

#### (c) Fan tap control

##### 1) Heating

- a) Fan tap control is performed in accordance with the low pressure (sensed by PSL) and the outdoor air temperature (sensed by Tho-A). However, when it is within the detected temperature range when the power is ON, the fan tap starts at a low speed when high pressure control is on with heating operation, it operates according to the following.

	A Zone	B Zone
C Zone	4 speed	4 speed
D Zone	6 speed	6 speed





- b) If the outdoor fan starts when the outdoor temperature (detected by Tho-A) is 12°C or higher, it starts under the following conditions.
- ① After starting at the 4-speed fan tap, the speed changes to 2 speed after 3 seconds.
  - ② After forced operation at the 2 speed fan tap for 4 minutes, control changes to the control in item a).
  - ③ If outdoor fan control is started by the high pressure sensor during this control sequence, this control sequence has priority, and if the outdoor temperature is 12°C or higher, the forced 4-minute 2 speed fan tap operation continues.

##### 2) Cooling


Fan tap control is performed in accordance with the high pressure (sensed by PSH) and the outdoor air temperature (sensed by Tho-A). However, when it is within the detected temperature range when the power is ON, the fan tap starts at a low speed.

	A Zone	B Zone	C Zone
D Zone	6 speed	4 speed	2 speed
E Zone	4 speed	2 speed	1 speed
F Zone	4 speed	1 speed	0



#### (d) Snow fan control



If jumper wire J8 (SW4-8) on the outdoor unit PCB is open, a full stop is performed, and in the anomalous stop mode, if the temperature of the outdoor air at the outdoor unit fan becomes 3°C or lower, it runs at 6th speed for 30 seconds once every 10 minutes.



#### (4) Defrosting

##### (a) Temperature conditions defrosting

- (i) When all the following conditions are satisfied, temperature conditions defrosting begins.
  - 1) There have been 45 minutes of cumulative compressor operation since defrosting was completed, or there have been 30 minutes of cumulative compressor operation since the start of heating operation (remote control unit ON).
  - 2) 5 minutes have passed since the compressor went ON.
  - 3) 5 minutes have passed since the outdoor fan started operating.
  - 4) When one of the following conditions is met after all of the conditions above are met.
    - ① When the outside air temperature sensed by the outdoor heat exchanger temperature thermistor (Tho-R) is below the defrosting start temperature shown in Table. 1 below continuously for 60 seconds.
    - ② When the intake gas saturation temperature determined from the value detected by the low pressure sensor (PSL) and the temperature detected by the outside air temperature thermistor (Tho-A) is below the defrosting start temperature shown in Table. 2 continuously for 3 minutes. (However, detection by the low pressure sensor (PSL) is not performed for 10 minutes after the compressor starts.)
    - ③ When the temperature detected by the outside air temperature thermistor (Tho-A) is  $-10^{\circ}\text{C}$  or higher but less than  $5^{\circ}\text{C}$ , and the low pressure is lower than 0.243 MPa, or when the temperature sensed by the outside air temperature thermistor (Tho-A) is lower than  $-10^{\circ}\text{C}$  and the low pressure is less than 0.2048 MPa. (However, the amount of actual compressor operating time since the end of defrosting in item 1) above is 30 minutes.)



##### (ii) Changing the defrosting start temperature range

Disconnect jumper J15 on the outdoor PCB.

- 1) When there is a total of 30 minutes of operation in the heating mode after defrosting is terminated.
- 2) When the temperatures detected by the outdoor heat exchanger temperature thermistor (Tho-R) and the outside air temperature thermistor (Tho-A) are below the defrosting start temperature in Fig. 1 continuously for 30 seconds, or when the intake gas saturation temperature determined from the value detected by the low pressure sensor (PSL) and the temperature detected by the outside air temperature thermistor (Tho-A) is below the defrosting start temperature shown in Fig. 2 continuously for 30 seconds.
- 3) When conditions are normal except for items 1) and 2) above.



### (iii) Defrosting end conditions


If either of the following conditions is satisfied, the defrosting end operation starts.

- 1) When 10 minutes have passed since the start of defrosting.
- 2) When an outdoor heat exchanger thermistor (Tho-R) temperature of 18 (12) °C or higher is detected continuously for 10 seconds or longer.

Note (1) Values in ( ) show in the case where jumper J15 is open.

### (b) Time conditions defrosting (Oil return control during heating)

- (i) When 4 hours of cumulative running time have passed since the compressor's power was turned ON and cumulative compressor running time in the first operation in the heating mode exceeds 1 hour. However, if the mode was changed from cooling to heating, 30 minutes after the compressor was turned ON.
  - (ii) If temperature conditions defrost operating time prior to time conditions defrosting was 2 minutes 30 seconds or longer, the time conditions defrost timer (4 hours) is reset. (It is regarded that oil return during temperature conditions defrosting was complete.)
  - (iii) Time conditions defrost is performed after the 4-hour timer's time is up, or 45 minutes or more after the previous temperature conditions defrost is completed, whichever is the slowest.
  - (iv) Defrosting end conditions
    - 1) When 2 minutes 30 seconds have passed since the start of defrost operation and an outdoor heat exchanger thermistor (Tho-R) temperature of 18 (12) °C or higher is detected continuously for 10 seconds or longer.
- Note (1) Values in ( ) show in the case where jumper J15 is open.
- 2) When 10 minutes have passed since the start of defrosting.
- (v) If the temperature detected by the outdoor heat exchanger thermistor M is 12°C or higher within 2 minutes 30 seconds after defrosting starts, the outdoor fan runs at speed 6, then stops when the temperature drops to 9°C or lower.




Note (1) The fan stops without relation to the temperature when 2 minutes 30 seconds have passed.

## (5) Compressor protective control

### (a) Discharge pipe temperature control


If the discharge pipe temperature exceeds the set value, the compressor's speed is controlled to suppress the rise in the discharge pipe temperature. If it rises still higher, the compressor is stopped.

#### (i) Compressor speed control



#### (ii) Discharge pipe temperature anomaly

- 1) If the discharge pipe temperature rises to 130°C or higher, the compressor is stopped. It recovers automatically if the temperature drops to 90°C or lower.



- 2) If the discharge pipe temperature is anomalous 5 times within 60 minutes, or if the temperature remains at 130°C or higher continuously for 60 minutes, including when the compressor is stopped, the unit performs an anomalous stop (E36).

Note (1) If the discharge pipe temperature does not drop to 90°C or lower continuously for 45 minutes after a discharge temperature anomaly occurs, the compressor cannot be restarted. (It is possible to reset it using the remote control unit.)

### (b) Current safe control

- 1) If the input current value (converter inlet N-phase) at the inverter inlet exceeds the set value, the compressor's speed drops. If the detected value increases even if the speed goes down, the speed will drop even further.
- 2) This control ends if the value drops below the cancellation value continuously for 3 minutes or below the set value continuously for 6 minutes.




### (c) High pressure control

#### (i) Heating

##### 1) Compressor speed protect control

- a) During compressor operation, when all the following conditions are satisfied, compressor speed is reduced.
  - ① SW4-7 ON: when the pressure for the high pressure exceeds 3.0MPa.
  - ② SW4-7 OFF: when the pressure for the high pressure exceeds 3.2MPa.
- b) This control ends when the pressure for the high pressure is the above pressure or lower than for six minutes continuously.
- c) When the compressor frequency is 20 Hz and the pressure for the high pressure exceeds 3.8 MPa, the compressor stops.
- d) Control of outside fan by pressure for high pressure (PSH)  
If the pressure for the high pressure reaches 3.204 (2.807) MPa or greater during heating operation, the outdoor fan is set to speed 2.




Note (1) The values within ( ) will be displayed when sw4-7 is switched off.

#### (ii) Cooling

- a) When the high pressure is 3.507 MPa or greater during compressor operation, the compressor speed is reduced.
- b) The high pressure is detected 1 minute later, and if it is 3.507 MPa or higher, the speed drops further.
- c) If the high pressure drops below 3.507 MPa, this control ends and speed protect release operation begins.

#### (iii) Control by outdoor heat exchanger temperature

- 1) If the temperature at the outdoor heat exchanger rises to 65°C (continuation 2 seconds) or higher during cooling, the compressor is stopped. If the temperature drops to 55°C or lower, the compressor recovers automatically.



- 2) If the outdoor heat exchanger temperature rises to 65°C 5 times within 60 minutes, or is 65°C or higher continuously for 60 minutes, including when the compressor is stopped, the unit is subjected to an anomalous stop (E35).


Note (1) If the outdoor heat exchanger temperature drops to 55°C continuously for 3 minutes after an anomalous stop occurs, it is possible to reset it using the remote control unit.

#### (iv) Anomalous pressure sensing by the high pressure sensor (PSH)

- 1) If the high pressure (PSH) is 4.055 MPa or greater, the compressor is stopped.
- 2) If the high pressure (PSH) is 3.658 MPa or less, it returns automatically.
- 3) If high pressure (PSH) of 3.658 MPa or greater continues for 60 minutes or more after 4.055 MPa or greater is detected five times within 60 minutes for item a) above, the unit is stopped abnormally (E40).


### (d) Power transistor temperature control

If the power transistor's cooling fin temperature (Tho-P) exceeds the set temperature, the compressor's capacity is controlled, preventing the power transistor's temperature from rising.



**(ii) Power transistor overheating protection**

The compressor is stopped if the power transistor's temperature rises to 110°C. If the temperature drops to 90°C within 3 minutes, the compressor recovers automatically, but if this process is repeated 5 times in 60 minutes, or if the temperature stays at 110°C continuously for 60 minutes, an anomalous stop is performed (E41).



**(e) Low pressure control**

**(i) Compressor speed control**

- 1) If 10 minutes have passed since the compressor started and all the following conditions are satisfied, the compressor's speed is reduced.
  - ① Pressure measured by the low pressure sensor (PSL) is  $\leq 0.150$  MPa continuously for 10 seconds.
- 2) The low pressure is measured 10 seconds later, and if it is 0.150 MPa or lower, the compressor speed is reduced even further.
- 3) If the low pressure rises to 0.189 MPa or higher, this control ends and speed protect release operation begins.

**(ii) Low pressure abnormal detection**

- 1) If the low pressure sensor senses a pressure of 0.079 MPa or lower continuously for 15 seconds and if 10 minutes have passed since the compressor started, the pressure detected by the low pressure sensor is 0.15 MPa or lower and super heat operation with a temperature of 30°C or higher is detected continuously for 60 seconds, the compressor stops.
- 2) If the low pressure sensor detects a pressure of 0.227 MPa or higher continuously for 10 seconds, operation is resumed 3 minutes later.

**(iii) Low pressure abnormal stop control**

- 1) If the conditions in item (ii) occur 3 times in 60 minutes, including when the compressor is stopped, a low pressure (PSL) of 0.079 MPa or lower is detected continuously for 60 minutes or longer and a low pressure (PSL) of 0.079 MPa or lower is detected continuously after the compressor starts, an emergency stop is performed (E49).



**(f) High pressure ratio protection control**

During heating, the compressor's speed is controlled in accordance by the low pressure sensor and high pressure sensor.

**(i) Starting conditions**

When all the following conditions are satisfied:

- ① When 5 minutes have passed since the compressor started in the heating mode.
- ② If the outdoor fan is ON and 5 minutes have passed since operation started.
- ③ If 5 minutes have passed since defrosting ended.
- ④ If the pressure levels detected by the low pressure sensor (PSL) and high pressure sensor (PSH) are within the control range shown in the figures below for 30 seconds.



**(ii) Control contents**

The compressor's speed is reduced. 1 minute later, the sensors operate again and if the ratio is within the range in item ④, the speed is reduced still further.

**(iii) End conditions**

When operation has continued 6 minutes outside the control range in item ④.

**(g) Inverter protection control**

**(i) Current cut control**

This prevents overcurrent in the inverter. If the current exceeds the set value, the compressor is stopped. 3 minutes later, it recovers automatically, but if current cut operates 4 times within 15 minutes, the compressor is subjected to an anomalous stop (E42).

**(h) Compressor Protection at Low Frequencies**

- 1) If a low frequency of 30 Hz or lower continues for 20 minutes or longer, the compressor is run at 30 Hz for 1 minute.
- 2) If the high pressure becomes 3.5 MPa or higher during this control, refrigerant return is performed for 60 seconds.
- 3) If the compressor cannot be run at 30 Hz. for 1 minute 30 seconds by protective control, etc., the compressor is forcibly stopped for 3 minutes.

**(6) Thermistor disconnection (discharge • suction • heat exchanger • outdoor under-dome, temperature, low pressure sensor and high pressure sensor)**

**(a) Outdoor heat exchanger, outdoor thermistor, low pressure sensor, high pressure sensor**

If a temperature of  $-50^{\circ}\text{C}$  or lower is sensed by the outdoor heat exchanger thermistor, or  $-30^{\circ}\text{C}$  or lower is sensed by the outdoor thermistor for 5 seconds, or the low pressure sensor or high pressure sensor voltage is 0 V or lower or 3.94 V or higher in the interval between 2 minutes and 2 minutes 20 seconds after the compressor goes ON, the compressor is stopped. After a 3-minute delay, the compressor is restarted, but if this occurs 3 times within 40 minutes, an abnormal stop is performed.

Note (1) No sensing is performed during defrosting or for 3 minutes after defrosting.

**(b) Discharge pipe, suction pipe, under-dome temperature thermistor**

If the discharge pipe thermistor temperature detects a temperature of  $3^{\circ}\text{C}$  or lower and the suction pipe and under-dome temperature thermistor detects a temperature of  $-50^{\circ}\text{C}$  or lower continuously for 5 seconds in the interval between 10 minutes and 10 minutes 20 seconds after the compressor goes ON, the compressor is stopped. After a 3-minute delay, the compressor is restarted, but if the same conditions are detected again 3 times within 40 minutes, an anomalous stop is performed.


Note (1) No sensing is performed during defrosting or for 3 minutes after defrosting.

**(7) Silent mode control**


Silent mode operation is started by the CnG2 connector on the outdoor unit PCB being in the open state, or by a command from the remote controller.

**(a) Silent mode operation is effective within the following temperature ranges.**

**During Cooling**




**During Heating**



- (b) When the outdoor fan is started, it starts in 4th speed, then after 20 seconds of operation, the fan tap upper limit becomes 2nd speed.
- (c) The upper limit of the compressor operating frequency is set at 80 Hz.


**(8) Oil separator bypass valve (SV2, 3) control (SV2 is normally ON while the compressor is operating.)**

- (a) The oil separator bypass valves (SV3) are controlled in accordance with the compressor speed.




**(b) When the following conditions are established, SV3 goes ON regardless of the compressor's speed.**


- 1) If the temperature detected by the under-dome temperature thermistor (Tho-C) during compressor operation is as shown below.



- 2) If the pressure detected by the high pressure sensor (PSH) during heating and during compressor operation is as shown below.



- 3) If the pressure detected by the low pressure sensor (PSL) during compressor operation is as shown below.



#### (9) Anomalous stop due to anomalous compressor start

- If the compressor cannot change to the DC motor rotor position detection operation within 5 seconds after compressor start conditions are established, the compressor stops temporarily, then after 3 minutes, performs the position detection operation.
- If it cannot change to the position detection operation a 20 time, it is judged that a compressor anomalous start condition exists and it is subjected to an anomalous stop (E59).

#### (10) Compressor anomalous rotor lock

If, after changing to the compressor rotor position detection operation, the rotor position cannot be detected a second time, the compressor is stopped. After 3 minutes, it recovers automatically, but if this occurs 4 times within 15 minutes, the compressor is subjected to an anomalous stop (E60).

#### (11) Test operation

- Test operation can be performed from the outdoor unit using DIP switches SW5-1, 2 on the outdoor unit PCB.

SW5-1	ON	SW5-2	OFF	Test run for heating
	OFF	ON	ON	Test run for cooling
				Normally and after test operation

Be sure to turn SW5-1 OFF when the test operation is terminated.

#### (12) Pump down control

Pump down operation can be performed by operating DIP switches (SW5-1, 2, 3). (Pump down operation cannot be started while an indoor unit is operating or when there is an anomalous stop.)

##### (a) Pump down procedure

- Close the liquid side service valve to the outdoor unit.
- Set SW5-2 (test operation mode) in the ON (cooling) position.
- Set SW5-3 (pump down switch) in the ON position.
- Set SW5-1 (test operation switch) in the ON position. Pump down operation will start.

##### (b) Control contents

- In the cooling mode, the compressor is started with the target speed set at 60 Hz.
- The red and green LED's on the outdoor unit PCB flashes continuously and "POS" is displayed in the 7-segment LED.
- Except for low pressure control, each type of protection and anomalous sensing control is activated.
- Compressor protective start B is cancelled.
- The electronic expansion valves (cooling, heating) are opened.

##### (c) Control end conditions

End control is carried out through any of the following conditions.

- Low Pressure  $\leq$  0.087 MPa is detected continuously for 5 seconds.
  - Red LED: Lighted; Green LED: flashing; 7-segment LED: "POE" is displayed.
  - At Low Pressure > 0.087 MPa, restarting is possible. (Turn SW5-1 OFF temporarily, then reset.)
- Stop by abnormal sensing control
  - Red LED: Lighted; Green LED: flashing; 7-segment LED: Anomalous stop error code is displayed. displayed.
  - Restarting is impossible. Turn the power off, then on again to recover normal operation.
- When cumulative compressor operating time through pump down control has reached 5 minutes.
  - Red LED: Off; Green LED: flashing; 7-segment LED: No display.
  - Repeat of the pump down operation is possible. (Turn SW5-1 OFF temporarily, then reset.)
- If either SW5-1, 2 or 3 is turned OFF during pump down.

**Caution:** If the pump down switch is pressed, communications with the indoor units are canceled, so "Communications Anomaly, E5" is displayed on the indoor units and on the remotecontroller. However, there is nothing anomalous.

#### (13) Refrigerant Return Control

- If any of the following conditions is satisfied while the electronic expansion valve for heating (EEVh) during compressor operation in the heating mode, refrigerant is returned from each indoor unit with the thermostat off, the fan running, the unit in the OFF state or that is currently experiencing an emergency stop, in sequence at 30 second intervals.
  - Low pressure  $\leq$  0.2 MPa
  - Overheating  $\geq$  30 degrees
  - Discharge pipe temperature  $\geq$  120°C
- When refrigerant return is completed for all the affected indoor units, or if the compressor goes OFF during this control, refrigerant return control is terminated.

#### (14) Cooling and heating forced operation

Turning SW3-7 on the outdoor unit PCB ON and shorting and opening CnG1 (with short pin), forces the indoor units to operate in the cooling or heating mode. If an operation mode other than a forced mode is commanded from the indoor units, mode mismatch is displayed in the remotecontroller, etc.

SW3-7	CnG1	Operation
OFF	Open circuit, Short circuit	Normal operation
ON	Open Circuit	Cooling
	Short Circuit	Heating

Note (1) When the unit is shipped from the factory, SW3-7 is OFF and CnG1 is open.

#### (15) Condensation protection control

(a) When there is one or more indoor units with an electronic expansion valve (EEVC) completely open with cooling operation or drying operation and thermo ON, the compressor speed and outdoor unit fan are controlled.

- ① The lower limit value for the speed of the compressor shall be 50 Hz.
- ② If the cooling electronic expansion valve is completely open at a compressor speed of 50 Hz or less, the outdoor fan tap is dropped with speed 1 / 5 minutes.
- ③ When the outdoor fan tap is speed 2 or less with a compressor speed of 50 Hz or less, the compressor speed is lowered with 6 Hz / 5 minutes with the cooling electronic expansion valve completely open. (The lower limit value is 30 Hz)

(b) This control ends when there is other than the cooling electronic expansion valves being completely open when thermo is ON for all indoor units.

#### (16) Connected indoor units count protection

If the number of connected indoor units exceeds 8 units, an anomalous stop (E43) is performed.

#### (17) External input operation



External input: From CnS1, operation permission/prohibition control; From CnS2: Demand control/normal operation switching.

- J13: Switches between CnS1 and CnS2 input method.

J13 short circuit: Level input by CnS1 and CnS2.


J13 open: Pulse input by CnS1 and CnS2.

(a) From CnS1, operation permission/prohibition control


Input : CnS1	CnS1 input method change: J13	CnS1 : Operation permission/Prohibition mode change
	J13; Short circuit Lever input	Operation prohibition mode → Operation permission mode
	J13; Disconnection Pulse input	Operation permission/Prohibition model change (Reversal)
	J13; Short circuit	Operation permission mode → Operation prohibition mode
	J13; Disconnection	— (NOP)

- 1) The remote controller displays the operating mode. "To Option" sends the operating mode.
- 2) CnS1, performs the following operations by the changing of jumper wire J1 from short circuit to open circuit.  
If pulse input, the pulse duration is 500 ms or more.

① Operation with J13 short circuit



② Operation with J13 disconnection



(b) From CnS2, operation permission/prohibition control

Input : CnS2	CnS2 input method Formula switching: J13	Demand control/normal operating switching CnS2 :
	J13; Short circuit Level input	Demand control → Normal operation
	J13; Open circuit Pulse input	Normal operation/Demand control switching (Reversal)
	J13; Short circuit	Normal operation → Demand control
	J13; Open circuit	— (NOP)

Note (1) The factory settings are: J13 - short circuit; CnS2 - short circuit (short pin connection)

- 1) The remote controller displays the operating mode. “To Option” sends the operating mode.
- 2) Demand control


It is possible to switch the demand using jumper wires J5 and J6.

J6	J5	Compressor output (%)	Upper limit of compressor operation (Hz)
1	1	80	80
1	0	60	60
0	1	40	40
0	0	0	0


Note (1) 0: Open, 1: Shorted

- 3) CnS2, performs the following operations by the changing of jumper wire J13 from short circuit to open circuit.  
If pulse input, the pulse duration is 500 ms or more.

① J13 - Short circuit



② J13 - Open circuit



**(18) Switching between operation and stoppage**

- Set the channel of 7-segment LED to "70".
- Currently logged data is displayed in the data display part.  
"0": first push priority (factory default).  
"1": last push priority.
- Push down SW7 continuously for 3 seconds.
- Characters on the data display part flicker once every 0.5 second. Notice that the "Write Mode" will be ended if there is no switch input for 10 seconds in this state.
- Push down SW8 to switch to "1".

In the flickering state, if SW7 is pushed down continuously for 3 seconds, the "1" of data display part will light up and the setting will be saved.

The content saved after any revision won't be lost even if power supply is switched on again. If another revision is desired, repeat operation and set again.

## (19) 7-Segment display

The data in the following table can be displayed using the display select switch (SW8: 1's digit; SW9: 10's digit).

Code No.	Contents of display	Data display range	Minimum units	Remarks
00	CM1 operating frequency, error code or pump down display	0~120	1Hz	Normally, the frequency is displayed. When there is an error, E?? is displayed. During pump down, PoS, PoE is displayed.
02	Tho-A (Outdoor air temp.)	L,-20~43	1°C	[L] is indicated when the temperature is -20°C or below and the actual temperature is indicated when it is higher than -20°C and up to 43°C.
03	Tho-R (Heat exchanger temp. 1) (Exit. Front)	L,-25~73	1°C	[L] is indicated when the temperature is -25°C or below and the actual temperature is indicated when it is higher than -25°C and up to 73°C.
07	Tho-D (Discharge pipe temp.)	L,31~136	1°C	[L] is indicated when the temperature is 31°C or below and the actual temperature is indicated when it is higher than 31°C and up to 136°C.
10	Tho-C (Under-dome temp.) (CM1)	L,5~80	1°C	[L] is indicated when the temperature is 5°C or below and the actual temperature is indicated when it is higher than 5°C and up to 80°C.
12	Tho-P (Power transistor temp.) (CM1)	L,31~136	1°C	[L] is indicated when the temperature is 31°C or below and the actual temperature is indicated when it is higher than 31°C and up to 136°C.
16	Tho-S (Suction pipe temp.)	L,-25~73	1°C	[L] is indicated when the temperature is -25°C or below and the actual temperature is indicated when it is higher than -25°C and up to 73°C.
18	Super heat	0~50	0.1°C	
20	CT1 (CM1) Current	0~50	1A	
22	EEVH Heating expansion valve opening angle	0~500	1 Pulse	
25	EEVC Expansion Valve opening angle for ending cooling.	0~500	1 Pulse	
26	FM01 Number of rotations			Order of 100: UH, Order of 10: H Order of 1: L
27	FM02 Number of rotations			Order of 100: UH, Order of 10: H Order of 1: L
28	PSH (Hi pressure sensor)	0~5.00	0.01MPa	
29	PSL (Low pressure sensor)	0~2.00	0.01MPa	
30	Crankcase heater	0,1	—	Order of 100: —, Order of 10: CH1, Order of 1: — (0: OFF, 1: ON)
32	SV2, SV3	0,1	—	Order of 100: —, Order of 10: SV2 Order of 1: SV3 (0: close, 1: open)
34	20S	0,1	—	Order of 100: 20S, Order of 10: — Order of 1: — (0: close, 1: open)
35	Compressor stop causes ①	0,1	—	Order of 100 : Defective under-dome thermistor Order of 10 : Defective outdoor unit heat exchanger thermistor Order of 1 : — (0:Normal, 1: Anomaly)
36	Compressor stop causes ②	0,1	—	Order of 100 : — Order of 10 : — Order of 1 : —Defective discharge pipe thermistor (0:Normal, 1: Anomaly)
37	Compressor stop causes ③	0,1	—	Order of 100 : Defective under-dome thermistor Order of 10 : Anomalous high pressure Order of 1 : — (0:Normal, 1: Anomaly)
38	Compressor stop causes ④	0,1	—	Order of 100 : Defective suction pipe thermistor Order of 10 : Defective low pressure sensor Order of 1 : Defective high pressure sensor (0:Normal, 1: Anomaly)
39	Compressor stop causes ⑤	0,1	—	Order of 100 : Anomalous in inverter 1 communication Order of 10 : — Order of 1 : Anomalous high pressure (0:Normal, 1: Anomaly)
40	Compressor stop causes ⑥	0,1	—	Order of 100 : Anomalous low pressure Order of 10 : Anomalous discharge pipe temp. Order of 1 : — (0:Normal, 1: Anomaly)
41	Compressor stop causes ⑦	0,1	—	Order of 100 : Defect CM1 starting Order of 10 : — Order of 1 : CM1 Rotor lock (0:Normal, 1: Anomaly)
42	Compressor stop causes ⑧	0,1	—	Order of 100 : — Order of 10 : CM1 Current cut Order of 1 : — (0:Normal, 1: Anomaly)
43	Compressor stop causes ⑨	0,1	—	Order of 100 : Power transistor overheating Order of 10 : — Order of 1 : 0 (0:Normal, 1: Anomaly)
44	Compressor stop causes ⑩	0,1	—	Order of 100 : Heating high pressure protection Order of 10 : Stop command from indoor Order of 1 : 0 (0:Normal, 1: Anomaly)
45	Compressor stop causes ⑪	0,1	—	Order of 100 : Dilution protection Order of 10 : Demand control 0% Order of 1 : Low frequency protection (0:Normal, 1: Anomaly)
46	Control status	0,1	—	Order of 100 : During equal oil control Order of 10 : During oil return control Order of 1 : During defrost (0:Non-operative, 1: Operation)



Code No.	Contents of display	Data display range	Minimum units	Remarks
47	Control status	0,1	–	Order of 100 : During discharge temp. control Order of 10 : During high pressure control Order of 1 : During current safe control (0:Non-operative, 1: Operation)
48	Control status	0,1	–	Order of 100 : During low pressure control Order of 10 : During power transistor control Order of 1 : – (0:Non-operative, 1: Operation)
49	Control status	0,1	–	Order of 100 : Cooling high pressure protection control Order of 10 : High pressure power ratio Order of 1 : – (0:Non-operative, 1: Operation)
50	Number of connected indoor unit	0~50	1	
51	Number of operation indoor unit	0~50	1	
52	Required Hz total	0~999	1Hz	
53	Target Fk	0~999	1Hz	
54	Compressor cumulative operating time (CM1)	0~655	100h	
56	Discharge pressure saturation temperature	-50~70	0.1°C	1°C at -10 or lower
57	Air inlet pressure saturation temperature	-50~30	0.1°C	1°C at -10 or lower
58	Target cooling low pressure	0.60~0.90	0.01MPa	
63	Inverter 1 operating frequency command	0~120	1Hz	
66	Control status	0,1	–	Order of 100 : During silent mode Order of 10 : During capacity measurement mode Order of 1 : During test operation (0:Non-operative, 1: Operation)
67	Control status	0. 1	–	Order of 100 : Unmatch Order of 10 : Indoor EEV check Order of 1 : Refrigerant volume measurement (0:Non-operative, 1: Operation)
68	Control status	0. 1	–	Order of 100 : Piping cleaning Order of 10 : – Order of 1 : – (0:Non-operative, 1: Operation)
75	Snow protection fan control	0,1	–	0: Snow protection fan control deactivated 1: Snow protection fan control activated
76	Check operation	0,1	–	0: Not implemented 1: Completed
77	Data reset	---, dEL	–	
80	Counter · Thermistor disconnection	0~2	–	
81	Counter · Inverter communications error	0~3	–	
82	Counter · High pressure protection	0,1	–	
83	Counter · Compressor 1 starting failure	0,1	–	
84	Counter · Anomalous low pressure ①	0~4	–	
87	Counter · Motor lock of compressor	0~3	–	
88	Counter · Overheating of power transistor	0~4	–	
89	Counter · Anomalous temp. of discharge pipe	0,1	–	
91	Counter · Current cut (CM1)	0~3	–	
93	Counter · Indoor-outdoor communications error	0~255	–	
95	Counter · CPU reset	0~255	–	
96	Counter · Anomalous FM01	0~255	–	
97	Counter · Anomalous FM02	0~255	–	
98	Program version	–	–	Example (2.11)
99	Auto send display	–	–	

## (20) Saving of Operation Data

Operating data for a period of 30 minutes prior to the time when trouble occurs are recorded, and these data can be fetched to a personal computer through the RS232C connector on the control board. Data are updated continuously, and when there is an anomalous stop, data updates stop at that point. Pressing DIP switch SW7 for 3 seconds causes the data to be erased. Data can also be sampled at 1 minutes intervals during operation and fetched to a personal computer.

Code No.	Write-in contents	Record data			
		Data write-in range	Write-in unit	Number of bytes	Contents
1	Anomaly code	00~99	—	1	00: No anomalous, outdoor unit all anomalous ???
2	Address of unit where trouble occurred	00~FF	—	1	0~3F: Outdoor side, 40~6F: Indoor side
3	Operation mode	0~4	—	1	0 Stop
					2 Cooling
					4 Heating
4	High pressure sensor	0.00~6.00	A/D value	1	
5	Low pressure sensor	0.00~1.00	A/D value	1	
6	Tho-R1 (Heat exchanger temp. 1)	-35~75	A/D value	2	
10	Tho-D (Discharge pipe temp.) (CM1)	20~140	A/D value	1	
14	Tho-A (Outdoor air temp.)	-30~40	A/D value	1	
15	Tho-P (Power transistor temp.) (Heat dissipation fin)	20~140	A/D value	1	
16	Tho-C (Under-dome temp.)	-15~75	A/D value	2	
17	Tho-S (Suction pipe temp.)	-35~75	A/D value	2	
20	CT1 Current	0~50	A/D value	1	
24	Power source voltage	180~220	A/D value	1	
26	Solenoid valve	—	—	1	Bit0 20S 0:OFF, 1:ON
					Bit2 SV2 0:OFF, 1:ON
					Bit3 SV3 0:OFF, 1:ON
27	Crankcase heater etc.	—	—	1	Bit0 CH 0:OFF, 1:ON
28	Fan speed	0~15	1 speed	1	
31	FM1(AC) speed	0~3	1 speed	1	0:OFF, 1:Lo, 2:Me, 3:Hi
32	FM2(AC) speed	0~3	1 speed	1	0:OFF, 1:Lo, 2:Me, 3:Hi
34	EEV-c opening angle	0~65535	1 pulse	2	
35	EEV-h opening angle	0~65535	1pulse	2	
36	Indoor unit connection number	0~255	1 unit	1	
37	Indoor unit connection capacity	0~65535	—	2	
38	Indoor unit thermostat ON number	0~255	1 unit	1	
39	Indoor unit thermostat ON capacity	0~65535	—	2	
40	Required Hz total	0~65535	1Hz	2	
41	Target Fk	0~65535	1Hz	2	
42	Inverter CM1 operation frequency	0~255	1Hz	1	
44	Answer Hz total	0~65535	1Hz	2	
45	Expansion valve compensation frequency (Heating thermostat OFF)	0~255	1Hz	1	
48	CM1 Cumulative operating time (estimated)	0~65535	1h	2	
49	CM1 Compressor start times	0~65535	20 times	2	
50	Compressor stop causes	—	—	1	Bit0 Defective outdoor temperature thermistor
					Bit1 Defective outdoor unit heat exchanger thermistor
					Bit2 Defective low pressure sensor
					Bit3 Inverter anomalous communication
					Bit4 Anomalous high pressure
					Bit5 Defect inverter starting
					Bit6 Anomalous low pressure
					Bit7 Rata lock
51	Compressor stop causes	—	—	1	Bit0 Power transistor overheating
					Bit1 Defective discharge pipe thermistor
					Bit2 Anomalous discharge pipe temp.
					Bit3 Current cut
					Bit4 Anomalous heat exchanger and high pressure
					Bit5 Defective high pressure sensor
					Bit6 Defective suction pipe thermistor
					Bit7 Defective under-dome thermistor
52	Compressor stop causes	—	—	1	Bit0 —
					Bit1 Low frequency protective stop
					Bit2 Indoor stop command
					Bit3 Dilution protective stop
					Bit4 Stop by Demand
					Bit5 High pressure protective stop
					Bit6 Operating mode switching stop
					Bit7 —
53	Control status	0~180	1 second	1	CM1 3-minute delay timer

Code No.	Write-in contents	Record data			
		Data write-in range	Write-in unit	Number of bytes	Contents
59	Control status oil return	0~2	—	1	0 None
					1 Waiting for oil return
					2 Under for oil return
60	Control status defrost conditions	0~3	—	1	0 None
					1 Temperature conditions
					2 Strengthening temperature conditions
					3 Time conditions
61	Control status defrost status	0~6	—	1	0 None
					1 Frequency down & maintain
					2 —
					3 To maximum frequency
					4 Until end conditions are established
					5 Frequency down and maintain
					6 Defrost end operation
62	Control status Td	0~4	—	1	0 None
					1 Frequency down
					2 Holding frequency
					3 Waiting for cancel
					4 Establishing cancel conditions
63	Control status	0, 1	—	1	Discharge pipe temperature thermistor error counter
64	Control status HP	0~4	—	1	0 None
					1 Frequency down
					2 Holding frequency
					3 Waiting for cancel
					4 Establishing cancel conditions
65	Control status	0, 1	—	1	HP Error counter
66	Control status CS	0~4	—	1	0 None
					1 Frequency down
					2 Holding frequency
					3 Waiting for cancel
					4 Establishing cancel conditions
67	Control status LP	0~4	—	1	0 None
					1 Frequency down
					2 Holding frequency
					3 Waiting for cancel
					4 Establishing cancel conditions
68	Control status	0, 1	—	1	LP Error counter
72	Control status PT	0~4	—	1	0 None
					1 Frequency down
					2 Holding frequency
					3 Waiting for cancel
					4 Establishing cancel conditions
74	Control status CH compressor protective start	0~17	—	1	0~16 During protective start
					17 Protective start end
75	Control status	0, 1	—	1	External operation (CnS1) 0: Operation prohibition 1: Operation permission
76	Control status	0, 1	—	1	Demand (CnS2) 0: None 1: Under control
77	Control status	0, 1	—	1	Demand (CnG1) 0: None 1: Under control
78	Control status	0, 1	—	1	Demand (CnG2) 0: None 1: Under control
80	Control status	0~3	—	1	Inverter · Current cut anomaly counter
81	Control status	0~4	—	1	Inverter · Power transistor overheating anomaly counter
82	Control status	0~3	—	1	Inverter · Rotor lock anomaly counter
83	Control status	0~1	—	1	Inverter · Starting failure counter
84	Control status	0~3	—	1	Inverter · Communications anomaly counter
88	Control status	0~2	—	1	Thermistor disconnection counter
89	Control status	0, 1	—	1	Frequency release operation 0: None 1: Under control
90	Registered indoor units 1~8 operation mode	0~4	—	8	0: AUTO
					1: DRY
					2: COOL
					3: FAN
					4: HEAT
91	Registered indoor units 1~8 required Hz	0~255	1Hz	8	
92	Registered indoor units 1~8 answer Hz	0~255	1Hz	8	
93	Registered indoor units 1~8 local control	—	—	1	Operating mode unmatched
94	Registered indoor units 1~8 local control	—	—	1	Oil return

◆ **Models FDCA224HKXE4R, 280HKXE4R, 335HKXE4R**

**(1) Operations of major functional items under each operation mode**

Functional item \ Operation mode	Cooling		Fan	Heating			Dehumidify
	Thermostat ON	Thermostat OFF		Thermostat ON	Thermostat OFF	Defrost	
Indoor unit fan	Remote controller command	Remote controller command	Remote controller command	Remote controller command	Intermittent operation	○ → ×	○ / ×
Indoor unit electronic expansion valve	Overheating control response	Fully closed	Fully closed	Overheating control response	60 pulse	Model-specific aperture opening angle	Overheating Control Response
Compressor [CM1]	○	×	×	○	×	○	○ / ×
Magnetic contactor CM1 [52C1]	○	○	× / ○	○	○	○	○
Outdoor unit fan [FMO-1]	○ / ×	×	× / ○	○ / ×	×	○ → ×	○ / ×
Outdoor unit fan [FMO-2]	○	×	× / ○	○	×	○ → ×	○ / ×
Inverter cooling fan [FMC1]	○ / ×	○ / ×	×	○ / ×	○ / ×	○ / ×	○ / ×
4 way valve [20S]	×	×	×	○	○	○ → ×	×
Electronic expansion valve for heating [EEVH1, 2]	Fully open	Fully open	Fully closed	Opening Angle Control	Fully closed	Opening Angle Control	Fully open
Electronic expansion valve for sub-cooling [EEVSC]	Opening Angle Control	Fully closed	Fully closed	Opening Angle Control	Fully closed	Fully closed	Opening Angle Control
Solenoid valve [SV1]	○ / ×	×	×	○ / ×	×	○ / ×	○ / ×
Solenoid valve [SV6]	○ / ×	×	×	○ / ×	×	○ / ×	○ / ×
Solenoid valve [SV11]	×	×	×	○ / ×	×	×	×
Solenoid valve [SV12]	×	×	×	×	×	×	×
Crankcase heater [CH1]	○ / ×	○ / ×	○ / ×	○ / ×	○ / ×	○ / ×	○ / ×

Notes(1) ○ : ON, × : OFF, ○/× : ON or OFF

**(2) 4-way valve switching assurance**

When the compressor is switching from the stopped state to the start state, after the compressor start control functions, there is an increase in frequency from 10Hz (synchronous operation).

**(a) 0-20Hz Operation**

It operates in the range of 0 – 20Hz. However, in this operation, the compressor cannot be operated with the current safe, high pressure controls, low pressure controls, power transistor temp. controls, discharge temp. control, under-dome temp. control or compression ratio protection controls.

**(b) 20 – 40Hz (49) Operation**

Maximum frequency is determined based on the temperature detected with the outdoor air temperature thermistor (Tho-A).

- 1) If the temperature is 0 °C or lower, after starting with 49Hz as the maximum frequency, it stops at 49Hz.
- 2) If the temperature is higher than 0°C, after starting with 40Hz as the maximum frequency, it stops at 40Hz. However, if the starting conditions for current safe, high pressure controls, low pressure controls, power transistor temp. controls, discharge temp. controls or compression ratio protection controls are satisfied during this time, this control ends and control according to current safe, high pressure controls, low pressure controls, power transistor temp. controls, discharge temp. controls, under-dome temp. control or compression ratio protection controls commences, and if the compressor's frequency is determined and cancelled, operation returns to normal operation.

### (3) Compressor protective start

After 4-way valve switching assurance is completed, the following compressor protection begins.

		Initial Start (Remote controller ON error cancel)	Thermostat ON start	
			Operation Mode Changed While Thermostat Was OFF	Operation Mode Unchanged While Thermostat Was OFF
Compressor ON count: 1st time	Less than 45 minutes after power ON	Compressor protective start B according to crankcase heater's power ON time	Compressor protective start B according to crankcase heater's power ON time	Compressor protective start B according to crankcase heater's power ON time
	45 minutes or more after power ON	Compressor protective start A according to crankcase heater's power ON time	Compressor protective start A according to crankcase heater's power ON time	Compressor protective start A according to crankcase heater's power ON time
Compressor ON count: From 2nd time	Less than 45 minutes after stop	Protective start	Protective start	Protective start
	45 minutes or more after stop	Compressor protective start A according to crankcase heater's power ON time	Compressor protective start A according to crankcase heater's power ON time	Compressor protective start A according to crankcase heater's power ON time

Note: If the under-dome temperature exceeds 30°C, compressor protective start A and B end and operation starts.

#### (a) Compressor protective start

The compressor's speed is controlled as follows, regardless of the target frequency.

- 1) Operation occurs at 20Hz for a 1 minute 45 second period following a compressor start.
- 2) Operation occurs in accordance with pressure control after the post-start 1 minute 45 second period.

#### (b) Compressor protective start sequence "A" according to crankcase heater power ON time

The cumulative power ON time from power ON is calculated, and compressor protective start sequence "A" control occurs at the 1st compressor start after a 45-minute period, and at all subsequent compressor starts that follow a power ON after a compressor stop of 45 minutes or longer.

- 1) The inverter is set to 20Hz following 4-way valve switching assurance. The target frequency is then established 1 minute after a 1-minute period has elapsed since the frequency reduction to 20Hz was reached.
- 2) During a 15-minute period following the start, the 20Hz frequency is increased at a rate of 5Hz per minute, and the start of the 15-minute period becomes the inverter's start completion point (10Hz).
- 3) If the inverter is stopped within a 15-minute period after a compressor start, this control increases the frequency 5Hz per minute for 15 minutes when the compressor starts again.


#### (c) Compressor protective start sequence "B" according to crankcase heater power ON time

The cumulative power ON time from power ON is calculated, and compressor protective start sequence "B" control occurs at the 1st compressor start within a 45-minute period.

- 1) The inverter is set to 20Hz following 4-way valve switching assurance. The target frequency is then established 1 minute after a 1-minute period has elapsed since the frequency reduction to 20Hz was reached.
- 2) During a 18-minute period following the start, the 20Hz frequency is increased at a rate of 5Hz per minute, and the start of the 18-minute period becomes the inverter's start completion point (10Hz).
- 3) The frequency is increased 5Hz per minute through the 18-minute to 24-minute period, and this control ends when 24 minutes is reached.
- 4) After this control ends 1 time, the system reverts to protective start "A" control from the 2nd time, or after 45 minutes have elapsed.
- 5) If the inverter is stopped for 24 minutes following a compressor start, a protective start is performed when started again, and protective start sequence "B" control increases the frequency for a period of 24 minutes. However, the system reverts to protective start sequence "A" control when started again if 45 minutes or more have elapsed since the inverter stop.

#### (4) Cooling high pressure control

- 2-unit operation is switched to 1-unit operation by the outdoor fan speed running at high pressure.




Control termination conditions

- 1) When a mode other than cooling or dehumidifying is selected.
- 2) When compressor stops

#### (5) Cooling low pressure control

During cooling and dehumidifying operations, a constant low pressure is maintained by compressor frequency control.

- (a) After compressor protective start ends (1 minute 45 seconds), the compressor's frequency is controlled as shown below.



Unit: MPa

Model	LPS (1)	LPS (2)	LPS (3)
224	0.80	0.75	0.70
280	0.82	0.77	0.73
335	0.82	0.79	0.76

- (b) Control termination conditions

- (i) When a mode other than cooling or dehumidifying is selected.
- (ii) When the compressor stops.

#### (6) Heating high pressure control

During heating operation, a constant high pressure is maintained by compressor frequency control.

- (a) Control activation condition

1 minute 45 seconds have elapsed since the completion of a compressor protective start.

- (b) Control description

The compressor frequency is controlled to maintain a high pressure of 2.75Mpa.


- (c) Control termination conditions

- (i) When a mode other than heating is selected.
- (ii) When the compressor stops.

## (7) Heating low pressure control

Low pressure is controlled in accordance with the outdoor unit's fan speed during a heating operation.

- After compressor protective start ends (1 minute 45 seconds), when the low pressure is 0.80 MPa or higher, this control is activated.
- The outdoor unit's fan speed is controlled in accordance with the low pressure by switching between 2-unit and 1-unit operation.



Control termination conditions

- When a mode other than heating is selected.
- When the compressor stops.

## (8) Emergency stop control

When an indoor unit's external input (optional: refrigerant leakage, etc.) indicates a refrigerant leak, that information is transmitted to the outdoor unit, stopping operation. An emergency stop error is then transmitted to all indoor units that are running.

- Error stop occurs when the "emergency stop" command is received from the indoor unit.
- Error code E63 occurs, and the "emergency stop" command is transmitted to all indoor units.
- When a "emergency stop clear" command is received from the indoor unit, the outdoor unit's error status is cleared, and an "emergency stop clear" command is transmitted to all the indoor units.

## (9) Compression ratio protection control

The frequency is reduced in accordance with the compressor's compression ratio.


### (a) Control activation conditions

This control is activated when all the following conditions are satisfied.

- When 10 minutes or more have elapsed since the compressor start.
- When the low pressure is 0.18MPa or higher, and the high pressure is 3.52MPa or lower.

Note (1) The above does not apply for a 10-minute period following a defrost, or when pump-down control is in progress.

### (b) Control description



### (c) Control termination conditions

Control ends when any one of the following conditions is satisfied.

- When the low pressure is 0.18MPa or higher, and the high pressure is 3.52MPa or lower.
- When the compression ratio falls below the cancel value.

## (10) Outdoor fan control

### (a) DC fan motor control

The outdoor fan tap has 0 speed to 4nd speed assigned as the regular speed depending on the model and operation mode. Under normal operation, 1st speed and 4nd speed is used, and in each outdoor fan control, control is stepless between 1st speed and 4nd speed.

### (b) Outdoor fan tap

Unit:  $\text{min}^{-1}$

Fan tap	FDCA224, 280				FDCA335			
	Cooling		Heating		Cooling		Heating	
	FM <sub>O1</sub>	FM <sub>O2</sub>	FM <sub>O1</sub>	FM <sub>O2</sub>	FM <sub>O1</sub>	FM <sub>O2</sub>	FM <sub>O1</sub>	FM <sub>O2</sub>
1th speed	0	160	0	160	0	160	0	160
2th speed	0	400	0	400	0	400	0	400
3th speed	160	160	160	160	160	160	160	160
4th speed	835	835	835	835	1060	1060	1060	1060

### (c) When operation is starting, operation is at 4nd speed.

### (d) Judgment of whether or not to start the DC fan motor

- If the outdoor fan starts after stopping, the fan speed is checked and start control is performed.
- If the unit is stopped (free-running state) and the fan speed is in reverse, either FM<sub>O1</sub> or FM<sub>O2</sub> is  $700 \text{ min}^{-1}$  or higher, it is not started, and if both FM<sub>O1</sub> and FM<sub>O2</sub> is under  $700 \text{ min}^{-1}$  for 3 seconds, it is started.
- The compressor is started regardless of the state of the outdoor fan, and the above contents are sensed 5 seconds or more after the time that 52C1 goes ON.


## (11) Snow protection fan control

### (a) This control is enabled/disabled by the selector switch at the 7-segment display.

- Set the Code No. to "75".
- "0" or "1" displays at the data display area.  
0: Outdoor fan control disabled (factory setting)  
1: Outdoor fan control enabled
- Press SW7 continuously for 3 seconds.
- "0" or "1" blinks every 0.5 seconds at the data display area.
- Press SW8 to toggle between the blinking "0" and "1" displays.
- If SW7 is pressed for 3 seconds or longer while "0" and "1" is blinking, the blinking stops, and that enabled/disabled setting is registered. If enabled, fan control occurs as described below.
- Outdoor fan control occurs in accordance with the information stored in memory, even if the power is turned OFF and back ON again.

### (b) Control description

- If the outside temperature drops to  $3^{\circ}\text{C}$  or lower when all units are stopped, or during an error stop, the outdoor fan runs at level 4 speed once every 10 minutes.



Outdoor air temperature ( $^{\circ}\text{C}$ )


- The outdoor fan runs for 30 seconds.
- During this snow protection control, the compressor's magnetic contactor (52C1) is ON.



## (12) Silent mode control


- (a) If the silent mode start signal is received from an indoor unit or CnG2 (with short pin) is shorted, if the outdoor temperature is within the following range, operation is performed in the silent mode.

### • Cooling



Outdoor air temperature (°C)

### • Heating



Outdoor air temperature (°C)

- (b) Outdoor fan upper limit speed, compressor upper limit operating speed (other than for 30 seconds after startup and during defrost operation).

model \ Item	Upper limit fan speed	Upper limit compressor operating speed
FDCA224	400 min <sup>-1</sup>	58 Hz
FDCA280	400 min <sup>-1</sup>	76 Hz
FDCA335	500 min <sup>-1</sup>	79 Hz

## (13) Forced heating/cooling operation

With this control, SW3-7 on the outdoor unit PCB is turned on and CnG1 (equipped with short circuit pin) is shorted or opened so as to forcibly determine whether the indoor unit is operated for cooling or heating. If any operation mode other than the forcible mode is commanded from the indoor unit, the mode unmatched message is displayed on the remote controller or others and the operation enters in the blowing mode.

SW3-7	CnG1	Operation
OFF	Open/short	Normal operation
ON	Open	Cooling
	Short	Heating

Note (1) SW-7 is at OFF and CnG1 is open at the shipping from factory.

## (14) Indoor unit connection number protection

If the number of indoor units on the connection exceeds the number as listed below, the compressor stops with the error stop.

model \ Item	All model
Number of units on connection	20 units

Note (1) They are the numbers of units used for judgement of error for the purpose of control and not equal to the numbers of units which can be connected.

## (15) Defrosting


### (a) Temperature condition defrosting

#### (i) Conditions for starting defrosting

When all the following conditions are met, the defrosting operation will start.

- 1) The cumulative operating time of the compressor comes up to 33 minutes after completion of a defrosting operation, or it comes up to 33 minutes after a heating operation starts (the remote controller is turned on).
- 2) If 8 minutes have passed after the compressor goes ON after it has gone OFF.
- 3) If 8 minutes have passed after one outdoor unit fan goes ON after all outdoor fans have gone OFF.
- 4) After all the above conditions are satisfied,

when the temperature at the outdoor heat exchanger thermistor (Tho-R) and outdoor temperature thermistor is below the defrost initiation temperature in the above graph continuously for 3 minutes.



## (ii) Conditions for finishing defrosting

- Standard (J14: shorted)
  - 1) When the increase of the temperature of the heat exchanger thermistor (Tho-R1 or Tho-R2) is greater than 9°C.
  - 2) When 12 minutes have passed since defrosting started.
- With operation Judgment Function (J14: Open)
  - 1) If Tho-R1 and R2 are  $\geq 9^{\circ}\text{C}$ , after 2 minutes and 30 seconds have passed since defrosting started, if either of the following conditions is satisfied, the defrosting end operation starts.
    - a) 2 minutes and 30 seconds have passed since the temperature sensed by either Tho-R1 or Tho-R2 is 14°C or higher.
    - b) The temperature sensed by either Tho-R1 or Tho-R2 is 30°C or higher.
    - c) 14 minutes have passed since the start of defrosting.
  - 2) If Tho-R1 or R2 are  $< 9^{\circ}\text{C}$  after 2 minutes and 30 seconds have passed since defrosting started, if either of the following conditions is satisfied, the defrosting end operation starts.
    - a) 5 minutes have passed since the temperature sensed by either Tho-R1 or Tho-R2 is 14°C or higher.
    - b) The temperature sensed by either Tho-R1 or Tho-R2 is 30°C or higher.
    - c) 14 minutes have passed since the start of defrosting.

## (b) Time condition defrosting (oil return)

### (i) Defrosting start conditions

- 1) Defrosting starts when the heating mode is in effect at the 1st compressor start following a power ON, and when the heating mode is in effect after 2 hours of cumulative operation time. However, if mode switching from cooling to heating occurred, defrosting starts 33 minutes after CM1 operation begins.
- 2) If there was 5 minutes or more of temperature condition defrosting before time condition defrosting, the 10-hour timer for time condition defrosting is reset.
- 3) The "time condition defrosting" time is the point when the detected oil rise amount reaches the setting value (following 2 hours of cumulative compressor operation time counting from the 1st compressor start after power ON), or the point when 10 hours elapse, whichever comes first.
- 4) When the 10-hour timer period elapses, time condition defrosting occurs at the completion of the previous temperature condition defrosting operation, or after 33 minutes, whichever comes first.


### (ii) Defrosting end conditions

If either of the following conditions is satisfied, the defrosting end operation starts.


- 1) If defrosting continues for 5 minutes and the temperature sensed by Tho-R1 and Tho-R2 becomes 9°C or higher.
- 2) If 12 minutes has passed since defrosting started.

## (16) Oil separator solenoid valve (SV6) control

- (a) If the inverter compressor starts, solenoid valve SV6 opens (goes ON), then 15 seconds later, it starts.
- (b) SV6 stays open (ON) for 3 minutes, until compressor protective start are completed.
- (c) If the compressor operating frequency becomes 80Hz or higher, SV6 opens (goes ON) and it goes off if the frequency is 76Hz or lower.



- (d) If the inverter compressor goes off after SV6 opens (goes ON), SV6 remains open (ON) for 3 minutes and 10 seconds, then closes (goes OFF).



## (17) Unit protective maintenance related devices

### (a) Test operation mode

- Outdoor unit test operation mode operation is started by the DIP switches SW5-1 and 5-2 on the outdoor unit control board.

#### Switch functions


SW5-1	ON	SW5-2	OFF	Heating Test Operation
	OFF		ON	Cooling Test Operation
	OFF	Normal or Test Operation End		

Notes (1) Leave all DIP Switches except 5-1 and 5-2 OFF.


(2) This operation takes priority over other options such as the center console. It sets the options in the operating state.

### (b) Under-dome temperature control


- The oil separator solenoid valve (SV6) are controlled in accordance with the temperature at the under-dome thermistor (Tho-C) installed on the compressor.



- The compressor's capacity is controlled in accordance with the under-dome temperature (Tho-C).




- The cooling solenoid (SV1) is controlled in accordance with the under-dome temperature (Tho-C).



### (c) Cooling high pressure protective control

- During cooling and dehumidifying operation, if the high pressure sensor (PSH) exceeds the cooling high pressure upper limit value while the compressor is ON. However, this is not valid until the frequency reaches 20 Hz after the inverter starts.




- When the high pressure exceeds the cooling high pressure upper limit value, the compressor's capacity drops, then after 5 seconds pass, if the cooling high pressure upper limit is still exceeded, the capacity is lowered still further.
- If the high pressure drops below the cooling high pressure upper limit value, and that condition continues for 1 minute. After that, control returns to cooling normal control.

**(d) Heating high pressure protective control**

**(i) Compressor capability control by high pressure**

- 1) During heating, if the high pressure sensor (PSH) exceeds the heating high pressure upper limit value while the compressor is ON. However, this is not valid until the frequency reaches 20 Hz after the inverter starts.



- 2) When the high pressure exceeds the heating high pressure upper limit value, the compressor's capacity drops, then after 5 seconds pass, if the heating high pressure upper limit is still exceeded, the capacity is lowered still further.
- 3) If the high pressure drops below the heating high pressure upper limit value, and that condition continues for 1 minute. After that, control returns to heating normal control.

**(ii) Outdoor unit fan speed control in accordance with high pressure**

- 1) Starting conditions


When the high pressure is 3.0 MPa or greater after compressor protection start and end (1 min. 45 sec.).

- 2) Control contents

a) Fan speed is controlled between 160 to 835 (1060)  $\text{min}^{-1}$ . Fan motors 01 and 2 have the same speed.

Note (1) The values in parentheses are for FDCA335.


b) When the high pressure reaches or exceeds the following values, the fan motor FM01 (right side) is stopped.



- 3) Under the following conditions, outdoor unit fan speed control is ended.
  - a) When the mode has been switched from heating operation to another mode.
  - b) If the compressor stops.
  - c) When the high pressure is below 3.0 MPa.

**(iii) Solenoid Valve (SV6) Control**


- 1) The solenoid valve (SV6) goes ON when the high pressure (sensed by PSH) rises to 3.5 MPa or higher during heating operation.



- 2) Under the following conditions, solenoid valve (SV6) control is ended.
  - When the mode has been switched from heating operation to another mode.
  - If the compressor stops.
  - If the high pressure (sensed by PSH) becomes lower than 3.0 MPa.

**(e) Inverter cooling fan control**

- (i) Inverter power transistor temperature rises are controlled by the cooling fan (FMC) in accordance with the temperature sensed by the power transistor temperature thermistor (Tho-P) after the inverter starts.




- (ii) A cooling fan ON status is maintained for 3 minutes 10 seconds if the cooling fan (FMC) is ON when the compressor is switched from ON to OFF.


**(f) Discharge pipe temperature control**

If the discharge pipe temperature (sensed by Tho-D) exceeds the set value, the compressor cooling solenoid valve (SV1) goes ON, the indoor expansion valve opens and the compressor's capacity is controlled, thus suppressing rises in the discharge pipe temperature. If the temperature rises even further, the compressor stops.

- (i) Compressor Cooling Solenoid Valve (SV1) Control




- (ii) Compressor control



- (iii) Discharge pipe temperature error

- When the discharge pipe temperatures (Tho-D detection) rise beyond 130°C and is maintained for 2 seconds, the compressors are stopped but it will be reset if the temperatures drop below 90°C.



- If the discharge pipe temperature (Tho-D detection) occurs twice within 60 minutes or the condition higher than 130 °C has continued for 60 minutes including the duration of time of compressor stop, the unit operation is stopped with the error stop.

Note (1) Unless the temperature of 90 °C or under is maintained for 45 minutes after the discharge pipe error, the unit cannot be started again. (Reset the power supply to clear.)

**(g) Current safe control**

- (i) The compressor speed is reduced if the inverter inlet's input voltage (converter inlet L3-phase) exceeds the setting value. If the input voltage still remains above the setting value, the speed is reduced again.
- (ii) This control ends when the input voltage drops below the setting value for 3 continuous minutes.

**(h) Current cut control**

Cuts an inverter overcurrent. When the current exceeds the setting value, the inverter is immediately stopped, and is then automatically restarted 3 minutes later. If 4 overcurrent cuts occur within a 15-minute period, 52C1 is switched OFF, and an error stop status is established.

**(i) Anomalous high pressure increase protection**


If the high pressure side pressure switch [63H1: 3.8 Open / 2.9 Closed MPa] operates 5 times within 60 minutes or operates for 60 minutes, an anomalous stop is performed.

However, when first operated, the compressor is stopped, then after a 3-minute delay, normal operation is resumed.

**(j) Power transistor temperature control**


If the temperature of the power transistor cooling fins (sensed by Tho-P) exceeds the set value, the compressor's capacity is controlled to keep the power transistor's temperature from rising. If it rises still higher, the compressor is stopped.

1) Compressor control



2) Power transistor temperature anomaly

- If the temperature sensed by the power transistor temperature thermistor rises to 110°C or higher, the compressor is stopped.




- If the power transistor's temperature is anomalous 5 times within 60 minutes, or if the temperature is 110°C or higher for 60 minutes continuously, including when the compressor is stopped, an anomalous stop is performed.

**(k) Low pressure protective control**

If the low pressure (sensed by PSL) drops below the set value, the compressor's capacity is controlled to prevent the low level pressure from dropping. If it drops still further, the compressor is stopped.

1) Compressor control




Note (1) Starting Conditions

- 1 minutes and 45 seconds have passed since starting.
- Sensed continuously for 10 seconds

2) Low pressure anomaly

- If the low pressure (sensed by PSL) drops to 0.134 MPa or lower continuously for 30 seconds, the compressor is stopped and if a pressure of 0.18 MPa or higher is detected continuously for 10 seconds, the compressor is automatically reset. If this occurs 2 times within 60 minutes, an anomalous stop is performed.



- A low pressure (sensed by PSL) of 0.18 MPa or lower while the compressor is stopped, or sensed continuously for 30 seconds while the compressor is operating, is prohibited.
- First cooling operation after the power is turned on

If a low pressure of 0.003 MPa or lower is detected continuously for 60 seconds after 4-way valve switching assurance, the compressor is stopped, and if a low pressure of 0.18 MPa or higher is detected continuously for 10 seconds, the compressor is restarted automatically, but if an anomalous pressure is detected again, an anomalous stop is performed. It is possible to reset the system only by turning the power off, then turning it on again.

## **(18) Pump down control**

Pump down operation can be performed through operation of DIP switches (SW5-1, 2, 3). (Pump down operation cannot be done during indoor unit operation, backup operation or during an anomalous stop.)

### **(a) Pump down procedure**

- 1) Close the liquid side service valve on the outdoor unit.
- 2) Turn SW5-2 (test operation operating mode) ON (cooling).
- 3) Turn SW5-3 (pump down switch) ON.
- 4) Turn SW5-1 (test operation switch) ON. This will start the pump down operation.

### **(b) Control**

- 1) The compressor operates in cooling mode with 52Hz (280, 335:62Hz) as the upper frequency limit.
- 2) The red and green (LED's) on the outdoor control PCB flashes together continuously and "PoS" is displayed in the 7-segment display.
- 3) Except for low pressure control, all the protective and anomaly sensing controls are activated.
- 4) Test operation commands are sent to the indoor units.
- 5) The sub cooling coil electronic expansion valve (EEVSC) closes fully during pump down control.

### **(c) Ending**

If any of the following conditions exists, pump down operation ends.

- 1) If a low pressure (sensed by PSL) of  $\leq 0.01$  MPa is detected continuously for 5 seconds.
  - a) The displays are as follows.

· Red LED: Lights up continuously	· Green LED: flashing
· 7-segment LED display: PoE	· Remote controller: Stop
  - b) It is possible for operation to restart if the low pressure (sensed by PSL) becomes  $> 0.01$  MPa.
- 2) If operation is stopped by anomaly sensing control.
- 3) If the cumulative compressor operation time totals 15 minutes.
  - a) The displays are as follows.

· Red LED: Off	· Green LED: flashing
· 7-segment LED display: No display	· Remote controller: Stop
- 4) If any one of DIP switches SW5-1, 2 or 3 is turned OFF during the pump down operation.

## (19) External input operation



External input: From CnS1, operation permission/prohibition control; From CnS2: Demand control/normal operation switching.

- J13: Switches between CnS1 and CnS2 input method.

J13 short circuit: Level input by CnS1 and CnS2.


J13 open: Pulse input by CnS1 and CnS2.

### (a) From CnS1, operation permission/prohibition control


Input : CnS1	CnS1 input method change: J13	CnS1 : Operation permission/Prohibition mode change
	J13; Short circuit Lever input	Operation prohibition mode → Operation permission mode
	J13; Disconnection Pulse input	Operation permission/Prohibition model change (Reversal)
	J13; Short circuit	Operation permission mode → Operation prohibition mode
	J13; Disconnection	— (NOP)

- 1) The remote controller displays the operating mode. “To Option” sends the operating mode.
- 2) CnS1, performs the following operations by the changing of jumper wire J1 from short circuit to open circuit.  
If pulse input, the pulse duration is 500 ms or more.

#### ① Operation with J13 short circuit



#### ② Operation with J13 disconnection





(b) From CnS2, operation permission/prohibition control

Input : CnS2	CnS2 input method Formula switching: J13	CnS2 : Demand control/normal operating switching
Short circuit	J13; Short circuit Level input	Demand control → Normal operation
Open circuit	J13; Open circuit Pulse input	Normal operation/Demand control switching (Reversal)
Short circuit	J13; Short circuit	Normal operation → Demand control
Open circuit	J13; Open circuit	— (NOP)

Note (1) The factory settings are: J13 - short circuit; CnS2 - short circuit (short pin connection)

1) The remote controller displays the operating mode. “To Option” sends the operating mode.

2) Demand control

It is possible to switch the demand using DIP switch SW4-5, 6.


SW45	SW4-6	Compressor output (%)
0	0	80
1	0	60
0	1	40
1	1	0

Note (1) 0: Open, 1: Shorted


3) CnS2, performs the following operations by the changing of jumper wire J13 from short circuit to open circuit.

If pulse input, the pulse duration is 500 ms or more.

① J13 - Short circuit



② J13 - Open circuit



## (20) 7-Segment display

The data in the following table can be displayed using the display select switch (SW8: 1's digit; SW9: 10's digit).

Code No.	Contents of display	Data display range	Minimum units	Remarks
–	Unusual cade Pump down Check mode Outdoor unit setup	–	–	E?? PoE, PoS CH? OPE??
00	CM1 operating frequency	0~130	1Hz	
02	Tho-A Outdoor air temp.	L,-20~43	1°C	[L] is indicated when the temperature is -20°C or below and the actual temperature is indicated when it is higher than -20°C and up to 43°C.
03	Tho-R1 Heat exchanger temp. 1 (Exit. Front)	L,-25~73	1°C	[L] is indicated when the temperature is -25°C or below and the actual temperature is indicated when it is higher than -25°C and up to 73°C.
04	Tho-R2 Heat exchanger temp. 2 (Exit. Rear)	L,-25~73	1°C	[L] is indicated when the temperature is -25°C or below and the actual temperature is indicated when it is higher than -25°C and up to 73°C.
05	Tho-R3 Heat exchanger temp. 3 (Entrance. Front)	L,-25~73	1°C	[L] is indicated when the temperature is -25°C or below and the actual temperature is indicated when it is higher than -25°C and up to 73°C.
06	Tho-R4 Heat exchanger temp. 4 (Entrance. Rear)	L,-25~73	1°C	[L] is indicated when the temperature is -25°C or below and the actual temperature is indicated when it is higher than -25°C and up to 73°C.
07	Tho-D1 Discharge pipe temp.	L,31~136	1°C	[L] is indicated when the temperature is 31°C or below and the actual temperature is indicated when it is higher than 31°C and up to 136°C.
10	Tho-C1 Under-dome temp.	L,5~90	1°C	[L] is indicated when the temperature is 5°C or below and the actual temperature is indicated when it is higher than 5°C and up to 80°C.
12	Tho-P1 Power transistor temp.	L,31~136	1°C	[L] is indicated when the temperature is 31°C or below and the actual temperature is indicated when it is higher than 31°C and up to 136°C.
14	Tho-SC Sub-cooling coil temp.1	L,18~73	1°C	[L] is indicated when the temperature is 18°C or below and the actual temperature is indicated when it is higher than 18°C and up to 73°C.
15	Tho-SC Sub-cooling coil temp.2	L,-25~73	1°C	[L] is indicated when the temperature is -25°C or below and the actual temperature is indicated when it is higher than -25°C and up to 73°C.
16	Tho-S Suction pipe temp.	L,-25~73	1°C	[L] is indicated when the temperature is -25°C or below and the actual temperature is indicated when it is higher than -25°C and up to 73°C.
17	Cooling operation super cooling	0~50	0.1°C	
18	Super heat	0~50	0.1°C	
19	Superheat of sub-cooling coil	0~50	0.1°C	
20	CT1 Current	0~50	1A	
22	EEVH1 Heating expansion valve opening angle	0~500	1 Pulse	
23	EEVH2 Heating expansion valve opening angle	0~500	1 Pulse	
24	Opening angle of EEVSC overcooling coil expansion valve	0~500	1 Pulse	
26	FM01 Number of rotations	0~999	10 min <sup>-1</sup>	
27	FM02 Number of rotations	0~999	10 min <sup>-1</sup>	
28	PSH High pressure sensor	0~5.00	0.01MPa	
29	PSL Low pressure sensor	0~2.00	0.01MPa	
30	FMC1 Cooling fan Crankcase heater	0,1	–	Order of 100 : FMC1 Order of 10 : CH1 Order of 1 : – (0: OFF, 1: ON)
31	63H1	0,1	–	Order of 100 : 63H1 Order of 10 : – (0: Close, 1: Open)
32	SV1	0,1	–	Order of 100 : SV1 Order of 10 : – Order of 1 : – (0: Close, 1: Open)

Code No.	Contents of display	Data display range	Minimum units	Remarks
33	SV6	0,1	—	Order of 100 : SV6 Order of 10 : — Order of 1 : — (0: Close, 1: Open)
34	20S	0,1	—	Order of 100 : 20S, Order of 10 : — Order of 1 : — (0: close, 1: open)
35	Compressor stop causes ①	0,1	—	Order of 100 : Defective outdoor temperature thermistor Order of 10 : Defective outdoor unit heat exchanger thermistor 1 Order of 1 : Defective outdoor unit heat exchanger thermistor 2 (0:Normal, 1: Anomaly)
36	Compressor stop causes ②	0,1	—	Order of 100 : Defective outdoor unit heat exchanger thermistor 3 Order of 10 : Defective outdoor unit heat exchanger thermistor 4 Order of 1 : Defective discharge pipe thermistor (0:Normal, 1: Anomaly)
37	Compressor stop causes ③	0,1	—	Order of 100 : — Order of 10 : Defective Sub cooling coil thermistor 1 Order of 1 : Defective Sub cooling coil thermistor 2 (0:Normal, 1: Anomaly)
38	Compressor stop causes ④	0,1	—	Order of 100 : Defective suction pipe thermistor Order of 10 : Defective low pressure sensor Order of 1 : Defective high pressure sensor (0:Normal, 1: Anomaly)
39	Compressor stop causes ⑤	0,1	—	Order of 100 : Anomaly in inverter 1 Order of 10 : — Order of 1 : Anomalous high pressure (0:Normal, 1: Anomaly)
40	Compressor stop causes ⑥	0,1	—	Order of 100 : Anomalous low pressure Order of 10 : Anomalous discharge pipe thermistor Order of 1 : — (0:Normal, 1: Anomaly)
41	Compressor stop causes ⑦	0,1	—	Order of 100 : Defect CM starting Order of 10 : — Order of 1 : Rotor lock (0:Normal, 1: Anomaly)
42	Compressor stop causes ⑧	0,1	—	Order of 100 : — Order of 10 : CM Current cut Order of 1 : — (0:Normal, 1: Anomaly)
43	Compressor stop causes ⑨	0,1	—	Order of 100 : Power transistor overheating Order of 10 : — Order of 1 : Anomalous in DC fan1 (0:Normal, 1: Anomaly)
44	Compressor stop causes ⑩	0,1	—	Order of 100 : Anomalous in DC fan2 Order of 10 : Stop command from indoor Order of 1 : Operation mode charge (0:Normal, 1: Anomaly)
45	Compressor stop causes ⑪	0,1	—	Order of 100 : Dilute protection Order of 10 : Demand control 0% Order of 1 : 0 (0:Normal, 1: Anomaly)
46	Control status	0,1	—	Order of 100 : During equal oil equalization control Order of 10 : During oil return control Order of 1 : During defrost (0:Non-operation, 1: Operation)
47	Control status	0,1	—	Order of 100 : During Td control Order of 10 : During HP control Order of 1 : During CS control (0:Non-operation, 1: Operation)
48	Control status	0,1	—	Order of 100 : During LP control Order of 10 : During PT control Order of 1 : Under cooling low pressure control (0:Non-operation, 1: Operation)
49	Control status	0,1	—	Order of 100 : Cooling high pressure protection control Order of 10 : High pressure power ratio Order of 1 : Under heating low pressure control (0:Non-operation, 1: Operation)
50	Number of connected indoor unit	0~50	1	
51	Number of operation indoor unit	0~50	1	
52	Required Hz total	0~999	1Hz	
53	Target Fk	0~999	1Hz	
54	Compressor cumulative operating time (CM1)	0~655	100h	
56	Discharge pressure saturation temperature	-50~70	0.1°C	1°C at -10 or lower
57	Air inlet pressure saturation temperature	-50~30	0.1°C	1°C at -10 or lower
58	Target cooling low pressure	0.00~2.00	0.01MPa	
59	Target heating high pressure	1.60~4.15	0.01MPa	
63	Inverter 1 operating frequency command	0~130	1Hz	
66	Control status	0,1	—	Order of 100 : During silent mode Order of 10 : During capacity measurement mode Order of 1 : During test operation (0:Non-operation, 1: Operation)
67	Control status	0,1	—	Order of 100 : Unmatch Order of 10 : Indoor EEV check Order of 1 : — (0:Non-operation, 1: Operation)

Code No.	Contents of display	Data display range	Minimum units	Remarks
68	Control status	0,1	—	Order of 100 : Piping cleaning Order of 10 : Under-dome temperature control Order of 1 : Compression ratio protection control (0:Non-operation, 1: Operation)
70	Operation priority switching	0,1	—	0: Prior press priority (when shipped) 1: After press priority
71	High pressure control of cooling	2.2, 2.5	0.01MPa	2.2: Factory setting 2.5: Alternate setting
72	Low pressure control of cooling	-0.05~+0.05	0.01MPa	0.00: Factory setting
73	Heating high pressure compensation	0.00~0.30	0.01MPa	0.00: Factory setting
74	Low pressure of heating	0.80, 0.90	—	0.80: Factory setting 0.90: Alternate setting
75	Snow protection fan control	0,1	—	0: Snow protection fan control deactivated 1: Snow protection fan control activated
77	Data reset	---, dEL	—	
78	Figure language sub version	—	—	(Example: 730)
79	Figure language logic version	—	—	(Example: 126)
80	Counter · Thermistor disconnection	0~2	—	
81	Counter · Inverter 1 communications error	0~3	—	
82	Counter · High pressure protection	0~4	—	
83	Counter · Compressor 1 starting failure	0,1	—	
84	Counter · Anomalous low pressure ① (Under stop)	0~4	—	
85	Counter · Anomalous low pressure ② (Immediately after starting)	0,1	—	
86	Counter · Anomalous low pressure ③ (Under operation)	0~4	—	
87	Counter · Motor lock of compressor 1	0~3	—	
88	Counter · Overheating of power transistor 1	0~4	—	
89	Counter · Anomalous temp. of discharge pipe 1	0,1	—	
91	Counter · Current cut (CM1)	0~3	—	
93	Counter · Indoor-outdoor communications error	0~255	—	
94	Counter · Outdoor inverter communications error 2	0~255	—	
95	Counter · CPU reset	0~255	—	
96	Counter · Anomalous FM01	0~255	—	
97	Counter · Anomalous FM02	0~255	—	
98	Program version	—	—	Example (2.70)
99	Auto send display	—	—	

## (21) Saving of Operation Data

Operating data for a period of 30 minutes prior to the time when trouble occurs are recorded, and these data can be fetched to a personal computer through the RS232C connector on the control board. Data are updated continuously, and when there is an anomalous stop, data updates stop at that point. Pressing DIP switch SW7 for 3 seconds causes the data to be erased. Data can also be sampled at 1 ~ 60 second intervals during operation and fetched to a personal computer.

- Data is transmitted from a personal computer upon demand.

Data	Data Range	Example
Software version	ASCII 15-byte	KD4C270##### (#: NULL)
PID (program ID)	ASCII 2-byte	D8
Outdoor unit capacity	ASCII 3-byte	280
Power supply frequency	ASCII 2-byte	60
Outdoor address	ASCII 2-byte	00 ~ 3F
Indoor address × 16 units	ASCII 2-byte × 16 units	40 ~ 7F
Indoor capacity × 16 units	ASCII 3-byte × 16 units	022 ~ 280

Code No.	Write-in contents	Record data			
		Data write-in range	Write-in unit	Number of bytes	Contents
00	Anomaly code	00~99		1	00: No anomaly, outdoor unit all anomalous ???
01	Address of unit where trouble occurred	00~FF	–	1	0~3F: Outdoor unit side, 40~6F: Indoor unit side
02	Operation mode	0~2	–	1	0 Stop
					2 Cooling
					4 Heating
03	High pressure sensor	0.00~5.00	A/D value	1	
04	Low pressure sensor	0.00~2.00	A/D value	1	
05	Heat exchanger temp. 1 (Exit, Front)	-35~75	A/D value	2	Cooling liquid side
06	Heat exchanger temp. 2 (Exit, Rear)	-35~75	A/D value	2	Cooling liquid side
07	Heat exchanger temp. 3 (Entrance, Front)	-35~75	A/D value	2	Cooling gas side
08	Heat exchanger temp. 4 (Entrance, Rear)	-35~75	A/D value	2	Cooling gas side
09	Tho-D Discharge pipe temp.	20~140	A/D value	1	
11	Tho-C Under-dome temp.	-15~90	A/D value	1	
13	Tho-A Outdoor air temp.	-20~43	A/D value	1	
14	Tho-P Power transistor temp. (Heat dissipation fin)	20~140	A/D value	1	
16	Tho-SC Sub cooling coil temp. 1	18~73	A/D value	1	Liquid pipe side
17	Tho-H Sub cooling coil temp. 2	-35~75	A/D value	2	Suction pipe side
18	Tho-S Suction pipe temp.	-35~75	A/D value	2	
19	Cooling operation super cooling	0~50	A/D value	1	
20	Super heat	0~50	A/D value	1	
21	Super heat of sub-cooling coil	0~50	A/D value	1	
22	CT1 Current	0~50	A/D value	1	

Code No.	Write-in contents	Record data			
		Data write-in range	Write-in unit	Number of bytes	Contents
24	Power source voltage	180~500	A/D value	1	
25	Pressure switch	—	—	1	Bit0 63H1 0: open, 1: close
26	Solenoid valve	—	—	1	Bit0 20S 0:OFF, 1:ON Bit2 SV1 0:OFF, 1:ON Bit4 SV6 0:OFF, 1:ON
27	Crankcase heater etc.	—	—	1	Bit0 CH1 0:OFF, 1:ON Bit2 FM1.2 0:OFF, 1:ON
28	FM01 Number of rotations	0~65535	10 min <sup>-1</sup>	2	
29	FM02 Number of rotations	0~65535	10 min <sup>-1</sup>	2	
30	EEVH1 opening angle	0~65535	1pulse	2	
31	EEVH2 opening angle	0~65535	1pulse	2	
32	EEVSC opening angle	0~65535	1pulse	2	
34	Indoor unit connection number	0~255	1 unit	1	
35	Indoor unit connection capacity	0~65535	—	2	
36	Indoor unit thermostat ON number	0~255	1 unit	1	
37	Indoor unit thermostat ON capacity	0~65535	—	2	
38	Required Hz total	0~65535	1Hz	2	
39	Target FK	0~65535	1Hz	2	
40	Inverter CM1 operation frequency	0~255	1Hz	1	
42	Answer Hz total	0~65535	1Hz	2	
43	Compressor cumulative operating time (estimate)	0~65535	1 h	2	
45	Compressor start times	0~65535	×20 times	2	
47	Compressor stop causes			1	Bit0 Defective outdoor temperature thermistor Bit1 Defective outdoor unit heat exchanger 1 thermistor Bit2 Defective outdoor unit heat exchanger 2 thermistor Bit3 Defective outdoor unit heat exchanger 3 thermistor Bit4 Defective outdoor unit heat exchanger 4 thermistor Bit5 Defective discharge pipe thermistor Bit7 Defective sub-cooling coil thermistor 1
48	Compressor stop causes	—	—	1	Bit0 Defective sub-cooling coil thermistor 2 Bit1 Defective suction pipe thermistor Bit2 Defective low pressure sensor Bit3 Defective high pressure sensor Bit4 Inverter 1 anomalous communication Bit6 Anomalous high pressure Bit7 Anomalous Low pressure
49	Compressor stop causes	—	—	1	Bit0 Td1 Anomalous discharge pipe temp. Bit2 CM starting defect Bit4 Rotor lock of CM Bit6 Current cut of CM

Code No.	Write-in contents	Record data			
		Data write-in range	Write-in unit	Number of bytes	Contents
50	Compressor stop causes	-	-	1	Bit0 Power transistor 1 overheating
					Bit1 Power transistor 2 overheating
					Bit2 FM01 anomaly
					Bit3 FM02 anomaly
					Bit4 Compressor stop command from indoor unit
					Bit6 Dilution rate protection
					Bit7 Demand control 0%
51	Control status	0~180	1 second	1	CM 3-minute delay timer
53	Discharge pressure saturation temperature	-50~70	0.1°C	2	
54	Intake pressure saturation temperature	-50~70	0.1°C	2	
55	Control status oil return	0,1	-	1	0 None
					1 Under control
56	Control status oil return	0~2	-	1	0 None
					1 Waiting for oil return
					2 Under oil return
57	Control status defrost conditions	0~3	-	1	0 None
					1 Temperature conditions
					2 Strengthening temperature conditions
					3 Time conditions
58	Control status defrost status	0~4	-	1	0 None
					1 Defrosting status 1
					2 Defrosting status 2
					3 Defrosting status 3
					4 Defrosting status 4
59	Control status Td	0~2	-	1	0 None
					1 Frequency down
					2 Under. control
60	Control status	0, 1	-	1	Td1 error counter
62	Control status HP	0~2	-	1	0 None
					1 Frequency down
					2 Under high pressure control
63	Control status	0~1	-	1	HP error (63H1) counter
64	Control status CS	0~2	-	1	0 None
					1 Frequency down
					2 Under CS control
65	Control staus LP	0~2	-	1	0 None
					1 Frequency down
					2 Under low pressure control
66	Control status	0~3	-	1	LP error (when stopped) counter
67	Control status	0~4	-	1	LP error (when started) counter
68	Control status	0,1	-	1	LP error (when driving) counter
69	Control status PT	0~2	-	1	0 None
					1 Frequency down
					2 Under PT control
70	Check operation status	-	-	1	Bit0 Unmatch check
					Bit1 Indoor side EEV check
					Bit3 Piping cleaning
71	Control status	0~360	1 minutes	2	CH compressor protection timer
72	Control status CH compressor protective start	0~15	-	1	15 Protective start end
					0~14 During protective start
73	Switch etc.	-	-	1	External operation (CnS1)
					0: Operation prohibition
					1: Operation permission
					Demand (CnS2)
					0: None
					1: Under control
					Forced cooling, heating (CnG1)
					0: None
					1: Under control
					Silent mode (CnG2)
					0: None
					1: Under control

Code No.	Write-in contents	Record data			
		Data write-in range	Write-in unit	Number of bytes	Contents
					<div>Bit4</div> <div>Back up operation</div> <div>0: None</div> <div>1: Back up operation</div> <div>Bit5</div> <div>Hz cancel operation</div> <div>0: None</div> <div>1: Under control</div>
74	Control status	0~3	—	1	Current cut anomaly counter
75	Control status	0~4	—	1	Power transistor overheating anomaly counter
76	Control status	0~3	—	1	Rotor lock anomaly counter
77	Control status	0~1	—	1	Starting failure counter
78	Control status	0~3	—	1	Communications anomaly counter
79	Control status	0~3	—	1	Current cut anomaly counter
84	Control status	0~1	—	1	DC fan motor 1 error counter
85	Control status	0~1	—	1	DC fan motor 2 error counter
86	Control status	0~2	—	1	Sensor disconnection counter
87	Control status	0~255	—	1	Communications error counter
88	Registered indoor units 1~8 operation mode	0~4	—	8	<div>0</div> <div>AUTO</div> <div>1</div> <div>DRY</div> <div>2</div> <div>COOL</div> <div>3</div> <div>FAN</div> <div>4</div> <div>HEAT</div>
89	Registered indoor units 1~8 required Hz	0~255	1Hz	8	
90	Registered indoor units 1~8 answer Hz	0~255	1Hz	8	
91	Operation priority switching	0~1	—	1	<div>0</div> <div>Prior press priority</div> <div>1</div> <div>After press priority</div>
92	High pressure control of cooling	2.2,2.5	0.01MPa	1	
93	Cooling low pressure compensation	-0.05~+0.05	0.01MPa	1	
94	Low pressure control of heating	0.8,0.9	0.01MPa	1	
95	Snow protection fan control	0~1	—	1	<div>0</div> <div>With</div> <div>1</div> <div>None</div>
96	CM1 frequency command	0~130	1Hz	1	
98	Target cooling low pressure	0.00~2.00	0.01MPa	1	
99	Control status TC	0~2	—	1	<div>0</div> <div>None</div> <div>1</div> <div>Frequency down</div> <div>2</div> <div>Under-dome temperature control</div>
100	Target heating high pressure	1.60~4.15	0.01MPa	1	1.60MPa It shifts and outputs.
101	Heating high pressure compensation	0.00~0.30	0.01MPa	1	
102	Control / status SCR	0~2	—	1	<div>0</div> <div>None</div> <div>1</div> <div>Frequency down</div> <div>2</div> <div>Under compression ratio protection control</div>



# **All-in-one type (also for combined use) and Combined type.**

◆ **Models** FDCA335HKXE4R-K, 400HKXE4R, 450HKXE4R, 504HKXE4R, 560HKXE4R, 615HKXE4R, 680HKXE4R, 735HKXE4, 800HKXE4, 850HKXE4, 900HKXE4, 960HKXE4R, 1010HKXE4R, 1065HKXE4R, 1130HKXE4R, 1180HKXE4R, 1235HKXE4R, 1300HKXE4R, 1360HKXE4R

## **(1) Operations of major functional items under each operation mode**

Functional item	Cooling		Fan	Heating			Dehumidify
	Thermostat ON	Thermostat OFF		Thermostat ON	Thermostat OFF	Defrost	
Indoor unit fan	Remote controller command	Remote controller command	Remote controller command	Remote controller command	Intermittent operation	○ → ×	○ / ×
Indoor unit electronic expansion valve	Overheating control response	Fully closed	Fully closed	Overheating control response	60 pulse	Model-specific aperture opening angle	Overheating Control Response
Compressor [CM1]	○	×	×	○	×	○	○ / ×
Magnetic contactor CM1 [52C1]	○	○	× / ○	○	○	○	○
Compressor [CM2]	○ / ×	×	×	○ / ×	×	○	○ / ×
Magnetic contactor CM2 [52C2]	○	○	×	○	○	○	○
Outdoor unit fan [FMO-1]	○ / ×	×	× / ○	○ / ×	×	○ → ×	○ / ×
Outdoor unit fan [FMO-2]	○	×	× / ○	○	×	○ → ×	○ / ×
Inverter cooling fan [FMC1, 2]	○ / ×	○ / ×	×	○ / ×	○ / ×	○ / ×	○ / ×
Ventilation fan [FMC3]	○ / ×	○ / ×	×	○ / ×	○ / ×	○ / ×	○ / ×
4 way valve [20S]	×	×	×	○	○	○ → ×	×
Electronic expansion valve for heating [EEVH1, 2]	Fully open	※1	※2	Opening angle control	※2	Fully closed / Fully open	Fully open
Electronic expansion valve for sub-cooling [EEVSC]	Opening angle control	Fully closed	Fully closed	Fully closed	Fully closed	Fully closed	Opening angle control
Solenoid valve [SV1]	○ / ×	×	×	○ / ×	×	○ / ×	○ / ×
Solenoid valve [SV2]	○ / ×	×	×	○ / ×	×	○ / ×	○ / ×
Solenoid valve [SV6] [SV7]	○ / ×	×	×	○ / ×	×	○ / ×	○ / ×
Solenoid valve [SV11]	×	×	×	○ / ×	×	×	×
Solenoid valve [SV12]	×	×	×	×	×	×	×
Crankcase heater [CH1,2]	○ / ×	○ / ×	○ / ×	○ / ×	○ / ×	○ / ×	○ / ×

Notes(1) ○ : ON, × : OFF, ○/× : ON or OFF, ×/○ : OFF or ON


(2) ※1: The master is fully open and the slave is fully closed.

(3) ※2: Switching from cooling to OFF is in accordance with ※1. Switching from heating to OFF is in accordance with low pressure protective control for both master and slave units, with the valve being fully closed except for opening angle.

## **(2) Compressor starting order and load classes**

### **(a) All-in-one type (FDCA335 ~ FDCA680)**

1) The starting order of compressors 1 and 2 is switched each time an outdoor unit stop occurs.




2) The loads and corresponding operation frequencies for each compressor are shown in the table below (the table shows CM1 being started first. When CM2 is started first, the CM1 frequency indicated for load class 1 applies to CM2 instead.)

Load Class	0	1	2
CM1	0Hz	20~112Hz	42~120Hz
CM2	0Hz	0Hz	42~120Hz

### **(b) Combined (FDCA735 ~ FDCA1360)**

**Combination specifications: Master unit + 1 slave unit**



Operating frequency ranges for each compressor corresponding to different loads are as shown below. The following table applies to the case when CM01 starts at first. (When CM11 starts first, the frequency of CM01 for the Load Category 1 becomes the frequency of CM11.

Load Category		0	1	2	3
Master unit	CM01	0Hz	20~112Hz	42~112Hz	42~120Hz
	CM02	0Hz	0Hz	0Hz	42~120Hz
Slave unit	CM11	0Hz	0Hz	42~112Hz	42~120Hz
	CM12	0Hz	0Hz	0Hz	42~120Hz

### (3) Compressor start control between outdoor units (Master unit/slave unit)

#### (a) Determining the starting order for the master unit and slave units

Determine the starting order for the outdoor units of master unit and slave units, which is decided by the order in which the power switches are turned on.

- 1) Starting order of master unit (N=0) ... First
- 2) Starting order of slave unit 1 (N=1) ..... Second

#### (b) Determining starting order for compressors within master unit and slave unit groups.

Determine the starting order for compressors 1 and 2 within the master unit and slave unit groups as follows.

- 1) Starting order of compressor 1 (M=0) ... First
- 2) Starting order of compressor 2 (M=1) ... Second

#### (c) Compressor starting order and start control for combination specifications I

When all outdoor units change from the full stop state to the cooling/dehumidifying operation (including when all indoor units start from the cooling thermostat OFF state)

- 1) Start control
  - a) Starting is controlled by determining the start order and the stop order for compressors in the load categories.
  - b) When only one outdoor unit is used, the starting order for compressor 1 and compressor 2 is switched on each occasion when the outdoor unit stops.
  - c) Each time the master unit and each slave unit stop independently of each other, the starting order for compressor 1 and compressor 2 is switched.
  - d) Each time an outdoor unit stops within the master unit and slave unit groups, the starting order for compressors within the master unit and slave unit groups is switched.

Starting order of outdoor units    Master unit→Slave unit

Model	Starting Order of Outdoor Units	Starting Order of Compressors
<b>FDCA355~680</b>	—	CM 1 → CM 2 → CM 1
<b>FDCA735~1360</b>	Master unit → Slave unit → Master unit	CM 1 → CM 2 → CM 1

#### (d) Compressor starting order and start control for combination specifications II

When all outdoor units change from the full stop state or a cooling/dehumidifying operation to the heating operation (Excluding starting from the heating thermostat OFF state)

- 1) Start control
 

This is same as the cooling/dehumidifying operation.
- 2) After the compressor which is first in the starting order starts, all outdoor units are started temporarily in accordance with the operation order N.
- 3) 4-way valves (20S) are subject to the control prior to the start of the compressor.
- 4) 4-way valve switching protection
  - a) Regarding the outdoor unit which is second in the starting order, the 4-way valve (20S) is turned ON in compliance with 4-way valve switching protection control in order to perform 4-way valve switching protection control. (During the 4-way valve switching protection operation, the outdoor fan motor is operated under normal control.)
  - b) After 4-way valve switching protection operation, the compressors are stopped in accordance with the target operation frequency. (4-way valve is in the ON condition.)
  - c) Unless all 4-way valves on the outdoor units which are in second place in the starting order can be turned ON, the Compressor ON command is transmitted continually until they are turned ON.

### (4) Starting the compressor (Master unit/slave unit)

As shown in the following table, compressor starts occur in accordance with the amount of elapsed time from power ON, and in accordance with the number of starts that have occurred. However, during defrost control, oil return control, and equal oil control, starts occur in accordance with those controls.

Condition	Start Method
① Defrost control 1st start occurs 45 minutes or more after power ON, and subsequent starts occur after a power ON that follows a compressor stop of 45 minutes or longer.	After 4-way valve switching assurance, perform compressor protective start sequence "A" in accordance with the crankcase heater ON time. (See page 362)
② Oil return control 1st start occurs less than 45 minutes after power ON.	After 4-way valve switching assurance, perform compressor protective start sequence "A" in accordance with the crankcase heater ON time. (See page 362)
③ Equal oil control Starts other than ① and ② above.	After 4-way valve switching assurance, perform a compressor protective start sequence.

**(a) 4-way valve switching assurance**

When the compressor (CM1, CM2) is switching from the stopped state to the start state, after the compressor start control functions, there is an increase in frequency from 10Hz (synchronous operation).

**(i) 0-20Hz Operation**

It operates in the range of 0 – 20Hz. However, in this operation, the compressor cannot be operated with the current safe, high pressure controls, low pressure controls, power transistor temp. controls, discharge temp. control, under-dome temp. control or compression ratio protection controls.

**(ii) 20 – 40Hz (48) Operation**

Maximum frequency is determined based on the temperature detected with the outdoor air temperature thermistor (Tho-A).

- 1) If the temperature is 0 °C or lower, after starting with 48Hz as the maximum frequency, it stops at 48Hz.
- 2) If the temperature is higher than 0°C, after starting with 40Hz as the maximum frequency, it stops at 40Hz. However, if the starting conditions for current safe, high pressure controls, low pressure controls, power transistor temp. controls, discharge temp. controls or compression ratio protection controls are satisfied during this time, this control ends and control according to current safe, high pressure controls, low pressure controls, power transistor temp. controls, discharge temp. controls, under-dome temp. control or compression ratio protection controls commences, and if the compressor's frequency is determined and cancelled, operation returns to normal operation.

**(b) Compressor protective start**

- (i) After 4-way valve switching assurance is completed, the following compressor protection begins.

		Initial Start (Remote controller ON error cancel)	Thermostat ON start	
			Operation Mode Changed While Thermostat Was OFF	Operation Mode Unchanged While Thermostat Was OFF
Compressor ON count: 1st time	Less than 45 minutes after power ON	Compressor protective start B according to crankcase heater's power ON time	Compressor protective start B according to crankcase heater's power ON time	Compressor protective start B according to crankcase heater's power ON time
	45 minutes or more after power ON	Compressor protective start A according to crankcase heater's power ON time	Compressor protective start A according to crankcase heater's power ON time	Compressor protective start A according to crankcase heater's power ON time
Compressor ON count: From 2nd time	Less than 45 minutes after stop	Protective start	Protective start	Protective start
	45 minutes or more after stop	Compressor protective start A according to crankcase heater's power ON time	Compressor protective start A according to crankcase heater's power ON time	Compressor protective start A according to crankcase heater's power ON time

Note: If the under-dome temperature exceeds 30°C, compressor protective start A and B end and operation starts.

- (ii) The compressor's speed is as follows regardless of the target frequency.
  - 1) Up to 1 minute and 45 seconds after the compressor starts, operation is at 20Hz.
  - 2) When 1 minute and 45 seconds has passed since starting, operation is in accordance with the target speed.

**(c) Compressor protective starting sequence A, in accordance with the amount of time power to the crankcase heater has been on.**

The amount of time the power to the heater has been on since the power was switched ON is calculated, and if 45 or more minutes have passed and it is the first start, or if 45 or more minutes have passed and the compressor has been stopped, then the power turned on again, and the cumulative number of starts is 2 times or more, starting is done according to this control sequence.

- 1) The inverter is set to 20Hz following 4-way valve switching assurance. The target frequency is then established 1 minute after a 1-minute period has elapsed since the frequency reduction to 20Hz was reached.
- 2) During a 15-minute period following the start, the 20Hz frequency is increased at a rate of 5Hz per minute, and the start of the 15-minute period becomes the inverter's start completion point (10Hz).
- 3) If the inverter is stopped within a 15-minute period after a compressor start, this control increases the frequency 5Hz per minute for 15 minutes when the compressor starts again.

**(d) Compressor protective starting sequence B, in accordance with the amount of time power to the crank-case heater has been on.**

Power on time is calculated after the power is turned ON, and the first compressor start if less than 45 minutes have passed is according to this control.

- 1) The inverter is set to 20Hz following 4-way valve switching assurance. The target frequency is then established 1 minute after a 1-minute period has elapsed since the frequency reduction to 20Hz was reached.
- 2) During a 18-minute period following the start, the 20Hz frequency is increased at a rate of 5Hz per minute, and the start of the 18-minute period becomes the inverter's start completion point (10Hz).
- 3) The frequency is increased 5Hz per minute through the 18-minute to 24-minute period, and this control ends when 24 minutes is reached.
- 4) After this control ends 1 time, the system reverts to protective start "A" control from the 2nd time, or after 45 minutes have elapsed.
- 5) If the inverter is stopped for 24 minutes following a compressor start, a protective start is performed when started again, and protective start sequence "B" control increases the frequency for a period of 24 minutes. However, the system reverts to protective start sequence "A" control when started again if 45 minutes or more have elapsed since the inverter stop.

## (5) Compressor pre-start control (Master unit/slave unit)

(a) The following control occurs from the point when the compressor ON conditions are satisfied.

(i) Pre-start control when operation mode is the same as at the previous operation:


- 1) If in the "cooling / dehumidifying" mode, the 4-way valve switches OFF. If in the "heating" mode, it switches ON. However, When in the same mode as at the previous operation, with the prescribed power ON condition (see above item) established, the 4-way valve's power ON status continues as it is
- 2) Solenoid valves SV6 and SV7 switch ON.
- 3) The apertures of the heating mode's EEVH1, 2, and the sub cooling coil's EEVSC are set to their initial opening angles. The EEVH1 and 2 expansion valves are started first, and after their operation is completed, the EEVSC expansion valve operation begins.

(Unit: Pulse)

Name \ Item	Operation mode	
	Cooling	Heating
EEVH1, 2	470	10
EEVSC	32	0


Note (1) Master units and slave units are operated by the unit.

### ◆Cooling → Heating




4) Fan motors FMO1, FMO2, and the compressor start 15 seconds after the compressor ON conditions are satisfied.

# ◆Heating → Cooling



## (6) Cooling high pressure control (Master unit/slave unit)

- 2-unit operation is switched to 1-unit operation by the outdoor fan speed running at high pressure.




Control termination conditions

- 1) When a mode other than cooling or dehumidifying is selected.
- 2) When compressor stops

## (7) Cooling low pressure control (Master unit only)

During cooling and dehumidifying operations, a constant low pressure is maintained by compressor frequency control.

- (a) After compressor protective start ends (1 minute 45 seconds), the compressor's frequency is controlled as shown below.



Model	LPS (1)	LPS (2)	LPS (3)	N1	N2	N1-5	N2-5
335	0.81	0.79	0.77	60Hz × 1	46Hz × 2	55Hz × 1	41Hz × 2
400	0.80	0.77	0.73	70Hz × 1	50Hz × 2	65Hz × 1	45Hz × 2
450	0.81	0.79	0.75	70Hz × 1	54Hz × 2	65Hz × 1	49Hz × 2
504	0.82	0.79	0.71	70Hz × 1	54Hz × 2	65Hz × 1	49Hz × 2
560	0.82	0.78	0.69	70Hz × 1	64Hz × 2	65Hz × 2	59Hz × 2
615	0.81	0.77	0.67	80Hz × 1	70Hz × 2	75Hz × 1	65Hz × 2
680	0.81	0.77	0.65	80Hz × 1	70Hz × 2	75Hz × 1	65Hz × 2
735	0.82	0.79	0.76	70Hz × 2	50Hz × 4	65Hz × 2	45Hz × 4
800	0.80	0.77	0.73	70Hz × 2	50Hz × 4	65Hz × 2	45Hz × 4
850	0.82	0.79	0.71	70Hz × 2	54Hz × 4	65Hz × 2	49Hz × 4
900	0.82	0.78	0.69	70Hz × 2	64Hz × 4	65Hz × 2	59Hz × 4
960	0.82	0.78	0.69	70Hz × 2	64Hz × 4	65Hz × 2	59Hz × 4
1010	0.82	0.79	0.76	80Hz × 2	80Hz × 4	75Hz × 2	75Hz × 4
1065	0.82	0.79	0.76	80Hz × 2	80Hz × 4	75Hz × 2	75Hz × 4
1130	0.82	0.79	0.71	70Hz × 2	54Hz × 4	65Hz × 2	49Hz × 4
1180	0.82	0.79	0.71	70Hz × 2	54Hz × 4	65Hz × 2	49Hz × 4
1235	0.82	0.78	0.69	70Hz × 2	64Hz × 4	65Hz × 2	59Hz × 4
1300	0.82	0.78	0.69	70Hz × 2	64Hz × 4	65Hz × 2	59Hz × 4
1360	0.81	0.77	0.67	70Hz × 2	64Hz × 4	65Hz × 2	59Hz × 4

- (b) Control termination conditions
- When a mode other than cooling or dehumidifying is selected.
  - When the compressor stops.

## (8) Heating high pressure control (Master unit only)

During heating operation, a constant high pressure is maintained by compressor frequency control.

### (a) Control activation condition

1 minute 45 seconds have elapsed since the completion of a compressor protective start.

### (b) Control description

The compressor frequency is controlled to maintain a high pressure of 2.75Mpa.

### (c) Control termination conditions


- When a mode other than heating is selected.
- When the compressor stops.

## (9) Heating low pressure control (Master unit/slave unit)

- Low pressure is controlled in accordance with the outdoor unit's fan speed during a heating operation.

- (a) After compressor protective start ends (1 minute 45 seconds), when the low pressure is 0.80 MPa or higher, this control is activated.

- (b) The outdoor unit's fan speed is controlled in accordance with the low pressure by switching between 2-unit and 1-unit operation.



Control termination conditions

- When a mode other than heating is selected.
- When the compressor stops.

**(10) Outdoor fan control (Master unit/slave unit)****(a) DC fan motor control**

The outdoor fan tap has 0 speed to 4th speed assigned as the regular speed depending on the model and operation mode. Under normal operation, 1st speed and 4th speed is used, and in each outdoor fan control, control is stepless between 1st speed and 4th speed.

**(b) Outdoor fan tap**Unit: min<sup>-1</sup>

Fan tap	FDCA335, 400				FDCA450				Remarks
	Cooling		Heating		Cooling		Heating		
	FM <sub>o1</sub>	FM <sub>o2</sub>	FM <sub>o1</sub>	FM <sub>o2</sub>	FM <sub>o1</sub>	FM <sub>o2</sub>	FM <sub>o1</sub>	FM <sub>o2</sub>	
0th speed	0	0	0	0	0	0	0	0	Stop
1th speed	0	160	0	160	0	160	0	160	1-unit operation min. speed
2th speed	0	400	0	400	0	400	0	400	1-unit operation max. speed
3th speed	160	160	160	160	160	160	160	160	2-unit operation min. speed
4th speed	960	960	960	960	1080	1080	1080	1080	2-unit operation max. speed

Unit: min<sup>-1</sup>

Fan tap	FDCA504～1360				Remarks
	Cooling		Heating		
	FM <sub>o1</sub>	FM <sub>o2</sub>	FM <sub>o1</sub>	FM <sub>o2</sub>	
0th speed	0	0	0	0	Stop
1th speed	0	160	0	160	1-unit operation min. speed
2th speed	0	400	0	400	1-unit operation max. speed
3th speed	160	160	160	160	2-unit operation min. speed
4th speed	1140	1140	1140	1140	2-unit operation max. speed

**(c) When operation is starting, operation is at 4th speed.****(d) Judgment of whether or not to start the DC fan motor**

- (i) If the outdoor fan starts after stopping, the fan speed is checked and start control is performed.
- (ii) If the unit is stopped (free-running state) and the fan speed is in reverse, either FM<sub>o1</sub> or FM<sub>o2</sub> is 700 min<sup>-1</sup> or higher, it is not started, and if both FM<sub>o1</sub> and FM<sub>o2</sub> is under 700 min<sup>-1</sup> for 3 seconds, it is started.
- (iii) The compressor is started regardless of the state of the outdoor fan, and the above contents are sensed 5 seconds or more after the time that 52C1 goes ON.

**(11) Snow protection fan control (Master unit/slave unit)**

**Set this for the master unit as well as slave units.**


**(a) This control is enabled/disabled by the selector switch at the 7-segment display.**

- ① Set the Code No. to "75".
- ② "0" or "1" displays at the data display area.  
0: Outdoor fan control disabled (factory setting)  
1: Outdoor fan control enabled
- ③ Press SW7 continuously for 3 seconds.
- ④ "0" or "1" blinks every 0.5 seconds at the data display area.
- ⑤ Press SW8 to toggle between the blinking "0" and "1" displays.
- ⑥ If SW7 is pressed for 3 seconds or longer while "0" and "1" is blinking, the blinking stops, and that enabled/disabled setting is registered. If enabled, fan control occurs as described below.
- ⑦ Outdoor fan control occurs in accordance with the information stored in memory, even if the power is turned OFF and back ON again.



**(b) Control description**



- (i) If the outside temperature drops to 3°C or lower when all units are stopped, or during an error stop, the outdoor fan runs at level 4 speed once every 10 minutes.



- (ii) The outdoor fan runs for 30 seconds.  
 (iii) During this snow protection control, the compressor's magnetic contactor (52C1) is ON.

**(12) Silent mode control (Master unit/slave unit)**

- (a) If the silent mode start signal is received from an indoor unit or CnG2 (with short pin) is shorted, if the outdoor temperature is within the following range, operation is performed in the silent mode.

**• Cooling****• Heating**


- (b) Outdoor fan maximum speed & maximum compressor operation frequency (excluding the 30-second period after a start, and defrost operations)
- The maximum outdoor fan speed is 500min<sup>-1</sup>.
  - Maximum compressor operation frequency Max. Operation Frequency (Hz)

Model	Frequency(Hz)	Model	Frequency(Hz)	Model	Frequency(Hz)
FDCA335	46 × 2	FDCA735	42 × 4	FDCA1130	70 × 4
FDCA400		FDCA800	46 × 4	FDCA1180	74 × 4
FDCA450	52 × 2	FDCA850	50 × 4	FDCA1235	78 × 4
FDCA504	60 × 2	FDCA900	52 × 4	FDCA1300	
FDCA560	70 × 2	FDCA960	56 × 4	FDCA1360	
FDCA615	78 × 2	FDCA1010	60 × 4	—	—
FDCA680	84 × 2	FDCA1065	64 × 4	—	—

**(13) Inverter cooling fan control (Master unit/slave unit)**

This control applies to the master unit and slave units independently.

- (a) After the inverter starts, the cooling fans (FMO1, 2) are turned ON or OFF depending on the temperatures detected by the power transistor thermistor (Tho-P1, 2).



- (b) When the compressor changes from the ON to the OFF state, if the cooling fan is turned ON, the fan continues in the ON state for 3 minutes 10 seconds.

#### (14) Compression ratio protection control (Master unit/slave unit)

The frequency is reduced in accordance with the compressor's compression ratio.


##### (a) Control activation conditions

This control is activated when all the following conditions are satisfied.

- (i) When 10 minutes or more have elapsed since the compressor start.
- (ii) When the low pressure is 0.18MPa or higher, and the high pressure is 3.52MPa or lower.

Note (1) The above does not apply for a 10-minute period following a defrost, or when pump-down control is in progress.

##### (b) Control description



##### (c) Control termination conditions

Control ends when any one of the following conditions is satisfied.

- (i) When the low pressure is 0.18MPa or higher, and the high pressure is 3.52MPa or lower.
- (ii) When the compression ratio falls below the cancel value.

#### (15) Forced heating/cooling operation (Master unit only)

With this control, SW3-7 on the outdoor unit PCB is turned on and CnG1 (equipped with short circuit pin) is shorted or opened so as to forcibly determine whether the indoor unit is operated for cooling or heating. If any operation mode other than the forcible mode is commanded from the indoor unit, the mode unmatched message is displayed on the remote controller or others and the operation enters into the fan mode.

SW3-7	CnG1	Operation
OFF	Open/short	Normal operation
ON	Open	Cooling
	Short	Heating

Note (1) SW-7 is at OFF and CnG1 is open at the shipping from factory.

#### (16) Indoor unit connection number protection (Master unit only)

If the number of indoor units on the connection exceeds the number as listed below, the compressor stops with the error stop.

Item	model	All model
Number of units on connection		48 units

Note (1) They are the numbers of units used for judgement of error for the purpose of control and not equal to the numbers of units which can be connected.

## (17) Defrosting (Master unit/slave unit)


If defrosting start conditions are established at the outdoor unit heat exchanger for any of the indoor units, a defrosting operation starts.

### (a) Temperature condition defrosting

#### (i) Conditions for starting defrosting

When all the following conditions are met, the defrosting operation will start.

- 1) The cumulative operating time of the compressor comes up to 33 minutes after completion of a defrosting operation, or it comes up to 33 minutes after a heating operation starts (the remote controller is turned on).
- 2) If 8 minutes have passed after the compressor goes ON after it has gone OFF.
- 3) If 8 minutes have passed after one outdoor unit fan goes ON after all outdoor fans have gone OFF.
- 4) After all the above conditions are satisfied,



when the temperature at the outdoor heat exchanger thermistor (Tho-R) and outdoor temperature thermistor is below the defrost initiation temperature in the above graph continuously for 3 minutes.

#### (ii) Conditions for finishing defrosting

- Standard (J14: shorted)
  - 1) When the increase of the temperature of the heat exchanger thermistor (Tho-R1 or Tho-R2) is greater than 9°C.
  - 2) When 12 minutes have passed since defrosting started.
- With operation Judgment Function (J14: Open)
  - 1) If Tho-R1 and R2 are  $\geq 9^{\circ}\text{C}$ , after 2 minutes and 30 seconds have passed since defrosting started, if either of the following conditions is satisfied, the defrosting end operation starts.
    - a) 2 minutes and 30 seconds have passed since the temperature sensed by either Tho-R1 or Tho-R2 is 14°C or higher.
    - b) The temperature sensed by either Tho-R1 or Tho-R2 is 30°C or higher.
    - c) 14 minutes have passed since the start of defrosting.
  - 2) If Tho-R1 or R2 are  $< 9^{\circ}\text{C}$  after 2 minutes and 30 seconds have passed since defrosting started, if either of the following conditions is satisfied, the defrosting end operation starts.
    - a) 5 minutes have passed since the temperature sensed by either Tho-R1 or Tho-R2 is 14°C or higher.
    - b) The temperature sensed by either Tho-R1 or Tho-R2 is 30°C or higher.
    - c) 14 minutes have passed since the start of defrosting.

### (b) Time condition defrosting (oil return)

#### (i) Defrosting start conditions

- 1) Defrosting starts when the heating mode is in effect at the 1st compressor start following a power ON, and when the heating mode is in effect after 2 hours of cumulative operation time. However, if mode switching from cooling to heating occurred, defrosting starts 33 minutes after CM1 operation begins.
- 2) If there was 5 minutes or more of temperature condition defrosting before time condition defrosting, the 10-hour timer for time condition defrosting is reset.
- 3) The "time condition defrosting" time is the point when the detected oil rise amount reaches the setting value (following 2 hours of cumulative compressor operation time counting from the 1st compressor start after power ON), or the point when 10 hours elapse, whichever comes first.
- 4) When the 10-hour timer period elapses, time condition defrosting occurs at the completion of the previous temperature condition defrosting operation, or after 33 minutes, whichever comes first.


## (ii) Defrosting end conditions

If either of the following conditions is satisfied, the defrosting end operation starts.


- 1) The temperature sensed by Tho-R1 and Tho-R2 becomes 9°C or higher.
- 2) If 12 minutes has passed since defrosting started.

## (18) Oil separator solenoid valve (SV6, 7) control (Master unit/slave unit)


- (a) If the inverter compressor (CM1, 2) starts, solenoid valve SV6, 7 opens (goes ON), then 15 seconds later, it starts.
- (b) SV6, 7 stays open (ON) for 3 minutes, until 4-way valve switching assurance and compressor protective start are completed.
- (c) If the compressor operating frequency becomes 80Hz or higher, SV6, 7 opens (goes ON) and it goes off if the frequency is 76Hz or lower.



- (d) If the inverter compressor goes off after SV6, 7 opens (goes ON), SV6, 7 remains open (ON) for 3 minutes and 10 seconds, then closes (goes OFF).



- (e) During heating operations, The SV6 and SV7 valves switch ON when the high pressure is 3.5MPa or higher, and switch OFF when the high pressure is 3.0MPa or lower.



## (19) Emergency stop control

When an indoor unit's external input (optional: refrigerant leakage, etc.) indicates a refrigerant leak, that information is transmitted to the outdoor unit, stopping operation. An emergency stop error is then transmitted to all indoor units that are running.

- (a) Error stop occurs when the "emergency stop" command is received from the indoor unit.
- (b) Error code E63 occurs, and the "emergency stop" command is transmitted to all indoor units.
- (c) When a "emergency stop clear" command is received from the indoor unit, the outdoor unit's error status is cleared, and an "emergency stop clear" command is transmitted to all the indoor units.

## (20) Outdoor unit combined protection (Master unit/slave unit)

This protection judges the capacity of outdoor units that can be connected and displays any errors on the 7-segment display. However, it does not perform emergency stops or send any error messages to the indoor units.

### (a) Combined units

The errors of units other than the following combined units are not responded to by this function.

Outdoor unit model	Combined outdoor unit model						
Model	FDCA335 HKXE4R-K	FDCA400 HKXE4R	FDCA450 HKXE4R	FDCA504 HKXE4R	FDCA560 HKXE4R	FDCA615 HKXE4R	FDCA680 HKXE4R
FDCA735	1	1	—	—	—	—	—
FDCA800	—	2	—	—	—	—	—
FDCA850	—	1	1	—	—	—	—
FDCA900	—	—	2	—	—	—	—
FDCA960	—	—	1	1	—	—	—
FDCA1010	—	—	—	2	—	—	—
FDCA1065	—	—	—	1	1	—	—
FDCA1130	—	—	—	—	2	—	—
FDCA1180	—	—	—	—	1	1	—
FDCA1235	—	—	—	—	—	2	—
FDCA1300	—	—	—	—	—	1	1
FDCA1360	—	—	—	—	—	—	2

### (b) 7-segment display during an error

Outdoor unit model	Data display	Operation disabling content
OPE	3	Combined outdoor units are disabled.

### (c) Control termination conditions

Control ends when compressors stop in all units.

## (21) Automatic backup operation (Master unit/slave unit)

When one or more compressors fail, operation occurs using only the normal compressors.

(a) Automatic backup operation is only enabled when SW3-2 is ON (alternate setting) at the master unit.

(b) The following error status are disabled and not detected at failed compressors.

- |  |  |
|--|--|
| ① L3-phase "open phase" error (E32)                  | ⑩ DC fan error (E48)                                       |
| ② Discharge pipe temperature error (E36)             | ⑪ Power transistor overheating (continuous) (E51)          |
| ③ Heat exchanger thermistor disconnection (E37)      | ⑫ Suction pipe thermistor disconnection (E53)              |
| ④ Outdoor temperature thermistor disconnection (E38) | ⑬ High pressure and low pressure sensor disconnected (E54) |
| ⑤ Discharge pipe temperature thermistor (E39)        | ⑭ Under-dome temperature sensor disconnected (E55)         |
| ⑥ High pressure error (E40)                          | ⑮ Power transistor temperature sensor disconnected (E56)   |
| ⑦ Power transistor overheating (E41)                 | ⑯ Compressor start error (E59)                             |
| ⑧ Current cut (E42)                                  | ⑰ Compressor rotor lock error (E60)                        |
| ⑨ Inverter PCB communication error (E45)             |  |

(c) If any of the item (b) errors shown above occur while a compressor is running, that compressor is stopped, but other compressors continue running as usual.

(d) After recovering from the error, with start conditions satisfied, the compressors (CM1, 2) which are capable of running at the minimum frequency are started.

(e) An automatic recovery does not occur if a thermistor disconnection/severed wire occurs 3 times within 40 minutes. (Unit is stopped.)

(f) When a failure-recovered compressor is started, the other compressors revert back to their usual control.

## (22) Unit protective maintenance related devices

### (a) Test operation mode (Master unit only)

- 1) This control is performed from the master unit. It cannot be controlled from the slave unit side. If control from the slave unit side is attempted, the following codes are indicated on the 7-segment display.

Code indicator	Data indicator	Description of disabled control
OPE	10	Setting from a slave unit is invalid.

Note (1) Normal display can be restored if the test operation control switch is reset.

- 2) Outdoor unit test operation mode operation is started by the DIP switches SW5-1 and 5-2 on the outdoor unit PCB.

#### Switch functions



SW5-1	ON	SW5-2	OFF	Heating Test Operation
	OFF		ON	Cooling Test Operation
				Normal or Test Operation End

Notes (1) Leave all DIP Switches except 5-1 and 5-2 OFF.


(2) This operation takes priority over other options such as the center console. It sets the options in the operating state.

### (b) Under-dome temperature control (Master unit/slave unit)



- 1) The oil separator solenoid valve (SV6, 7) are controlled in accordance with the temperature at the under-dome thermistor (Tho-C) installed on the compressor.



- 2) The compressor's capacity is controlled in accordance with the under-dome temperature (Tho-C1, 2).



- 3) The cooling solenoid (SV1, 2) is controlled in accordance with the under-dome temperature (Tho-C).




### (c) High pressure protective control (Master unit/slave unit)

During cooling and heating operations, high pressure is detected by the high pressure sensor (PSH), and the compressor and outdoor fan are controlled to prevent the pressure from rising.

- 1) Cooling


High pressure based compressor control



Note (1) High pressure of less than 3.70MPa continues for 1 minute

## 2) Heating

### a) High pressure based fan speed control



Note (1) High pressure of less than 3.00MPa continues for 1 minute

### b) High pressure based fan speed control

#### i) Control activation conditions

When a high pressure of 3.0MPa or higher occurs 1 minute 45 seconds after a compressor protective start completion.


#### ii) Control description

- ① The fan speed is kept within a 160~960 (1080)  $\text{min}^{-1}$  range.

Both fan motors (FMo1 & 2) run at the same speed.

Note (1) Values shown in parentheses apply to the FDCA450 model.


- ② The FMo1 fan motor (right side) stops if the high pressure exceeds the value shown below.



#### iii) Control termination conditions

- ① When a mode other than heating is selected.
- ② When the compressor stops.
- ③ When the high pressure becomes less than 3.0MPa.

### 3) Solenoid valves SV6 & SV7 open (ON) when the high pressure reaches 3.5MPa or higher.



## (d) Compressor protective start control (Master unit/slave unit)

### 1) Compressor protection at low frequency

- a) 30Hz operation is performed for 1 minute when a 29Hz or lower operation has continued for 20 minutes.

### 2) Compressor start delay (3-minute timer)

The inverter compressor (CM1) does not start again for 3 minutes after being stopped by cooling/heating thermostat control, by the remote controller, or by an error.


**(e) Discharge pipe temperature control (Master unit/slave unit)**

If the discharge pipe temperature (sensed by Tho-D1, D2) exceeds the set value, the compressor cooling solenoid valve (SV1, 2) goes ON, the indoor expansion valve opens and the compressor's capacity is controlled, thus suppressing rises in the discharge pipe temperature. If the temperature rises even further, the compressor stops.

(i) Compressor cooling solenoid Valve (SV1, 2) control




(ii) Compressor control



(iii) Discharge pipe temperature error

- When the discharge pipe temperatures (Tho-D1, D2 detection) rise beyond 130°C and is maintained for 2 seconds, the compressors are stopped but it will be reset if the temperatures drop below 90°C.



- Compressors are counted individually if a discharge pipe temperature (Tho-D1, D2 detection) error occurs 2 times within 60 minutes.
- Control description

When the master unit auto-backup operation is invalid (SW3-2 ON), it stops with an anomalous stop. When the master unit auto-backup operation is valid (SW3-2 OFF, the factory setting), it does not stop with an anomalous stop and the compressor remains stopped.

Note (1) Unless the temperature of 90 °C or under is maintained for 45 minutes after the discharge pipe error, the unit cannot be started again. (Reset the power supply to clear.)

**(f) Current safe control (Master unit/slave unit)**

- (i) The compressor speed is reduced if the inverter inlet's input voltage (converter inlet L3-phase) exceeds the setting value while the compressor is running at a speed of 20Hz or higher. If the setting value is still exceeded after the speed reduction, the speed is reduced again.
- (ii) This control ends when the input voltage drops below the setting value for a continuous period of 3 minutes, and the speed protection cancel operation begins.
- (iii) This is performed by the master unit and slave units independently.

**(g) Current cut control (Master unit/slave unit)**

This control prevents overcurrent conditions at the inverter. The inverter is immediately stopped when the current exceeds the setting value, and is then automatically restarted 3 minutes later. If the current control is activated 4 times within 15 minutes, 52C1 and 52C2 are switched OFF, and an error stop occurs.

**(h) Anomalous high pressure increase protection (Master unit/slave unit)**

If the high pressure side pressure switch [63H1-1, 63H1-2: 4.15 Open / 3.15 Closed MPa] operates 5 times within 60 minutes or operates for 60 minutes, an abnormal stop is performed.


However, when first operated, the compressor is stopped, then after a 3-minute delay, normal operation is resumed.



**(i) Power transistor temperature control (Master unit/slave unit)**


If the temperature of the power transistor cooling fins (sensed by Tho-P) exceeds the set value, the compressor's capacity is controlled to keep the power transistor's temperature from rising. If it rises still higher, the compressor is stopped.

1) Compressor control



2) Power transistor temperature anomaly

- If the temperature sensed by the power transistor temperature thermistor rises to 110°C or higher, the compressor (CM1, 2) is stopped.




- If the power transistor's temperature is anomalous 5 times within 60 minutes, or if the temperature is 110°C or higher for 15 minutes continuously, including when the compressor is stopped, an abnormal stop is performed.

**(j) Low pressure protective control (Master unit only)**

If the low pressure (sensed by PSL) drops below the set value, the compressor's capacity is controlled to prevent the low level pressure from dropping. If it drops still further, the compressor is stopped.

1) Compressor control




Note (1) Starting Conditions

- Later than 1 minute 45 seconds after compressor operation starts
- Sensed continuously for 10 seconds

2) Low pressure anomaly

- If the low pressure (sensed by PSL) drops to 0.134 MPa or lower continuously for 30 seconds, the compressor is stopped and if a pressure of 0.18 MPa or higher is detected continuously for 10 seconds, the compressor is automatically reset. If this occurs 2 times within 60 minutes, an anomalous stop is performed.



- A low pressure (sensed by PSL) of 0.18 MPa or lower while the compressor is stopped, or sensed continuously for 30 seconds while the compressor is operating, is prohibited.
- First cooling operation after the power is turned on

If a low pressure of 0.003 MPa or lower is detected continuously for 60 seconds after 4-way valve switching assurance, the compressor is stopped, and if a low pressure of 0.18 MPa or higher is detected continuously for 10 seconds, the compressor is restarted automatically, but if an anomalous pressure is detected again, an anomalous stop is performed. It is possible to reset the system only by turning the power off, then turning it on again.

3) Heating electronic expansion valve (EEVH1, 2) opening angle control when heating operation is stopped

- If heating operation is stopped, the pulse to the heating electronic expansion valves (EEVH1, 2) is changed to 100 if the low pressure is less than 0.236 MPa.
- After that, if the low pressure rises to 0.246 MPa or higher while operation is stopped, the heating electronic expansion valves (EEVH1, 2) are opened fully.

### (23) Pump down control (Master unit/slave unit)

- (a) This control is performed from the master unit side. It cannot be controlled from the slave unit side. If control from the slave unit side is attempted, the following codes are displayed on the 7-segment display of the slave unit.

Code indicator	Data indicator	Description of disabled control
OPE	10	Setting from a slave unit is invalid.

Note (1) The display returns to normal if the pump-down control switch is reset.

- (b) Pump down operation can be performed through operation of DIP switches (SW5-1, 2, 3). (Pump down operation cannot be done during indoor unit operation, backup operation or during an anomalous stop.)

#### (i) Pump down procedure

- 1) Close the liquid side service valve on the outdoor unit.
- 2) Turn SW5-2 (test operation operating mode) ON (cooling).
- 3) Turn SW5-3 (pump down switch) ON.
- 4) Turn SW5-1 (test operation switch) ON.

#### (ii) Control

- 1) In the cooling mode, it operates with the compressor's pump-down frequency (see the following table) as the upper limit.

Model	Frequency (Hz)	Model	Frequency (Hz)	Model	Frequency (Hz)
FDCA335	80×1	FDCA735	74×2	FDCA1130	60×4
FDCA400	80×1	FDCA800	80×2	FDCA1180	64×4
FDCA450	46×2	FDCA850	42×4	FDCA1235	68×4
FDCA504	52×2	FDCA900	46×4	FDCA1300	68×4
FDCA560	60×2	FDCA960	48×4	FDCA1360	72×4
FDCA615	68×2	FDCA1010	52×4	—	—
FDCA680	72×2	FDCA1065	56×4	—	—

- 2) The red and green (LED's) on the outdoor control PCB flashes together continuously and "PoS" is displayed in the 7-segment display.
- 3) Except for low pressure control, all the protective and anomalous sensing controls are activated.
- 4) Test operation commands are sent to the indoor units.
- 5) The sub cooling coil electronic expansion valve (EEVSC) closes fully during pump down control.
- 6) Oil equalization control and oil return control (cooling and heating) are prohibited.

#### (iii) Ending

If any of the following conditions exists, pump down operation ends.

- 1) If a low pressure (sensed by PSL) of  $\leq 0.01$  MPa is detected continuously for 5 seconds.
  - a) The displays are as follows.
    - Red LED: Lights up continuously
    - Green LED: flashing
    - 7-segment LED display: PoE
    - Remote controller: Stop
- 2) If operation is stopped by anomalous sensing control.
- 3) If the cumulative compressor operation time totals 15 minutes.
  - a) The displays are as follows.
    - Red LED: stays OFF
    - Green LED: flashing
    - 7-segment LED display: No display
    - Remote controller: Stop
- 4) If any one of DIP switches SW5-1, 2 or 3 is turned OFF during the pump down operation.

## (24) External input operation (Master unit only)



External input: From CnS1, operation permission/prohibition control; From CnS2: Demand control/normal operation switching.

- J13: Switches between CnS1 and CnS2 input method.

J13 short circuit: Level input by CnS1 and CnS2.

J13 open: Pulse input by CnS1 and CnS2.


### (a) From CnS1, operation permission/prohibition control

Input : CnS1	CnS1 input method change: J13	CnS1 : Operation permission/Prohibition mode change
	J13; Short circuit Lever input	Operation prohibition mode → Operation permission mode
	J13; Disconnection Pulse input	Operation permission/Prohibition model change (Reversal)
	J13; Short circuit	Operation permission mode → Operation prohibition mode
	J13; Disconnection	— (NOP)


- 1) The remote controller displays the operating mode. “To Option” sends the operating mode.
- 2) CnS1, performs the following operations by the changing of jumper wire J1 from short circuit to open circuit.

If pulse input, the pulse duration is 500 ms or more.

#### ① Operation with J13 short circuit



#### ② Operation with J13 disconnection



(b) From CnS2, operation permission/prohibition control

Input : CnS2	CnS2 input method Formula switching: J13	CnS2 : Demand control/normal operating switching
Short circuit	J13; Short circuit Level input	Demand control → Normal operation
Open circuit	J13; Open circuit Pulse input	Normal operation/Demand control switching (Reversal)
Short circuit	J13; Short circuit	Normal operation → Demand control
Open circuit	J13; Open circuit	— (NOP)

Note (1) The factory settings are: J13 - short circuit; CnS2 - short circuit (short pin connection)

1) The remote controller displays the operating mode. “To Option” sends the operating mode.

2) Demand control

It is possible to switch the demand using DIP switch SW4-5, 6.


SW4-5	SW4-6	Compressor output (%)
0	0	80
1	0	60
0	1	40
1	1	0

Note (1) 0: Open, 1: Shorted


3) CnS2, performs the following operations by the changing of jumper wire J13 from short circuit to open circuit.

If pulse input, the pulse duration is 500 ms or more.

① J13 - Short circuit



② J13 - Open circuit



**(25) 7-Segment display (Master unit/slave unit)**

The data in the following table can be displayed using the display select switch (SW8: 1's digit; SW9: 10's digit).

Code No.	Contents of display	Data display range	Minimum units	Remarks
—	Unusual code Pump down Check mode Outdoor unit setup	—	—	E?? PoE, PoS CH? OPE??
00	CM1 operating frequency	0~130	1Hz	
01	CM2 operating frequency	0~130	1Hz	
02	Tho-A Outdoor air temp.	L,-20~43	1°C	[L] is indicated when the temperature is -20°C or below and the actual temperature is indicated when it is higher than -20°C and up to 43°C.
03	Tho-R1 Heat exchanger temp. 1 (Exit. Front)	L,-25~73	1°C	[L] is indicated when the temperature is -25°C or below and the actual temperature is indicated when it is higher than -25°C and up to 73°C.
04	Tho-R2 Heat exchanger temp. 2 (Exit. Rear)	L,-25~73	1°C	[L] is indicated when the temperature is -25°C or below and the actual temperature is indicated when it is higher than -25°C and up to 73°C.
05	Tho-R3 Heat exchanger temp. 3 (Entrance. Front)	L,-25~73	1°C	[L] is indicated when the temperature is -25°C or below and the actual temperature is indicated when it is higher than -25°C and up to 73°C.
06	Tho-R4 Heat exchanger temp. 4 (Entrance. Rear)	L,-25~73	1°C	[L] is indicated when the temperature is -25°C or below and the actual temperature is indicated when it is higher than -25°C and up to 73°C.
07	Tho-D1 Discharge pipe temp.	L,31~136	1°C	[L] is indicated when the temperature is 31°C or below and the actual temperature is indicated when it is higher than 31°C and up to 136°C.
08	Tho-D2 Discharge pipe temp.	L,31~136	1°C	[L] is indicated when the temperature is 31°C or below and the actual temperature is indicated when it is higher than 31°C and up to 136°C.
10	Tho-C1 Under-dome temp.	L,5~90	1°C	[L] is indicated when the temperature is 5°C or below and the actual temperature is indicated when it is higher than 5°C and up to 80°C.
11	Tho-C2 Under-dome temp.	L,5~90	1°C	[L] is indicated when the temperature is 5°C or below and the actual temperature is indicated when it is higher than 5°C and up to 80°C.
12	Tho-P1 Power transistor temp.	L,31~136	1°C	[L] is indicated when the temperature is 31°C or below and the actual temperature is indicated when it is higher than 31°C and up to 136°C.
13	Tho-P2 Power transistor temp.	L,31~136	1°C	[L] is indicated when the temperature is 31°C or below and the actual temperature is indicated when it is higher than 31°C and up to 136°C.
14	Tho-SC Sub-cooling coil temp.1	L,18~73	1°C	[L] is indicated when the temperature is 18°C or below and the actual temperature is indicated when it is higher than 18°C and up to 73°C.
15	Tho-SC Sub-cooling coil temp.2	L,-25~73	1°C	[L] is indicated when the temperature is -25°C or below and the actual temperature is indicated when it is higher than -25°C and up to 73°C.
16	Tho-S Suction pipe temp.	L,-25~73	1°C	[L] is indicated when the temperature is -25°C or below and the actual temperature is indicated when it is higher than -25°C and up to 73°C.
17	Cooling operation super cooling	0~50	0.1°C	
18	Super heat	0~50	0.1°C	
19	Super heat of sub-cooling coil	0~50	0.1°C	
20	CT1 Current	0~70	1A	
21	CT2 Current	0~70	1A	
22	EEVH1 Heating expansion valve opening angle	0~500	1 Pulse	
23	EEVH2 Heating expansion valve opening angle	0~500	1 Pulse	
24	Opening angle of EEVSC overcooling coil expansion valve	0~500	1 Pulse	
26	FM01 Number of rotations	0~1500	10 min <sup>-1</sup>	

Code No.	Contents of display	Data display range	Minimum units	Remarks
27	FM02 Number of rotations	0~1500	10 min <sup>-1</sup>	
28	PSH High pressure sensor	0~5.00	0.01MPa	
29	PSL Low pressure sensor	0~2.00	0.01MPa	
30	FMC1, 2 Cooling fan Crankcase heater	0,1	—	Order of 100 : FMC1, 2 Order of 10 : CH1 Order of 1 : CH2 (0: OFF, 1: ON)
31	63H1-1 63H1-2	0,1	—	Order of 100 : 63H1-1, 2 Order of 10 : — (0: Close, 1: Open)
32	SV1 SV2	0,1	—	Order of 100 : SV1 Order of 10 : SV2 Order of 1 : — (0: Close, 1: Open)
33	SV6 SV7	0,1	—	Order of 100 : SV6 Order of 10 : SV7 Order of 1 : — (0: Close, 1: Open)
34	20S	0,1	—	Order of 100 : 20S, Order of 10 : — Order of 1 : — (0: close, 1: open)
35	Compressor stop causes ①	0,1	—	Order of 100 : Defective outdoor temperature thermistor Order of 10 : Defective outdoor unit heat exchanger thermistor 1 Order of 1 : Defective outdoor unit heat exchanger thermistor 2 (0:Normal, 1: Abnormal)
36	Compressor stop causes ②	0,1	—	Order of 100 : Defective outdoor unit heat exchanger thermistor 3 Order of 10 : Defective outdoor unit heat exchanger thermistor 4 Order of 1 : Defective discharge pipe thermistor 1 (0:Normal, 1: Abnormal)
37	Compressor stop causes ③	0,1	—	Order of 100 : Defective discharge pipe thermistor 2 Order of 10 : Defective Sub cooling coil thermistor 1 Order of 1 : Defective Sub cooling coil thermistor 2 (0:Normal, 1: Abnormal)
38	Compressor stop causes ④	0,1	—	Order of 100 : Defective suction pipe thermistor Order of 10 : Defective low pressure sensor Order of 1 : Defective high pressure sensor (0:Normal, 1: Abnormal)
39	Compressor stop causes ⑤	0,1	—	Order of 100 : Anomaly in inverter 1 Order of 10 : Anomaly in inverter 2 Order of 1 : Anomalous high pressure (0:Normal, 1: Abnormal)
40	Compressor stop causes ⑥	0,1	—	Order of 100 : Anomalous low pressure Order of 10 : Anomalous discharge pipe thermistor 1 Order of 1 : Anomalous discharge pipe thermistor 2 (0:Normal, 1: Abnormal)
41	Compressor stop causes ⑦	0,1	—	Order of 100 : Defect CM1 starting Order of 10 : Defect CM2 starting Order of 1 : Rotor lock CM1 (0:Normal, 1: Abnormal)
42	Compressor stop causes ⑧	0,1	—	Order of 100 : Rotor lock CM2 Order of 10 : CM1 Current cut Order of 1 : CM2 Current cut (0:Normal, 1: Abnormal)
43	Compressor stop causes ⑨	0,1	—	Order of 100 : Power transistor 1 overheating Order of 10 : Power transistor 2 overheating Order of 1 : Anomaly in DC fan1 (0:Normal, 1: Abnormal)
44	Compressor stop causes ⑩	0,1	—	Order of 100 : Anomaly in DC fan2 Order of 10 : Stop command from indoor Order of 1 : Operation mode charge (0:Normal, 1: Abnormal)
45	Compressor stop causes ⑪	0,1	—	Order of 100 : Dilute protection Order of 10 : Demand control 0% Order of 1 : 0 (0:Normal, 1: Abnormal)
46	Control status	0,1	—	Order of 100 : During equal oil control Order of 10 : During oil return control Order of 1 : During defrost (0:Non-operation, 1: Operation)
47	Control status	0,1	—	Order of 100 : During Td control Order of 10 : During HP control Order of 1 : During CS control (0:Non-operation, 1: Operation)
48	Control status	0,1	—	Order of 100 : During LP control Order of 10 : During PT control Order of 1 : Under cooling low pressure control (0:Non-operation, 1: Operation)
49	Control status	0,1	—	Order of 100 : Cooling high pressure protection control Order of 10 : Heating high pressure protection control Order of 1 : Heating low pressure protection control (0:Non-operation, 1: Operation)
50	Number of connected indoor unit	0~50	1	
51	Number of operation indoor unit	0~50	1	
52	Required Hz total	0~999	1Hz	
53	Target Fk	0~999	1Hz	
54	Compressor cumulative operating time (CM1)	0~655	100h	

Code No.	Contents of display	Data display range	Minimum units	Remarks
55	Compressor cumulative operating time (CM2)	0~655	100h	
56	Discharge pressure saturation temperature	-50~70	0.1°C	1°C at -10 or lower
57	Air inlet pressure saturation temperature	-50~30	0.1°C	1°C at -10 or lower
58	Target cooling low pressure	0.00~2.00	0.01MPa	
59	Target heating high pressure	1.60~4.15	0.01MPa	
60	Counter · Compressor 2 starting failure	0, 1	—	
61	Counter · Motor lock compressor 2	0~3	—	
62	Power transistor 2 overheating	0~4	—	
63	Inverter 1 operating frequency command	0~130	1Hz	
64	Inverter 2 operating frequency command	0~130	1Hz	
65	Counter · Inverter 2 communications error	0~3	—	
66	Control status	0,1	—	Order of 100 : During silent mode Order of 1 : During test operation (0:Non-operation, 1: Operation)
67	Control status	0,1	—	Order of 100 : Unmatch Order of 10 : Indoor EEV check Order of 1 : — (0:Non-operation, 1: Operation)
68	Control status	0,1	—	Order of 100 : Piping cleaning Order of 10 : Under-dome temperature control Order of 1 : Compression ratio protection control (0:Non-operation, 1: Operation)
70	Operation priority switching	0,1	—	0: Prior press priority (when shipped) 1: After press priority
71	High pressure control of cooling	2.2, 2.5	0.01MPa	2.2: Factory setting 2.5: Alternate setting
72	low pressure control of cooling	-0.05~+0.05	0.01MPa	0.00: Factory setting
73	Heating high pressure compensation	0.00~0.30	0.01MPa	0.00: Factory setting
74	Low pressure of heating	0.80, 0.90	—	0.8: Factory setting 0.9: Alternate setting
75	Snow protection fan control	0,1	—	0: Snow protection fan control deactivated 1: Snow protection fan control activated
77	Data reset	---, dEL	—	
80	Counter · Thermistor disconnection	0~2	—	
81	Counter · Inverter 1 communications error	0~3	—	
82	Counter · High pressure protection	0~4	—	
83	Counter · Compressor 1 starting failure	0,1	—	
84	Counter · Anomalous low pressure ① (Under stop)	0~4	—	





## (26) Saving of Operation Data (Master unit/slave unit)

Operating data for a period of 30 minutes prior to the time when trouble occurs are recorded, and these data can be fetched to a personal computer through the RS232C connector on the control board. Data are updated continuously, and when there is an abnormal stop, data updates stop at that point. Pressing DIP switch SW7 for 5 seconds causes the data to be erased. Data can also be sampled at 1 ~ 60 second intervals during operation and fetched to a personal computer.

- Data is transmitted from a personal computer upon demand.

Data	Data Range	Example
Software version	ASCII 15-byte	KD3C218##### (#: NULL)
PID (program ID)	ASCII 2-byte	5D
Outdoor unit capacity	ASCII 3-byte	As shown in table at right
Power supply frequency	ASCII 2-byte	60
Outdoor address	ASCII 2-byte	00 ~ 3F
Indoor address × 16 units	ASCII 2-byte × 16 units	40 ~ 7F
Indoor capacity × 16 units	ASCII 3-byte × 16 units	022 ~ 280

Outdoor capacity data	Remarks
All-in-one type Ex: 16PS or S16	S: Horsepower of all-in-one type and all-in-one type (also for combined use)
Master unit of combination Ex: 32PS or S32	S: Horsepower of all-in-one type and all-in-one type (also for combined use)
Combined slave units Ex: 12PS or C12	C: Horsepower of combined slave units

Code No.	Write-in contents	Record data			
		Data write-in range	Write-in unit	Number of bytes	Contents
00	Anomalous code	00~99	–	1	00: No anomalous, outdoor unit all anomalous ???
01	Address of unit where trouble occurred	00~FF	–	1	0~3F: Outdoor unit side, 40~6F: Indoor unit side
02	Operation mode	0~2	–	1	0 Stop
					1 Cooling
					2 Heating
03	High pressure sensor	0.00~5.00	A/D value	1	
04	Low pressure sensor	0.00~2.00	A/D value	1	
05	Heat exchanger temp. 1 (Exit, Front)	-35~75	A/D value	2	Cooling liquid side
06	Heat exchanger temp. 2 (Exit, Rear)	-35~75	A/D value	2	Cooling liquid side
07	Heat exchanger temp. 3 (Entrance, Front)	-35~75	A/D value	2	Cooling gas side
08	Heat exchanger temp. 4 (Entrance, Rear)	-35~75	A/D value	2	Cooling gas side
09	Tho-D1 Discharge pipe temp.	20~140	A/D value	1	
10	Tho-D2 Discharge pipe temp.	20~140	A/D value	1	
11	Tho-C1 Under-dome temp.	-15~90	A/D value	1	
12	Tho-C2 Under-dome temp.	-15~90	A/D value	1	
13	Tho-A Outdoor air temp.	-20~43	A/D value	1	
14	Tho-P1 Power transistor temp. (Heat dissipation fin)	20~140	A/D value	1	
15	Tho-P2 Power transistor temp. (Heat dissipation fin)	20~140	A/D value	1	
16	Tho-SC Sub cooling coil temp. 1	18~73	A/D value	1	Liquid pipe side
17	Tho-H Sub cooling coil temp. 2	-35~75	A/D value	2	Suction pipe side
18	Tho-S Suction pipe temp.	-35~75	A/D value	2	
19	Cooling operation super cooling	0~50	A/D value	1	
20	Super heat	0~50	A/D value	1	

Code No.	Write-in contents	Record data			
		Data write-in range	Write-in unit	Number of bytes	Contents
21	Super heat of sub-cooling coil	0~50	A/D value	1	
22	CT1 Current	0~50	A/D value	1	
23	CT2 Current	0~50	A/D value	1	
24	Power source voltage	180~500	A/D value	1	
25	Pressure switch	—	—	1	<div>Bit0 63H1 0: open, 1: close</div> <div>Bit1 63H1-R 0: open, 1: ON</div> <div>Bit2 63L 0: open, 1: ON</div>
26	Solenoid valve	—	—	1	<div>Bit0 20S 0: OFF, 1: ON</div> <div>Bit2 SV1 0: OFF, 1: ON</div> <div>Bit3 SV2 0: OFF, 1: ON</div> <div>Bit4 SV6 0: OFF, 1: ON</div> <div>Bit5 SV7 0: OFF, 1: ON</div> <div>Bit6 SV11 0: open, 1: ON</div> <div>Bit7 SV12 0: open, 1: ON</div>
27	Crankcase heater etc.	—	—	1	<div>Bit0 CH1 0: OFF, 1: ON</div> <div>Bit1 CH2 0: OFF, 1: ON</div> <div>Bit2 FM1.2 0: OFF, 1: ON</div> <div>Bit3 FMC3 0: OFF, 1: ON</div>
28	FM01 Number of rotations	0~65535	10 min <sup>-1</sup>	2	
29	FM02 Number of rotations	0~65535	10 min <sup>-1</sup>	2	
30	EEVH1 opening angle	0~65535	1pulse	2	
31	EEVH2 opening angle	0~65535	1pulse	2	
32	EEVSC opening angle	0~65535	1pulse	2	
34	Indoor unit connection number	0~255	1 unit	1	
35	Indoor unit connection capacity	0~65535	—	2	
36	Indoor unit thermostat ON number	0~255	1 unit	1	
37	Indoor unit thermostat ON capacity	0~65535	—	2	
38	Required Hz total	0~65535	1Hz	2	
39	Target FK	0~65535	1Hz	2	
40	Inverter CM1 operation frequency	0~255	1Hz	1	
41	Inverter CM2 operation frequency	0~255	1Hz	1	
42	Answer Hz total	0~65535	1Hz	2	
43	Compressor 1 cumulative operating time (estimate)	0~65535	1 h	2	
44	Compressor 2 cumulative operating time (estimate)	0~65535	1 h	2	
45	Compressor 1 start times	0~65535	20 times	2	
46	Compressor 2 start times	0~65535	20 times	2	
47	Compressor stop causes	—	—	1	<div>Bit0 Defective outdoor temperature thermistor</div> <div>Bit1 Defective outdoor unit heat exchanger 1 thermistor</div> <div>Bit2 Defective outdoor unit heat exchanger 2 thermistor</div> <div>Bit3 Defective outdoor unit heat exchanger 3 thermistor</div> <div>Bit4 Defective outdoor unit heat exchanger 4 thermistor</div> <div>Bit5 Defective discharge pipe thermistor 1</div> <div>Bit6 Defective discharge pipe thermistor 2</div> <div>Bit7 Defective sub-cooling coil thermistor 1</div>

Code No.	Write-in contents	Record data			
		Data write-in range	Write-in unit	Number of bytes	Contents
48	Compressor stop causes	-	-	1	Bit0 Defective sub-cooling coil thermistor 2
					Bit1 Defective suction pipe thermistor
					Bit2 Defective low pressure sensor
					Bit3 Defective high pressure sensor
					Bit4 Inverter 1 anomalous communication
					Bit5 Inverter 2 anomalous communication
					Bit6 Anomalous high pressure
					Bit7 Anomalous Low pressure
49	Compressor stop causes	-	-	1	Bit0 Td1 Anomalous discharge pipe temp.
					Bit1 Td2 Anomalous discharge pipe temp.
					Bit2 CM1 starting defect
					Bit3 CM2 starting defect
					Bit4 Rotor lock of CM1
					Bit5 Rotor lock of CM2
					Bit6 Current cut of CM1
					Bit7 Current cut of CM2
50	Compressor stop causes	-	-	1	Bit0 Power transistor 1 overheating
					Bit1 Power transistor 2 overheating
					Bit2 FM01 anomaly
					Bit3 FM02 anomaly
					Bit4 Compressor stop command from indoor unit
					Bit6 Dilution rate protection
					Bit7 Demand control 0%
51	Control status	0~180	1 second	1	CM1 3-minute delay timer
52	Control status	0~180	1 second	1	CM2 3-minute delay timer
53	Discharge pressure saturation temperature	-50~70	0.1°C	2	
54	Intake pressure saturation temperature	-50~70	0.1°C	2	
55	Control status oil return	0,1	-	1	0 None
					1 Under control
56	Control status oil return	0~2	-	1	0 None
					1 Waiting for oil return
					2 Under oil return
57	Control status defrost conditions	0~3	-	1	0 None
					1 Temperature conditions
					2 Strengthening temperature conditions
					3 Time conditions
58	Control status defrost status	0~4	-	1	0 None
					1 Defrosting status 1
					2 Defrosting status 2
					3 Defrosting status 3
					4 Defrosting status 4
59	Control status Td	0~2	-	1	0 None
					1 Frequency down
					2, 3 Under Td control
60	Control status	0~1	-	1	Td1 error counter
61	Control status	0, 1	-	1	Td2 error counter
62	Control status HP	0~2	-	1	0 None
					1 Frequency down
					2, 3 Under high pressure control
63	Control status	0~1	-	1	HP error (63H1) counter
64	Control status CS	0~2	-	1	0 None
					1 Frequency down
					2, 3 Under CS control
65	Control status LP	0~2	-	1	0 None
					1 Frequency down
					2, 3 Under low pressure control
66	Control status	0~3	-	1	LP error (when stopped) counter
67	Control status	0~4	-	1	LP error (when started) counter

Code No.	Write-in contents	Record data			
		Data write-in range	Write-in unit	Number of bytes	Contents
68	Control status	0,1	—	1	LP error (when driving) counter
69	Control status PT	0~2	—	1	0 None
					1 Frequency down
					2, 3 Under PT control
70	Check operation status	—	—	1	Bit0 Unmatch check
					Bit1 Indoor side EEV check
					Bit3 Piping cleaning
71	Control status	0~360	3 minutes	1	CH compressor protection timer
72	Control status CH compressor protective start	0~15	—	1	15 Protective start end
					0~14 During protective start
73	Switch etc.	—	—	1	External operation (CnS1)
					Bit0 0: Operation prohibition
					1: Operation permission
					Demand (CnS2)
					Bit1 0: None
					1: Under control
					Forced cooling, heating (CnG1)
					Bit2 0: None
					1: Under control
					Silent mode (CnG2)
					Bit3 0: None
					1: Under control
					Back up operation
					Bit4 0: None
					1: Back up operation
					Hz cancel operation
					Bit5 0: None
					1: Under control
74	Control status	0~3	—	1	Current cut anomaly counter (INV1)
75	Control status	0~4	—	1	Power transistor overheating anomaly counter (INV1)
76	Control status	0~3	—	1	Rotor lock anomaly counte (INV1)
77	Control status	0~1	—	1	Starting failure counter (INV1)
78	Control status	0~3	—	1	Communications anomaly counter (INV1)
79	Control status	0~3	—	1	Current cut anomaly counter (INV2)
80	Control status	0~4	—	1	Power transistor overheating anomaly counter (INV2)
81	Control status	0~3	—	1	Rotor lock anomaly counte (INV2)
82	Control status	0~1	—	1	Starting failure counter (INV2)
83	Control status	0~3	—	1	Communications anomaly counter (INV2)
84	Control status	0~1	—	1	DC fan motor 1 error counter
85	Control status	0~1	—	1	DC fan motor 2 error counter
86	Control status	0~2	—	1	Thermistor disconnection counter
87	Control status	0~255	—	1	Communications error counter (INV)
88	Registered indoor units 1~8 operation mode	0~4	—	8	0 AUTO
					1 DRY
					2 COOL
					3 FAN
					4 HEAT



## ■ KXR series

### All-in-one type

#### ◆ Models FDCA224HKXRE4R, 280HKXRE4R, 335HKXRE4R

#### (1) Operations of major functional items under each operation mode

Functional item \ Operation mode	Cooling		Fan	Heating			Dehumidify
	Thermostat ON	Thermostat OFF		Thermostat ON	Thermostat OFF	Defrost	
Indoor unit fan	Remote controller command	Remote controller command	Remote controller command	Remote controller command	Intermittent operation	○ → ×	○ / ×
Indoor unit electronic expansion valve	Overheating control response	Fully closed	Fully closed	Overheating control response	60 pulse	Model-specific aperture opening angle	Overheating Control Response
Compressor [CM1]	○	×	×	○	×	○	○ / ×
Magnetic contactor CM1 [52C1]	○	○	× / ○	○	○	○	○
Outdoor unit fan [FMO-1]	○ / ×	×	× / ○	○ / ×	×	○ → ×	○ / ×
Outdoor unit fan [FMO-2]	○	×	× / ○	○	×	○ → ×	○ / ×
Inverter cooling fan [FMC1]	○ / ×	○ / ×	×	○ / ×	○ / ×	○ / ×	○ / ×
4 way valve [20S, SL]	Refer to following table.						
Electronic expansion valve for heating [EEVH1, 2]	Refer to following table.						
Electronic expansion valve for sub-cooling [EEVSC]	Refer to following table.						
Solenoid valve [SV6]	○ / ×	×	×	○ / ×	×	○ / ×	○ / ×
Solenoid valve [SV11]	×	×	×	○ / ×	×	×	×
Crankcase heater [CH1]	○ / ×	○ / ×	○ / ×	○ / ×	○ / ×	○ / ×	○ / ×

Notes(1) ○ : ON, × : OFF, ○/× : ON or OFF

- 4-way valve (20S, SL), heating expansion valve (EEVH1, 2) and sub-cooling expansion valve (EEVSC) operating pattern  
The operating pattern for outdoor unit is determined from the run/stop signals and cooling/heating signals from the indoor units and from the indoor unit model capacity.

Note (1) Switching of the operating pattern is controlled by the capacity of indoor units which have their thermostat ON and the pressure sensors (PSH, PSL).

Operating pattern	Outdoor heat exchanger		4-way valve			Electronic expansion valve		
	Heat exchanger 1	Heat exchanger 2	Used for heat exchanger	20S	20SL	EEVH1	EEVH2	EEVSC
C8	COND	COND	COND 100%	×	×	Fully open	Fully open	PI control
C4	COND	—	COND 50%	×	○	Fully open	Fully closed	PI control
C1	COND	—	COND 0~50%	×	○	60-100	Fully closed	PI control
C2	COND	EVA	COND 0%	×	○	60-100	PI control	PI control
C0	—	—	COND 0%	○	○	Fully closed	Fully closed	Fully closed
E4	EVA	—	EVA 50%	○	○	PI control	Fully closed	Fully closed
E8	EVA	EVA	EVA 100%	○	○	PI control	PI control	Fully closed

Note (1) ○ : ON, × : OFF

#### (2) 4-way valve switching assurance

When the compressor is switching from the stopped state to the start state, after the compressor start control functions, there is an increase in frequency from 10Hz (synchronous operation).

##### (a) 0-20Hz Operation

It operates in the range of 0 – 20Hz. However, in this operation, the compressor cannot be operated with the current safe, high pressure controls, low pressure controls, power transistor temp. controls, discharge temp. control, under-dome temp. control or compression ratio protection controls.

##### (b) 20 – 40Hz (49) Operation

Maximum frequency is determined based on the temperature detected with the outdoor air temperature thermistor (Tho-A).

- If the temperature is 0 °C or lower, after starting with 49Hz as the maximum frequency, it stops at 49Hz.
- If the temperature is higher than 0°C, after starting with 40Hz as the maximum frequency, it stops at 40Hz. However, if the starting conditions for current safe, high pressure controls, low pressure controls, power transistor temp. controls, discharge temp. controls or compression ratio protection controls are satisfied during this time, this control ends and control according to current safe, high pressure controls, low pressure controls, power transistor temp. controls, discharge temp. controls, under-dome temp. control or compression ratio protection controls commences, and if the compressor's frequency is determined and cancelled, operation returns to normal operation.

### (3) Compressor protective start

After 4-way valve switching assurance is completed, the following compressor protection begins.

		Initial Start (Remote controller ON error cancel)	Thermostat ON start	
			Operation Mode Changed While Thermostat Was OFF	Operation Mode Unchanged While Thermostat Was OFF
Compressor ON count: 1st time	Less than 45 minutes after power ON	Compressor protective start B according to crankcase heater's power ON time	Compressor protective start B according to crankcase heater's power ON time	Compressor protective start B according to crankcase heater's power ON time
	45 minutes or more after power ON	Compressor protective start A according to crankcase heater's power ON time	Compressor protective start A according to crankcase heater's power ON time	Compressor protective start A according to crankcase heater's power ON time
Compressor ON count: From 2nd time	Less than 45 minutes after stop	Protective start	Protective start	Protective start
	45 minutes or more after stop	Compressor protective start A according to crankcase heater's power ON time	Compressor protective start A according to crankcase heater's power ON time	Compressor protective start A according to crankcase heater's power ON time

Note: If the under-dome temperature exceeds 30°C, compressor protective start A and B end and operation starts.

#### (a) Compressor protective start

The compressor's speed is controlled as follows, regardless of the target frequency.

- 1) Operation occurs at 20Hz for a 1 minute 45 second period following a compressor start.
- 2) Operation occurs in accordance with pressure control after the post-start 1 minute 45 second period.

#### (b) Compressor protective start sequence "A" according to crankcase heater power ON time

The cumulative power ON time from power ON is calculated, and compressor protective start sequence "A" control occurs at the 1st compressor start after a 45-minute period, and at all subsequent compressor starts that follow a power ON after a compressor stop of 45 minutes or longer.

- 1) The inverter is set to 20Hz following 4-way valve switching assurance. The target frequency is then established 1 minute after a 1-minute period has elapsed since the frequency reduction to 20Hz was reached.
- 2) During a 15-minute period following the start, the 20Hz frequency is increased at a rate of 5Hz per minute, and the start of the 15-minute period becomes the inverter's start completion point (10Hz).
- 3) If the inverter is stopped within a 15-minute period after a compressor start, this control increases the frequency 5Hz per minute for 15 minutes when the compressor starts again.


#### (c) Compressor protective start sequence "B" according to crankcase heater power ON time

The cumulative power ON time from power ON is calculated, and compressor protective start sequence "B" control occurs at the 1st compressor start within a 45-minute period.

- 1) The inverter is set to 20Hz following 4-way valve switching assurance. The target frequency is then established 1 minute after a 1-minute period has elapsed since the frequency reduction to 20Hz was reached.
- 2) During a 18-minute period following the start, the 20Hz frequency is increased at a rate of 5Hz per minute, and the start of the 18-minute period becomes the inverter's start completion point (10Hz).
- 3) The frequency is increased 5Hz per minute through the 18-minute to 24-minute period, and this control ends when 24 minutes is reached.
- 4) After this control ends 1 time, the system reverts to protective start "A" control from the 2nd time, or after 45 minutes have elapsed.
- 5) If the inverter is stopped for 24 minutes following a compressor start, a protective start is performed when started again, and protective start sequence "B" control increases the frequency for a period of 24 minutes. However, the system reverts to protective start sequence "A" control when started again if 45 minutes or more have elapsed since the inverter stop.

#### (4) Cooling high pressure control

- 2-unit operation is switched to 1-unit operation by the outdoor fan speed running at high pressure.



Control termination conditions


- 1) When a mode other than cooling or dehumidifying is selected.
- 2) When compressor stops

#### (5) Cooling low pressure control

During cooling and dehumidifying operations, a constant low pressure is maintained by compressor frequency control.

- (a) Compressor frequency control occurs as shown below, 1 minute 45 seconds after the completion of a compressor protective start.

Unit: MPa			
Model	LPS (1)	LPS (2)	LPS (3)
FDCA224	0.80	0.75	0.70
FDCA280	0.82	0.77	0.73
FDCA335	0.82	0.79	0.76



- (b) Control termination conditions

- (i) When a mode other than cooling or dehumidifying is selected.
- (ii) When the compressor stops.
- (iii) When oil return control is on.

#### (6) Heating high pressure control

During heating operation, a constant high pressure is maintained by compressor frequency control.

##### (a) Control activation condition

1 minute 45 seconds have elapsed since the completion of a compressor protective start.

##### (b) Control description

The compressor frequency is controlled to maintain a high pressure of 2.90Mpa.


##### (c) Control termination conditions

- (i) When a mode other than heating is selected.
- (ii) When the compressor stops.
- (iii) When a dehumidifying operation has started.



## (7) Heating low pressure control

- Switches the outdoor unit fan speed through pressure.



Control termination conditions

- When a mode other than heating is selected.
- When the compressor stops.

## (8) Emergency stop control

When an indoor unit's external input (optional: refrigerant leakage, etc.) indicates a refrigerant leak, that information is transmitted to the outdoor unit, stopping operation. An emergency stop error is then transmitted to all indoor units that are running.

- Error stop occurs when the "emergency stop" command is received from the indoor unit.
- Error code E63 occurs, and the "emergency stop" command is transmitted to all indoor units.
- When a "emergency stop clear" command is received from the indoor unit, the outdoor unit's error status is cleared, and an "emergency stop clear" command is transmitted to all the indoor units.

## (9) Compression ratio protection control

The frequency is reduced in accordance with the compressor's compression ratio.


### (a) Control activation conditions

This control is activated when all the following conditions are satisfied.

- When 10 minutes or more have elapsed since the compressor start.
- When the low pressure is 0.18MPa or higher, and the high pressure is 3.52MPa or lower.

Note (1) The above does not apply for a 10-minute period following a defrost, or when pump-down control is in progress.

### (b) Control description



### (c) Control termination conditions

Control ends when any one of the following conditions is satisfied.

- When the low pressure is 0.18MPa or higher, and the high pressure is 3.52MPa or lower.
- When the compression ratio falls below the cancel value.


## (10) Snow protection fan control

(a) This control is enabled/disabled by the selector switch at the 7-segment display.

- ① Set the Code No. to "75".
- ② "0" or "1" displays at the data display area.  
0: Outdoor fan control disabled (factory setting)  
1: Outdoor fan control enabled
- ③ Press SW7 continuously for 3 seconds.
- ④ "0" or "1" blinks every 0.5 seconds at the data display area.
- ⑤ Press SW8 to toggle between the blinking "0" and "1" displays.
- ⑥ If SW7 is pressed for 3 seconds or longer while "0" and "1" is blinking, the blinking stops, and that enabled/disabled setting is registered. If enabled, fan control occurs as described below.
- ⑦ Outdoor fan control occurs in accordance with the information stored in memory, even if the power is turned OFF and back ON again.

(b) Control description

- (i) If the outside temperature drops to 3°C or lower when all units are stopped, or during an error stop, the outdoor fan runs at level 4 speed once every 10 minutes.




Outdoor air temperature (°C)

- (ii) The outdoor fan runs for 30 seconds.
- (iii) During this snow protection control, the compressor's magnetic contactor (52C1) is ON.

## (11) Silent mode control


If the silent mode start signal is received from an indoor unit or CnG2 (with short pin) is shorted, if the outdoor temperature is within the following range, operation is performed in the silent mode.

• Cooling



Outdoor air temperature (°C)

• Heating



Outdoor air temperature (°C)

## (12) Indoor unit connection number protection

If the number of indoor units on the connection exceeds the number as listed below, the compressor stops with the error stop.

Item	model	All model
Number of units on connection		20 units


Note (1) They are the numbers of units used for judgement of error for the purpose of control and not equal to the numbers of units which can be connected.

### (13) Defrosting

#### (a) Conditions for starting defrosting

When all the following conditions are met, the defrosting operation will start.

- 1) When the outdoor unit operating pattern is E8.
- 2) The cumulative operating time of the compressor comes up to 33 minutes after completion of a defrosting operation, or it comes up to 33 minutes after a heating operation starts (the remote controller is turned on).
- 3) If 8 minutes have passed after the compressor goes ON after it has gone OFF.
- 4) If 8 minutes have passed after one outdoor unit fan goes ON after all outdoor fans have gone OFF.
- 5) After all the above conditions are satisfied, when the temperature at the outdoor heat exchanger thermistor (Tho-R) and outdoor temperature thermistor is below the defrost initiation temperature in the above graph continuously for 3 minutes.



#### (b) Conditions for finishing defrosting

- Standard (J14: shorted)
  - 1) When the increase of the temperature of the heat exchanger thermistor (Tho-R1 or Tho-R2) is greater than 9°C.
  - 2) When 12 minutes have passed since defrosting started.
- With operation Judgment Function (J14: Open)
  - 1) If Tho-R1 and R2 are  $\geq 9^{\circ}\text{C}$ , after 2 minutes and 30 seconds have passed since defrosting started, if either of the following conditions is satisfied, the defrosting end operation starts.
    - a) 2 minutes and 30 seconds have passed since the temperature sensed by either Tho-R1 or Tho-R2 is 14°C or higher.
    - b) The temperature sensed by either Tho-R1 or Tho-R2 is 30°C or higher.
    - c) 14 minutes have passed since the start of defrosting.
  - 2) If Tho-R1 or R2 are  $< 9^{\circ}\text{C}$  after 2 minutes and 30 seconds have passed since defrosting started, if either of the following conditions is satisfied, the defrosting end operation starts.
    - a) 5 minutes have passed since the temperature sensed by either Tho-R1 or Tho-R2 is 14°C or higher.
    - b) The temperature sensed by either Tho-R1 or Tho-R2 is 30°C or higher.
    - c) 14 minutes have passed since the start of defrosting.


#### (c) Dehumidifying operation interrupted

- 1) Compressor stopped
- 2) Oil return control conditions established

In the relationship between oil return and dehumidifying operation, oil return has priority and if the system begins oil return during a dehumidifying operation, the dehumidifying operation is interrupted and the oil return operation is executed.


#### (14) Oil separator solenoid valve (SV6) control

- (a) SV6 stays open (ON) for 3 minutes, compressor protective start are completed.
- (b) If the compressor operating frequency becomes 80Hz or higher, SV6 opens (goes ON) and it goes off if the frequency is 76Hz or lower.




Actual compressor frequency (Hz)

- (c) If the inverter compressor goes off after SV6 opens (goes ON), SV6 remains open (ON) for 3 minutes and 10 seconds, then closes (goes OFF).



- (d) During a heating operation, when the high pressure becomes 3.5 MPa or higher, SV6 is opened (turned ON) and when the high pressure drops to 3.0 MPa or lower, SV6 is closed (turned OFF).



High pressure (MPa)

#### (15) Unit protective maintenance related devices

##### (a) Test operation mode

- 1) Outdoor unit test operation mode operation is started by the DIP switches SW5-1 and 5-2 on the outdoor unit control PCB.


##### Switch functions

SW5-1	ON	SW5-2	OFF	Heating Test Operation
			ON	Cooling Test Operation
	OFF	Normal or Test Operation End		


Notes (1) This operation takes priority over other options such as the center console. It sets the options in the operating state.

##### (b) Under-dome temperature control

- 1) The oil separator solenoid valve (SV6) are controlled in accordance with the temperature at the under-dome thermistor (Tho-C) installed on the compressor.



- 2) The compressor's capacity is controlled in accordance with the under-dome temperature (Tho-C).




### (c) High pressure protective control

If the high pressure sensor (PSH) detects the high pressure during cooling or heating operation and controls the compressor capacity, outdoor unit fan and oil separator solenoid (SV6) to raise the pressure.

#### 1) Cooling


Compressor capacity control through high pressure



Note (1) Continues for 1 minute if the high pressure is less than 3.7 Mpa.

#### 2) Heating

a) Compressor capacity control through high pressure



Note (1) Continues for 1 minute if the high pressure is less than 3.7 Mpa.

b) Compressor capacity control through fan speed control

##### i) Start conditions


After compressor protection starts (1 minute 45 seconds), when the high pressure becomes 3.0 MPa or higher.

##### ii) Control content

- ① The fan speed is controlled within a range of 160 and 835 (1060)  $\text{min}^{-1}$ . Fan motors FMO1 and 2 are given a common speed.

Note (1) Values in ( ) show for model FDCA335.

- ② If the high pressure becomes higher than the following value, fan motor FMO1 (right side) stops.




##### iii) End conditions

- ① When the system changes from heating operation to another mode.
- ② When the compressor stops.
- ③ When the high pressure drops below 3.0 MPa.

### 3) Solenoid Valve (SV6) Control


- 1) The solenoid valve (SV6) goes ON when the high pressure (sensed by PSH) rises to 3.5 MPa or higher during heating operation.



### (d) Discharge pipe temperature control


If the temperature of the discharge pipe (sensed by Tho-D1) exceeds the set value, the compressor's capacity is controlled and the rise in the discharge pipe temperature is controlled. If it continues to rise, the compressor stops.

- (i) Compressor control



- (ii) Discharge pipe temperature error

- When the discharge pipe temperatures (Tho-D1 detection) rise beyond 130°C and is maintained for 2 seconds, the compressors are stopped but it will be reset if the temperatures drop below 90°C.



- If the discharge pipe temperature (Tho-D1 detection) occurs twice within 60 minutes or the condition higher than 130 °C has continued for 60 minutes including the duration of time of compressor stop, the unit operation is stopped with the error stop.

Note (1) Unless the temperature of 90 °C or under is maintained for 45 minutes after the discharge pipe error, the unit cannot be started again. (Reset the power supply to clear.)

### (e) Current safe control

- (i) The compressor speed is reduced if the inverter inlet's input voltage (converter inlet L3-phase) exceeds the setting value.  
If the input voltage still remains above the setting value, the speed is reduced again.
- (ii) This control ends when the input voltage drops below the setting value for 3 continuous minutes.

### (f) Current cut control

Cuts an inverter overcurrent. When the current exceeds the setting value, the inverter is immediately stopped, and is then automatically restarted 3 minutes later. If 4 overcurrent cuts occur within a 15-minute period, 52C1 is switched OFF, and an error stop status is established.

### (g) Anomalous high pressure increase protection


If the high pressure side pressure switch [63H1: 4.15 Open / 3.15 Closed MPa] operates 5 times within 60 minutes or operates for 60 minutes, an abnormal stop is performed.

However, when first operated, the compressor is stopped, then after a 3-minute delay, normal operation is resumed.

#### (h) Power transistor temperature control


If the temperature of the power transistor cooling fins (sensed by Tho-P) exceeds the set value, the compressor's capacity is controlled to keep the power transistor's temperature from rising. If it rises still higher, the compressor is stopped.

##### 1) Compressor control



##### 2) Power transistor temperature anomaly

- If the temperature sensed by the power transistor temperature thermistor rises to 110°C or higher, the compressor is stopped.




- If the power transistor's temperature is anomalous 5 times within 60 minutes, or if the temperature is 110°C or higher for 60 minutes continuously, including when the compressor is stopped, an anomalous stop is performed.

#### (i) Low pressure protective control

If the low pressure (sensed by PSL) drops below the set value, the compressor's capacity is controlled to prevent the low level pressure from dropping. If it drops still further, the compressor is stopped.

##### 1) Compressor control




Note (1) Starting Conditions

- 1 minutes and 45 seconds have passed since starting.
- Sensed continuously for 10 seconds

##### 2) Low pressure anomaly

- If the low pressure (sensed by PSL) drops to 0.134 MPa or lower continuously for 30 seconds, the compressor is stopped and if a pressure of 0.18 MPa or higher is detected continuously for 10 seconds, the compressor is automatically reset. If this occurs 2 times within 60 minutes, an anomalous stop is performed.



- Compressor operation at a low pressure (sensed by PSL) of 0.18 MPa or lower continuously for 30 seconds while stopped is prohibited. If this state is sensed 5 times in 60 minutes, it results in an anomalous stop. Recovery is possible only by resetting the power supply.
- When operating the unit in cooling mode the first time after turning on the power  
If a low pressure of 0.003 MPa or lower is detected continuously for 60 seconds after 4-way valve switching protection, the compressor is stopped, and if a pressure of 0.18 MPa or higher is detected continuously for 10 seconds the compressor restarts automatically. However, if this state is detected again 2 times within 60 minutes, it results in an emergency stop. Recovery is possible only by resetting the power supply.

## **(16) Pump down control**

Pump down operation can be performed through operation of DIP switches (SW5-1, 2, 3). (Pump down operation cannot be done during indoor unit operation, backup operation or during an anomalous stop.)

### **(a) Pump down procedure**

- 1) Close the liquid side service valve on the outdoor unit.
- 2) Turn SW5-2 (test operation operating mode) ON (cooling).
- 3) Turn SW5-3 (pump down switch) ON.
- 4) Turn SW5-1 (test operation switch) ON. This will start the pump down operation.

### **(b) Control**

- 1) The compressor operates in cooling mode with 224: 50Hz (280, 335: 62Hz) as the upper frequency limit.
- 2) The red and green (LED's) on the outdoor control PCB flashes together continuously and "PoS" is displayed in the 7-segment display.
- 3) Except for low pressure control, all the protective and anomalous sensing controls are activated.

### **(c) Ending**

If any of the following conditions exists, pump down operation ends.

- 1) If a low pressure (sensed by PSL) of  $\leq 0.01$  MPa is detected continuously for 5 seconds.
  - a) The displays are as follows.

· Red LED: Lights up continuously	· Green LED: flashing
· 7-segment LED display: PoE	· Remote controller: Stop
- 2) If operation is stopped by anomalous sensing control.
- 3) If the cumulative compressor operation time totals 15 minutes.
  - a) The displays are as follows.

· Red LED: Off	· Green LED: flashing
· 7-segment LED display: No display	· Remote controller: Stop
- 4) If any one of DIP switches SW5-1, 2 or 3 is turned OFF during the pump down operation.



## (17) External input operation

External input: From CnS1, operation permission/prohibition control; From CnS2: Demand control/normal operation switching.

- J13: Switches between CnS1 and CnS2 input method.

J13 short circuit: Level input by CnS1 and CnS2.


J13 open: Pulse input by CnS1 and CnS2.

### (a) From CnS1, operation permission/prohibition control


Input : CnS1	CnS1 input method change: J13	CnS1 : Operation permission/Prohibition mode change
	J13; Short circuit Lever input	Operation prohibition mode → Operation permission mode
	J13; Disconnection Pulse input	Operation permission/Prohibition model change (Reversal)
	J13; Short circuit	Operation permission mode → Operation prohibition mode
	J13; Disconnection	— (NOP)

- 1) The remote controller displays the operating mode. “To Option” sends the operating mode.
- 2) CnS1, performs the following operations by the changing of jumper wire J1 from short circuit to open circuit.  
If pulse input, the pulse duration is 500 ms or more.

#### ① Operation with J13 short circuit



#### ② Operation with J13 disconnection



(b) From CnS2, operation permission/prohibition control

Input : CnS2	CnS2 input method Formula switching: J13	CnS2 : Demand control/normal operating switching
Short circuit	J13; Short circuit Level input	Demand control → Normal operation
Open circuit	J13; Open circuit Pulse input	Normal operation/Demand control switching (Reversal)
Short circuit	J13; Short circuit	Normal operation → Demand control
Open circuit	J13; Open circuit	— (NOP)

Note (1) The factory settings are: J13 - short circuit; CnS2 - short circuit (short pin connection)

1) The remote controller displays the operating mode. “To Option” sends the operating mode.

2) Demand control

It is possible to switch the demand using DIP switch SW4-5, 6.


SW45	SW4-6	Compressor operation upper limits			Compressor output (%)
		224	280	335	
0	0	66Hz	79Hz	95Hz	80
1	0	50Hz	62Hz	70Hz	60
0	1	33Hz	40Hz	48Hz	40
1	1	OFF	OFF	OFF	0

Note (1) 0: Open, 1: Shorted


3) CnS2, performs the following operations by the changing of jumper wire J13 from short circuit to open circuit.

If pulse input, the pulse duration is 500 ms or more.

① J13 - Short circuit



② J13 - Open circuit



## (18) 7-Segment display

The data in the following table can be displayed using the display select switch (SW8: 1's digit; SW9: 10's digit).

Code No.	Contents of display	Data display range	Minimum units	Remarks
–	Unusual code Pump down Check mode Outdoor unit setup	–	–	E?? PoE, PoS CH? OPE??
00	CM1 operating frequency	0~130	1Hz	
02	Tho-A Outdoor air temp.	L,-20~43	1°C	[L] is indicated when the temperature is -20°C or below and the actual temperature is indicated when it is higher than -20°C and up to 43°C.
03	Tho-R1 Heat exchanger temp. 1 (Exit. Front)	L,-25~73	1°C	[L] is indicated when the temperature is -25°C or below and the actual temperature is indicated when it is higher than -25°C and up to 73°C.
04	Tho-R2 Heat exchanger temp. 2 (Exit. Rear)	L,-25~73	1°C	[L] is indicated when the temperature is -25°C or below and the actual temperature is indicated when it is higher than -25°C and up to 73°C.
05	Tho-R3 Heat exchanger temp. 3 (Entrance. Front)	L,-25~73	1°C	[L] is indicated when the temperature is -25°C or below and the actual temperature is indicated when it is higher than -25°C and up to 73°C.
06	Tho-R4 Heat exchanger temp. 4 (Entrance. Rear)	L,-25~73	1°C	[L] is indicated when the temperature is -25°C or below and the actual temperature is indicated when it is higher than -25°C and up to 73°C.
07	Tho-D1 Discharge pipe temp.	L,31~136	1°C	[L] is indicated when the temperature is 31°C or below and the actual temperature is indicated when it is higher than 31°C and up to 136°C.
10	Tho-C1 Under-dome temp.	L,5~90	1°C	[L] is indicated when the temperature is 5°C or below and the actual temperature is indicated when it is higher than 5°C and up to 80°C.
12	Tho-P1 Power transistor temp.	L,31~136	1°C	[L] is indicated when the temperature is 31°C or below and the actual temperature is indicated when it is higher than 31°C and up to 136°C.
14	Tho-SC Sub-cooling coil temp.1	L,18~73	1°C	[L] is indicated when the temperature is 18°C or below and the actual temperature is indicated when it is higher than 18°C and up to 73°C.
15	Tho-H Sub-cooling coil temp.2	L,-25~73	1°C	[L] is indicated when the temperature is -25°C or below and the actual temperature is indicated when it is higher than -25°C and up to 73°C.
16	Tho-S Suction pipe temp.	L,-25~73	1°C	[L] is indicated when the temperature is -25°C or below and the actual temperature is indicated when it is higher than -25°C and up to 73°C.
17	Cooling operation super cooling	0~50	0.1°C	
18	Super heat	0~50	0.1°C	
19	Super heat of sub-cooling coil	0~50	0.1°C	
20	CT1 Current	0~50	1A	
22	EEVH1 Heating expansion valve opening angle	0~500	1 Pulse	
23	EEVH2 Heating expansion valve opening angle	0~500	1 Pulse	
24	Opening angle of EEVSC overcooling coil expansion valve	0~500	1 Pulse	
26	FM01 Number of rotations	0~999	10 min <sup>-1</sup>	
27	FM02 Number of rotations	0~999	10 min <sup>-1</sup>	
28	PSH High pressure sensor	0~5.00	0.01MPa	
29	PSL Low pressure sensor	0~2.00	0.01MPa	
30	FMC1 Cooling fan Crankcase heater	0,1	–	Order of 100 : FMC1 Order of 10 : CH1 Order of 1 : – (0: OFF, 1: ON)
31	63H1-1, (63H1-2) (63H1-R)	0,1	–	Order of 100 : 63H1-1, 2 Order of 10 : 63H1-R (0: Close, 1: Open)
32	SV1 (SV2) (20SL)	0,1	–	Order of 100 : SV1 Order of 10 : SV2 Order of 1 : 20SL (0: Close, 1: Open)

Code No.	Contents of display	Data display range	Minimum units	Remarks
33	SV6 (SV7) SV10	0,1	—	Order of 100 : SV6 Order of 10 : SV7 Order of 1 : SV10 (0: Close, 1: Open)
34	20S SV11 SV12	0,1	—	Order of 100 : 20S Order of 10 : SV11 Order of 1 : SV12 (0: close, 1: open)
35	Compressor stop causes ①	0,1	—	Order of 100 : Defective outdoor temperature thermistor Order of 10 : Defective outdoor unit heat exchanger thermistor 1 Order of 1 : Defective outdoor unit heat exchanger thermistor 2 (0:Normal, 1: Anomaly)
36	Compressor stop causes ②	0,1	—	Order of 100 : Defective outdoor unit heat exchanger thermistor 3 Order of 10 : Defective outdoor unit heat exchanger thermistor 4 Order of 1 : Defective discharge pipe1 thermistor (0:Normal, 1: Anomaly)
37	Compressor stop causes ③	0,1		Order of 100 : — Order of 10 : Defective Sub cooling coil thermistor 1 Order of 1 : Defective Sub cooling coil thermistor 2 (0:Normal, 1: Anomaly)
38	Compressor stop causes ④	0,1	—	Order of 100 : Defective suction pipe thermistor Order of 10 : Defective low pressure sensor Order of 1 : Defective high pressure sensor (0:Normal, 1: Anomaly)
39	Compressor stop causes ⑤	0,1	—	Order of 100 : Anomalous in inverter 1 Order of 10 : — Order of 1 : Anomalous high pressure (0:Normal, 1: Anomaly)
40	Compressor stop causes ⑥	0,1	—	Order of 100 : Anomalous low pressure Order of 10 : Anomalous discharge pipe1 thermistor Order of 1 : — (0:Normal, 1: Anomaly)
41	Compressor stop causes ⑦	0,1	—	Order of 100 : Defect CM starting Order of 10 : — Order of 1 : Rotor lock (0:Normal, 1: Anomaly)
42	Compressor stop causes ⑧	0,1	—	Order of 100 : — Order of 10 : CM1 Current cut Order of 1 : — (0:Normal, 1: Anomaly)
43	Compressor stop causes ⑨	0,1	—	Order of 100 : Power transistor1 overheating Order of 10 : — Order of 1 : Anomalous in DC fun1 (0:Normal, 1: Anomaly)
44	Compressor stop causes ⑩	0,1	—	Order of 100 : Anomalous in DC fun2 Order of 10 : Stop command from indoor Order of 1 : Operation mode charge (0:Normal, 1: Anomaly)
45	Compressor stop causes ⑪	0,1	—	Order of 100 : Dilute protection Order of 10 : Demand control 0% Order of 1 : 0 (0:Normal, 1: Anomaly)
46	Control status	0,1	—	Order of 100 : During equal oil control Order of 10 : During oil return control Order of 1 : During defrost (0:Non-operation, 1: Operation)
47	Control status	0,1	—	Order of 100 : During Td control Order of 10 : During HP control Order of 1 : During CS control (0:Non-operation, 1: Operation)
48	Control status	0,1	—	Order of 100 : During LP control Order of 10 : During PT control Order of 1 : Under cooling low pressure control (0:Non-operation, 1: Operation)
49	Control status	0,1	—	Order of 100 : Cooling high pressure protection control Order of 10 : High pressure power ratio Order of 1 : Under heating low pressure control (0:Non-operation, 1: Operation)
50	Number of connected indoor unit	0~50	1	
51	Number of operation indoor unit	0~50	1	
52	Required Hz total	0~999	1Hz	
53	Target Fk	0~999	1Hz	
54	Compressor cumulative operating time (CM1)	0~655	100h	
56	Discharge pressure saturation temperature	-50~70	0.1°C	1°C at -10 or lower
57	Air inlet pressure saturation temperature	-50~70	0.1°C	1°C at -10 or lower
58	Target cooling low pressure	0.00~2.00	0.01MPa	
59	Target heating high pressure	1.60~4.15	0.01MPa	
63	Inverter 1 operating frequency command	0~130	1Hz	
66	Control status	0,1	—	Order of 100 : During silent mode Order of 10 : During capacity measurement mode Order of 1 : During test operation (0:Non-operation, 1: Operation)
67	Control status	0,1	—	Order of 100 : Unmatch Order of 10 : Indoor EEV check Order of 1 : — (0:Non-operation, 1: Operation)

Code No.	Contents of display	Data display range	Minimum units	Remarks
68	Control status	0,1	—	Order of 100 : Piping cleaning Order of 10 : Under-dome temperature control Order of 1 : Compression ratio protection control (0:Non-operation, 1: Operation)
69	Outdoor operation pattern	0~9	—	9: C4, 8:C3, 7:C2, 6:C1, 5:C0 4: E1, 3:E2, 2:E3, 1:E4
70	Operation priority switching	0,1	—	0: Prior press priority (when shipped) 1: After press priority
71	High pressure control of cooling	2.2, 2.5	0.01MPa	2.2: Factory setting 2.5: Alternate setting
72	low pressure control of cooling	-0.05~+0.05	0.01MPa	0.00: Factory setting
73	Heating high pressure compensation	0.00~0.30	0.01MPa	0.00: Factory setting
74	Low pressure of heating	0.80, 0.90	—	0.80: Factory setting 0.90: Alternate setting
75	Snow protection fan control	0,1	—	0: Snow protection fan control deactivated 1: Snow protection fan control activated
77	Data reset	---, dEL	—	
78	Figure language sub version	—	—	(Example: 730)
79	Figure language logic version	—	—	(Example: 126)
80	Counter · Thermistor disconnection	0~2	—	
81	Counter · Inverter 1 communications error	0~3	—	
82	Counter · High pressure protection	0,1	—	
83	Counter · Compressor 1 starting failure	0,1	—	
84	Counter · Anomalous low pressure ① (Under stop)	0~4	—	
85	Counter · Anomalous low pressure ② (Immediately after starting)	0,1	—	
86	Counter · Anomalous low pressure ③ (Under operation)	0~3	—	
87	Counter · Motor lock of compressor 1	0~3	—	
88	Counter · Overheating of power transistor 1	0~4	—	
89	Counter · Anomalous temp. of discharge pipe 1	0,1	—	
91	Counter · Current cut (CM1)	0~3	—	
93	Counter · Indoor-outdoor communications error	0~255	—	
94	Counter · Outdoor inverter communications error 2	0~255	—	
95	Counter · CPU reset	0~255	—	
96	Counter · Anomalous FM01	0~255	—	
97	Counter · Anomalous FM02	0~255	—	
98	Program version	—	—	
99	Auto send display	—	—	

## (19) Saving of Operation Data

Operating data for a period of 30 minutes prior to the time when trouble occurs are recorded, and these data can be fetched to a personal computer through the RS232C connector on the control board. Data are updated continuously, and when there is an abnormal stop, data updates stop at that point. Pressing DIP switch SW7 for 3 seconds causes the data to be erased. Data can also be sampled at 1 minute intervals during operation and fetched to a personal computer.

- Data is transmitted from a personal computer upon demand.

Data	Data Range	Example
Software version	ASCII 15-byte	KD4C270##### (#: NULL)
PID (program ID)	ASCII 2-byte	D8
Outdoor unit capacity	ASCII 3-byte	280
Power supply frequency	ASCII 2-byte	60
Outdoor address	ASCII 2-byte	00 ~ 3F
Indoor address × 16 units	ASCII 2-byte × 16 units	40 ~ 7F
Indoor capacity × 16 units	ASCII 3-byte × 16 units	022 ~ 280

Code No.	Write-in contents	Record data			
		Data write-in range	Write-in unit	Number of bytes	Contents
00	Anomaly code	00~99		1	00: No anomalous, outdoor unit all anomalous ???
01	Address of unit where trouble occurred	00~FF	–	1	0~3F: Outdoor unit side, 40~6F: Indoor unit side
02	Operation mode	0~2	–	1	0 Stop
					2 Cooling
					4 Heating
03	High pressure sensor	0.00~5.00	A/D value	1	
04	Low pressure sensor	0.00~2.00	A/D value	1	
05	Heat exchanger temp. 1 (Exit, Front) (Tho-R1)	-35~75	A/D value	2	Cooling liquid side
06	Heat exchanger temp. 2 (Exit, Rear) (Tho-R2)	-35~75	A/D value	2	Cooling liquid side
07	Heat exchanger temp. 3 (Entrance, Front) (Tho-R3)	-35~75	A/D value	2	Cooling gas side
08	Heat exchanger temp. 4 (Entrance, Rear) (Tho-R4)	-35~75	A/D value	2	Cooling gas side
09	Tho-D1 Discharge pipe temp.	20~140	A/D value	1	
11	Tho-C1 Under-dome temp.	-15~90	A/D value	1	
13	Tho-A Outdoor air temp.	-20~43	A/D value	1	
14	Tho-P1 Power transistor temp. (Heat dissipation fin)	20~140	A/D value	1	
16	Tho-SC Sub cooling coil temp. 1	18~73	A/D value	1	Liquid pipe side
17	Tho-H Sub cooling coil temp. 2	-35~75	A/D value	2	Suction pipe side
18	Tho-S Suction pipe temp.	-35~75	A/D value	2	
19	Cooling operation super cooling	0~50	0.01°C	2	
20	Super heat	0~50	0.01°C	2	
21	Super heat of sub-cooling coil	0~50	0.01°C	2	
22	CT1 Current	0~50	A/D value	1	

Code No.	Write-in contents	Record data			
		Data write-in range	Write-in unit	Number of bytes	Contents
24	Power source voltage	180~500	A/D value	1	
25	Pressure switch	—	—	1	Bit0 63H1 0: open, 1: close
26	Solenoid valve	—	—	1	Bit0 20S 0:OFF, 1:ON Bit1 20SL 0:OFF, 1:ON Bit2 SV1,2 0:OFF, 1:ON Bit4 SV6 0:OFF, 1:ON Bit5 SV7 0:OFF, 1:ON Bit6 SV11,12 0:OFF, 1:ON
27	Crankcase heater etc.	—	—	1	Bit0 CH1 0:OFF, 1:ON Bit2 FM1,2 0:OFF, 1:ON
28	FM01 Number of rotations	0~65535	10 min <sup>-1</sup>	2	
29	FM02 Number of rotations	0~65535	10 min <sup>-1</sup>	2	
30	EEVH1 opening angle	0~65535	1pulse	2	
31	EEVH2 opening angle	0~65535	1pulse	2	
32	EEVSC opening angle	0~65535	1pulse	2	
34	Indoor unit connection number	0~255	1 unit	1	
35	Indoor unit connection capacity	0~65535	—	2	
36	Indoor unit thermostat ON number	0~255	1 unit	1	
37	Indoor unit thermostat ON capacity	0~65535	—	2	
38	Required Hz total	0~65535	1Hz	2	
39	Target FK	0~65535	1Hz	2	
40	Inverter CM1 operation frequency	0~255	1Hz	1	
42	Answer Hz total	0~65535	1Hz	2	
43	Compressor cumulative operating time (estimate)	0~65535	1 h	2	
45	Compressor start times	0~65535	20 times	2	
47	Compressor stop causes			1	Bit0 Defective outdoor temperature thermistor Bit1 Defective outdoor unit heat exchanger 1 thermistor Bit2 Defective outdoor unit heat exchanger 2 thermistor Bit3 Defective outdoor unit heat exchanger 3 thermistor Bit4 Defective outdoor unit heat exchanger 4 thermistor Bit5 Defective discharge pipe thermistor Bit7 Defective sub-cooling coil thermistor 1
48	Compressor stop causes	—	—	1	Bit0 Defective sub-cooling coil thermistor 2 Bit1 Defective suction pipe thermistor Bit2 Defective low pressure sensor Bit3 Defective high pressure sensor Bit4 Inverter 1 anomalous communication Bit6 Anomalous high pressure Bit7 Anomalous Low pressure
49	Compressor stop causes	—	—	1	Bit0 Td1 Anomalous discharge pipe temp. Bit2 CM starting defect Bit4 Rota lock of CM Bit6 Current cut of CM

Code No.	Write-in contents	Record data				
		Data write-in range	Write-in unit	Number of bytes	Contents	
50	Compressor stop causes	-	-	1	Bit0	Power transistor 1 overheating
					Bit1	Power transistor 2 overheating
					Bit2	FM01 anomaly
					Bit3	FM02 anomaly
					Bit4	Compressor stop command from indoor unit
					Bit6	Dilution rate protection
					Bit7	Demand control 0%
51	Control status	0~180	1 second	1	CM 3-minute delay timer	
53	Discharge pressure saturation temperature	-50~70	0.01°C	2		
54	Intake pressure saturation temperature	-50~70	0.01°C	2		
55	Control status oil return	0,1	-	1	0	None
					1	Under control
56	Control status oil return	0~2	-	1	0	None
					1	Waiting for oil return
					2	Under oil return
57	Control status defrost conditions	0~3	-	1	0	None
					1	Temperature conditions
					2	Strengthening temperature conditions
					3	Time conditions
58	Control status defrost status	0~4	-	1	0	None
					1	Defrosting status 1
					2	Defrosting status 2
					3	Defrosting status 3
					4	Defrosting status 4
59	Control staus Td	0~2	-	1	0	None
					1	Frequency down
					2	Discharge pipe temp.
60	Control status	0, 1	-	1	Td1 error counter	
62	Control status HP	0~2	-	1	0	None
					1	Frequency down
					2	Under high pressure control
63	Control status	0~1	-	1	HP error (63H1) counter	
64	Control status CS	0~2	-	1	0	None
					1	Frequency down
					2	Under CS control
65	Control status LP	0~2	-	1	0	None
					1	Frequency down
					2	Under low pressure control
66	Control status	0~3	-	1	LP error (when stopped) counter	
67	Control status	0~4	-	1	LP error (when started) counter	
68	Control status	0,1	-	1	LP error (when driving) counter	
69	Control status PT	0~2	-	1	0	None
					1	Frequency down
					2	Under PT control
70	Check operation status	-	-	1	Bit0	Unmatch check
					Bit1	Indoor side EEV check
					Bit3	Piping cleaning
71	Control status	0~360	1 minutes	2	CH compressor protection timer	
72	Control status CH compressor protective start	0~15	-	1	15	Protective start end
					0~14	During protective start
73	Switch etc.	-	-	1	Bit0	External operation (CnS1)
						0: Operation prohibition
						1: Operation permission
						Demand (CnS2)
					Bit1	0: None
						1: Under control
						Forced cooling, heating (CnG1)
					Bit2	0: None
						1: Under control
						Silent mode (CnG2)
					Bit3	0: None
						1: Under control
					Bit4	Back up operation
						0: None
						1: Back up operation
Bit5		Hz cancel operation				
		0: None				
		1: Under control				



Code No.	Write-in contents	Record data			
		Data write-in range	Write-in unit	Number of bytes	Contents
74	Control status	0~3	—	1	Current cut anomaly counter
75	Control status	0~4	—	1	Power transistor overheating anomaly counter
76	Control status	0~3	—	1	Rotor lock anomaly counte
77	Control status	0~1	—	1	Starting failure counter
78	Control status	0~3	—	1	Communications anomaly counter
79	Control status	0~3	—	1	Current cut anomaly counter
84	Control status	0~1	—	1	DC fan motor 1 error counter
85	Control status	0~1	—	1	DC fan motor 2 error counter
86	Control status	0~2	—	1	Sensor disconnection counter
87	Control status	0~255	—	1	Communications error counter
88	Registered indoor units 1~8 operation mode	0~4	—	8	0 AUTO
					1 DRY
					2 COOL
					3 FAN
					4 HEAT
89	Registered indoor units 1~8 required Hz	0~255	1Hz	8	
90	Registered indoor units 1~8 answer Hz	0~255	1Hz	8	
91	Operation priority switching	0~1	—	1	0 Prior press priority
					1 After press priority
92	High pressure control of cooling	2,2,2,5	0.01MPa	1	
93	Cooling low pressure compensation	-0.05~+0.05	0.01MPa	1	
94	Low pressure control of heating	0.8,0,9	0,01MPa	1	
95	Snow protection fan control	0~1	1Hz	1	0 With
					1 None
96	CM1 frequency command	0~130	1Hz	1	
98	Target cooling low pressure	0.00~2.00	0.01MPa	1	
99	Control status TC	0~2	—	1	0 None
					1 Frequency down
					2 Under-dome temperature control
100	Target heating high pressure	1.60~4.15	0.01MPa	1	
101	Heating high pressure compensation	0.00~0.30	0.01MPa	1	
102	Control / status SCR	0~2	—	1	0 None
					1 Frequency down
					2 Under compression ratio protection control
103	Target amount of overheating during heating	0~255	0.1°C	1	The actual range is 5°C ~ 11°C.
104	Cumulative amount of oil rise.	0~255	10cc	1	The actual range is 0 cc ~ 1100 cc.
105	Total capacity of thermostat ON indoor units during cooling.	0~65535		2	
106	Total capacity of thermostat ON indoor units during heating.	0~65535		2	
107	Outdoor unit operating pattern	0~255	1	1	The actual range is 0 ~ 17.

## **(20) Outdoor unit control**

If an outdoor unit (a unit with all the heat exchangers integrated, and all the outdoor air and supply air processing units) is connected to multiple indoor units, as a rule, the cooling low pressure target and the heating high pressure target for cooling or heating are specified when the object is ventilation.

During cooling (evaporation temperature): 15°C

During heating (condensation temperature): 30°C

### **(a) Starting conditions**

When only the thermostat of the outdoor unit for the operating indoor units is in the ON state.

### **(b) Control contents**

- (i) 0.22 MPa is added to the target cooling low pressure during compressor cooling low pressure control.
- (ii) The target heating high pressure is set at 1.77 MPa during compressor heating high pressure control.

### **(c) End conditions**

When the outdoor unit changes to operation other than outdoor unit only (thermostat ON) after the outdoor unit begins single operation.

## **(21) Pump down control during stop (liquid backflow prevention)**

### **(a) Pump down control before starting**

- (i) Control contents
  - 1) The EEV on indoor units which are in cooling mode is fully closed.
  - 2) When the outdoor unit's operating mode is heating, EEVH1, 2 are fully closed.
  - 3) The EEVSC is fully closed.
  - 4) The outdoor unit's operating pattern is not changed.
- (ii) Starting conditions
  - 1) Operation start after a stop.
  - 2) When there is an operation start after an indoor unit switches from cooling to heating.
  - 3) When oil return control starts.
  - 4) When normal control is recovered after oil return control ends.
- (iii) End conditions
  - 1) When the compressor stops.
  - 2) When 5 minutes have passed since the compressor went ON.
  - 3) Low pressure sensor  $\leq 0.4$  MPa (outdoor unit operating mode is cooling)  
Low pressure sensor  $\leq 0.3$  MPa (outdoor unit operating mode is heating)

### **(b) Pump down control after stop**

- (i) Control contents
  - 1) The EEV on indoor units which are in cooling mode is fully closed.
  - 2) When the outdoor unit's operating mode is heating, EEVH1, 2 are fully closed.
  - 3) The EEVSC is fully closed.
  - 4) The operating frequency command applied to the compressor is maintained. (protective control is activated)
  - 5) The speed command applied to the outdoor unit's fan is maintained.
  - 6) The outdoor unit's operating pattern does not change.
- (ii) Starting Conditions

When operation stops after operation.
- (iii) End conditions
  - 1) When there is a full emergency stop.
  - 2) Low pressure sensor  $\leq 0.4$  MPa (outdoor unit operating mode is cooling)  
Low pressure sensor  $\leq 0.3$  MPa (outdoor unit operating mode is heating)

## (22) Outdoor unit equal pressure control

In a cooling/heating free multi-system, if an indoor unit is switched from cooling to heating, this control functions through a branch flow controller to switch the high pressure gas line and the low pressure gas line. When the branch flow controller's switching occurs, the pressure differential between the high pressure and low pressure sides is first changed to equal pressure, then switching is accomplished. Pressure equalization is done by switching the 4-way valve with the compressor stopped, so if any indoor unit is switched from cooling to heating, the compressor stops.

### (a) Starting conditions

- (i) When switching an indoor unit from cooling to heating during compressor operation (except during oil return or defrost control).
- (ii) When all the indoor units are fully stopped and the compressor is stopped.
- (iii) When the system is starting oil return control and the compressor is stopped.

### (b) Control contents

- (i) When an indoor unit is switched from cooling to heating, the compressor is stopped for 3 minutes. (auto recovery)
- (ii) Outdoor unit cooling operation (outdoor unit heat exchanger high pressure → 4-way valve 20S, 20SL ON.  
Outdoor unit heating operation (outdoor heat exchanger low pressure) → 4-way valve 20S, 20SL OFF.
- (iii) This control is performed beginning 10 seconds after the compressor stops and continues for 2 minutes 40 seconds.


### (c) End condition

After being stopped for 2 minutes 40 seconds.


## (23) Indoor unit branch flow controller control

If you switch between cooling and heating at an indoor unit in the free multi cooling/heating system, switching between the high pressure gas line and the low pressure gas line is accomplished by the branch flow controller. The branch flow controller performs control using the output from CNT on the indoor unit's control PCB. The CNT output operates with a x2 (heating output) bit and 2 x3 bits, so there are 4 branch flow controller states.


### ① Cooling state (No power state)




### ② Heating state



### ③ Intermediate state (Equal pressure state)



### ④ Oil return state



**(a) Branch flow controller's control when the indoor unit's operating state changes**


When the state of an indoor unit changes between cooling, heating and oil return, the branch flow controller is changed in the following sequence.

- (i) In the case of Cooling → Heating, Cooling → Oil return, Heating → Oil return or Cooling/Heating → Full stop (Compressor stop)

(Recovery from oil return is excluded.)

<Control Content>


- If the outdoor unit is running and the compressor stops, after 5 seconds, the equal pressure state is maintained for 2 minutes 50 seconds, then the output is in accordance with the operating mode.
- If the compressor stops by the outdoor unit stopping, after 5 seconds, the equal pressure state is maintained for 2 minutes 50 seconds. Then the power off state (cooling state) is output.



(ii) Oil return → Cooling / Heating (Recovery from oil return)

<Control Content>

- Recovery from oil return while the outdoor unit is running causes the compressor to stop causes the output to be in accordance with the operating mode after 1 minute 25 seconds without entering the equal pressure state.



### All-in-one type and Combined type

- ◆ Models FDCA335HKXRE4R-K, 400HKXRE4R, 450HKXRE4R, 504HKXRE4R, 560HKXRE4R, 615HKXRE4R, 680HKXRE4R, 735HKXRE4R, 800HKXRE4R, 850HKXRE4R, 900HKXRE4R, 1010HKXRE4R, 1065HKXRE4R, 1130HKXRE4R, 1180HKXRE4R, 1235HKXRE4R, 1300HKXRE4R, 1360HKXRE4R

#### (1) Operations of major functional items under each operation mode

Functional item	Operation mode	Cooling		Fan	Heating			Dehumidify
		Thermostat ON	Thermostat OFF		Thermostat ON	Thermostat OFF	Defrost	
Indoor unit fan		Remote controller command	Remote controller command	Remote controller command	Remote controller command	Intermittent operation	○ → ×	○ / ×
Indoor unit electronic expansion valve		Overheating control response	Fully closed	Fully closed	Overheating control response	60 pulse	Model-specific aperture opening angle	Overheating Control Response
Compressor [CM1]		○	×	×	○	×	○	○ / ×
Magnetic contactor CM1 [52C1]		○	○	× / ○	○	○	○	○
Compressor [CM2]		○ / ×	×	×	○ / ×	×	○	○ / ×
Magnetic contactor CM2 [52C2]		○	○	×	○	○	○	○
Outdoor unit fan [FMO-1]		○ / ×	×	× / ○	○ / ×	×	○ → ×	○ / ×
Outdoor unit fan [FMO-2]		○	×	× / ○	○	×	○ → ×	○ / ×
Inverter cooling fan [FMC1, 2]		○ / ×	○ / ×	×	○ / ×	○ / ×	○ / ×	○ / ×
4 way valve [20S, SL]		Refer to following table.						
Electronic expansion valve for heating [EEVH1, 2]		Refer to following table.						
Electronic expansion valve for sub-cooling [EEVSC]		Refer to following table.						
Solenoid valve [SV4]		When the operating pattern is C2, ○ (See the table below concerning operating patterns.)						
Solenoid valve [SV6]		○ / ×	×	×	○ / ×	×	○ / ×	○ / ×
Solenoid valve [SV7]		○ / ×	×	×	○ / ×	×	○ / ×	○ / ×
Solenoid valve [SV11]		×	×	×	○ / ×	×	×	×
Crankcase heater [CH1,2]		○ / ×	○ / ×	○ / ×	○ / ×	○ / ×	○ / ×	○ / ×

Notes(1) ○ : ON, × : OFF, ○/× : ON or OFF, ×/○ : OFF or ON

- 4-way valve (20S, SL), heating expansion valve (EEVH1, 2) and sub-cooling expansion valve (EEVSC) operating pattern

The operating pattern for outdoor unit is determined from the run/stop signals and cooling/heating signals from the indoor units and from the indoor unit model capacity.

Note (1) Switching of the operating pattern is controlled by the capacity of indoor units which have their thermostat ON and the pressure sensors (PSH, PSL).


Operating pattern	Outdoor heat exchanger		For heat exchanger use	4-way Valve		Electronic expansion valve		
	Heat exchanger 1	Heat exchanger 2		20S	20SL	EEVH1	EEVH2	EEVSC
C8	COND	COND	COND 100%	×	×	Fully open	Fully open	PI control
C4	COND	—	COND 50%	×	○	Fully open	Fully closed	PI control
C1	COND	EVA	COND 0%	×	○	60-100	PI control	PI control
C2	COND	—	COND 0~50%	×	○	60-100	Fully closed	PI control
C0	—	—	COND 0%	○	○	Fully closed	Fully closed	Fully closed
E4	EVA	—	EVA 50%	○	○	PI control	Fully closed	Fully closed
E8	EVA	EVA	EVA 100%	○	○	PI control	PI control	Fully closed

Note (1) ○ : ON, × : OFF

## (2) Compressor starting order and load classes

The run/stop sequence of the compressors is according to compressor start control between the outdoor units in accordance with their respective standard and mixed specifications.


### (a) Standard specifications ([FDCA400~680]: 2-compressor specifications)



The operating frequency range of each compressor with respect to the load is as shown below, with the table below showing the case where CM1 is started for the first time. (In the case of starting from CM2, the CM1 frequency for load category 1 is the CM2 frequency.

Load category	0	1	2
CM1	0Hz	20~112Hz	31~120Hz
CM2	0Hz	0Hz	31~120Hz

### (b) Combination specifications (FDCA735~1360): Master unit + 1 slave unit



Operating frequency ranges for each compressor corresponding to different loads are as shown below. The following table applies to the case when CM01 starts at first. (When CM11 starts first, the frequency of CM01 for the load category 1 becomes the frequency of CM11.

If the system starts from CM1, the CH1 frequency in load category 1 becomes the CM1 frequency.

Load Category		0	1	2	3
Master unit	CM01	0Hz	20~112Hz	31~112Hz	31~120Hz
	CM02	0Hz	0Hz	0Hz	31~120Hz
Slave unit	CM11	0Hz	0Hz	31~112Hz	31~120Hz
	CM12	0Hz	0Hz	0Hz	31~120Hz

### (3) Compressor start control between outdoor units (Master unit/slave unit)

#### (a) Determining the starting order for the master unit and slave units

Determine the starting order for the outdoor units of master unit and slave units, which is decided by the order in which the power switches are turned on.

- 1) Starting order of master unit (N=0) ... First
- 2) Starting order of slave unit 1 (N=1) ..... Second

#### (b) Determining starting order for compressors within master unit and slave unit groups.

Determine the starting order for compressors 1 and 2 within the master unit and slave unit groups as follows.

- 1) Starting order of compressor 1 (M=0) ... First
- 2) Starting order of compressor 2 (M=1) ... Second

#### (c) Compressor starting order and start control for combination specifications I

When all outdoor units change from the full stop state to the cooling/dehumidifying operation (including when all indoor units start from the cooling thermostat OFF state)

- 1) Start control
  - a) Starting is controlled by determining the start order and the stop order for compressors in the load categories.
  - b) When only one outdoor unit is used, the starting order for compressor 1 and compressor 2 is switched on each occasion when the outdoor unit stops.
  - c) Each time the master unit and each slave unit stop independently of each other, the starting order for compressor 1 and compressor 2 is switched.
  - d) Each time an outdoor unit stops within the master unit and slave unit groups, the starting order for compressors within the master unit and slave unit groups is switched.

Starting order of outdoor units      Master unit→Slave unit

Model	Starting order of outdoor units	Starting order of compressors
FDCA400~680	—	CM 1 → CM 2 → CM 1
FDCA735~1360	Master unit → Slave unit → Master unit	CM 1 → CM 2 → CM 1

#### (d) Compressor starting order and start control for combination specifications II

The following control is activated when all the outdoor units are operated.

- 1) After the compressor which is first in the starting order starts, all outdoor units are started temporarily in accordance with the operation order N.
- 2) 4-way valves (20S) are subject to the control prior to the start of the compressor.
- 3) 4-way valve switching protection
  - a) Regarding the outdoor unit which is second in the starting order, the 4-way valve (20S) is turned ON in compliance with 4-way valve switching protection control in order to perform 4-way valve switching protection control. (During the 4-way valve switching protection operation, the outdoor blower is operated under normal control.)
  - b) After 4-way valve switching protection operation, the compressors are stopped in accordance with the target operation frequency. (4-way valve is in the ON condition.)
- 4) Unless all 4-way valves on the outdoor units which are in second place in the starting order can be turned ON, the Compressor ON command is transmitted continually until they are turned ON.



#### (4) Snow protection fan control (Master unit/slave unit)


Set this for the master unit as well as slave units.

##### (a) This control is enabled/disabled by the selector switch at the 7-segment display.

- ① Set the Code No. to "75".
- ② "0" or "1" displays at the data display area.  
0: Outdoor fan control disabled (factory setting)  
1: Outdoor fan control enabled
- ③ Press SW7 continuously for 3 seconds.
- ④ "0" or "1" blinks every 0.5 seconds at the data display area.
- ⑤ Press SW8 to toggle between the blinking "0" and "1" displays.
- ⑥ If SW7 is pressed for 3 seconds or longer while "0" and "1" is blinking, the blinking stops, and that enabled/disabled setting is registered. If enabled, fan control occurs as described below.
- ⑦ Outdoor fan control occurs in accordance with the information stored in memory, even if the power is turned OFF and back ON again.

##### (b) Control description

- (i) If the outside temperature drops to 3°C or lower when all units are stopped, or during an error stop, the outdoor fan runs at level 4 speed once every 10 minutes.




Outdoor air temperature (°C)

- (ii) The outdoor fan runs for 30 seconds.
- (iii) During this snow protection control, the compressor's magnetic contactor (52C1) is ON.

#### (5) Silent mode control (Master unit/slave unit)


- (a) If the silent mode start signal is received from an indoor unit or CnG2 (with short pin) is shorted, if the outdoor temperature is within the following range, operation is performed in the silent mode.

##### • Cooling



Outdoor air temperature (°C)

##### • Heating



Outdoor air temperature (°C)

- (b) Outdoor fan maximum speed & maximum compressor operation frequency (excluding the 30-second period after a start, and defrost operations)

- 1) The maximum outdoor fan speed is 335 ~ 450: 500min<sup>-1</sup>, 504 ~ 6801: 660min<sup>-1</sup>.

Note (1) In the case of a combination unit, the slave unit is made independent and runs with the above speed.


- 2) Maximum compressor operation frequency Max. Operation Frequency (Hz)

Model	(Hz)	Model	(Hz)	Model	(Hz)
FDCA400	46 × 4	FDCA735	42 × 4	FDCA1065	64 × 4
FDCA450	52 × 4	FDCA800	46 × 4	FDCA1130	70 × 4
FDCA504	60 × 2	FDCA850	50 × 4	FDCA1180	74 × 4
FDCA560	70 × 2	FDCA900	52 × 4	FDCA1235	78 × 4
FDCA615	78 × 2	FDCA960	56 × 4	FDCA1300	78 × 4
FDCA680	84 × 2	FDCA1010	60 × 4	FDCA1360	78 × 4

## (6) Inverter cooling fan control (Master unit/slave unit)

This control applies to the master unit and slave units independently.

- (a) After the inverter starts, the cooling fans (FCM1, 2) are turned ON or OFF depending on the temperatures detected by the power transistor thermistor (Tho-P1, 2).



- (b) When the compressor changes from the ON to the OFF state, if the cooling fan is turned ON, the fan continues in the ON state for 3 minutes 10 seconds.

## (7) Compression ratio protection control (Master unit/slave unit)

The frequency is reduced in accordance with the compressor's compression ratio.


### (a) Control activation conditions

This control is activated when all the following conditions are satisfied.

- (i) When 10 minutes or more have elapsed since the compressor start.
- (ii) When the low pressure is 0.18MPa or higher, and the high pressure is 3.52MPa or lower.

Note (1) The above does not apply for a 10-minute period following a defrost, or when pump-down control is in progress.

### (b) Control description



### (c) Control termination conditions

Control ends when any one of the following conditions is satisfied.

- (i) When the low pressure is 0.18MPa or higher, and the high pressure is 3.52MPa or lower.
- (ii) When the compression ratio falls below the cancel value.


## (8) Defrosting (Master unit/slave unit)

If the conditions for starting defrosting of the outdoor heat exchanger of any of the outdoor units are established during compressor operation, defrost operation starts.

### (a) Conditions for starting defrosting

When all the following conditions are met, the defrosting operation will start.

- 1) When the outdoor unit operating pattern is E8.
- 2) The cumulative operating time of the compressor comes up to 33 minutes after completion of a defrosting operation, or it comes up to 33 minutes after a heating operation starts (the remote controller is turned on).
- 3) If 8 minutes have passed after the compressor goes ON after it has gone OFF.
- 4) If 8 minutes have passed after one outdoor unit fan goes ON after all outdoor fans have gone OFF.
- 5) After all the above conditions are satisfied, when the temperature at the outdoor heat exchanger thermistor (Tho-R) and outdoor temperature thermistor is below the defrost initiation temperature in the above graph continuously for 3 minutes.



**(b) Conditions for finishing defrosting**

- Standard (J14: shorted)
  - 1) When the increase of the temperature of the heat exchanger thermistor (Tho-R1 or Tho-R2) is greater than 9°C.
  - 2) When 12 minutes have passed since defrosting started.
- With operation Judgment Function (J14: Open)
  - 1) If Tho-R1 and R2 are  $\geq 9^{\circ}\text{C}$ , after 2 minutes and 30 seconds have passed since defrosting started, if either of the following conditions is satisfied, the defrosting end operation starts.
    - a) 2 minutes and 30 seconds have passed since the temperature sensed by either Tho-R1 or Tho-R2 is 14°C or higher.
    - b) The temperature sensed by either Tho-R1 or Tho-R2 is 30°C or higher.
    - c) 14 minutes have passed since the start of defrosting.
  - 2) If Tho-R1 or R2 are  $< 9^{\circ}\text{C}$  after 2 minutes and 30 seconds have passed since defrosting started, if either of the following conditions is satisfied, the defrosting end operation starts.
    - a) 5 minutes have passed since the temperature sensed by either Tho-R1 or Tho-R2 is 14°C or higher.
    - b) The temperature sensed by either Tho-R1 or Tho-R2 is 30°C or higher.
    - c) 14 minutes have passed since the start of defrosting.


**(c) Dehumidifying Operation Interrupted**

- 1) Compressor stopped
- 2) Oil return control conditions established


In the relationship between oil return and dehumidifying operation, oil return has priority and if the system begins oil return during a dehumidifying operation, the dehumidifying operation is interrupted and the oil return operation is executed.

**(9) Oil separator solenoid valve (SV6, 7) control (Master unit/slave unit)**


- (a) 3 minutes after the compressor starts, the solenoids (SV6, 7) open (go ON).
- (b) If the compressor operating frequency becomes 80Hz or higher, SV6, 7 opens (goes ON) and it goes off if the frequency is 76Hz or lower.



- (c) If the inverter compressor goes off after SV6, 7 opens (goes ON), SV6, 7 remains open (ON) for 3 minutes and 10 seconds, then closes (goes OFF).



- (d) During heating operations, The SV6 and SV7 valves switch ON when the high pressure is 3.5MPa or higher, and switch OFF when the high pressure is 3.0MPa or lower.



## (10) Emergency stop control

When an indoor unit's external input (optional: refrigerant leakage, etc.) indicates a refrigerant leak, that information is transmitted to the outdoor unit, stopping operation. An emergency stop error is then transmitted to all indoor units that are running.

- (a) Error stop occurs when the "emergency stop" command is received from the indoor unit.
- (b) Error code E63 occurs, and the "emergency stop" command is transmitted to all indoor units.
- (c) When a "emergency stop clear" command is received from the indoor unit, the outdoor unit's error status is cleared, and an "emergency stop clear" command is transmitted to all the indoor units.

## (11) Automatic backup operation

When one or more compressors fail, operation occurs using only the normal compressors.

- (a) Automatic backup operation is only enabled when SW3-2 is ON (alternate setting) at the master unit.
- (b) The following error status are disabled and not detected at failed compressors.
  - ① L3-phase "open phase" error (E32)
  - ② Discharge pipe temperature error (E36)
  - ③ Heat exchanger thermistor disconnection (E37)
  - ④ Outdoor temperature thermistor disconnection (E38)
  - ⑤ Discharge pipe temperature thermistor (E39)
  - ⑥ High pressure error (E40)
  - ⑦ Power transistor overheating (E41)
  - ⑧ Current cut (E42)
  - ⑨ Inverter PCB communication error (E45)
  - ⑩ DC fan error (E48)
  - ⑪ Power transistor overheating (continuous) (E51)
  - ⑫ Suction pipe thermistor disconnection (E53)
  - ⑬ Under-dome temperature sensor disconnected (E55)
  - ⑭ Power transistor temperature sensor disconnected (E56)
  - ⑮ Compressor start error (E59)
  - ⑯ Compressor rotor lock error (E60)
- (c) If any of the item (b) errors shown above occur while a compressor is running, that compressor is stopped, but other compressors continue running as usual.
- (d) After recovering from the error, with start conditions satisfied, the compressors (CM1, 2) which are capable of running at the minimum frequency are started.
- (e) When a failure-recovered compressor is started, the other compressors revert back to their usual control.

## (12) Unit protective maintenance related devices (Master unit only)

### (a) Test operation mode

- 1) This control is performed from the master unit. It cannot be controlled from the slave unit side. If control from the slave unit side is attempted, the following codes are indicated on the 7-segment display.

Code indicator	Data indicator	Description of disabled control
OPE	10	Setting from a slave unit is invalid.

Note (1) Normal display can be restored if the test operation control switch is reset.

- 2) Outdoor unit test operation mode operation is started by the DIP switches SW5-1 and 5-2 on the outdoor unit PCB.



### Switch functions

SW5-1	ON	SW5-2	OFF	Heating Test Operation
	OFF		ON	Cooling Test Operation
		Normal or Test Operation End		


Notes (1) This operation takes priority over other options such as the center console. It sets the options in the operating state.

### (b) Under-dome temperature control

- 1) The oil separator solenoid valve (SV6, 7) are controlled in accordance with the temperature at the under-dome thermistor (Tho-C) installed on the compressor.



- 2) The compressor's capacity is controlled in accordance with the under-dome temperature (Tho-C1, 2).




### (c) High pressure protective control (Master unit/slave unit)

During cooling and heating operations, high pressure is detected by the high pressure sensor (PSH), and the compressor and outdoor fan are controlled to prevent the pressure from rising.

#### 1) Cooling


##### High pressure based compressor control



Note (1) High pressure of less than 3.70MPa continues for 1 minute

#### 2) Heating

##### a) High pressure based fan speed control



Note (1) High pressure of less than 3.7MPa continues for 1 minute

##### b) High pressure based fan speed control

###### i) Control activation conditions

When a high pressure of 3.0MPa or higher occurs 1 minute 45 seconds after a compressor protective start completion.


###### ii) Control description

- ① The fan speed is kept within a 160~960 (1080) min-1 range.

Both fan motors (FMo1 & 2) run at the same speed.

Note (1) Values shown in parentheses apply to the FDCA450 model.


- ② The FMo1 fan motor (right side) stops if the high pressure exceeds the value shown below.



###### iii) Control termination conditions

- ① When a mode other than heating is selected.
- ② When the compressor stops.
- ③ When the high pressure becomes less than 3.0MPa.


#### 3) Solenoid valves SV6 & SV7 open (ON) when the high pressure reaches 3.5MPa or higher.



**(d) Discharge pipe temperature control**


If the temperature of the discharge pipe (Tho-D1, D2) exceeds the set value, the compressor's capacity is controlled and the rise in the discharge pipe temperature is controlled. If it continues to rise, the compressor stops. (The master unit and slave units perform this operation independently.)

**(i) Compressor control**



**(ii) Discharge pipe temperature error**

- When the discharge pipe temperatures (Tho-D1, D2 detection) rise beyond 130°C and is maintained for 2 seconds, the compressors are stopped but it will be reset if the temperatures drop below 90°C.



- Compressors are counted individually if a discharge pipe temperature (Tho-D1, D2 detection) error occurs 2 times within 60 minutes.
- Control description

When the master unit auto-backup operation is invalid (SW3-2 ON), it stops with an anomalous stop. When the master unit auto-backup operation is valid (SW3-2 OFF, the factory setting), it does not stop with an anomalous stop and the compressor remains stopped.

Note (1) Unless the temperature of 90 °C or under is maintained for 60 minutes after the discharge pipe error, the unit cannot be started again. (Reset the power supply to clear.)

**(e) Current safe control (Master unit/slave unit)**

- The compressor speed is reduced if the inverter inlet's input voltage (converter inlet L3-phase) exceeds the setting value while the compressor is running at a speed of 20Hz or higher. If the setting value is still exceeded after the speed reduction, the speed is reduced again.
- This control ends when the input voltage drops below the setting value for a continuous period of 3 minutes, and the speed protection cancel operation begins.
- This is performed by the master unit and slave units independently.

**(f) Anomalous high pressure increase protection (Master unit/slave unit)**


If the high pressure side pressure switch [63H1-1, 63H1-2: 4.15 Open / 3.15 Closed MPa] operates 5 times within 60 minutes or operates for 60 minutes, an anomalous stop is performed.

However, when first operated, the compressor is stopped, then after a 3-minute delay, normal operation is resumed.

**(g) Power transistor temperature control (Master unit/slave unit)**


If the temperature of the power transistor cooling fins (sensed by Tho-P) exceeds the set value, the compressor's capacity is controlled to keep the power transistor's temperature from rising. If it rises still higher, the compressor is stopped.

1) Compressor control



2) Power transistor temperature anomaly

- If the temperature sensed by the power transistor temperature thermistor rises to 110°C or higher, the compressor (CM1, 2) is stopped.




- If the power transistor's temperature is abnormal 5 times within 60 minutes (E41), or if the temperature is 110°C or higher for 15 minutes continuously (E51), including when the compressor is stopped, an anomalous stop is performed.

**(h) Low pressure protective control (Master unit/slave unit)**


If the low pressure (sensed by PSL) drops below the set value, the compressor's capacity is controlled to prevent the low level pressure from dropping. If it drops still further, the compressor is stopped.

1) Compressor control



2) Low pressure anomaly

- If the low pressure (sensed by PSL) drops to 0.134 MPa or lower continuously for 30 seconds, the compressor is stopped and if a pressure of 0.18 MPa or higher is detected continuously for 10 seconds, the compressor is automatically reset. If this occurs 5 times within 60 minutes, an anomalous stop is performed.



- Compressor operation at a low pressure (sensed by PSL) of 0.18 MPa or lower continuously for 30 seconds while stopped is prohibited. If this state is sensed 5 times in 60 minutes, it results in an anomalous stop. Recovery is possible only by resetting the power supply.
- When operating the unit in cooling mode the first time after turning on the power

If a low pressure of 0.003 MPa or lower is detected continuously for 60 seconds after 4-way valve switching protection, the compressor is stopped, and if a pressure of 0.18 MPa or higher is detected continuously for 10 seconds the compressor restarts automatically. However, if this state is detected again 2 times within 60 minutes, it results in an emergency stop. Recovery is possible only by resetting the power supply.

### (13) Pump down control

- (a) This control is performed from the master unit side. It cannot be controlled from the slave unit side. If control from the slave unit side is attempted, the following codes are displayed on the 7-segment display of the slave unit.

Code indicator	Data indicator	Description of disabled control
OPE	10	Setting from a slave unit is invalid.

Note (1) The display returns to normal if the pump-down control switch is reset.

- (b) Pump down operation can be performed through operation of DIP switches (SW5-1, 2, 3). (Pump down operation cannot be done during indoor unit operation, backup operation or during an anomalous stop.)

#### (i) Pump down procedure

- 1) Close the liquid side service valve on the outdoor unit.
- 2) Turn SW5-2 (test operation operating mode) ON (cooling).
- 3) Turn SW5-3 (pump down switch) ON.
- 4) Turn SW5-1 (test operation switch) ON.

#### (ii) Control

- 1) The red and green (LED's) on the outdoor control PCB flashes together continuously and "PoS" is displayed in the 7-segment display.
- 2) Except for low pressure control, all the protective and anomalous sensing controls are activated.
- 3) Test operation commands are sent to the indoor units.

#### (iii) Ending

If any of the following conditions exists, pump down operation ends.

- 1) If a low pressure (sensed by PSL) of  $\leq 0.01$  MPa is detected continuously for 5 seconds.
  - a) The displays are as follows.
    - Red LED: Lights up continuously
    - Green LED: flashing
    - 7-segment LED display: PoE
    - Remote controller: Stop
- 2) If operation is stopped by anomalous sensing control.
- 3) If the cumulative compressor operation time totals 15 minutes.
  - a) The displays are as follows.
    - Red LED: stays OFF
    - Green LED: flashing
    - 7-segment LED display: No display
    - Remote controller: Stop
- 4) If any one of DIP switches SW5-1, 2 or 3 is turned OFF during the pump down operation.

### (14) External input operation (Master unit/slave unit)

External input: From CnS1, operation permission/prohibition control; From CnS2: Demand control/normal operation switching.

- J13: Switches between CnS1 and CnS2 input method.

J13 short circuit: Level input by CnS1 and CnS2.

J13 open: Pulse input by CnS1 and CnS2.


#### (a) From CnS1, operation permission/prohibition control

Input : CnS1	CnS1 input method change: J13	CnS1 : Operation permission/Prohibition mode change
	J13; Closed circuit Lever input	Operation prohibition mode → Operation permission mode
	J13; Disconnection Pulse input	Operation permission/Prohibition mode change (Reversal)
	J13; Closed circuit	Operation permission mode → Operation prohibition mode
	J13; Disconnection (open)	— (NOP)




- 1) The remote controller displays the operating mode. “To Option” sends the operating mode.
- 2) CnS1, performs the following operations by the changing of jumper wire J1 from closed circuit to open circuit.  
If pulse input, the pulse duration is 500 ms or more.

① Opreation with J13 closed circuit



② Opreation with J13 disconnection (open)



(b) From CnS2, operation permission/prohibition control

Input : CnS2	CnS2 input method Formula switching: J13	CnS2 : Demand control/normal operating switching
	J13; Closed circuit Level input	Demand control → Normal operation
	J13; Open circuit Pulse input	Normal operation/Demand control switching (Reversal)
	J13; Closed circuit	Normal operation → Demand control
	J13; Open circuit	— (NOP)

Note (1) The factory settings are: J13 - closed circuit; CnS2 - closed circuit (closed pin connection)

- 1) The remote controller displays the operating mode. “To Option” sends the operating mode.
- 2) Demand control


It is possible to switch the demand using DIP switch SW4-5, 6.

SW45	SW4-6	Compressor output (%)
0	0	80
1	0	60
0	1	40
1	1	0


Note (1) 0: Open, 1: Closed

3) CnS2, performs the following operations by the changing of jumper wire J13 from short circuit to open circuit.  
If pulse input, the pulse duration is 500 ms or more.

① J13 - Closed circuit



② J13 - Open circuit



**(15) 7-Segment display (Master unit/slave unit)**

The data in the following table can be displayed using the display select switch (SW8: 1's digit; SW9: 10's digit).

Code No.	Contents of display	Data display range	Minimum units	Remarks
—	Unusual cade Pump down Check mode Outdoor unit setup	—	—	E?? PoE, PoS CH? OPE??
00	CM1 operating frequency	0~130	1Hz	
01	CM2 operating frequency	0~130	1Hz	
02	Tho-A Outdoor air temp.	L,-20~43	1°C	[L] is indicated when the temperature is -20°C or below and the actual temperature is indicated when it is higher than -20°C and up to 43°C.
03	Tho-R1 Heat exchanger temp. 1 (Exit. Front)	L,-25~73	1°C	[L] is indicated when the temperature is -25°C or below and the actual temperature is indicated when it is higher than -25°C and up to 73°C.
04	Tho-R2 Heat exchanger temp. 2 (Exit. Rear)	L,-25~73	1°C	[L] is indicated when the temperature is -25°C or below and the actual temperature is indicated when it is higher than -25°C and up to 73°C.
05	Tho-R3 Heat exchanger temp. 3 (Entrance. Front)	L,-25~73	1°C	[L] is indicated when the temperature is -25°C or below and the actual temperature is indicated when it is higher than -25°C and up to 73°C.
06	Tho-R4 Heat exchanger temp. 4 (Entrance. Rear)	L,-25~73	1°C	[L] is indicated when the temperature is -25°C or below and the actual temperature is indicated when it is higher than -25°C and up to 73°C.
07	Tho-D1 Discharge pipe temp.	L,31~136	1°C	[L] is indicated when the temperature is 31°C or below and the actual temperature is indicated when it is higher than 31°C and up to 136°C.
08	Tho-D2 Discharge pipe temp.	L,31~136	1°C	[L] is indicated when the temperature is 31°C or below and the actual temperature is indicated when it is higher than 31°C and up to 136°C.
10	Tho-C1 Under-dome temp.	L,5~90	1°C	[L] is indicated when the temperature is 5°C or below and the actual temperature is indicated when it is higher than 5°C and up to 80°C.
11	Tho-C2 Under-dome temp.	L,5~90	1°C	[L] is indicated when the temperature is 5°C or below and the actual temperature is indicated when it is higher than 5°C and up to 80°C.
12	Tho-P1 Power transistor temp.	L,31~136	1°C	[L] is indicated when the temperature is 31°C or below and the actual temperature is indicated when it is higher than 31°C and up to 136°C.
13	Tho-P2 Power transistor temp.	L,31~136	1°C	[L] is indicated when the temperature is 31°C or below and the actual temperature is indicated when it is higher than 31°C and up to 136°C.
14	Tho-SC Sub-cooling coil temp.1	L,18~73	1°C	[L] is indicated when the temperature is 18°C or below and the actual temperature is indicated when it is higher than 18°C and up to 73°C.
15	Tho-SC Sub-cooling coil temp.2	L,-25~73	1°C	[L] is indicated when the temperature is -25°C or below and the actual temperature is indicated when it is higher than -25°C and up to 73°C.
16	Tho-S Suction pipe temp.	L,-25~73	1°C	[L] is indicated when the temperature is -25°C or below and the actual temperature is indicated when it is higher than -25°C and up to 73°C.
17	Cooling operation super cooling	0~50	0.1°C	
18	Super heat	0~50	0.1°C	
19	Super heat of sub-cooling coil	0~50	0.1°C	
20	CT1 Current	0~70	1A	
21	CT2 Current	0~70	1A	
22	EEVH1 Heating expansion valve opening angle	0~500	1 Pulse	
23	EEVH2 Heating expansion valve opening angle	0~500	1 Pulse	
24	Opening angle of EEVSC overcooling coil expansion valve	0~500	1 Pulse	
26	FM01 Number of rotations	0~999	10 min <sup>-1</sup>	

Code No.	Contents of display	Data display range	Minimum units	Remarks
27	FM02 Number of rotations	0~999	10 min <sup>-1</sup>	
28	PSH High pressure sensor	0~5.00	0.01MPa	
29	PSL Low pressure sensor	0~2.00	0.01MPa	
30	FMC1, 2 Cooling fan Crankcase heater	0,1	—	Order of 100 : FMC1, 2 Order of 10 : CH1 Order of 1 : — (0: OFF, 1: ON)
31	63H1-1 63H1-2 (63H1-R)	0,1	—	Order of 100 : 63H1-1, 2 Order of 10 : 63H1-R (0: Close, 1: Open)
32	SV1 SV2 20SL	0,1	—	Order of 100 : SV1 Order of 10 : SV2 Order of 1 : 20SL (0: Close, 1: Open)
33	SV6 SV7	0,1	—	Order of 100 : SV6 Order of 10 : SV7 Order of 1 : — (0: Close, 1: Open)
34	20S SV11	0,1	—	Order of 100 : 20S, Order of 10 : SV11 Order of 1 : — (0: close, 1: open)
35	Compressor stop causes ①	0,1	—	Order of 100 : Defective outdoor temperature thermistor Order of 10 : Defective outdoor unit heat exchanger thermistor 1 Order of 1 : Defective outdoor unit heat exchanger thermistor 2 (0:Normal, 1: Anomaly)
36	Compressor stop causes ②	0,1	—	Order of 100 : Defective outdoor unit heat exchanger thermistor 3 Order of 10 : Defective outdoor unit heat exchanger thermistor 4 Order of 1 : Defective discharge pipe thermistor 1 (0:Normal, 1: Anomaly)
37	Compressor stop causes ③	0,1	—	Order of 100 : Defective discharge pipe thermistor 2 Order of 10 : Defective Sub cooling coil thermistor 1 Order of 1 : Defective Sub cooling coil thermistor 2 (0:Normal, 1: Anomaly)
38	Compressor stop causes ④	0,1	—	Order of 100 : Defective suction pipe thermistor Order of 10 : Defective low pressure sensor Order of 1 : Defective high pressure sensor (0:Normal, 1: Anomaly)
39	Compressor stop causes ⑤	0,1	—	Order of 100 : Anomaly in inverter 1 Order of 10 : Anomaly in inverter 2 Order of 1 : Anomalous high pressure (0:Normal, 1: Anomaly)
40	Compressor stop causes ⑥	0,1	—	Order of 100 : Anomalous low pressure Order of 10 : Anomalous discharge pipe thermistor 1 Order of 1 : Anomalous discharge pipe thermistor 2 (0:Normal, 1: Anomaly)
41	Compressor stop causes ⑦	0,1	—	Order of 100 : Defect CM1 starting Order of 10 : Defect CM2 starting Order of 1 : Rotor lock CM1 (0:Normal, 1: Anomaly)
42	Compressor stop causes ⑧	0,1	—	Order of 100 : Rotor lock CM2 Order of 10 : CM1 Current cut Order of 1 : CM2 Current cut (0:Normal, 1: Anomaly)
43	Compressor stop causes ⑨	0,1	—	Order of 100 : Power transistor 1 overheating Order of 10 : Power transistor 2 overheating Order of 1 : Anomaly in DC fun1 (0:Normal, 1: Anomaly)
44	Compressor stop causes ⑩	0,1	—	Order of 100 : Anomaly in DC fun2 Order of 10 : Stop command from indoor Order of 1 : Operation mode charge (0:Normal, 1: Anomaly)
45	Compressor stop causes ⑪	0,1	—	Order of 100 : Dilute protection Order of 10 : Demand control 0% Order of 1 : 0 (0:Normal, 1: Anomaly)
46	Control status	0,1	—	Order of 100 : During equal oil control Order of 10 : During oil return control Order of 1 : During defrost (0:Non-operation, 1: Operation)
47	Control status	0,1	—	Order of 100 : During Td control Order of 10 : During HP control Order of 1 : During CS control (0:Non-operation, 1: Operation)
48	Control status	0,1	—	Order of 100 : During LP control Order of 10 : During PT control Order of 1 : Under cooling low pressure control (0:Non-operation, 1: Operation)
49	Control status	0,1	—	Order of 100 : Cooling high pressure protection control Order of 10 : Heating high pressure protection control Order of 1 : Heating low pressure protection control (0:Non-operation, 1: Operation)
50	Number of connected indoor unit	0~50	1	
51	Number of operation indoor unit	0~50	1	
52	Required Hz total	0~999	1Hz	
53	Target Fk	0~999	1Hz	
54	Compressor cumulative operating time (CM1)	0~655	100h	

Code No.	Contents of display	Data display range	Minimum units	Remarks
55	Compressor cumulative operating time (CM2)	0~655	100h	
56	Discharge pressure saturation temperature	-50~70	0.1°C	1°C at -10 or lower
57	Air inlet pressure saturation temperature	-50~30	0.1°C	1°C at -10 or lower
58	Target cooling low pressure	0.00~2.00	0.01MPa	
59	Target heating high pressure	1.60~4.15	0.01MPa	
60	Counter · Compressor 2 starting failure	0, 1	—	
61	Counter · Motor lock compressor 2	0~3	—	
62	Power transistor 2 overheating	0~4	—	
63	Inverter 1 operating frequency command	0~130	1Hz	
64	Inverter 2 operating frequency command	0~130	1Hz	
65	Counter · Inverter 2 communications error	0~3	—	
66	Control status	0,1	—	Order of 100 : During silent mode Order of 1 : During test operation (0:Non-operation, 1: Operation)
67	Control status	0,1	—	Order of 100 : Unmatch Order of 10 : Indoor EEV check Order of 1 : — (0:Non-operation, 1: Operation)
68	Control status	0,1	—	Order of 100 : Piping cleaning Order of 10 : Under-dome temperature control Order of 1 : Compression ratio protection control (0:Non-operation, 1: Operation)
69	Outdoor operation pattern	0~17	—	
70	Operation priority switching	0,1	—	0: Prior press priority (when shipped) 1: After press priority
71	High pressure control of cooling	2.2, 2.5	0.01MPa	2.2: Factory setting 2.5: Alternate setting
72	Low pressure control of cooling	-0.05~+0.05	0.01MPa	0.00: Factory setting
73	Heating high pressure compensation	0.00~0.30	0.01MPa	0.00: Factory setting
74	Low pressure of heating	0.80, 0.90	—	0.8: Factory setting 0.9: Alternate setting
75	Snow protection fan control	0,1	—	0: Snow protection fan control deactivated 1: Snow protection fan control activated
77	Data reset	---, dEL	—	
78	Graphic language sub-version	—	—	Example (730)
79	Graphic language logic version	—	—	Example (126)
80	Counter · Thermistor disconnection	0~2	—	
81	Counter · Inverter 1 communications error	0~3	—	
82	Counter · High pressure protection	0, 1	—	
83	Counter · Compressor 1 starting failure	0,1	—	



## (16) Saving of Operation Data (Master unit/slave unit)

Operating data for a period of 30 minutes prior to the time when trouble occurs are recorded, and these data can be fetched to a personal computer through the RS232C connector on the control board. Data are updated continuously, and when there is an anomalous stop, data updates stop at that point. Pressing DIP switch SW7 for 5 seconds causes the data to be erased. Data can also be sampled at 1 minute intervals during operation and fetched to a personal computer.

- Data is transmitted from a personal computer upon demand.

Data	Data Range	Example
Software version	ASCII 15-byte	KD3C218##### (#: NULL)
PID (program ID)	ASCII 2-byte	5D
Outdoor unit capacity	ASCII 3-byte	As shown in table at right
Power supply frequency	ASCII 2-byte	60
Outdoor address	ASCII 2-byte	00 ~ 3F
Indoor address × 16 units	ASCII 2-byte × 16 units	40 ~ 7F
Indoor capacity × 16 units	ASCII 3-byte × 16 units	022 ~ 280

Outdoor capacity data	Remarks
Master unit of combination Ex: 32PS or S32	S: Horsepower of combined master units
Combined slave units Ex: 12PS or C12	C: Horsepower of combined slave units
In the case of the fixed type Ex: 24PS or C24	S: Horsepower of combined master units

Code No.	Write-in contents	Record data			
		Data write-in range	Write-in unit	Number of bytes	Contents
00	Anomaly code	00~99	–	1	00: No anomalous, outdoor unit all anomalous ???
01	Address of unit where trouble occurred	00~FF	–	1	0~3F: Outdoor unit side, 40~6F: Indoor unit side
02	Operation mode	0~2	–	1	0 Stop
					1 Cooling
					2 Heating
03	High pressure sensor	0.00~5.00	A/D value	1	
04	Low pressure sensor	0.00~2.00	A/D value	1	
05	Heat exchanger temp. 1 (Exit, Front)	-35~75	A/D value	2	Cooling liquid side
06	Heat exchanger temp. 2 (Exit, Rear)	-35~75	A/D value	2	Cooling liquid side
07	Heat exchanger temp. 3 (Entrance, Front)	-35~75	A/D value	2	Cooling gas side
08	Heat exchanger temp. 4 (Entrance, Rear)	-35~75	A/D value	2	Cooling gas side
09	Tho-D1 Discharge pipe temp.	20~140	A/D value	1	
10	Tho-D2 Discharge pipe temp.	20~140	A/D value	1	
11	Tho-C1 Under-dome temp.	-15~90	A/D value	1	
12	Tho-C2 Under-dome temp.	-15~90	A/D value	1	
13	Tho-A Outdoor air temp.	-20~43	A/D value	1	
14	Tho-P1 Power transistor temp. (Heat dissipation fin)	20~140	A/D value	1	
15	Tho-P2 Power transistor temp. (Heat dissipation fin)	20~140	A/D value	1	
16	Tho-SC Sub cooling coil temp. 1	18~73	A/D value	1	Liquid pipe side
17	Tho-H Sub cooling coil temp. 2	-35~75	A/D value	2	Suction pipe side
18	Tho-S Suction pipe temp.	-35~75	A/D value	2	
19	Cooling operation super cooling	0~50	0.01°C	2	
20	Super heat	0~50	0.01°C	2	
21	Super heat of sub-cooling coil	0~50	0.01°C	2	

Code No.	Write-in contents	Record data			
		Data write-in range	Write-in unit	Number of bytes	Contents
22	CT1 Current	0~50	A/D value	1	
23	CT2 Current	0~50	A/D value	1	
24	Power source voltage	180~500	A/D value	1	
25	Pressure switch	—	—	1	<div>Bit0 63H1 0: open, 1: close</div> <div>Bit1 63H1-R 0: open, 1: close</div> <div>Bit2 63L 0: open, 1: close</div>
26	Solenoid valve	—	—	1	<div>Bit0 20S 0:OFF, 1:ON</div> <div>Bit1 20SL 0:OFF, 1:ON</div> <div>Bit2 SV1 0:OFF, 1:ON</div> <div>Bit3 SV2 0:OFF, 1:ON</div> <div>Bit4 SV6 0:OFF, 1:ON</div> <div>Bit5 SV7 0:OFF, 1:ON</div> <div>Bit6 SV11 0:OFF, 1:ON</div> <div>Bit7 SV12 0:OFF, 1:close</div>
27	Crankcase heater etc.	—	—	1	<div>Bit0 CH1 0:OFF, 1:ON</div> <div>Bit1 CH2 0:OFF, 1:ON</div> <div>Bit2 FM1.2 0:OFF, 1:ON</div> <div>Bit3 FM3 0:OFF, 1:ON</div> <div>Bit4 SV3 0:OFF, 1:ON</div> <div>Bit5 SV4 0:OFF, 1:ON</div>
28	FM01 Number of rotations	0~65535	10 min <sup>-1</sup>	2	
29	FM02 Number of rotations	0~65535	10 min <sup>-1</sup>	2	
30	EEVH1 opening angle	0~65535	1pulse	2	
31	EEVH2 opening angle	0~65535	1pulse	2	
32	EEVSC opening angle	0~65535	1pulse	2	
34	Indoor unit connection number	0~255	1 unit	1	
35	Indoor unit connection capacity	0~65535	—	2	
36	Indoor unit thermostat ON number	0~255	1 unit	1	
37	Indoor unit thermostat ON capacity	0~65535	—	2	
38	Required Hz total	0~65535	1Hz	2	
39	Target FK	0~65535	1Hz	2	
40	Inverter CM1 operation frequency	0~255	1Hz	1	
41	Inverter CM2 operation frequency	0~255	1Hz	1	
42	Answer Hz total	0~65535	1Hz	2	
43	Compressor 1 cumulative operating time (estimate)	0~65535	1 h	2	
44	Compressor 2 cumulative operating time (estimate)	0~65535	1 h	2	
45	Compressor 1 start times	0~65535	20 times	2	
46	Compressor 2 start times	0~65535	20 times	2	
47	Compressor stop causes	—	—	1	<div>Bit0 Defective outdoor temperature thermistor</div> <div>Bit1 Defective outdoor unit heat exchanger 1 thermistor</div> <div>Bit2 Defective outdoor unit heat exchanger 2 thermistor</div> <div>Bit3 Defective outdoor unit heat exchanger 3 thermistor</div> <div>Bit4 Defective outdoor unit heat exchanger 4 thermistor</div> <div>Bit5 Defective discharge pipe thermistor 1</div> <div>Bit6 Defective discharge pipe thermistor 2</div> <div>Bit7 Defective sub-cooling coil thermistor 1</div>



Code No.	Write-in contents	Record data			
		Data write-in range	Write-in unit	Number of bytes	Contents
48	Compressor stop causes	-	-	1	Bit0 Defective sub-cooling coil thermistor 2
					Bit1 Defective suction pipe thermistor
					Bit2 Defective low pressure sensor
					Bit3 Defective high pressure sensor
					Bit4 Inverter 1 Anomalous communication
					Bit5 Inverter 2 Anomalous communication
					Bit6 Anomalous high pressure
					Bit7 Anomalous Low pressure
49	Compressor stop causes	-	-	1	Bit0 Td1 Anomalous discharge pipe temp.
					Bit1 Td2 Anomalous discharge pipe temp.
					Bit2 CM1 starting defect
					Bit3 CM2 starting defect
					Bit4 Rotor lock of CM1
					Bit5 Rotor lock of CM2
					Bit6 Current cut of CM1
					Bit7 Current cut of CM2
50	Compressor stop causes	-	-	1	Bit0 Power transistor 1 overheating
					Bit1 Power transistor 2 overheating
					Bit2 FM01 anomaly
					Bit3 FM02 anomaly
					Bit4 Compressor stop command from indoor unit
					Bit6 The compressor stops in accordance with the operation pattern.
					Bit7 Stops when switching between cooling and heating.
					Bit8 Demand control 0%
51	Control status	0~180	1 second	1	CM1 3-minute delay timer
52	Control status	0~180	1 second	1	CM2 3-minute delay timer
53	Discharge pressure saturation temperature	-50~70	0.01°C	2	
54	Intake pressure saturation temperature	-50~70	0.01°C	2	
55	Control status oil return	0,1	-	1	0 None
					1 Under control
56	Control status oil return	0~2	-	1	0 None
					1 Waiting for oil return
					2 Under oil return
57	Control status defrost conditions	0~3	-	1	0 None
					1 Temperature conditions
					2 Strengthening temperature conditions
					3 Time conditions
58	Control status defrost status	0~4	-	1	0 None
					1 Defrosting status 1
					2 Defrosting status 2
					3 Defrosting status 3
					4 Defrosting status 4
59	Control status Td	0~2	-	1	0 None
					1 Frequency down
					2 Under Td control
60	Control status	0~1	-	1	Td1 error counter
61	Control status	0, 1	-	1	Td2 error counter
62	Control status HP	0~2	-	1	0 None
					1 Frequency down
					2, 3 Under high pressure control
63	Control status	0~1	-	1	HP error (63H1) counter
64	Control status CS	0~2	-	1	0 None
					1 Frequency down
					2, 3 Under CS control
65	Control status LP	0~2	-	1	0 None
					1 Frequency down
					2, 3 Under low pressure control
66	Control status	0~3	-	1	LP error (when stopped) counter
67	Control status	0~4	-	1	LP error (when started) counter

Code No.	Write-in contents	Record data				
		Data write-in range	Write-in unit	Number of bytes	Contents	
68	Control status	0,1	–	1	LP error (when driving) counter	
69	Control status PT	0~2	–	1	0	None
					1	Frequency down
					2	Under PT control
70	Check operation status	–	–	1	Bit0	When pump-down control is activated during starting and stopping
					Bit1	When outdoor unit equal pressure control is activated
					Bit3	Increase master unit compressor 1 equal oil addition frequency (Hz)
					Bit4	Increase master unit compressor 2 equal oil addition frequency (Hz)
					Bit5	Increase slave unit compressor 1 equal oil addition frequency (Hz)
					Bit6	Increase slave unit compressor 2 equal oil addition frequency (Hz)
					Bit7	Increase equal oil rotation addition frequency (Hz)
71	Control status	0~360	3 minutes	2	CH compressor protection timer	
72	Control status CH compressor protective start	0~15	–	1	15	Protective start end
					0~14	During protective start
73	Switch etc.	–	–	1	Bit0	External operation (CnS1)
						0: Operation prohibition
						1: Operation permission
					Bit1	Demand (CnS2)
						0: None
						1: Under control
					Bit2	Forced cooling, heating (CnG1)
						0: None
						1: Under control
					Bit3	Silent mode (CnG2)
						0: None
						1: Under control
					Bit4	Back up operation
						0: None
						1: Back up operation
Bit5	Hz cancel operation					
	0: None					
	1: Under control					
74	Control status	0~3	–	1	Current cut anomaly counter (INV1)	
75	Control status	0~4	–	1	Power transistor overheating anomaly counter (INV1)	
76	Control status	0~3	–	1	Rotor lock anomaly counter (INV1)	
77	Control status	0~1	–	1	Starting failure counter (INV1)	
78	Control status	0~3	–	1	Communications anomaly counter (INV1)	
79	Control status	0~3	–	1	Current cut anomaly counter (INV2)	
80	Control status	0~4	–	1	Power transistor overheating anomaly counter (INV2)	
81	Control status	0~3	–	1	Rotor lock anomaly counter (INV2)	
82	Control status	0~1	–	1	Starting failure counter (INV2)	
83	Control status	0~3	–	1	Communications anomaly counter (INV2)	
84	Control status	0~1	–	1	DC fan motor 1 error counter	
85	Control status	0~1	–	1	DC fan motor 2 error counter	
86	Control status	0~2	–	1	Thermistor disconnection counter	
87	Control status	0~255	–	1	Communications error counter (INV)	
88	Registered indoor units 1~8 operation mode	0~4	–	8	0	AUTO
					1	DRY
					2	COOL
					3	FAN
					4	HEAT

Code No.	Write-in contents	Record data			
		Data write-in range	Write-in unit	Number of bytes	Contents
89	Registered indoor units 1~8 required Hz	0~255	1Hz	8	
90	Registered indoor units 1~8 answer Hz	0~255	1Hz	8	
91	Operation priority switching	0~1	-	1	0 Prior press priority
					1 After press priority
92	High pressure control of cooling	2,2,2,5	0.01MPa	1	
93	Cooling low pressure compensation	-0.05~0.05	0.01MPa	1	
94	Low pressure control of heating	0.8,0,9	0.01MPa	1	
95	Snow protection fan control	0~1	-	1	0 With
					1 None
96	CM1 frequency command	0~130	1Hz	1	
97	CM2 frequency command	0~130	1Hz	1	
98	Target cooling low pressure	0.00~2.00	0.01MPa	1	
99	Control status TC	0~2	-	1	0 None
					1 Frequency down
					2, 3 Under-dome temperature control
100	Target heating high pressure	1.60~4.15	0.01MPa	2	
101	Heating high pressure compensation	0.00~0.30	0.01MPa	1	
102	Control / status SCR	0~2	-	1	0 None
					1 Frequency down
					2, 3 Under compression ratio protection control
103	Heating target CSST temperature difference	0~255	0.1°C	1	The actual range is 5 ~ 30 deg.
104	Cumulative amount of oil rise.	0~255	10cc	1	The actual range is 0 cc ~ 1100 cc.
105	Total capacity of thermostat ON indoor units during cooling.	0~65535		2	
106	Total capacity of thermostat ON indoor units during heating.	0~65535		2	
107	Outdoor unit operating pattern	0~255	1	1	The actual range is 0 ~ 17.
108	Oil return countdown	0~255	3 minutes	1	The actual range is 0 ~ 600 minutes (10 hrs).
109	Indoor EEV control status	-	-	1	Bit0 Indoor unit EEV fully closed sensor control
					Bit1 Indoor unit non-heating avoidance control
					Bit2 Indoor unit heating stop indoor unit minute opening control
					Bit3 Indoor unit cooling start control
					Bit4 Indoor unit heating start control

## **(17) Pump down control during stop (liquid backflow prevention) (master unit)**

### **(a) Pump down control before starting**

- (i) Control contents
  - 1) The EEV on indoor units which are in cooling mode is fully closed.
  - 2) When the outdoor unit's operating mode is heating, EEVH1, 2 are fully closed.
  - 3) The EEVSC is fully closed.
  - 4) The outdoor unit's operating pattern is not changed.
- (ii) Starting conditions
  - 1) Operation start after a stop.
  - 2) When there is an operation start after an indoor unit switches from cooling to heating.
  - 3) When oil return control starts.
  - 4) When normal control is recovered after oil return control ends.
- (iii) End conditions
  - 1) When the compressor stops.
  - 2) When 5 minutes have passed since the compressor went ON.
  - 3) Low pressure sensor  $\leq 0.4$  MPa (outdoor unit operating mode is cooling)  
Low pressure sensor  $\leq 0.3$  MPa (outdoor unit operating mode is heating)

### **(b) Pump down control after stop**

- (i) Control contents
  - 1) The EEV on indoor units which are in cooling mode is fully closed.
  - 2) When the outdoor unit's operating mode is heating, EEVH1, 2 are fully closed.
  - 3) The EEVSC is fully closed.
  - 4) The operating frequency command applied to the compressor is maintained. (protective control is activated)
  - 5) The speed command applied to the outdoor unit's fan is maintained.
  - 6) The outdoor unit's operating pattern does not change.
- (ii) Starting conditions
  - When operation stops after operation.
- (iii) End conditions
  - 1) When there is a full emergency stop.
  - 2) Low pressure sensor  $\leq 0.4$  MPa (outdoor unit operating mode is cooling)  
Low pressure sensor  $\leq 0.3$  MPa (outdoor unit operating mode is heating)

## **(18) Outdoor unit control (master unit)**

If an outdoor unit (a unit with all the heat exchangers integrated, and all the outdoor air and supply air processing units) is connected to multiple indoor units, as a rule, the cooling low pressure target and the heating high pressure target for cooling or heating are specified when the object is ventilation.

During cooling (evaporation temperature): 15°C

During heating (condensation temperature): 30°C

### **(a) Starting conditions**

When only the thermostat of the outdoor unit for the operating indoor units is in the ON state.

### **(b) Control contents**

- (i) 0.22 MPa is added to the target cooling low pressure during compressor cooling low pressure control.
- (ii) The target heating high pressure is set at 1.77 MPa during compressor heating high pressure control.

### **(c) End conditions**

When the outdoor unit changes to operation other than outdoor unit only (thermostat ON) after the outdoor unit begins single operation.

## (19) Outdoor unit equal pressure control (Master unit)

In a cooling/heating free multi-system, if an indoor unit is switched from cooling to heating, this control functions through a branch flow controller to switch the high pressure gas line and the low pressure gas line. When the branch flow controller's switching occurs, the pressure differential between the high pressure and low pressure sides is first changed to equal pressure, then switching is accomplished. Pressure equalization is done by switching the 4-way valve with the compressor stopped, so if any indoor unit is switched from cooling to heating, the compressor stops.

### (a) Starting conditions

- (i) When switching an indoor unit from cooling to heating during compressor operation (except during oil return or defrost control).
- (ii) When all the indoor units are fully stopped and the compressor is stopped.
- (iii) When the system is starting oil return control and the compressor is stopped.

### (b) Control contents

- (i) When an indoor unit is switched from cooling to heating, the compressor is stopped for 3 minutes. (auto recovery)
- (ii) Outdoor unit cooling operation (outdoor unit heat exchanger high pressure)
  - After the compressor stops for 10 seconds, the 4-way valve (20S) goes ON → OFF → ON, then for 35 seconds each time, then returns to the OFF position.
- Outdoor unit heating operation (outdoor heat exchanger low pressure)
  - After the compressor stops for 10 seconds, the 4-way valve (20S) goes OFF → ON → OFF, then for 35 seconds each time, then returns to the ON position.
- (iii) EEVH1, 2 are fully closed after the compressor stops.
- (iv) For 180 seconds after the compressor stops, SV6 and 7 go ON.
- (v) For 180 seconds after the compressor stops, when there is low pressure on side 2 of the outdoor heat exchanger (4-way valve 20SL: ON), SV11 goes ON.

### (c) End condition


After being stopped for 180 seconds.

- (d) Control is executed by the master unit, which performs all judgments, then the slave units follow the master unit.


## (20) Indoor unit branch flow controller control

If you switch between cooling and heating at an indoor unit in the free multi cooling/heating system, switching between the high pressure gas line and the low pressure gas line is accomplished by the branch flow controller. The branch flow controller performs control using the output from CNT on the indoor unit's control board. The CNT output operates with a x2 (heating output) bit and 2 x3 bits, so there are 4 branch flow controller states.


### ① Cooling state (No power state)




### ② Heating state



### ③ Intermediate state (Equal pressure state)



### ④ Oil return state



**(a) Branch flow controller's control when the indoor unit's operating state changes**


When the state of an indoor unit changes between cooling, heating and oil return, the branch flow controller is changed in the following sequence.

- (i) In the case of Cooling → Heating, Cooling → Oil return, Heating → Oil return or Cooling/Heating → Full stop (Compressor stop)

(Recovery from oil return is excluded.)

<Control Content>


- If the outdoor unit is running and the compressor stops, after 5 seconds, the equal pressure state is maintained for 2 minutes 50 seconds, then the output is in accordance with the operating mode.
- If the compressor stops by the outdoor unit stopping, after 5 seconds, the equal pressure state is maintained for 2 minutes 50 seconds. Then the power off state (cooling state) is output.



(ii) Oil return → Cooling / Heating (Recovery from oil return)

<Control Content>

- Recovery from oil return while the outdoor unit is running causes the compressor to stop causes the output to be in accordance with the operating mode after 1 minute 25 seconds without entering the equal pressure state.



(21) Outdoor unit combined protection (Master unit/Slave unit)

This protection judges the capacity of outdoor units that can be connected and displays any errors on the 7-segment display. However, it does not perform emergency stops or send any error messages to the indoor units.

(a) Combined units

The errors of units other than the following combined units are not responded to by this function.

Outdoor unit model	Combined outdoor unit model						
	FDCA335 HKXRE4R-K	FDCA400 HKXRE4R	FDCA450 HKXRE4R	FDCA504 HKXRE4R	FDCA560 HKXRE4R	FDCA615 HKXRE4R	FDCA680 HKXRE4R
FDCA735	1	1	—	—	—	—	—
FDCA800	—	2	—	—	—	—	—
FDCA850	—	1	1	—	—	—	—
FDCA900	—	—	2	—	—	—	—
FDCA960	—	—	1	1	—	—	—
FDCA1010	—	—	—	2	—	—	—
FDCA1065	—	—	—	1	1	—	—
FDCA1130	—	—	—	—	2	—	—
FDCA1180	—	—	—	—	1	1	—
FDCA1235	—	—	—	—	—	2	—
FDCA1300	—	—	—	—	—	1	1
FDCA1360	—	—	—	—	—	—	2

(b) 7-segment display during an error

Code display	Data display	Operation disabling content
OPE	3	Combined outdoor units are disabled.

## 4.7 MAINTENANCE DATA

### (1) Before starting troubleshooting

(a) **Confirmation of the error code on the remote controller (by pressing the inspection switch) and the inspection display and normal display lamps on PCBs (Printed circuit board) of indoor/outdoor units**

The microcomputer detects errors on electrical components, which include the microcomputer itself, errors on the power supply line and errors (overload, etc.) on the refrigerant circuit and the location of trouble is displayed (with the combination of error symbols of remote controller, normal (green) and inspection (red) display LED on PCBs of indoor/outdoor units). When any error occurs, check first the inspection display. It will guide you to trouble point and assist you to complete the repair work quickly.

Error code of the remote controller is recorded on microcomputer after the trouble has been reset automatically so that, if you press the inspection switch of remote controller, the error code and the number of unit in trouble are displayed for 10sec. The inspection display lamp on the indoor/outdoor unit PCB keeps flashing (glowing) even after the trouble was reset automatically. Inspection lamp on the indoor unit PCB is turned off if the remote controller is reset.

#### 1) Inspection/normal: List of power display

Section	Display Section	Display	Contents of display
Remote controller	Power supply display	LCD	At power ON : Displays always the return air temperature and Center/Remote.
	Error code	LCD	At error : Displays E1 ~ E63 or blank depending on the kinds of error.
	Inspection display	Red-LED	At error : Flash continuously (indicates the occurrence of error).
Indoor/outdoor unit	Normal display	Green-LED2	At power ON (normal) : Flash continuously. At error : Off or continuous glowing or irregular illumination.
	Error display	Red-LED1	At error : Flash 1 ~ 3 times/5 sec for indoor unit depending on the kinds of error, continuous flash, irregular illumination or off. At error : Flash 1 ~ 6 times/10 sec for outdoor unit depending on the kinds of error, continuous flash, irregular illumination or off.
Inverter	Normal display	Green-LED	At power ON (normal) : Flash continuously. At error : Off or continuous glowing or irregular illumination.
	Error display	Red-LED	1 time flashes: Current cut (power transistor over-current) <ul style="list-style-type: none"> <li>• Short-circuited compressor wiring</li> <li>• Trouble on inverter PCB</li> <li>• Trouble on power transistor</li> <li>• Compressor motor neutral line disconnected.</li> </ul> 2 time flashes: Power transistor overheat <ul style="list-style-type: none"> <li>• Fastening of the power transistor to the heat dissipation fins (tighten the screws, apply silicone) is insufficient.</li> <li>• Power transistor is defective.</li> </ul> 3 time flashes: Compressor rotor lock <ul style="list-style-type: none"> <li>• Compressor breakdown</li> <li>• Inverter board breakdown</li> </ul> 4 time flashes: Compressor starting is defective. <ul style="list-style-type: none"> <li>• Compressor breakdown</li> <li>• Inverter board breakdown</li> <li>• Power transistor breakdown</li> </ul> Lights up : Transmission error between inverter and outdoor unit <ul style="list-style-type: none"> <li>• Connectors CN11 or CN12 is disconnected or broken wire between connectors</li> <li>• Error on outdoor control PCB</li> <li>• Error on inverter PCB</li> </ul>



## 2) Check Indicator Table

Whether a failure exists or not on the indoor unit and outdoor unit can be know by the contents of remote controller error code, indoor/outdoor unit green LED (power pilot lamp and microcomputer normality pilot lamp) or red LED (check pilot lamp).

Remote controller error code	Indoor unit LED		Outdoor unit LED		Cause
	Green	Red	Green	Red	
No-indication	Keeps flashing	Stays OFF	Keeps flashing	Stays OFF	Normal
	Stays OFF	Stays OFF	Stays OFF	Stays OFF	Power OFF, T phase wiring is open, power source failure
	Keeps flashing	*3 time flash	Keeps flashing	Stays OFF	Remote controller wires X and Y are reversely connected. *For wire breaking at power ON, the LED is OFF. Remote controller wire is open. (X wire breaking : A beep is produced and no indication is made. Z wire breaking : No beep and no indication) The remote controller wires Y and Z are reversely connected.
E1	Keeps flashing	Stays OFF	Keeps flashing	Stays OFF	The remote controller wires are connected to A and B on the terminal block. The indoor/outdoor signal wire are connected in loop form. The indoor unit micro-computer runs away.
	Stay OFF or Lights continuously	Stay OFF or Lights continuously	Keeps flashing	Stays OFF	Indoor unit PCB fault
	Keeps flashing	*3 time flash	Keeps flashing	Stays OFF	Remote control wire breakage (signal) *For wire breaking at power ON, the LED is OFF.
E2	Keeps flashing	1 time flash	Keeps flashing	Stays OFF	No. duplication at indoor unit addressing. More than 49 indoor unit are connected.
E3	Keeps flashing	2 time flash	Stays OFF	Stays OFF	Outdoor unit power supply OFF (detected only during operation)
	Keeps flashing	2 time flash	Keeps flashing	Stays OFF	The corresponding outdoor unit address No. is not found. (Detected only during operation)
	Keeps flashing	2 time flash	Irregular illumination	Stays OFF or Lights continuously	Outdoor unit power OFF (Detected only during operation)
E5	Keeps flashing	2 time flash	Keeps flashing	Stays OFF	Indoor / outdoor transmission error. Wire A and B swapping after power ON.
	Keeps flashing	2 time flash	Stays OFF	Stays OFF	Outdoor power unit failure (when the indoor power supply is different from the outdoor one).
	Keeps flashing	2 time flash	Irregular illumination	Stays OFF or Lights continuously	Outdoor unit microcomputer failure
E6	Keeps flashing	1 time flash	Keeps flashing	Stays OFF	Indoor unit heat exchanger thermistor failure
E7	Keeps flashing	1 time flash	Keeps flashing	Stays OFF	Indoor unit return air thermistor failure
E9	Keeps flashing	1 time flash	Keeps flashing	Stays OFF	The float SW operates (with FS only). Drain up kit wiring fault.
E10	Keeps flashing	Stays OFF	Keeps flashing	Stays OFF	When multi-unit control by remote controller is performed, the number of units is over (more than 17 units). Two remote controller are provided for one controller is performed.
E11	Keeps flashing	Stays OFF	Keeps flashing	Stays OFF	Addresses setting for plural remote controllers
E12	Keeps flashing	1 time flash	Keeps flashing	Stays OFF	Addresses No. combination error or addressing is performed with the following combinations.
					Outdoor No,
					Indoor No,
E16 <sup>(1)</sup>	Keeps flashing	1 time flash	Keeps flashing	Stays OFF	0~47
					48, 49
E28	Keeps flashing	Stays OFF	Keeps flashing	Stays OFF	Defect of fan motor.
					Remote controller thermistor failure

Note (1) In the case of FDT112, 140 or FDK22~56 type.

● Models FDCA140HKXEN4R, 140KXXES4R, 160HKXEN4R

Remote controller error code	Indoor unit LED		Outdoor unit LED		Outdoor LED 7-segment	Cause
	Green	Red	Green	Red		
<b>E30</b>	Keeps flashing	Stays OFF	Keeps flashing	1 time flash	E30	Unmatched indoor/outdoor connection
<b>E31</b>	Keeps flashing	Stays OFF	Keeps flashing	1 time flash	E31	Duplication outdoor unit address No. Outdoor unit address setting error.
<b>E32</b>	Keeps flashing	Stays OFF	Keeps flashing	1 time flash	E32	Absence of L2 phase (Voltage detection) (3-phase model)
<b>E34</b>	Keeps flashing	Stays OFF	Keeps flashing	1 time flash	E34	L3-phase wiring is open phase or reversal phase (3-phase model)
<b>E35</b>	Keeps flashing	Stays OFF	Keeps flashing	1 time flash	E35	Cooling high pressure error
<b>E36</b>	Keeps flashing	Stays OFF	Keeps flashing	1 time flash	E36-1	Discharge temperature (Tho-D) anomaly.
<b>E37</b>	Keeps flashing	Stays OFF	Keeps flashing	1 time flash	E37-1	Outdoor unit heat exchanger thermistor (Tho-R) failure
<b>E38</b>	Keeps flashing	Stays OFF	Keeps flashing	1 time flash	E38	Outdoor air temperature thermistor (Tho-A) failure
<b>E39</b>	Keeps flashing	Stays OFF	Keeps flashing	1 time flash	E39-1	Discharge pipe thermistor (Tho-D) failure
<b>E40</b>	Keeps flashing	Stays OFF	Keeps flashing	1 time flash	E40	High pressure (63H1) error
<b>E41</b>	Keeps flashing	Stays OFF	Keeps flashing	1 time flash	E41-1	Power transistor overheat
<b>E42</b>	Keeps flashing	Stays OFF	Keeps flashing	1 time flash	E42-1	Anomalous current cut of compressor
<b>E43</b>	Keeps flashing	Stays OFF	Keeps flashing	1 time flash	E43	The number of connectable units is exceeded.
<b>E45</b>	Keeps flashing	Stays OFF	Keeps flashing	1 time flash	E45-1	Transmission error between inverter and control PCB
<b>E46</b>	Keeps flashing	Stays OFF	Keeps flashing	Stays OFF	E46	Automatic address and remote controller address setting coexists in the same network.
<b>E49</b>	Keeps flashing	Stays OFF	Keeps flashing	1 time flash	E49	Low pressure (PSL) error
<b>E51</b>	Keeps flashing	Stays OFF	Keeps flashing	1 time flash	E51	Anomalous inverter
<b>E53</b>	Keeps flashing	Stays OFF	Keeps flashing	1 time flash	E53	Suction pipe thermistor (Tho-S) disconnection
<b>E54</b>	Keeps flashing	Stays OFF	Keeps flashing	1 time flash	E54-1	Low pressure sensor (PSL) disconnection/output error
	Keeps flashing	Stays OFF	Keeps flashing	2 time flash	E54-2	High pressure sensor (PSH) disconnection/output error
<b>E59</b>	Keeps flashing	Stays OFF	Keeps flashing	1 time flash	E59-1	Compressor startup error
<b>E60</b>	Keeps flashing	Stays OFF	Keeps flashing	1 time flash	E60-1	Compressor loader position detection error
<b>E63</b>	Keeps flashing	Stays OFF	Keeps flashing	1 time flash	E63	Emergency stop of indoor unit

- Models **FDCA224HKXE4R, 280HKXE4R, 335HKXE4R**  
**FDCA224HKXRE4R, 280HKXRE4R, 335HKXRE4R**

Remote controller error code	Indoor unit LED		Outdoor unit LED		Outdoor LED 7-Segment	Cause
	Green	Red	Green	Red		
<b>E30</b>	Keeps flashing	Stays OFF	Keeps flashing	1 time flash	E30	Unmatched indoor/outdoor connection
<b>E31</b>	Keeps flashing	Stays OFF	Keeps flashing	1 time flash	E31	Duplication outdoor unit address No. Outdoor unit address setting error.
<b>E32</b>	Keeps flashing	Stays OFF	Keeps flashing	1 time flash	E32	L3-phase wiring is open phase or reversal phase
<b>E36</b>	Keeps flashing	Stays OFF	Keeps flashing	1 time flash	E36-1	Discharge temperature (Tho-D1) anomaly.
<b>E37</b>	Keeps flashing	Stays OFF	Keeps flashing	1 time flash	E37-1	Outdoor unit heat exchanger thermistor (Tho-R1) failure
				2 time flash	E37-2	Outdoor unit heat exchanger thermistor (Tho-R2) failure
				3 time flash	E37-3	Outdoor unit heat exchanger thermistor (Tho-R3) failure
				4 time flash	E37-4	Outdoor unit heat exchanger thermistor (Tho-R4) failure
				5 time flash	E37-5	Outdoor unit heat exchanger thermistor (Tho-SC) failure
				6 time flash	E37-6	Outdoor unit heat exchanger thermistor (Tho-H) failure
<b>E38</b>	Keeps flashing	Stays OFF	Keeps flashing	1 time flash	E38	Outdoor air temperature thermistor (Tho-A) failure
<b>E39</b>	Keeps flashing	Stays OFF	Keeps flashing	1 time flash	E39-1	Discharge temperature thermistor (Tho-D1) failure
<b>E40</b>	Keeps flashing	Stays OFF	Keeps flashing	1 time flash	E40	High pressure (63H1-1) error
<b>E41</b>	Keeps flashing	Stays OFF	Keeps flashing	1 time flash	E41-1	Power transistor (CM1) overheat
<b>E42</b>	Keeps flashing	Stays OFF	Keeps flashing	1 time flash	E42-1	Anomalous current cut of compressor (CM1)
<b>E43</b>	Keeps flashing	Stays OFF	Keeps flashing	1 time flash	E43	The number of connectable units is exceeded.
<b>E45</b>	Keeps flashing	Stays OFF	Keeps flashing	1 time flash	E45-1	Transmission error between inverter and outdoor unit control PCB (CM1)
<b>E46</b>	Keeps flashing	Stays OFF	Keeps flashing	Stays OFF	—	Automatic address setting and remote controller address setting coexists in the same network.
<b>E48</b>	Keeps flashing	Stays OFF	Keeps flashing	1 time flash	E48-1	Anomaly in an outdoor fan motor FM01
				2 time flash	E48-2	Anomaly in an outdoor fan motor FM02
<b>E49</b>	Keeps flashing	Stays OFF	Keeps flashing	1 time flash	E49	Low pressure error (PSL)
<b>E53</b>	Keeps flashing	Stays OFF	Keeps flashing	1 time flash	E53	Suction pipe temperature thermistor (Tho-S) failure
<b>E54</b>	Keeps flashing	Stays OFF	Keeps flashing	1 time flash	E54-1	Low pressure sensor (PSL) disconnection/output error
				2 time flash	E54-2	High pressure sensor (PSH) disconnection/output error
<b>E59</b>	Keeps flashing	Stays OFF	Keeps flashing	1 time flash	E59-1	Compressor startup error (CM1)
<b>E60</b>	Keeps flashing	Stays OFF	Keeps flashing	1 time flash	E60-1	Compressor loader position detection error (CM1)
<b>E63</b>	Keeps flashing	Stays OFF	Keeps flashing	1 time flash	E63	Emergency stop of indoor unit

● Models **FDCA335HKXE4R-K, 400~1360HKXE4R**  
**FDCA335HKXRE4R-K, 400~1360HKXRE4R**

Remote controller error code	Indoor unit LED		Outdoor unit LED		Outdoor LED 7-Segment	Cause
	Green	Red	Green	Red		
<b>E30</b>	Keeps flashing	Stays OFF	Keeps flashing	1 time flash	E30	Unmatched indoor/outdoor connection
<b>E31</b>	Keeps flashing	Stays OFF	Keeps flashing	1 time flash	E31	Duplication outdoor unit address No. Outdoor unit address setting error.
<b>E32</b>	Keeps flashing	Stays OFF	Keeps flashing	1 time flash	E32	L3-phase wiring is open phase or reversal phase
<b>E36</b>	Keeps flashing	Stays OFF	Keeps flashing	1 time flash	E36-1	Discharge temperature (Tho-D1) anomaly.
				2 time flash	E36-2	Discharge temperature (Tho-D2) anomaly.
<b>E37</b>	Keeps flashing	Stays OFF	Keeps flashing	1 time flash	E37-1	Outdoor unit heat exchanger thermistor (Tho-R1) failure
				2 time flash	E37-2	Outdoor unit heat exchanger thermistor (Tho-R2) failure
				3 time flash	E37-3	Outdoor unit heat exchanger thermistor (Tho-R3) failure
				4 time flash	E37-4	Outdoor unit heat exchanger thermistor (Tho-R4) failure
				5 time flash	E37-5	Outdoor unit heat exchanger thermistor (Tho-SC) failure
				6 time flash	E37-6	Outdoor unit heat exchanger thermistor (Tho-H) failure
<b>E38</b>	Keeps flashing	Stays OFF	Keeps flashing	1 time flash	E38	Outdoor air temperature thermistor (Tho-A) failure
<b>E39</b>	Keeps flashing	Stays OFF	Keeps flashing	1 time flash	E39-1	Discharge temperature thermistor (Tho-D1) failure
				2 time flash	E39-2	Discharge temperature thermistor (Tho-D2) failure
<b>E40</b>	Keeps flashing	Stays OFF	Keeps flashing	1 time flash	E40	High pressure (63H1-1, 2) error
<b>E41</b>	Keeps flashing	Stays OFF	Keeps flashing	1 time flash	E41-1	Power transistor (CM1) overheat
				2 time flash	E41-2	Power transistor (CM2) overheat
<b>E42</b>	Keeps flashing	Stays OFF	Keeps flashing	1 time flash	E42-1	Anomalous current cut of compressor (CM1)
				2 time flash	E42-2	Anomalous current cut of compressor (CM2)
<b>E43</b>	Keeps flashing	Stays OFF	Keeps flashing	1 time flash	E43	The number of connectable units is exceeded.
<b>E45</b>	Keeps flashing	Stays OFF	Keeps flashing	1 time flash	E45-1	Transmission error between inverter and outdoor unit control PCB (CM1)
				2 time flash	E45-2	Transmission error between inverter and outdoor unit control PCB (CM2)
<b>E46</b>	Keeps flashing	Stays OFF	Keeps flashing	Stays OFF	—	Automatic address setting and remote controller address setting coexists in the same network.
<b>E48</b>	Keeps flashing	Stays OFF	Keeps flashing	1 time flash	E48-1	Anomaly in an outdoor fan motor FM01
				2 time flash	E48-2	Anomaly in an outdoor fan motor FM02
<b>E49</b>	Keeps flashing	Stays OFF	Keeps flashing	1 time flash	E49	Low pressure error (PSL)
<b>E51</b>	Keeps flashing	Stays OFF	Keeps flashing	1 time flash	E51-1	Power transistor overheating (CM1) (15 minute continuation)
				2 time flash	E51-2	Power transistor overheating (CM2) (15 minute continuation)
<b>E53</b>	Keeps flashing	Stays OFF	Keeps flashing	1 time flash	E53	Suction pipe temperature thermistor (Tho-S) failure
<b>E54</b>	Keeps flashing	Stays OFF	Keeps flashing	1 time flash	E54-1	Low pressure sensor (PSL) disconnection/output error
				2 time flash	E54-2	High pressure sensor (PSH) disconnection/output error
<b>E59</b>	Keeps flashing	Stays OFF	Keeps flashing	1 time flash	E59-1	Compressor startup error (CM1)
				2 time flash	E59-2	Compressor startup error (CM2)
<b>E60</b>	Keeps flashing	Stays OFF	Keeps flashing	1 time flash	E60-1	Compressor loader position detection error (CM1)
				2 time flash	E60-2	Compressor loader position detection error (CM2)
<b>E61</b>	Keeps flashing	Stays OFF	Keeps flashing	1 time flash	E61	Communication error between outdoor unit master unit and slave units.
<b>E63</b>	Keeps flashing	Stays OFF	Keeps flashing	1 time flash	E63	Emergency stop of indoor unit

### 3) Display sequence of error, inspection display lamp

#### a) One kind error

Display corresponding to the error is shown.

#### b) More than one errors.

Section	Display section
Error code of remote controller	•Displays the error of higher priority (When plural errors are persisting)
Inspection LED (red) of indoor unit PCB	<i>E1&gt;E10&gt;E11&gt;E2&gt;E3&gt;E5&gt;E7&gt;E9&gt;E12.....E63</i>
Inspection LED (red) of outdoor unit PCB	•Displays the present errors. (When a new error has occurred after the former error was reset.)

#### c) Timing of error detection

##### • Indoor unit side.

Error detail	Error code	Timing of error detection
Transmission error of remote controller indoor unit	<i>E1</i>	When the transmission error continuously for 2 min.
CPU is out of control		Resetting was performed at the rate of 1 time per second. An anomalous stop occurred 32-sec time flash.
Transmission error between indoor/outdoor units	<i>E5</i>	A check was made once every 20 second. An anomalous stop occurred 7 time running.
Broken wire of heat exchanger thermistor	<i>E6</i>	After a compressor ON command, this failure was detected for 5 second in the period of 2 minutes to 2 minutes and 20 seconds.
Broken wire of indoor unit return air thermistor	<i>E7</i>	This failure was detected continuously for 5 seconds.
Drain error (float switch motion)	<i>E9</i>	At all times from 31 seconds after power ON.

##### • Outdoor unit side.

Error detail	Error code	Timing of error detection
Discharge temperature anomaly	<i>E36</i>	A stop occurs when this anomaly occurs for 2 seconds running at 130°C. After a stop for 3 minutes, an recovery is automatically made. An anomalous stop occurs when this anomaly occurs 2(5) times for 60 minutes. (The anomalous state is held for 45 minutes.)
Broken wire of heat exchanger thermister	<i>E37</i>	This failure is detected when it occurs for 5 seconds running in the period of 2 minutes to 2 minutes and 20 seconds with the compressor ON. An anomalous stop occurs when this failure occurs 3 times for 40 minutes.
Broken wire of outdoor temperature thermistor	<i>E38</i>	
Broken wire of discharge thermistor	<i>E39</i>	This failure is detected when it occurs for 5 seconds running in the period of 10 minutes to 10 minutes and 20 seconds with the compressor ON. An anomalous stop occurs when this failure occurs 3 times for 40 minutes.
High pressure cut	<i>E40</i>	An anomalous stop occurs when this anomaly occurs 5 times for 60 minutes.
Power transistor overheat	<i>E41</i>	Stops at 110°C or higher, recovers automatically at 90°C or lower, anomalous stop if this occurs 5 times in 60 minutes.
Current cut	<i>E42</i>	An anomalous stop occurs when this anomaly occurs 4 times for 15 minutes.
Excessive number of indoor and outdoor units	<i>E43</i>	This error is detected when the number of connectable units is set over the specified value at remote control addressing.
Transmission error between inverter and outdoor unit PCB	<i>E45</i>	With a delay of 3 minutes, a recovery is automatically made. An anomalous stop occurs when this errors occurs 4 times for 15 minutes.
Broken wire of low pressures sensor	<i>E54</i>	If the voltage sensed by the sensor is 0V or lower, or 3.49 V or higher continuously for 5 seconds between 2 minutes and 2 minutes 20 seconds after the compressor goes ON, the compressor stops. After a 3-minute delay, the compressor restarts. If this state is detected 3 times in 40 minutes.
Broken wire of high pressures sensor		
Broken wire of under -doom sensor	<i>E55</i>	If a disconnection is detected continuously for 5 seconds between 10 minutes and 10 minutes 20 seconds after the compressor goes ON, the compressor stops. After a 3 minutes delay, the compressor restarts. If this state is detected 3 times in 40 minutes.

Note (1) value in ( ) indicates FDCA140 type.

#### d) Recording and reset of error

Error display	Memory	Reset
Error code	• Saves in memory the mode <sup>(1)</sup> of higher priority	<ul style="list-style-type: none"> <li>• Stop the unit operation by pressing the ON/OFF switch of remote controller.</li> <li>• Operation can be started again if the error has been reset. <sup>(2)</sup></li> </ul>
Indoor unit inspection lamp (red)	• Cannot save in memory	
Outdoor unit inspection lamp (red)	• Saves in memory the mode <sup>(1)</sup> of higher priority	

Notes (1) Priority is in the order of E1 > ... > E10 > ... > 63.

(2) Reset is disabled for 45min. at the error of outdoor unit or compressor overcurrent or the discharge gas temperature error.

#### e) Reset of error code in memory (when the error has been reset.)

**Indoor unit:** Press the Timer switch and the Stop switch while the Inspection switch of wired remote controller is held down or detach the power supply connector (CnW2) of indoor unit PCB and connect again or turn OFF the power.

**Outdoor unit:** Detach the power supply connector (CNA2) of outdoor unit PCB and connect again or turn OFF the power supply or turn on and off the SW3-1.

#### 4) Indications with 7-segement indicator

Refer to page FDCA140, 160 series: 335,

FDCA224~1360, 355HKXE4R: 353


FDCA355HKXE4R-K • FDCA400~1360HKXE4R: 380

FDCA224~355HKXRE4R: 402,

FDCA355HKXRE4R-K • FDCA400~1360HKXRE4R: 426

#### (2) Procedures of trouble diagnosis


When any error occurs, inspect in following sequence. Detailed explanation on each step is given later in this text.



### (a) Diagnosis by the power supply reset

When any error occurs, reset the power supply as described below to see if it is the result of accidental noise, etc.

Check at the indoor unit side.



#### Errors due to external noise, etc.

Error code may be displayed or the error may not be displayed normally even if the controller is normal because of external noise source<sup>(1)</sup> or joined or parallel arrangement of power cables and signal wires. It is because the wire of remote controller, wired remote controller signal wires for multiple units or the network signal wires may be influenced by external noises which are judged as signals by the microcomputer which reacts mistakenly.

When there is any noise source, it is necessary to shield wire for the remote controller and signal wires.

Note (1) High frequency medical machine, rectifier motor application device, thyristor, broadcast transmission tower, power transmission line, power line of electric train, automatic door motor, elevator (voltage drop), wireless telephone, high voltage power distribution line, computer, personal computer and their cables. These do not necessarily always cause problems but they can be a source of electrical noise.


(2) **Reference** Effect of noise

- When noises intrude into remote controller.

Anomalous or irregular display such as the flashing of irrelevant display (lamp) (for example, LEDs of cooling and heating illuminated simultaneously or the like) is observed even if the remote controller is not operated or the remote or the remote controller and, as the result, the operation of units may be disabled or similar anomalous phenomenons are observed.

- When noises intruded into the microcomputer of printed circuit board; State of operation becomes anomalous such as the units perform irregular operation while the remote controller is not operated, the operation cannot be stopped with the remote controller, etc.

**Electro magnetic noise prevention (example)**



**(b) Error diagnosis procedures at the indoor unit side**

To diagnose the error, measure the voltage (AC,DC), resistance, etc. at each connector around the printed circuit board of indoor unit PCB on the inspection display or the operation state of unit (no operation of compressor or blower, no switching of 4-way valve, etc.). If any defective parts are discovered, replace with the assembly of parts as shown next page.

**(i) Unit of replacement parts related to indoor unit printed circuit board** ( Electric components on and around the microcomputer)


Indoor unit printed circuit board, thermistor (Return air, heat exchanger), remote controller switch, limit switch, transformer, fuse

Note (1) Judges the troubles on the parts of driving power circuit or cooling cycle with the ordinary check method.



## (ii) Parts layout on the indoor unit printed circuit board

- The control board in the following figure shows for the FDT type.



### • Function of jumper wires

Name			Function
J1 (SW7-1)	With		Filter sign: Valid
	None <sup>(1)</sup>		Filter sign: Invalid
J2 (SW7-2)	With		Normal operation operable
	None <sup>(1)</sup>		Operation permission prohibited
J3 (SW7-3)	With	J4 (SW7-4)	Heating thermostat OFF: Intermittent operation
			Heating thermostat OFF: Lo operation
	None <sup>(1)</sup>	J4 (SW7-4)	Heating thermostat OFF: Stop
			—
J10 (SW10-2)	With	J11 (SW10-3)	Remote controller air flow: 3 speed
			Remote controller air flow: 1 speed
	None <sup>(1)</sup>	J11 (SW10-3)	Remote controller air flow: 2 speed
			Remote controller air flow: —

Note (1) "None" means that jumper wire is not provided on the PCB or the connection is cut

### • Function of DIP switches (SW5, 9)

Switch	Function
SW5-1	ON Test run of condensate pump motor
	OFF Normal
SW5-3	ON Input Reverse Invalid
	OFF signal Run stop
SW5-4	ON Emergency stop signal: Invalid
	OFF Emergency stop signal: Valid
SW9-3	ON Louver stop: Louver Range
	OFF Louver stop: Normal
SW9-4	ON Fan control: UH, H, M
	OFF Fan control: H, M, L

Note (1) All OFF under load condition.

### • Replacement procedure of indoor unit microcomputer printed circuit board

Microcomputer printed circuit board can be replaced with following procedure.

- Confirm the parts numbers. (Refer to the following parts layout drawing for the location of parts number.)

Parts No.	Model	Parts No.	Model
PJA505A157ZB	FDTA28~71	PJA505A158ZA	FDQM, FDUM, FDTW, FDFL, FDFU, FDUR, FDU
PJA505A157ZA	FDTA90~140	PJA505A158ZB	FDTQ, FDTs
PJA505A159ZA	FDE	PHA505A025ZA	FDKA22~71
PJA505A160ZA	FDTC		

### • Model select switch (SW6)

Model	22	28	36	45	56	71	90	112	140	224	280
Switch											
SW6-1	OFF	ON	OFF	ON	OFF	ON	ON	OFF	ON	ON	OFF
SW6-2	OFF	OFF	ON	ON	OFF	OFF	ON	OFF	OFF	ON	OFF
SW6-3	OFF	OFF	OFF	OFF	ON	ON	ON	OFF	OFF	OFF	ON
SW6-4	OFF	OFF	OFF	OFF	OFF	OFF	OFF	ON	ON	ON	ON

## (iii) Check method when the error code is displayed

Remote controller or Indication board: Inspection LED, error code

Indoor unit PCB: Red LED ( inspection display), Green LED ( CPU. normal display )

Outdoor unit PCB: Red LED ( inspection display), Green LED ( CPU. normal display )

## (iv) Check procedure depending on indication lamps (For the indoor unit)

The next page error diagnosis is applicable to cases where only 1 unit is installed in a network unless stated otherwise but the check method is same even if there are multiple units on the network. Except the network occupation state due to out of control indoor unit CPU, the error display indicates the state of respective units. Check each unit specified by the error display as explained on next page.


1

**Error display : No display**  
**LCD display : No display**

**[Polarity determination trouble]**

Indoor unit		Outdoor unit	
Red LED	Stays OFF	Red LED	Stays OFF
Green LED	Keeps flashing	Green LED	Keeps flashing

- When the LCD display (Center/Remote, temperature display, etc.) of remote controller flashes, it means the polarity on the unit is not yet determined. Polarity determination is completed within a few seconds after the power on. If it is not completed in time, CPU out of control, etc. is suspected.




- Notes (1) When CPU of one unit goes out of control, it occupying the transmission section of the network, so the transmission of other units are not done and the polarity of the whole network will not be determined.
- (2) The unit which has its indoor and green LED keeps flashing (or no lighting) is the one with a defective indoor unit PCB.
- (3) If it becomes normal after replacing the PCB, it can be considered that the PCB. is defective (defective network transmission circuit).

## 2


**Error display : No display**  
**LCD display : No display**

[Power supply line error]



Indoor unit		Outdoor unit	
Red LED	3 time flash	Red LED	Stays OFF
Green LED	Keeps flashing	Green LED	Keeps flashing


Flash of green LED means CPU is normal.



## 3


**Error display : E1**

[Communication error between remote controller~Indoor unit]




Indoor unit		Outdoor unit	
Red LED	*3 times flash	Red LED	Stays OFF
Green LED	Keeps flashing	Green LED	Keeps flashing

\* Lamp OFF if remote controller wire is broken at power ON.



Indoor unit		Outdoor unit	
Red LED	Stays OFF or Lights continuously	Red LED	Stays OFF
Green LED	Stays OFF or Lights continuously	Green LED	Keeps flashing




4

Error display : E2

[Duplicated indoor unit No. or more than 49 indoor unit are connected.]

Indoor unit		Outdoor unit	
Red LED	1 time flash	Red LED	Stays OFF
Green LED	Keeps flashing	Green LED	Keeps flashing



Notes (1) When correcting the unit number, check again the pairing of indoor/outdoor units (same Number assigned to coupled units) is correct.


(2) If it is normalized by changing PCB, judge the unit number input circuit is defective.

5


Error display : E6

[Defective indoor unit heat exchanger thermistor]

Indoor unit		Outdoor unit	
Red LED	1 time flash	Red LED	Stays OFF
Green LED	Keeps flashing	Green LED	Keeps flashing



Return air thermistor (Th-A)  
Indoor unit heat exchanger thermistor (Th-R1, R2, R3)  
Resistance temperature characteristics



● Display condition

If a temperature of -40°C or lower is detected by the thermistor continuously for 5 seconds.


Note (1) 22.5 kΩ at -6°C

6

Error display : E7

[Detective return air thermistor]

Indoor unit		Outdoor unit	
Red LED	1 time flash	Red LED	Stays OFF
Green LED	Keeps flashing	Green LED	Keeps flashing



Note (1) Characteristics as per the above graph.

● Display Condition


If a temperature of -20°C or lower is detected by the thermistor continuously for 5 seconds.

7

Error display : **E9**

[Drain trouble]

Indoor unit		Outdoor unit	
Red LED	1 time flash	Red LED	Stays OFF
Green LED	Keeps flashing	Green LED	Keeps flashing




8

Error display : **E10**

[Control of 1 remote controller VS multiple units – Excessive number of units (more than 17 units) ]

Indoor unit		Outdoor unit	
Red LED	Stays OFF	Red LED	Stays OFF
Green LED	Keeps flashing	Green LED	Keeps flashing




9

Error display : **E11**

[Addresses setting for plural remote controllers]

Indoor unit		Outdoor unit	
Red LED	Stays OFF	Red LED	Stays OFF
Green LED	Keeps flashing	Green LED	Keeps flashing




10

Error display : *E12*

[Address No. combination error or addressing is preformed with the following combinations.]

Indoor unit		Outdoor unit	
Red LED	1 time flash	Red LED	Stays OFF
Green LED	Keeps flashing	Green LED	Keeps flashing



Note (1)

Outdoor unit address No.	Indoor unit address No.
00 ~ 47	48, 49
48, 49	00 ~ 47


11

Error display : *E16*

[Indoor unit fan motor anomaly]

Indoor unit		Outdoor unit	
Red LED	1 time flash	Red LED	Stays OFF
Green LED	Keeps flashing	Green LED	Keeps flashing


◆ Only case of FDT112, 114 type



## ● Display conditions

If an indoor unit fan motor's speed is detected to be less than 200 rpm continuously for 30 seconds, the fan motor stops for 2 seconds. After 2 seconds, it starts again, but this occurs 4 times within a period of 1 hour.

◆ Only case of FDK22~71 type



● Display conditions


If an indoor unit fan motor's speed is detected to be less than 200 rpm continuously for 30 seconds, the fan motor stops for 2 seconds. After 2 seconds, it starts again, but this occurs 4 times within a period of 1 hour.

12

Error display : *E2B*

[Defective remote controller thermistor.]

Indoor unit		Outdoor unit	
Red LED	Stays OFF	Red LED	Stays OFF
Green LED	Keeps flashing	Green LED	Keeps flashing



Resistance-temperature characteristic of remote controller thermister

Temperature(°C)	Resistance value (kΩ)	Temperature(°C)	Resistance value (kΩ)	Temperature(°C)	Resistance value (kΩ)	Temperature(°C)	Resistance value (kΩ)
0	65	14	33	30	16	46	8.5
1	62	16	30	32	15	48	7.8
2	59	18	27	34	14	50	7.3
4	53	20	25	36	13	52	6.7
6	48	22	23	38	12	54	6.3
8	44	24	21	40	11	56	5.8
10	40	26	19	42	9.9	58	5.4
12	36	28	18	44	9.2	60	5.0



### (c) Error diagnosis procedures at the outdoor unit side

At the error diagnosis related to the outdoor unit, check at first the error code of remote controller and the illumination patterns of normal 1 and inspection display lamps in the same manner as the case of indoor unit.

Then estimate the outline, the cause and the location of error based on the pattern and proceed to the inspection and repair. Since the self diagnosis function by means of the microcomputers of indoor/outdoor units provide the judgement of error of microcomputers themselves irregularity power supply line, overload, etc. caused by the installation space, inadequate volume of refrigerant etc., the location and cause of trouble will be discovered without difficulty.


In addition, the display lamps error code of indoor/outdoor unit is kept flashing, (except when the power supply is interrupted) after the irregularity is automatically recovered to give irregularity information to the service personnel. If any mode of higher priority than the error retained in memory occurs after the reset of error, it is switched to that mode and saved in the memory.

#### (i) Replacement parts assembly related to the outdoor unit PCB

Outdoor unit PCB, outdoor unit inverter PCB, power transistor module, diode module, capacitor, reactor, noise filter, thermistor, (heat exchanger, discharge pipe, outdoor temperature etc.), fuse, transformer, etc.

#### (ii) Parts layout on the outdoor unit PCB

Models FDCA140HKXEN4R, 140HKXES4R, 160HKXES4R



#### • Function of DIP switch

Name	Function
SW3-1	ON Inspection LED reset
SW3-1	OFF Normal
SW3-2	ON Check operation - Effective
SW3-2	OFF Check operation - Invalid
SW3-4	ON Service SW - Service
SW3-4	OFF Service SW - Normal
SW3-5	ON Check operation - Check
SW3-5	OFF Check operation - Normal
SW3-6	ON Piping washing operation
SW3-6	OFF Normal
SW3-7	ON Forced cooling/heating
SW3-7	OFF Normal
SW3-8	ON Test mode
SW3-8	OFF None
SW5-1	ON Test run
SW5-1	OFF Normal
SW5-2	ON Test run operation - Cooling
SW5-2	OFF Test run operation - Heating
SW5-3	ON Pump down
SW5-3	OFF Normal

#### • Function of jumper wire


Name	Function
J8	With Snow protection control - None
J8 (SW4-8)	None (1) Snow protection control - With
J13	With External input level
J13	None (1) External input pulse
J15	With Defrosting - Normal
J15	None (1) Defrosting - Cold weather region

Model	Jumper wire	J1 (SW4-1)	J2 (SW4-2)	J3 (SW4-3)
FDCA140HKXEN4R		None (1)	None (1)	None (1)
FDCA140HKXES4R		With	None (1)	None (1)
FDCA160HKXES4R		With	None (1)	None (1)

Name	Function
J6 (SW4-6)	With Demand change (Compressor capability) 80%
J6 (SW4-6)	None (1) Demand change (Compressor capability) 60%
J5 (SW4-5)	With Demand change (Compressor capability) 40%
J5 (SW4-5)	None (1) Demand change (Compressor capability) 0%

Note (1) "None" means that jumper wire is not provided on the PCB or the connection is cut.

**Models FDCA224HKXE4R~FDCA680HKXE4R  
FDCA224HKXRE4R~FDCA680HKXRE4R**



• **Function of DIP switch**

Name		Function
SW3-1	ON	Inspection LED reset
	OFF	Normal
SW3-2	ON	Backup operation-With
	OFF	Backup operation-None
SW3-3	ON	Renewal
	OFF	Normal
SW3-7	ON	Forced cooling/heating
	OFF	Normal
SW3-8	ON	Test mode
	OFF	Normal
SW5-1	ON	Test run operatopm
	OFF	Normal
SW5-2	ON	Test run operation Cooling
	OFF	Test run operation - Heating
SW5-3	ON	Pump down
	OFF	Normal

SW4-1	SW4-2	SW4-3	SW4-4	Models
OFF	OFF	OFF	OFF	<b>FDCA224</b>
ON	OFF	OFF	OFF	<b>FDCA280</b>
OFF	ON	OFF	OFF	<b>FDCA335</b>
OFF	ON	OFF	OFF	<b>FDCA335-K</b>
OFF	OFF	ON	OFF	<b>FDCA400</b>
ON	OFF	ON	OFF	<b>FDCA450</b>
OFF	ON	ON	OFF	<b>FDCA504</b>
ON	ON	ON	OFF	<b>FDCA560</b>
OFF	OFF	OFF	ON	<b>FDCA615</b>
ON	OFF	OFF	ON	<b>FDCA680</b>

• **Function of jumper wire**

Name		Function
J13	With	External input level
	None <sup>(1)</sup>	External input pulse
J14	With	Defrosting temp. - Strengthening
	None <sup>(1)</sup>	Defrosting temp. - Normal
J15	With	Defrosting time - Cold weather region
	None <sup>(1)</sup>	Defrosting time - Normal

Note (1) "None" means that jumper wire is not provided on the PCB or the connection is cut.

Name		Function
SW4-6	ON	ON Demand change (Compressor capability) 0%
		OFF Demand change (Compressor capability) 40%
	OFF	ON Demand change (Compressor capability) 60%
		OFF Demand change (Compressor capability) 80%
—	SW4-7	ON Address setup of master/slave unit-slave
		OFF Address setup of master/slave unit-master

• **Replacement procedure of outdoor unit control printed circuit board.**

Micromputer printed circuit board can replaced with following procedure.

- 1) Confirm the parts numbers. (Refer to the following parts layout drawing for the location of parts number.)

Parts No.	Model
<b>PCB505A042NF</b>	FDCA140HKXEN4R
<b>PCB505A042NA</b>	FDCA140HKXES4R, 160HKXES4R
<b>PCB505A042MC</b>	FDCA224HKXE4R, 280HKXE4R, 335HKXE4R
<b>PCB505A041ZD</b>	FDCA335HKXE4R-K, 400HKXE4R~680HKXE4R
<b>PCB505A042RC</b>	FDCA224HKXRE4R, 280HKXRE4R, 335HKXRE4R
<b>PCB505A042RF</b>	FDCA335HKXRE4R-K, 400HKXRE4R~680HKXRE4R

### (iii) Parts layout on the outdoor unit inverter PCB


#### ● Replacement procedure of outdoor unit inverter printed circuit board

Inverter printed circuit board can replaced with following procedure.


- 1) Confirm the parts numbers. (Refer to the following parts layout drawing for the location of parts number.)

Parts No.	Model
PCB505A044ZD	FDCA140HKXEN4R
PCB505A044ZG	FDCA140HKXES4R, 160HKXES4R
PCB505A044ZA	FDCA224, 280, 335
PCB505A044ZB	FDCA335-K, 400~680

**Models FDCA140HKXEN4R, 140HKXES4R, 160HKXES4R, 224HKXE4R, 280HKXE4R, 335HKXE4R  
224HKXRE4R, 280HKXRE4R, 335HKXRE4R**



**Models FDCA335HKXE4R-K, 400HKXE4R~680HKXE4R  
FDCA335HKXRE4R-K, 400HKXRE4R~680HKXRE4R**




## Outdoor Unit controller failure diagnosis circuit diagram

### Model FDCA140HKXEN4R

#### Outdoor unit check points

Check items with the \* mark when the power is ON.



● Outdoor unit check points  
Check items with the \* mark when the power is ON.




● Check points of inverter outdoor unit

▷ Check with power ON at the points marked with \*.

This figure applies to the FDCA224, 280, 335.

The FDCA335-K, and 400~680 have 2 inverter related systems.



(iv) Check procedure depending on indication lamps (For the outdoor unit)

1


Error display : **E3** [Error on the outdoor unit signal line]

(Detected during operation only)

Indoor unit	
Red LED	2 time flash
Green LED	Keeps flashing

Outdoor unit	
Red LED	Stays OFF
Green LED	Stays OFF


Outdoor unit	
Red LED	Stays OFF
Green LED	Keeps flashing



Error display : **E3** [Error on the outdoor unit signal line]

(Detection at the power on)

Outdoor unit	
Red LED	Stays OFF or Lights continuously
Green LED	Irregular illumination




## 2

Error display : **E5**

[Outdoor unit signal line error, power supply error]


Indoor unit	
Red LED	2 time flash
Green LED	Keeps flashing

Outdoor unit	
Red LED	Stays OFF
Green LED	Stays OFF




Note (1) This case is limited to the separate power supplies to indoor/outdoor units. (Combination of (indoor unit) red LED 2 time flash and (outdoor unit) green LED stays off means that the power supply to the outdoor unit has been interrupted during operation.)

Outdoor unit	
Red LED	Stays OFF or Keeps flashing
Green LED	Irregular illumination



Outdoor unit	
Red LED	Stays OFF
Green LED	Keeps flashing



Notes (1) Check for poor connection (looseness, misconnection) at outdoor unit terminal block and broken signal wires between outdoor units.

(2) Check the poor connection or broken signal wires between indoor/outdoor units.




3

Error display : *E30*7-segment display : *E30*

[Connection error indoor and outdoor unit]

Indoor unit		Outdoor unit	
Red LED	Stays OFF	Red LED	1 time flash
Green LED	Keeps flashing	Green LED	Keeps flashing




4

Error display : *E31*7-segment display : *E31*

[Duplicated unit No. of outdoor units]

Indoor unit		Outdoor unit	
Red LED	Stays OFF	Red LED	1 time flash
Green LED	Keeps flashing	Green LED	Keeps flashing




5

Error display : *E32*7-segment display : *E32*

Indoor unit		Outdoor unit	
Red LED	Stays OFF	Red LED	1 time flash
Green LED	Keeps flashing	Green LED	Keeps flashing


Models FDCA224~1360

[Reversed phase on power supply or open 52C L3 phase (primary side) on power supply]



Note (1) Wrong wire connection of the reversed phase detection circuit is suspected occurred during replacement of the outdoor unit PCB. Replacement work should be performed carefully.

**Model FDCA140HKXES4R, 160HKXES4R**  
**[Absence of L2 phase (voltage detection)]**




**6**

**Error display : *E34***  
**7-segment display : *E34***

**[Reversed phase on power supply or open 52C L3 phase (primary side) at power supply]**  
**(Only case of FDCA140HKXES4R and 160HKXES4R model)**

Indoor unit		Outdoor unit	
Red LED	Stays OFF	Red LED	1 time flash
Green LED	Keeps flashing	Green LED	Keeps flashing



Note (1) Wrong wire connection of the reversed phase detection circuit is suspected occurred during replacement of the outdoor unit PCB. Replacement work should be performed carefully.


7

Error display : *E35*


[Cooling high pressure error]

7-segment display : *E35*

Indoor unit		Outdoor unit	
Red LED	Stays OFF	Red LED	1 time flash
Green LED	Keeps flashing	Green LED	Keeps flashing




#### • Anomalous Temperature Detection



#### • Display Conditions

If a temperature of 65°C or higher is detected 5 or more times within 60 minutes in the outdoor heat exchanger, including when the compressor is stopped, or this temperature is detected continuously for 60 minutes.



8


Error display : *E36*

[Discharge temperature error]

7-segment display : *E36-1*  
*E36-2*

Indoor unit		Outdoor unit	
Red LED	Stays OFF	Red LED	1 time flash <sup>(1)</sup>
Green LED	Keeps flashing	Green LED	Keeps flashing

Note (1): Single flashing (E36-1) of outdoor unit LED indicates Tho-D1 and double flashing (E36-2) indicates Tho-D2.





● Display conditions

If the discharge pipe temperature becomes 130°C or higher for 2 seconds, the compressor stops.

If it drops to 90°C or lower, the compressor restarts, but, if this operation occurs 2 (5) times within 60 minutes.

Note (1) Value in ( ) indicater FDCA140, 160 type.

● Anomalous temperature detection




9


Error display : **E37**7-segment display : **E37-1****E37-2****E37-3****E37-4****E37-5****E37-6****[Defective outdoor unit heat exchanger and sub-cooling coil thermistor]**

Indoor unit		Outdoor unit	
Red LED	Stays OFF	Red LED	1 time flash <sup>(1)</sup>
Green LED	Keeps flashing	Green LED	Keeps flashing

Note (1) Tho-R1 flashes 1 time (E37-1), Tho-R2 flashes 2 times (E37-2), Tho-R3 flashes 3 times (E37-3), Tho-R4 flashes 4 times (E37-4), Tho-SC flashes 5 times (E37-5), Tho-H flashes 6 times (E37-6).



Outdoor unit heat exchanger thermistor (Tho-R1~R4), sub-cooling coil (Tho-SC, H)  
Resistance temperature characteristics




- Display conditions

If the temperature sensed by the thermistor is  $-50^{\circ}\text{C}$  or lower continuously for 5 seconds between 2 minutes and 2 minutes 20 seconds after the compressor goes ON, the compressor stops. After a 3 minute delay, the compressor restarts. If this state is detected 3 times in 40 minutes.


10

Error display : **E38**7-segment display : **E38****[Defective outdoor temperature thermistor]**

Indoor unit		Outdoor unit	
Red LED	Stays OFF	Red LED	1 time flash
Green LED	Keeps flashing	Green LED	Keeps flashing



Temperature-resistance characteristics of outdoor temperature thermistor (Tho-A)



- Display Conditions

If the temperature detected by the thermistor is  $-30^{\circ}\text{C}$  or lower continuously for 5 seconds between 2 minutes and 2 minutes 20 seconds after the compressor goes ON, the compressor stops. After a 3 minute delay, the compressor restarts. If this condition is detected 3 times within 40 minutes.

11


Error display : *E39*

[Defective discharge pipe thermistor]

7-segment display : *E39-1*  
*E39-2*


Indoor unit		Outdoor unit	
Red LED	Stays OFF	Red LED	1 time flash <sup>(1)</sup>
Green LED	Keeps flashing	Green LED	Keeps flashing

Note (1) Single flashing (E39-1) of outdoor unit LED indicates Tho-D1 and double flashing (E39-2) indicates Tho-D2.



#### • Display conditions

If the temperature sensed by the thermistor is 3°C or lower continuously for 5 seconds between 10 minutes and 10 minutes 20 seconds after the compressor goes ON, the compressor stops. After a 3 minute delay, the compressor restarts. If this state is detected 3 times in 40 minutes.




12

Error display : *E40*

[63H1-1,2, motion]

7-segment display : *E40*

Indoor unit		Outdoor unit	
Red LED	Stays OFF	Red LED	1 time flash
Green LED	Keeps flashing	Green LED	Keeps flashing




#### • Display conditions


If the 63H1-1,2 goes OFF (open), the compressor stops. After a 3 minute delay, the compressor restarts. If this condition is detected 5 times within 60 minutes, or if the (open) state continues for 60 minutes without interruption.

#### • Anomalous pressure detection

Models FDC140, 160



Models FDCA224~1360



13


Error display : E41

[Power transistor overheating]

7-segment display : E41-1  
E41-2

Indoor unit		Outdoor unit	
Red LED	Stays OFF	Red LED	1 time flash <sup>(1)</sup>
Green LED	Keeps flashing	Green LED	Keeps flashing

Note (1) Single flashing (E41-1) of outdoor unit LED indicates power transistor (CM1) overheat and double flashing (E41-2) indicates power transistor (CM2) overheat.





● Display conditions

If the power transistor's temperature exceeds the set value, the compressor stops.

When the temperature drops to 90°C or lower, the compressor restarts, but if this occurs 5 times within 1 hour, or if this condition continues uninterrupted for 1 hour.

● Anomalous temperature detection.



14


Error display : E42

[Current cut]

7-segment display : E42-1  
E42-2

Indoor unit		Outdoor unit	
Red LED	Stays OFF	Red LED	1 time flash <sup>(1)</sup>
Green LED	Keeps flashing	Green LED	Keeps flashing

Note (1) Single flashing (E42-1) of outdoor unit LED indicates current cut (CM1) and double flashing (E42-2) indicates current cut (CM2).






15

Error display : **E43**  
 7-segment display : **E43**

[Excessive number of indoor units connected]

Indoor unit		Outdoor unit	
Red LED	Stays OFF	Red LED	1 time flash
Green LED	Keeps flashing	Green LED	Keeps flashing



- Notes (1) The maximum number of connectable units of each model is as follows :  
 FDCA140 type 6 (8), FDCA160 type 8  
 FDCA224 type 13, FDCA280 type 16  
 FDCA335 type 20, FDCA400 type 23  
 FDCA450 type 26, FDCA735 type 43  
 FDCA800 type 47, FDCA850~1360 type 48.
- (2) Outdoor No. setting check for indoor units (to see if outdoor No. is of other system)
- (3) In case of auto addressing erase the addresses stored in memory and perform re-setting


16

Error display : **E45**  
 7-segment display : **E45-1**  
                               **E45-2**

[Transmission error between inverter and Outdoor unit PCB]

Indoor unit		Outdoor unit	
Red LED	Stays OFF	Red LED	1 time flash <sup>(1)</sup>
Green LED	Keeps flashing	Green LED	Keeps flashing

Note (1) Single flashing (E45-1) of outdoor unit LED indicates transmission error between inverter and outdoor unit PCB (CM1).  
 Double flashing (E45-2) of outdoor unit LED indicates transmission error between inverter and outdoor unit PCB (CM2).




17

Error display : *E46*

7-segment display : —

( Automatic address setting and remote controller  
address setting coexists in the same network )

Indoor unit		Outdoor unit	
Red LED	Stays OFF	Red LED	Stays OFF
Green LED	Keeps flashing	Green LED	Keeps flashing



18


Error display : *E48*
 7-segment display : *E48-1*  
*E48-2*

[Anomaly in outdoor fan motor]

Indoor unit		Outdoor unit	
Red LED	Stays OFF	Red LED	1 time flash <sup>(1)</sup>
Green LED	Keeps flashing	Green LED	Keeps flashing

Note (1) Single flashing (E48-1) of outdoor unit LED indicates FM01 and double flashing (E48-2) indicates FM02.

#### • When outdoor unit is running



#### • Display Conditions


If an overcurrent or overheating signal is received from the outdoor fan motors (FM01, 2), the compressor and outdoor fans stop. They start again after 3 minutes, but if this same trouble occurs 5 times (separately for FM01, 2) again within 1 hour, or once within 45 minutes of the power being turned ON, an anomalous stop occurs.

19

Error display : *E49*  
7-segment display : *E49*

[Low pressure anomaly]

Indoor unit		Outdoor unit	
Red LED	Stays OFF	Red LED	1 time flash
Green LED	Keeps flashing	Green LED	Keeps flashing



• Display conditions

**Models FDCA140, 160**

If a pressure of 0.079 MPa or lower is detected by the low pressure sensor, the compressor stops. After a delay of 3 minutes, the compressor restarts, but if this occurs 3 times within 60 minutes, or if this pressure continues for 60 minutes, including when the compressor is stopped.


**Models FDCA224~1360**

- If the low pressure sensed by the low pressure sensor is 0.134 (0.079) MPa or lower, the compressor stops. After a 3 minute delay, the compressor restarts. If this occurs 2 times within 60 minutes.
- If the pressure sensed by the low pressure sensor while the compressor is stopped is 0.18 MPa or lower. If this occurs 5 times within 60 minutes.


Note (1) It recovers only if there is a power supply reset.

• Anomalous pressure detection

**Models FDCA140, 160**



**Models FDCA224~1360**




20

Error display : *E51*  
7-segment display : *E51*

[Anomalous inverter] (FDCA140 and 160 type only)

Indoor unit		Outdoor unit	
Red LED	Stays OFF	Red LED	1 time flash
Green LED	Keeps flashing	Green LED	Keeps flashing




Error display : **E51**  
 7-segment display : **E51-1**  
                               **E51-2**

[Power transistor overheating (15 minute continuation)]  
 [Combination model only]

Indoor unit		Outdoor unit	
Red LED	Stays OFF	Red LED	1 time flash <sup>(1)</sup>
Green LED	Keeps flashing	Green LED	Keeps flashing



Note (1) Single flashing (E51-1) of outdoor unit LED indicates power transistor (CM1) overheat and double flashing (E51-2) indicates power transistor (CM2) overheat.



● Display conditions

A power transistor temperature error occurs when a temperature of 110°C or higher continues for 15 minutes, including compressor stops.

● Anomalous temperature detection.





21

Error display : *E53*7-segment display : *E53*

[Defective suction pipe temperature thermistor]

Indoor unit		Outdoor unit	
Red LED	Stays OFF	Red LED	1 time flash
Green LED	Keeps flashing	Green LED	Keeps flashing



#### ● Display conditions

If the temperature detected by the thermistor is  $-50^{\circ}\text{C}$  or lower continuously for 5 seconds between 2(10) minutes and 2(10) minutes 20 seconds after the compressor goes ON, the compressor stops. After a 3 minute delay, the compressor restarts. If this condition is detected 3 times within 40 minutes.

Note(1) Value in ( ) indicator FDCA140, 160 type.


22

Error display : *E54*7-segment display : *E54-1*  
*E54-2*

[Defective low pressure and high pressure sensor]

Indoor unit		Outdoor unit	
Red LED	Stays OFF	Red LED	1 time flash <sup>(1)</sup>
Green LED	Keeps flashing	Green LED	Keeps flashing

Note (1) Single flashing (E54-1) indicates PSL and double flashing (E54-2) indicates PSH.



#### ● Display conditions

If the voltage detected by the sensor is 0V or lower or 3.49 V or higher continuously for 5 seconds between 2 minutes and 2 minutes 20 seconds after the compressor goes ON, the compressor stops. After a 3 minute delay, the compressor restarts. If this condition is detected 3 times within 40 minutes.

23


Error display : **E59**7-segment display : **E59-1**  
**E59-2**

[Anomaly in compressor starting]

Indoor unit		Outdoor unit	
Red LED	Stays OFF	Red LED	1 time flash <sup>(2)</sup>
Green LED	Keeps flashing	Green LED	Keeps flashing

Notes (1) Check if the power supply system is normal.

(2) Single flashing (E59-1) of outdoor unit LED indicates anomaly in compressor (CM1) starting and double flashing (E59-2) indicates anomaly in compressor (CM2) starting.



Note (1) While attempting to restart the compressor 2 or 3 times, the liquid refrigerant inside the compressor may be dispelled to outside the compressor and the starting anomaly may improve and recover.

## ● Display conditions

(1) If it can't be started in 20 attempts. (10 patterns × 2 times)

(2) A remote control reset is possible after 3 minutes passes.

24


Error display : **E60**7-segment display : **E60-1**  
**E60-2**

[Compressor loader position detection error]

Indoor unit		Outdoor unit	
Red LED	Stays OFF	Red LED	1 time flash <sup>(2)</sup>
Green LED	Keeps flashing	Green LED	Keeps flashing

Notes (1) Check if the power supply system is normal.

(2) Single flashing of outdoor unit LED indicates compressor (CM1) loader position detection error and double flashing indicates compressor (CM2) loader position detection error.



## ● Display conditions

(1) After rotor position detection operation, if the rotor's position cannot be detected again (4 times in 15 minutes), an error is displayed.


(2) A remote control reset is possible after 3 minutes passes.

25

Error display : **E61**  
7-segment display : **E61**

[Communications error between the master unit and slave units]  
[Combination model only]

Indoor unit		Outdoor unit	
Red LED	Stays OFF	Red LED	1 time flash
Green LED	Keeps flashing	Green LED	Keeps flashing




26

Error display : **E63**  
7-segment display : **E63**


[Emergency stop of indoor unit]

Indoor unit		Outdoor unit	
Red LED	Stays OFF	Red LED	1 time flash
Green LED	Keeps flashing	Green LED	Keeps flashing

Note (1) Check if the power supply system is normal.



## Checking the power transistor module (including the drive circuit)



### \*1 Power transistor module terminal short circuit check procedure

Disconnect the compressor wiring, then check for short circuits using a tester.

P-U, P-V, P-W

N-U, N-V, N-W

Check between the P and N terminals.

It is easy to make tester contact with the following locations on each of the terminals.

P: Red harness side of the power transistor module terminal block.

N: Blue harness side of the power transistor module terminal block.

U: End of red harness to the compressor.

V: End of white harness to the compressor


W: End of blue harness to the compressor

### (d) How to advance checks for each faulty symptom

#### (i) Inspection method when there is no error display

##### 1) Louver motor does not operate


► Inspect at the indoor unit side.






## 2) When the indoor unit blower does not operate (Except for FDT112, 140, FDK22~71 models)

► Inspect at the indoor unit side.



## 3) Four way valve does not switch during heating operation



(ii) When the cooling (heating) effect is felt insufficient. (Check also the refrigeration cycle for the refrigerant quantity, etc. in addition to the following.)

### 1) When the cooling effect is insufficient.

- Check if the protective function has tripped and, as a result, the compressor operation frequency has dropped below the specified frequency
- Does the indoor expansion valve operate properly? Is it clogged?
- Is the frosting prevention function operated?

### Check method of the indoor unit electronic expansion valve

Check the indoor controller output to the expansion valve with the following procedures.

► Check how much volt is detected at the expansion valve (SM) connector and at the pin at control side of the connector CnA (white, 7P (5 cores)), and measure also how many seconds the voltages are applied.

White~Brown	} Approx. DC 5V <sup>(2)</sup> is detected for approx. 15 seconds <sup>(1)</sup> at the power on.
Yellow~Brown	
Orange~Brown	
Blue~Brown	

► The indoor controller is normal if the seconds and voltages as indicated at left are confirmed.

When the expansion valve does not operate while the voltages are detected (operating sound is not heard), the expansion valve is defective.

► If the thermostat setting is changed, the expansion valve will operate approx. 20 seconds later. Then, approx. 5V will be confirmed at the CnA same as above.

Notes (1) 5V is maintained for 8 seconds after the power on, then it drops momentarily and recovers 5V for approx. 7 seconds.

(2) When measured with a digital multi-tester, voltages of approx. 6~3V are outputted one after another.

**(e) Check anomalous operation data with the remote controller**

Operation data are recorded when there is an anomalous state and these data can be displayed in the remote controller by operating the remote controller buttons.

- (1) Press the CHECK button.

The display will change from “ FUNCTION” → “ SET” → “OPERATION DATA ”

- (2) Press the button once. The display will change to “ERROR DATA ”.

- (3) Press the SET button to enter the anomalous operation data display mode.

- (4) If there are anomaly from the past, they will be displayed by an error code and unit No.

(Example) “E8” (Lighted up)

“I/U No. 00 ” (Flashing)

- (5) Using the or button, select the indoor unit No. you want to display the error data for.

If only one indoor unit is connected, the indoor unit No. does not change.

- (6) Fix the selection using the SET button. (The displayed indoor unit No. will change from flashing to light up continuously.)

(Example) “E8”

“DATA LOADING” (This message flashes while data are being read.)

↓

“E8”

“ERROR DATA ”

The data are then displayed beginning with item No. 01.

Displayed items are as shown below.

- (7) Display the other data for when the error occurred in order from the currently displayed operation data No. 01 using the or button.

\* Depending on the model, items for which corresponding data do not exist are not displayed.

- (8) To change the indoor unit, press the AIR CON No. button and return to the indoor unit selection display.

- (9) Press the ON/OFF button to end the anomalous operation data check.

**If you press the RESET button during the settings, the display returns to the previous setting screen.**

No.	Data item
01	(Operation mode)
02	SET TEMP. 27°C
03	RETURN AIR 28°C
04	I/U HEAT EXCH1 6°C
05	I/U HEAT EXCH2 5°C
06	I/U HEAT EXCH3 4°C
07	I/U FAN Hi
08	REQUIRED HERTZ 45Hz
09	SELECTED HERTZ 45Hz
10	EEV 480PULS
11	TOTAL I/U RUN 10500H
21	OUTDOOR 35°C
22	O/U HEAT EXCH1 55°C
23	O/U HEAT EXCH2 56°C
24	COMP HERTZ 85.0Hz
25	Hi PRESSURE 2.0MPa
26	Lo PRESSURE 0.40MPa
27	DISCHARGE 98°C
28	DOME BOTTOM 56°C
29	CT 26A
31	O/U FAN Hi
32	SILENT MODE ON
34	63H1 OFF
35	DEFROST OFF
36	TOTAL COMP RUN 8500H
37	EEV1 480PULS
38	EEV2 480PULS

## 5. WIRELESS KIT

### 5.1 FDT SERIES (OPTIONAL PARTS)

The FDT series is an exclusive series with all wired models. However, these models can also be used as wireless units by using the optional wireless kit.

#### Model

Model
FDT series all model

#### (1) Wireless kit model


Model	Paint color
RCN-T-35W-ER	Plaster white

#### (2) Accessories


Name	Quantity	Name	Quantity
Receiver	1	AAA dry cell battery	2
Wireless remote controller	1	Wood screw for holder	2
Remote controller holder	1	Parts set	1

#### (3) Receiving outside view and function

##### • Corner panel




##### • Receiver part details



#### (4) Wireless remote controller

unit: mm




#### (5) Attachment of wireless kit

##### (a) Installation of the receiver


##### 1) Preparation before installation

- ① Attach the cover panel supplied as an accessory onto the indoor unit according to the panel installation. (Refer to 216 page)
- ② Remove the air return grille. (Refer to 217 page)
- ③ Remove a corner panel located on the refrigerant pipe side.
- ④ Remove three screws and detach the cover (indicated as a shadowed area) from the indoor unit control box.



##### 2) Local setup


- ① Remove the cover by unscrewing two screws from the back of the receiver



Wireless kit backside

- ② Turn switches provided on the back of the PCB.  
Switches (SW1-4) provided on the receiver PCB are for setting the following.  
All switches are set to the ON position for shipment.

SW1	Prevention of unintended movement caused by interference.	ON:Normal OFF:Remote
SW2	Receiver master/slave setting	ON:Master OFF:Slave
SW3	Buzzer valid/invalid	ON:Valid OFF:Invalid
SW4	Cooling only/heat pump switching	ON:Heat pump OFF:Cooling only




- ③ When SW1 is turned to the OFF position, change the corresponding remote controller setting as follows.

Wireless remote controller setting change

Either pressing the “ACL” switch or inserting batteries with the “AIR FLOW” button depressed will change the mode setting to the radio interference prevention mode.

( \*When batteries are removed, the setting will be reset to the default setting. )  
( When batteries are removed, please follow the above procedure again. )


Please do not forget to explain the abovementioned operation method to the customer.  
The operation method is also set out in the instruction manual supplied with the indoor unit.



### 3) Attachment of wireless kit

- ① By loosening the panel hanger bolt, create a gap between the panel and the indoor unit.
- ② Lay the wireless kit wiring through the opening.
- ③ Place the wiring together with other wiring laid on site into the indoor unit.
- ④ Connect the wiring to the terminal block provided in the control box as follows.  
X-Red, Y-White, Z-Black.
- ⑤ Attach the wireless kit to the panel according to the panel installation. (Refer to 217 page)
- ⑥ Bundle redundant wiring together with other wiring laid on site.


Note (1) Ensure that wirings are not caught between the receiver and the panel in attaching the receiver.



## (6) Control of a plural number of indoor units with one remote controller

(a) Up to 16 indoor units can be connected.

- ① Connect indoor unit's (X), (Y) and (Z) terminal with 3-core connecting wires (remote controller signal wires). For a connecting wire, please refer to the "Restrictions on the thickness and length of a connecting wire".



- ② The receiver wiring must be connected only for the indoor unit that will be operated by the remote controller directly.
- ③ Set the address of remote controller communication to [0] through [F] avoiding overlap with the rotary switch SW2 provided on the indoor unit's PCB.


Note (1) Up to two receivers can be installed. When two receivers are used, it is necessary to turn SW2 provided on the PCB of one of the two receivers to the OFF position as a slave.

(b) Wireless remote controller operation distance

- ① Standard signal receiving range

[Condition] Illuminance at the receiver area: 300 lux.


(When no lighting fixture is located within 1m of PAC in an ordinary office)



- ② Relation between illuminance at the receiver and the receivable range viewed from above

[Condition] Relation between illuminance at the receiver and the receivable range when a remote controller is operated 1m above the floor under the ceiling that is 2.4m above the floor.

When illuminance doubles, the receivable range drops to two thirds.



- ③ Points for attention in connecting a plural number of indoor units

[Condition] Illuminance at the receiver area: 300 lux.

(When no lighting fixture is located within 1m of PAC in an ordinary office)

[When more than one unit are installed close each other]

Distance between units that can prevent them from making the same movement is 5m.

## (7) Check display list

Display	LED		Display method
	RUN	TIMER/CHECK	
Reception	Green	—	3 time flash (ON-0.25 seconds, OFF-0.25 seconds)
Hot keep	Green	—	Keeps flashing (ON-0.5 seconds, OFF-0.5 seconds)
Operation	Green	—	Lights continuously
Stop	Green	—	Stays OFF
Center mode	—	Yellow	3time flash (ON-0.25 seconds, OFF-0.25 seconds)
Check	—	Yellow	Keeps flashing (ON-0.5 seconds, OFF-0.5 seconds)
Filter sign	—	Yellow	Keeps flashing (ON-2 seconds, OFF-1 seconds)
Timer	—	Yellow	Lights continuously

## 5.2 EXCEPT FOR FDT SERIES

This product is dedicated for heat pump unit. Never install on the unit dedicated for cooling.

# SAFETY PRECAUTIONS

- Always read these “Safety Precautions” thoroughly before starting installation work.
- These precautions describe important information related to safety. Always observe these precautions.
- Refer to the installation manual enclosed with the indoor unit for the indoor unit installation methods.
- After completing the installation, carry out a test operation, and confirm that there are anomaly.

Also, explain the usage method to the user. Have the user store this manual for future reference.



## WARNING

- Contact the installation to your dealer or a specialist. Incorrect installation by the user could cause electric shocks and fires.
- Always follow this instruction manual and accurately carry out the installation work. Incorrect installation could cause electric shocks and fires.
- The electric work must be carried out by a qualified electrician according to the Electrical Installation Technical Standards, Wiring Regulations and Instruction Manual. Incorrect work could cause electric shocks or fires.
- Use the designated cable for the wiring and make sure that it is securely connected. Fix the cable so that the external force of the cable is not applied on the terminal connection section. Incomplete connections or fixing could cause heating and fires.
- Always use the enclosed parts and designated parts for the installation work parts. Use of parts not designated by Mitsubishi could cause electric shocks or fires.

### (1) Wireless kit model

RCND-KIT-HER

### (2) Accessories (Confirm the following accessories).

① Light detection adaptor		1
② Wiring (3m)		1
③ Parts set (A)		1
④ Parts set (B)		1
⑤ Parts set (C)		1
⑥ Wireless remote controller		1
⑦ User's manual		1

① Screw for light detection adaptor		2
② Fixing band		1
③ Clamp		5
④ Screw for clamp		5

① Remote controller holder		1
② Screw for holder		2
③ Dry cell for remote controller		1

① Light detection section installation bracket		1
② Screw for the bracket		2
③ Installation fitting		2

### (3) Setting of jumper wire

#### a) Method to prevent the malfunction due to the interference

Perform both procedures ① and ②.

This setting is made to prevent the interference with other household electric appliances or the interference occurred when two light detection adaptors are located closely.

#### ① Setting change of the wireless remote controller

While pressing the button, press button or load the battery. The setting changes to the interference prevention setting.

#### ② Modification of light detection adaptor substrate

Turn SW1-1 OFF (remote).

#### b) Changeover of Master/slave remote controller


When you use the wireless remote controller as the slave remote controller, Turn light detection adaptor SW1-2 OFF (slave).

#### c) How to set the 3 air-blow speeds


To change to 3-speed air blow, press the switch while holding down the button; or insert the batteries in the remote control while holding down the button. (In that case, set the temperature range from 16 to 30°C if using the heating mode; or set from 18 to 30°C if not using the heating mode.)

Note (1) To cancel all the remote control settings, press the switch. All remote control settings are then reset to initial (factory) settings.

## ● Wireless remote controller



## ● Light detection adaptor substrate



SW1-1  
(Mixed signal prevention)

SW1-2  
(Master/slave switching)

<b>SW1-1</b>	Prevention of malfunction from mixed signals	O N : Normal OFF : Remote
<b>SW1-2</b>	Receiver master/slave switching	O N : Master OFF : Slave

All switches are turned ON when the product is shipped from the factory.

### ⚠ CAUTION

\* When the battery is once removed, the setting returns to the initial setting condition (setting at factory shipping). Therefore, when the battery has been removed, perform the above mentioned wireless remote controller setting change work again.

Ensure to explain the handling method to the customer.  
(The handling method is also mentioned in the operation manual.)

## (4) Installation work

⚠ Avoid installing the receiver amp in the following positions, as faults may occur or light detection adaptor may be obstructed.

- ① Places subject to direct sunlight.
- ② Places near heat generating appliances.
- ③ Places with high humidity levels or where water may come in contact.
- ④ Places with bumpy surfaces.
- ⑤ Places near fluorescent lights (especially the inverter type) or where light may directly contact the light detection surface.
- ⑥ Places hidden by the indoor unit, etc., when looking from the wireless remote controller operation positions.
- ⑦ Places subject to the air blow off by the indoor unit.

The following two installation methods can be used to install the light detection adaptor onto the ceiling. Select a method according to the installation position.


### <Installation method>

- Installation with enclosed bracket.
- Direct installation onto the ceiling with wood screws.


### a) Drilling of the ceiling (ceiling opening)

Drill the light detection adaptor installation holes with the following dimensions at a the ceiling position where wires can be connected.

<b>(A) Installation with enclosed bracket.</b>	108 mm (H) × 108 mm (W)
<b>(B) Direct installation onto with wood screws.</b>	88 mm (H) × 101 mm (W)



### b) Wiring connected to the light detection adaptor



▷ Be careful of the wiring polarity. Ensure to connect the wire by matching the color of the wire with the color shown on the terminal block.

### ⚠ CAUTION

Do not connect the wiring to the power supply part of the terminal block.  
If it is connected, printed board will be damaged.


### c) Installation for light detection adaptor

Remove the screw on the side of the light detection adaptor, and sprit it into the upper case and lower case.  
Install the receiver with one of the four installation methods d) or e) shown next page.



#### d) Installation with enclosed bracket


Use this method when installing onto a gypsum board (7 or 18 mm), etc.



- ① Catch the two protrusion of the enclosed bracket onto the fitting as shown above, and temporarily fix with the screws.  
(The bracket has an up/down and front/back orientation. Confirm the top/bottom protrusion positions and the positional relation of the  $\phi 10$  holes on the bracket and the installation hole on the lower case with the above drawing.)
- ② Insert the end of the installation fitting into the back of the ceiling from the opening, and tighten the screws to fix the bracket onto the ceiling.
- ③ Pass the wiring from the rear side through the hole on the lower case.
- ④ Fit the lower case onto the bracket, and fix the lower case to the bracket using the two installation holes shown above.  
(The other four holes are not used.)
- ⑤ Follow steps ① to ③ for e) to complete the installation.

#### e) Direct installation onto the ceiling with wood screws

▷ Use this installation method when the ceiling is wooden, and there is no strength-wise problem in installing directly with wood screws.




- ① Fit the lower case into the ceiling opening. Make sure that the convex section on the back of the lower case and the clearance with the ceiling opening are as equal as possible on both sides.
- ② Using the two installation holes shown above, fix the lower case onto the ceiling with the enclosed wood screws.  
(The other four holes are not used.)
- ③ Fit the upper case onto the lower case, and tighten the screw.

## (5) Wireless remote controller operation distance

### a) When installed on ceiling

#### ① standard reception distance

Conditions	Reception section illuminance <u>300 lux</u> (When there are no lights on the ceiling within 1 m or the reception adaptor in a general office.)
------------	---




#### ② Relation of reception section illuminance and reception distance looking from flat plane

Conditions	Relation of the reception section illuminance and reception distance when the remote controller is operated at a height of 1 m from the floor with a ceiling height of 2.4 m. The reception distance becomes 2/3 when the illuminance is double.
------------	---

### b) When installed on wall

Conditions	Reception section illuminance <u>800 lux</u>
------------	--




## (6) Installation of remote controller

- Refer to the installation manual of remote controller

## (7) Trial run of cooling operation

- While pressing the back-up switch on the receiver unit, transmit the signal of cooling operation from the wireless remote controller.



- If the unit does not operate normally at the trial run, check the unit referring to the inspection items shown on the wiring diagram plate stuck on the indoor and outdoor unit.

---

# **INVERTER DRIVEN MULTI-INDOOR-UNIT CLIMATE CONTROL SYSTEM**

---



---

Air-Conditioning & Refrigeration Systems Headquarters  
16-5, 2-chome, Kounan, Minato-ku, Tokyo, 108-8215, Japan  
Fax : (03) 6716-5926